

ParaFlow™

Solution Analysis Report

Customer Name	DuPont Experimental Stn	Sample Drawn	Jun 20,2007
Unit Model No.	YPC22G46CXA	Report Date	Jul 6,2007
Unit Serial No.	GADM233620 #3	Report Number	R7871
Sample Received	Jun 28,2007	PO Number	2338793

Inhibitor Type: **Molybdate**

	<u>Sample Data</u>	<u>Allowable Range</u> <small>(Based on 55% LiBr)</small>	<u>Converted Data</u> <small>(Sample data converted to 55%)</small>
Sample Concentration	50.62 % LiBr		55.00 % LiBr
Sample Specific Gravity	1.539 at 75°F		1.620 at 75°F
Lithium Molybdate Inhibitor	132 mg/l	225-325	151 mg/l
Alkalinity (Lithium Hydroxide)	0.139 N	0.14-0.22	0.159 N
Dissolved Copper	9 mg/l	0-50	10 mg/l
Ammonia	86 mg/l	0-100	98 mg/l
Lithium Nitrate	9 mg/l		10 mg/l

Corrections Necessary

Lithium Molybdate Inhibitor	Add .000108 lbs. of solid Li ₂ MoO ₄ per lb. of solution in the unit OR Add .000034 gals of 30% Li ₂ MoO ₄ solution per lb. of solution in the unit.
Lithium Hydroxide	No
Copper Removal	No
Ammonia Removal	No

Data included in this report are the result of only one solution sample. If there is a drastic change in any parameter as compared with the last sample result, prior to adding chemicals or performing Copper or Ammonia Removal, it may be advisable to resample. The best method of preventing problems due to improper solution chemistry is by taking regular samples and trending the sample data. Maintaining proper Solution Chemistry is critical to the life of your ParaFlow Unit. **York Factory Service** is factory trained and authorized to perform the necessary chemical additions and adjustments required to keep your unit operable and reliable.