

YORK[®] ParaFlow[™] Inspection Report

FOR USE ON INSPECTION CONTRACT VISITS

Project Name: DuPont Experimental Station ID # ABS#4

Address: _____

Model No. YPC-ST-22646CX Serial No: GNC194230017 YORK Order: _____ Hrs. of Operation: 18,530 hrs / 551 shifts

By: KEVIN FRAZIE Date: 7/16/08 Time: 19:30 ~~AM~~ PM

MACHINE OPERATING CODE: Chilling Heating

% LOAD 72%
14,000 lbs/hr

TYPE OF VISIT:

Every Service Visit
Change/Over (Twice/yr.)
Performed As Required

Chilled Water	Inlet Temp (°F)	<u>52.8</u>
	Outlet Temp (°F)	<u>42.7</u>
	ΔP (psi) <u>3000 GPM</u>	<u>22</u>
Condenser Water	Inlet Temp (°F)	<u>74.3</u>
	Outlet Temp (°F)	<u>84.0</u>
	ΔP (psi) <u>5750 GPM</u>	<u>20</u>
High Temp Generator	Solution In Temp (°F) <u>62 At</u>	<u>230</u>
	Solution Out Temp (°F)	<u>292</u>
	Pressure (mm HG)	<u>320</u>
	Concentration (%) (Optional)	
Low Temp Generator	Solution In Temp (°F) <u>27 At</u>	<u>141</u>
	Solution Out Temp (°F)	<u>168</u>
	Refrigerant Out Temp (°F)	<u>165</u>
	Concentration (%) (Optional)	
Absorber <u>ABS H₂O</u> <u>Out = 80°F</u> <u>Weak/Strong</u>	Solution Out Temp (°F)	<u>90.0</u>
	Sol. Concentration (%) (Required) <u>6.25 mmHgA</u>	<u>56%</u>
Condenser	Abs. Spray Temp (°F)	<u>92/108</u>
	Refrigerant Out Temp (°F)	<u>87</u>
Evaporator	Refrigerant Temp (°F)	<u>40.0</u>
	Strm. Inlet Press. (PSIG)	<u>80</u>
Steam Models	Condensate Press. (PSIG)	<u>15</u>
	Gas Ent. Temp (°F)	
Heat Rec. Models	Gas Lvg. Temp (°F)	
	Auto Lifetime	<u>1854</u>
Purge Counters (if applicable)	Auto 7 Day	<u>0</u>
	Manual Lifetime	<u>0</u>
	Manual 7 Day	<u>108</u>

SERVICES PERFORMED

- | | |
|---|-------------------------------------|
| 1. Operational check of all controls | <input checked="" type="checkbox"/> |
| 2. Check refrigerant concentration | <input type="checkbox"/> |
| 3. Refrigerant blowdown | <input checked="" type="checkbox"/> |
| 4. Refrigerant added _____ gals. | <input type="checkbox"/> |
| 5. Refrigerant removed _____ gals. | <input type="checkbox"/> |
| 6. Check solution level | <input checked="" type="checkbox"/> |
| 7. Solution added _____ gals. | <input type="checkbox"/> |
| 8. Solution removed _____ gals. | <input type="checkbox"/> |
| 9. Solution sample taken <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> |
| 10. Octyl alcohol added _____ gals. | <input type="checkbox"/> |
| 11. Inhibitor / hydroxide added _____ type _____ lbs. | <input type="checkbox"/> |
| 12. Perform air leakage test and indicate length of time (hrs.)
Abso. _____ cc/min. Purge Tank _____ cc/min. _____ hrs.... | <input type="checkbox"/> |
| 13. Check torque on carbon-type rupture disk flange | <input type="checkbox"/> |
| 14. Check unit level. (once /yr.) <input type="checkbox"/> | <input type="checkbox"/> |
| 15. Steam units: | <input checked="" type="checkbox"/> |
| a. Inspect needle and control valves | <input type="checkbox"/> |
| b. Take condensate sample | <input type="checkbox"/> |
| 16. Heat Recovery units: | <input type="checkbox"/> |
| a. Check control damper operation | <input type="checkbox"/> |
| b. Check bypass damper operation | <input type="checkbox"/> |
| 17. Direct Fired units: | <input type="checkbox"/> |
| a. Inspect Burner / Components | <input type="checkbox"/> |
| b. Stack Temperature _____ °F _____ % O ₂ _____ % CO ₂ | <input type="checkbox"/> |

Sketch Area:

Rebuilt Condensate Regulator with EPDM elastomers. Cleaned and rebuilt ASCO Condensate Solenoid Valve.

Remarks / Recommendations:

PURGE TANK! 42.4 mm HgA CHILLER TONS: 1,262.5 CHILLER APPROACH: 2.7
ABSORBER SUBCOOLING: 0°F CONDENSATOR TONS: 2,396 CONDENSATOR APPROACH: 3.0
HEAT INPUT = 1245 TONS LBS/Hr./TON: 11.09 ABSORBER APPROACH: 10°F
HEAT BALANCE = 4.7%
C.O.P. = 1.01

Customer Signature: _____

	EVAPORATOR	REFRIGERANT TANK	ABSORBER	HIGH TEMPERATURE GENERATOR	LOW TEMPERATURE GENERATOR
LIQUID LEVEL	<u>ONT</u>				

If unit has additional sight glasses, sketch in and indicate liquid level.