



ParaFlow™ Inspection Report

FOR USE ON INSPECTION CONTRACT VISITS

Project Name: DuPont Experimental Station ID # Chiller # 2

Address: _____

Model No. YPC-ST-22G46CxA Serial No: GBDM248980 YORK Order: _____ Hrs. of Operation: 20,456 Hrs / 482 starts

By: KEVIN FRAZIE Date: 7/16/08 Time: 19:00 ~~AM~~ PM

MACHINE OPERATING CODE: Chilling Heating

% LOAD 63 / 14,800 TYPE OF VISIT: _____
LBS/HR

Every Service Visit
Change/Over (Twice/yr.)
Performed As Required

Chilled Water	Inlet Temp (°F)	<u>53.0</u>
	Outlet Temp (°F)	<u>41.5</u>
	ΔP (psi) <u>3000 GPM</u>	<u>22</u>
Condenser Water	Inlet Temp (°F)	<u>75</u>
	Outlet Temp (°F)	<u>85</u>
	ΔP (psi) <u>5960 GPM</u>	<u>18</u>
High Temp Generator	Solution In Temp (°F) <u>54A+</u>	<u>240</u>
	Solution Out Temp (°F)	<u>294</u>
	Pressure (mm HG)	<u>378</u>
	Concentration (%) (Optional)	<u>66%</u>
Low Temp Generator	Solution In Temp (°F) <u>16A+</u>	<u>155</u>
	Solution Out Temp (°F)	<u>171</u>
	Refrigerant Out Temp (°F)	<u>170</u>
	Concentration (%) (Optional)	<u>4</u>
Absorber <u>ABS H₂O</u> <u>Out = 80°F</u> <u>Weak / Strong</u>	Solution Out Temp (°F)	<u>87</u>
	Sol. Concentration (%) (Required) <u>9.5 mm Hg A</u>	<u>57.8</u>
	Abs. Spray Temp (°F)	<u>92/110</u>
Condenser	Refrigerant Out Temp (°F)	<u>87.6</u>
Evaporator	Refrigerant Temp (°F)	<u>38.6</u>
Steam Models	Stm. Inlet Press. (PSIG)	<u>80</u>
	Condensate Press. (PSIG)	<u>13</u>
Heat Rec. Models	Gas Ent. Temp (°F)	
	Gas Lvg. Temp (°F)	
Purge Counters (if applicable)	Auto Lifetime	<u>1748</u>
	Auto 7 Day	<u>22</u>
	Manual Lifetime	<u>25</u>
	Manual 7 Day	<u>123</u>

SERVICES PERFORMED

- Operational check of all controls
- Check refrigerant concentration
- Refrigerant blowdown
- Refrigerant added _____ gals.
- Refrigerant removed 30 gals.
- Check solution level
- Solution added _____ gals.
- Solution removed _____ gals.
- Solution sample taken Yes No
- Octyl alcohol added _____ gals.
- Inhibitor / hydroxide added 590 type Le 115
- Perform air leakage test and indicate length of time (hrs.)
Abso. _____ cc/min. Purge Tank _____ cc/min. _____ hrs.
- Check torque on carbon-type rupture disk flange
- Check unit level. (once /yr.)
- Steam units:
 - Inspect needle and control valves
 - Take condensate sample
- Heat Recovery units:
 - Check control damper operation
 - Check bypass damper operation
- Direct Fired units:
 - Inspect Burner / Components
 - Stack Temperature _____ °F _____ % O₂ _____ % CO₂

Sketch Area:
Repaired air Leaks on VP7, VS17, and Refrig Tank Sight Glass. Evacuated, added inhibitor, and started up. Purging should subside over time. Replaced Steam Condensate Regulator.

Remarks / Recommendations:
PURGE TANK: 30.5 mm Hg A CHILLER TONS: 1438 CHILLER APPROACH: 2.9°F
ABSORBER SUBCOOLING: 7°F CONDENSATOR TONS: 2,483 CONDENSATOR APPROACH: 2.6°F
HEAT INPUT = 1,300 TONS LBS/HR/TON: 10.3 ABSORBER APPROACH: 7.0°F
HEAT BALANCE = ~~100~~ 10%
C.O.P = 1.06 * HEAT BALANCE is HIGH. May have inaccurate sensors.

Customer Signature: _____

	EVAPORATOR	REFRIGERANT TANK	ABSORBER	HIGH TEMPERATURE GENERATOR	LOW TEMPERATURE GENERATOR
LIQUID LEVEL	<u>ONT</u>	● ● ●	● Tank ● Main Shell	●	<u>OW</u>

If unit has additional sight glasses, sketch in and indicate liquid level.

YORK[®] ParaFlow[™] Inspection Report

FOR USE ON INSPECTION CONTRACT VISITS

Project Name: DuPont Experimental Station ID # ABS#4

Address: _____

Model No. YPC-ST-22646CX Serial No: GNC194230017 YORK Order: _____ Hrs. of Operation: 18,530 hrs / 551 shifts

By: KEVIN FRAZIE Date: 7/16/08 Time: 19:30 ~~AM~~ PM

MACHINE OPERATING CODE: Chilling Heating

% LOAD 72%
14,000 lbs/hr

TYPE OF VISIT:

Every Service Visit
Change/Over (Twice/yr.)
Performed As Required

Chilled Water	Inlet Temp (°F)	<u>52.8</u>
	Outlet Temp (°F)	<u>42.7</u>
	ΔP (psi) <u>3000 GPM</u>	<u>22</u>
Condenser Water	Inlet Temp (°F)	<u>74.3</u>
	Outlet Temp (°F)	<u>84.0</u>
	ΔP (psi) <u>5750 GPM</u>	<u>20</u>
High Temp Generator	Solution In Temp (°F) <u>62 At</u>	<u>230</u>
	Solution Out Temp (°F)	<u>292</u>
	Pressure (mm HG)	<u>320</u>
	Concentration (%) (Optional)	
Low Temp Generator	Solution In Temp (°F) <u>27 At</u>	<u>141</u>
	Solution Out Temp (°F)	<u>168</u>
	Refrigerant Out Temp (°F)	<u>165</u>
	Concentration (%) (Optional)	
Absorber <u>ABS H₂O</u> <u>Out = 80°F</u> <u>Weak/Strong</u>	Solution Out Temp (°F)	<u>90.0</u>
	Sol. Concentration (%) (Required) <u>6.25 mmHgA</u>	<u>56%</u>
Condenser	Abs. Spray Temp (°F)	<u>92/108</u>
	Refrigerant Out Temp (°F)	<u>87</u>
Evaporator	Refrigerant Temp (°F)	<u>40.0</u>
	Strm. Inlet Press. (PSIG)	<u>80</u>
Steam Models	Condensate Press. (PSIG)	<u>15</u>
	Gas Ent. Temp (°F)	
Heat Rec. Models	Gas Lvg. Temp (°F)	
	Auto Lifetime	<u>1854</u>
Purge Counters (if applicable)	Auto 7 Day	<u>0</u>
	Manual Lifetime	<u>0</u>
	Manual 7 Day	<u>108</u>

SERVICES PERFORMED

- Operational check of all controls
- Check refrigerant concentration
- Refrigerant blowdown
- Refrigerant added _____ gals.
- Refrigerant removed _____ gals.
- Check solution level
- Solution added _____ gals.
- Solution removed _____ gals.
- Solution sample taken Yes No
- Octyl alcohol added _____ gals.
- Inhibitor / hydroxide added _____ type _____ lbs.
- Perform air leakage test and indicate length of time (hrs.)
Abso. _____ cc/min. Purge Tank _____ cc/min. _____ hrs.
- Check torque on carbon-type rupture disk flange
- Check unit level. (once /yr.)
- Steam units:
 - Inspect needle and control valves
 - Take condensate sample
- Heat Recovery units:
 - Check control damper operation
 - Check bypass damper operation
- Direct Fired units:
 - Inspect Burner / Components
 - Stack Temperature _____ °F _____ % O₂ _____ % CO₂

Sketch Area:

Rebuilt Condensate Regulator with EPDM elastomers. Cleaned and rebuilt ASCO Condensate Solenoid Valve.

Remarks / Recommendations:

PURGE TANK! 42.4 mm HgA CHILLER TONS: 1,262.5 CHILLER APPROACH: 2.7
ABSORBER SUBCOOLING: 0°F CONDENSATOR TONS: 2,396 CONDENSATOR APPROACH: 3.0
HEAT INPUT = 1245 TONS LBS/Hr./TON: 11.09 ABSORBER APPROACH: 10°F
HEAT BALANCE = 4.7%
C.O.P. = 1.01

Customer Signature: _____

	EVAPORATOR	REFRIGERANT TANK	ABSORBER	HIGH TEMPERATURE GENERATOR	LOW TEMPERATURE GENERATOR
LIQUID LEVEL	<u>ONT</u>				

If unit has additional sight glasses, sketch in and indicate liquid level.