

ParaFlow™

Solution Analysis Report

Customer Name	DuPont Experimental Stn	Sample Drawn	May 23,2017
Unit Model No.	YPCST22G46CXA	Report Date	Jun 7,2017
Unit Serial No.	GNCM94230017 #4	Report Number	R18615
Sample Received	Jun 1,2017	PO Number	1-50034091764

Inhibitor Type: Molybdate

	<u>Sample Data</u>	<u>Allowable Range</u> <small>(Based on 55% LiBr)</small>	<u>Converted Data</u> <small>(Sample data converted to 55%)</small>
Sample Concentration	52.66 % LiBr		55.00 % LiBr
Sample Specific Gravity	1.574 at 75°F		1.620 at 75°F
Lithium Molybdate Inhibitor	280 mg/l	225-325	301 mg/l
Alkalinity (Lithium Hydroxide)	0.152 N	0.14-0.22	0.163 N
Dissolved Copper	19 mg/l	0-100	20 mg/l
Ammonia	77 mg/l	0-100	83 mg/l
Lithium Nitrate	0 mg/l		0 mg/l

Corrections Necessary

Lithium Molybdate Inhibitor	No
Lithium Hydroxide	No
Copper Removal	No
Ammonia Removal	No

Data included in this report are the result of only one solution sample. If there is a drastic change in any parameter as compared with the last sample result, prior to adding chemicals or performing Copper or Ammonia Removal, it may be advisable to resample. The best method of preventing problems due to improper solution chemistry is by taking regular samples and trending the sample data. Maintaining proper Solution Chemistry is critical to the life of your ParaFlow Unit. **York Factory Service** is factory trained and authorized to perform the necessary chemical additions and adjustments required to keep your unit operable and reliable.