

- Kevin Frazee

Johnson Controls Inc - Branch N28-260 - WILMINGTON DE

**Unit ID: MRP626904**

Number: **3933113**

Worksite: **DUPONT EXP STATION**

Unit Manufacturer and Model: - -

**Component: COMPRESSOR**

Comp. Ref. NO.: **3229510**

Component Serial Number: **MRP626904**

Component Manufacturer and Model: **YORK OM3000**

Oil Type: **YORK K**

**SPECTROCHEMICAL ANALYSIS IN PARTS PER MILLION**

LOG DATE	LAB NO.	Iron	Chromium	Nickel	Aluminum	Lead	Copper	Tin	Silver	Titanium	Silicon	Boron	Sodium	Potassium	Molybdenum	Phosphorus	Zinc	Calcium	Barium	Magnesium	Antimony	Vanadium
Jan 31 2017	1613	1	<1	<1	<1	<1	9	<1	<0.1	<1	4	<1	1	<1	1	<1	<1	<1	<1	<1	<1	<1
Feb 24 2016	2081	1	<1	<1	<1	<1	10	2	<0.1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	1	<1
Mar 26 2008	2230	<1	<1	<1	2	<1	<1	2	<0.1	<1	<1	<1	9	<10	<5	<10	<1	<10	<10	<1	<30	<1



- Kevin Fraze

Johnson Controls Inc - Branch N28-260 - WILMINGTON DE

**Unit ID: MRP626904**  
 Number: **3933113**  
 Worksite: **DUPONT EXP STATION**

Unit Manufacturer and Model: - -

**Component: COMPRESSOR**  
 Comp. Ref. NO.: **3229510**  
 Component Serial Number: **MRP626904**

Component Manufacturer and Model: **YORK OM3000**  
 Oil Type: **YORK K**

**SAMPLE INFORMATION**

**PHYSICAL TEST RESULTS**

LAB NO.	MI/HR Unit	MI/HR Oil	Oil Add	FLTR CHG	Oil CHG	PHYSICAL TEST RESULTS				
						D6304(KF) ppm	Water(KF) ppm	D7279 Vis cSt	D974	TAN
1613	84481		0	-		31	31	33.3	0.03	0.03
2081	0		0	-		19	19	33.3	0.06	0.06
2230	48605					78	78	33.9	0.06	0.06



- Kevin Fraze

Johnson Controls Inc - Branch N28-260 - WILMINGTON DE

Unit ID: **MRP626904**  
Number: **3933113**  
Worksite: **DUPONT EXP STATION**

Unit Manufacturer and Model: - -

Component: **COMPRESSOR**  
Comp. Ref. NO.: **3229510**  
Component Serial Number: **MRP626904**

Component Manufacturer and Model: **YORK OM3000**  
Oil Type: **YORK K**

**Maintenance Recommendations for Lab NO. 1613** Reported On: **Feb 01 2017**

ANALYSIS INDICATES COMPONENT & LUBRICANT CONDITIONS ARE ACCEPTABLE. RESAMPLE at the next scheduled interval.

**Maintenance Recommendations for Lab NO. 2081** Reported On: **Feb 25 2016**

ANALYSIS INDICATES COMPONENT & LUBRICANT CONDITIONS ARE ACCEPTABLE. RESAMPLE at the next scheduled interval.

**Maintenance Recommendations for Lab NO. 2230** Reported On: **Mar 27 2008**

ANALYSIS INDICATES COMPONENT & LUBRICANT CONDITIONS ARE ACCEPTABLE. RESAMPLE at the next scheduled interval.