

# National Refrigerants, Inc.

## Analytical Laboratory

661 Kenyon Avenue  
Bridgeton, NJ 08302  
Telephone (856) 455-2776  
Fax (856) 455-4733

**Problems Found Action Required**

**Normal Results No Action Needed**

SL: 03

### Refrigerant Analysis Report

<b>Customer:</b>	Johnson Controls	<b>P.O. No.:</b>	NRIHP
<b>Address:</b>	812 First St Blvd. Wilmington, DE 19804	<b>Refrigerant Type:</b>	R-134a
<b>Contact:</b>	Kevin Fraze	<b>Job Location:</b>	DuPont Experimental Station
<b>Telephone:</b>	302-353-0315	<b>System S/N:</b>	657634
<b>Fax:</b>	kevin.m.fraze@jci.com	<b>Sample ID#:</b>	York Recovery Tank
		<b>Lab. Reference:</b>	181228-11
		<b>Date Rec.:</b>	12/28/18

### Analysis

### Sample Results

### In-Service Limits

Identification	By Gas Chromatography	R-134a	
Moisture	parts per million by weight	5	120 <u>Max.</u>
High Boiling Residue	per cent by volume	0.3	2 <u>Max.</u>
Acidity	parts per million (as HCl)	<0.20	1 <u>Max.</u>
Non-Condensable Gas	per cent by volume	-	1.5 <u>Max.</u>
Chloride	pass/fail	Pass	<u>pass</u>
Purity	% by weight (Gas Chromatography)	99.82	99.5 <u>Min.</u>
Particulates	pass/fail	Fail	<u>pass</u>
Other			

(1) 20 ppm for R-11, 113, 123.

**Comments:** The sample contains a small amount of medium sized black particles. The high boiling residue (0.30%) is a clear pale amber oil. All other above test results are normal. Trace organic impurities present are R-22: 0.16%, R-143a: 0.01% and R-152a: 0.01%. Recommend you check an oil sample for signs of compressor wear. Resample at next scheduled maintenance interval.

Laboratory Supervisor: Dan Wright, Manager

Digitally signed by Dan Wright, Manager  
DN: cn=Dan Wright, Manager, o=National Refrigerants Inc., ou=Analytical Lab, email=dan.wright@refrigerants.com, c=US  
Date: 2019.01.03 07:46:19 -0500

Date: 1/2/2019

Attention: This Report is provided to the Customer only and may not be utilized by any other person or entity without written confirmation of same by National Refrigerants, Inc. (NRI). Upon written request, and with the written permission of the Customer, NRI will confirm the substance of this Report to any person or entity requesting such confirmation. Any alteration of this document by any person may constitute a violation of State and/or Federal Civil Criminal Law in the United States and/or other countries. The technical data and comments provided on the sample you supplied is done as a service to you as a customer of NRI. Since conditions of its use are outside of NRI's control, NRI assumes no liability for the use of such information or any damages incurred through its use or application. Nothing contained in such information is to be construed as contractual or providing some form of warranty on the part of NRI.