

## E315 EDDY CURRENT CHILLER HISTORY

JOHNSON CONTROLS, INC.  
 812 First State Blvd  
 Delmarva Branch N28  
 Wilmington, DE 19804

### Units Tested by TAI Services

| Site   | Model #   | Test Date                 | Retest Due   |
|--|---|---------------------------|--|
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE                          | OM3000<br>Cond 0<br>Evap 0<br>Gen/Con 0<br>Abs 0            | Serial #<br>626904 #7     |  |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER#10</b> | OT T4 G2 ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0 | Serial #<br>GACM127699    | 11/6/2007    11/12/2009  |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #9</b> | OTT4G2-ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0   | Serial #<br>GACM127698 #9 | 11/26/2007    11/27/2009   |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #8</b> | OTT4G2-ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0   | Serial #<br>GACM117864 #8 | 11/29/2007    11/30/2009   |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #7</b> | OM3000<br>Cond 0<br>Evap 1852<br>Gen/Con 0<br>Abs 0         | Serial #<br>626904        | 11/19/2008    11/22/2009   |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #8</b> | OTT4G2-ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0   | Serial #<br>GACM117864 #8 | 4/22/2013 <span style="background-color: yellow;">4/22/2016</span> |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #9</b> | OTT4G2-ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0   | Serial #<br>GACM127698 #9 | 4/22/2013 <span style="background-color: yellow;">4/24/2016</span> |

JOHNSON CONTROLS, INC.  
 812 First State Blvd  
 Delmarva Branch N28  
 Wilmington, DE 19804

**Units Tested by TAI Services**

| Site   | Model #  | Test Date                                   | Retest Due        |
|--|--|---|-------------------|
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #10</b>          | OTT4G2- ZBES<br>Cond 883<br>Evap 699<br>Gen/Con 0<br>Abs 0 | 4/22/2013<br><br>Serial #<br>GACM127699 #10 | <b>4/25/2016</b>  |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #6<br/>COND.</b> | 17DA743<br>Cond 3990<br>Evap 0<br>Gen/Con 0<br>Abs 0       | 1/13/2014<br><br>Serial #<br>01588 #6       | <b>1/13/2016</b>  |
| DUPONT EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #6<br/>EVAP.</b> | 17DA743<br>Cond 0<br>Evap 2586<br>Gen/Con 0<br>Abs 0       | 2/11/2014<br><br>Serial #<br>01588 #6       | <b>2/12/2016</b>  |
| DUPONT/EXPERIMENTAL STATION<br>WILMINGTON, DE<br><br><b>CHILLER #7<br/>EVAP.</b> | OM3000<br>Cond 0<br>Evap 1852<br>Gen/Con 0<br>Abs 0        | 12/20/2010<br><br>Serial #<br>626904 #7     | <b>12/21/2012</b> |

\*\*\*

- No record of any Absorbers ever having been checked.
- No record of Chiller #7 Condenser tubes.

\*\*\*