

ParaFlow™ Solution Analysis Report

Customer Name	DuPont Experimental Stn	Sample Drawn	Jun 18,2018
Unit Model No.	YPCST22G46CXA	Report Date	Jul 23,2018
Unit Serial No.	GLCM157836 #1	Report Number	R19988
Sample Received	Jul 17,2018	PO Number	1-68767221225

Inhibitor Type: **Molybdate**

	<u>Sample Data</u>	<u>Allowable Range</u> (Based on 55% LiBr)	<u>Converted Data</u> (Sample data converted to 55%)
Sample Concentration	51.66 % LiBr		55.00 % LiBr
Sample Specific Gravity	1.557 at 75°F		1.620 at 75°F
Lithium Molybdate Inhibitor	109 mg/l	225-325	121 mg/l
Alkalinity (Lithium Hydroxide)	0.201 N	0.14-0.22	0.223 N
Dissolved Copper	59 mg/l	0-100	65 mg/l
Ammonia	117 mg/l	0-100	130 mg/l
Lithium Nitrate	30 mg/l		33 mg/l

Corrections Necessary

Lithium Molybdate Inhibitor	Add .000127 lbs. of solid Li ₂ MoO ₄ per lb. of solution in the unit OR Add .000039 gals of 30% Li ₂ MoO ₄ solution per lb. of solution in the unit.
Lithium Hydroxide	No
Copper Removal	No
Ammonia Removal	Yes Consult York Factory Service

Data included in this report are the result of only one solution sample. If there is a drastic change in any parameter as compared with the last sample result, prior to adding chemicals or performing Copper or Ammonia Removal, it may be advisable to resample. The best method of preventing problems due to improper solution chemistry is by taking regular samples and trending the sample data. Maintaining proper Solution Chemistry is critical to the life of your ParaFlow Unit. **York Factory Service** is factory trained and authorized to perform the necessary chemical additions and adjustments required to keep your unit operable and reliable.