

## ParaFlow™ Solution Analysis Report

Customer Name	DuPont Experimental Stn	Sample Drawn	Jun 29,2018
Unit Model No.	YPC22G46CXA	Report Date	Jul 23,2018
Unit Serial No.	GADM233620 #3	Report Number	R19979
Sample Received	Jul 17,2018	PO Number	1-68767221225

Inhibitor Type: **Molybdate**

	<u>Sample Data</u>	<u>Allowable Range</u> (Based on 55% LiBr)	<u>Converted Data</u> (Sample data converted to 55%)
Sample Concentration	<b>50.90</b> % LiBr		<b>55.00</b> % LiBr
Sample Specific Gravity	<b>1.543</b> at 75°F		<b>1.620</b> at 75°F
Lithium Molybdate Inhibitor	<b>250</b> mg/l	<b>225-325</b>	<b>284</b> mg/l
Alkalinity (Lithium Hydroxide)	<b>0.155</b> N	<b>0.14-0.22</b>	<b>0.176</b> N
Dissolved Copper	<b>44</b> mg/l	<b>0-100</b>	<b>50</b> mg/l
<b>Ammonia</b>	<b>121</b> mg/l	<b>0-100</b>	<b>137</b> mg/l
Lithium Nitrate	<b>60</b> mg/l		<b>68</b> mg/l

### Corrections Necessary

Lithium Molybdate Inhibitor	No	
Lithium Hydroxide	No	
Copper Removal	No	
<b>Ammonia Removal</b>	<b>Yes</b>	<b>Consult York Factory Service</b>

Data included in this report are the result of only one solution sample. If there is a drastic change in any parameter as compared with the last sample result, prior to adding chemicals or performing Copper or Ammonia Removal, it may be advisable to resample. The best method of preventing problems due to improper solution chemistry is by taking regular samples and trending the sample data. Maintaining proper Solution Chemistry is critical to the life of your ParaFlow Unit. **York Factory Service** is factory trained and authorized to perform the necessary chemical additions and adjustments required to keep your unit operable and reliable.