

## Refrigerant History

Service Request	Date Recorded	Leak Location	Leak Repaired	Initial Verification Test	30 Day Followup Test	Test method	Refrigerant Used	Amt Refrig Used
1-34691988271	6/21/2016 01:59:31 PM						R-134a	1,630
1-45765849262	1/30/2017 05:42:51 PM							
1-45765849262	2/16/2017 07:25:37 PM	ACCESS VALVE	Yes	Passed	Need to Schedule	Electronic Leak Detector	R-134a	150
1-58589405354	12/27/2017 04:10:47 PM	O-RING	Yes	Failed	Passed	Electronic Leak Detector	R-134a	