

Measurement data			
Filename	8C		
Measurement date	6/2/17 16:18		
Report generated from file	8C_hor_2017-02-06 16-18-00.5.Kevin Frazee.XML		
Report generated date	14/12/2017 12:05		
Operator	Kevin Frazee		
Measurement Program	Shaft horizontal AX3		
Measurement Unit	mils		
Serial no. Display / detector(s)	43278 / 43331 / 43305 / 0		
Temperature (min / max)	20.0 / 20.0 °C		
Distances (Inch)			
Coupling diameter	N/A		
SC	8.6		
SM	11.0		
M - MF1	12.5		
MF1 - MF2	36.0		
Machine data		Stationary Machine S	Movable Machine M
Name	Pump		Motor
Movable pair of feet	0		2
Locked pair of feet	2		0
Softfoot measured	No		No
Thermal compensation		Stationary Machine S	Movable Machine M
Vertical offset			N/A
Horizontal offset			N/A
Vertical angle			N/A
Horizontal angle			N/A
Tolerance			
Offset	N/A		Angle
			N/A
Result Vertical			
Result	Within tolerance		

