



To: Tom Sliwinski
Company: DuPont Experimental Station
Fax: 302-695-7775

Date: 9-5-07

Dear Tom,

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with York Service Johnson Controls, Inc. Standard Terms and conditions. *Pricing good for 30 Days from date of proposal.*

York Service is pleased to submit this proposal for your review: The following is a scope of work to be performed at: **Experimental Station Powerhouse** in order to repair the refrigerant leak on **Chiller #7 Evaporator Sight Glass**.

- **Scope of work to be performed:**
- **Shutdown and lock out chiller**
- **Transfer refrigerant to central tank and calculate loss**
- **Remove and replace sight glass cap, glass, all gaskets, and packings**
- **Pressurize with nitrogen and leak test entire chiller**
- **Evacuate chiller and perform vacuum hold test**
- **Transfer refrigerant back to chiller**
- **Unlock, start, and monitor performance**

Pricing for this scope of work.....\$ 6,951.00

York Service is pleased to submit this proposal for your review: The services detailed herein will be by qualified York Factory trained Technicians, between the hours of 8:00 a.m. to 4:30 p.m. Monday through Friday.

Upon your approval, please forward your purchase order to my attention so that work can begin. Any questions please call my cell phone at 302-275-3680 (Fax 302-996-0461)

Regards,

Joe Reilly
Service Sales Representative

Jeff Collins
Area Manager Delmarva

Accepted by: _____

P.O. _____

Date: _____