



To: Tom Sliwinski
Company: DuPont Experimental Station
Fax: 302-695-7775
Date: 03/27/08

Dear Tom,

The following work will need to be performed on **ABS #4** before startup. The expected lead-time for material is one week, and the work will take approximately 2 weeks.

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with York Service Johnson Controls, Inc. Standard Terms and Conditions. *Pricing good for 30 Days from date of proposal.*

York Service is pleased to submit this proposal for your review: The following is a scope of work to be performed at: **Experimental Station E315 Powerhouse.**

Scope

- **Lock Out Absorber #4**
- **Drain Lithium Bromide Solution into Portable Drums**
- **Remove Faulty Concentrated Solution Spray Pump**
- **Replace Pump Seal Ring and Install New Pump/Motor Assembly**
- **Replace Solution Sight Glasses**
- **Replace Motor Contactor and Overload Block**
- **Leak Test Pump Housing with Nitrogen Pressure**
- **Recharge Solution into the Chiller and Evacuate**
- **Startup and Inspect Pump Operation**

Price: \$34,567.00

York Service is pleased to submit this proposal for your review: The services detailed herein will be performed by qualified York Factory trained Technicians, between the hours of 8:00 a.m. to 4:30 p.m. Monday through Friday.

Upon your approval, please forward your purchase order to my attention so that work can begin. Any questions please call my cell phone at 302-275-4797 (Fax 302-996-0461)

Regards,

Kevin Frazee
York Service Technician

Joe Reilly
Service Sales Representative

Jeff Collins
Area Manager Delmarva

Accepted by: _____

P.O. _____

Date: _____