



To: Tom Sliwinski
Company: DuPont Experimental Station
Fax: 302-695-7775
Date: 03/27/08

Dear Tom,

The following work will need to be performed on **Chiller #7** to resolve Oil Return and Refrigerant Leak Issues.

Note: Due to the corrosion of the tank, it will be up to DuPont's discretion whether to proceed with the following work or look at replacing the entire Oil Return Vessel.

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with York Service Johnson Controls, Inc. Standard Terms and Conditions. *Pricing good for 30 Days from date of proposal.*

York Service is pleased to submit this proposal for your review: The following is a scope of work to be performed at: **Experimental Station E315 Powerhouse.**

Scope

- **Replace the 2 defective Oil Return Pot Electric Heaters**
- **Cut 1 ¼" Steel Refrig Gas Return Line**
- **Remove Leaking Pipe Threads**
- **Weld in New Nipple to Fix Refrig Leak**

Price: \$4,100.00

York Service is pleased to submit this proposal for your review: The services detailed herein will be performed by qualified York Factory trained Technicians, between the hours of 8:00 a.m. to 4:30 p.m. Monday through Friday.

Upon your approval, please forward your purchase order to my attention so that work can begin. Any questions please call my cell phone at 302-275-4797 (Fax 302-996-0461)

Regards,

Kevin Frazee
York Service Technician

Joe Reilly
Service Sales Representative

Jeff Collins
Area Manager Delmarva

Accepted by: _____

P.O. _____

Date: _____