



To: Tom Sliwinski
Company: DuPont Experimental Station
Fax: 302-695-7775
Date: 05/15/08

Dear Tom,

During the start up of Absorber #2, condensate from the steam generator abruptly ceased to flow, causing a shutdown. The following quote is for the labor and material involved with troubleshooting and resolving of the problem. Also included is the cost of labor to recover refrigerant from Chiller #7 Oil Return Vessel for Relief Valve Replacement.

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with York Service Johnson Controls, Inc. Standard Terms and Conditions. *Pricing good for 30 Days from date of proposal.*

York Service is pleased to submit this proposal for your review: The following is a scope of work to be performed at: **Experimental Station E315 Powerhouse.**

Scope

Absorber #2

- **Troubleshoot condensate problem**
- **Disassemble, Inspect, Clean Condensate Flow Valves**
- **Replace Condensate Back Pressure Regulator with DuPont's Spare**
- **Startup Steam System, Adjust, and Inspect Performance**

Chiller #7

- **Recover refrigerant from the Oil Return Vessel in order to Depressurize for DuPont Personnel to Replace Relief Valve**
- **Put Oil Return System back into service**

Price: \$2,347.00

York Service is pleased to submit this proposal for your review: The services detailed herein will be performed by qualified York Factory trained Technicians, between the hours of 8:00 a.m. to 4:30 p.m. Monday through Friday.

Upon your approval, please forward your purchase order to my attention so that work can begin.
Any questions please call my cell phone at 302-275-4797 (Fax 302-996-0461)

Regards,

Kevin Frazee
York Service Technician

Joe Reilly
Service Sales Representative

Jeff Collins
Area Manager Delmarva

Accepted by: _____

P.O. _____

Date: _____