



To: Tom Sliwinski
Company: DuPont Experimental Station
Fax: 302-695-7775
Date: 05/29/08

Dear Tom,

During the seasonal startup of all four Absorbers, I found some minor items, which will need to be replaced. This quote is for the replacement of those parts.

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with York Service Johnson Controls, Inc. Standard Terms and Conditions. *Pricing good for 30 Days from date of proposal.*

York Service is pleased to submit this proposal for your review: The following is a scope of work to be performed at: **Experimental Station E315 Powerhouse.**

Scope

- Replace Start / Stop Rocker Switches on all four Absorbers
- Replace Defective ABS#3 Refrig Temp Thermistor and keep one as a Spare
- Replace Defective ABS#1 Purge Transducer and keep one as a Spare
- Replace ABS#4 Main Solution Pump Overload Block

Price: \$2,028.00

York Service is pleased to submit this proposal for your review: The services detailed herein will be performed by qualified York Factory trained Technicians, between the hours of 8:00 a.m. to 4:30 p.m. Monday through Friday.

Upon your approval, please forward your purchase order to my attention so that work can begin. Any questions please call my cell phone at 302-275-4797 (Fax 302-996-0461)

Regards,

Kevin Frazee
York Service Technician

Joe Reilly
Service Sales Representative

Jeff Collins
Area Manager Delmarva

Accepted by: _____

P.O. _____

Date: _____