



**To:** Carol Baffone  
**Company:** DuPont Experimental Station  
**Fax:** 302-695-3520  
**Date:** 07/28/08

**Dear Carol,**

The following work is necessary in order to replace the defective Compressor #1, and keep your equipment in good operational condition.

We offer to furnish the equipment and services specified herein, at prices stated and in accordance with Johnson Controls, Inc. Standard Terms and Conditions. *Pricing good for 30 Days from date of proposal.*

Johnson Controls is pleased to submit this proposal for your review: The following is a scope of work to be performed at the: **DuPont Experimental Station Bldg. 336**

## **York YCAS190 Air-Cooled Chiller**

### **Scope:**

#### **On Circuit #1 Only**

- Recover Refrigerant
- Remove and Replace Compressor with Crane in North Parking Lot
- Change Oil, Oil Sight Glasses, Oil Filter, and Liquid Line Driers
- Leak test with Nitrogen and R-22 Trace  
**Note: Repair of any leaks will be an additional charge**
- Evacuate system and perform a Vacuum Hold Test
- Re-charge with New Refrigerant
- Start system and Inspect Performance

**Price: \$55,243.00**

**Note:** This quote is priced, assuming Roof Clearance will be available starting on a Friday after normal business hours for 4 hours, until Sunday evening. Roof clearance will need to be scheduled by DuPont.

The New Compressor will only have a One-Year Warranty. Extended Warranties are not available. There is also a Two Week lead time for the Compressor.

Johnson Controls is pleased to submit this proposal for your review: The services detailed herein will be performed by qualified York Factory trained Technicians.

Upon your approval, please forward your purchase order by fax to my attention so that work can begin. Any questions please call my cell phone at 302-275-4797 (Fax 302-996-0461).

Regards,

Kevin M. Frazee  
Service Technician

Joe Reilly  
Service Sales Representative

Jeff Collins  
Area Manager Delmarva

Accepted by: \_\_\_\_\_

P.O. \_\_\_\_\_

Date: \_\_\_\_\_