

	Form No.: 130.16-N1 (LS01)	506
	Supersedes: None	
LITERATURE SUPPLEMENT	File with: Form: 130.16-N1 (406)	
Subject: Flexsys Underfloor Design Level 2 MIT2 w/ Airvalve		

FIG. 22 - MODULAR CABLES on Page 19 of Form 130.16-N1 (406) has been revised. PAP-6 cable changed from Pin # 1 White to Pin # 2 White. The figure shown below incorporates the correction.

