



Service Operations
Machinery and Systems Division
Carrier Corporation

File
Date 1/25/68
Page 1 of 1

Subject: ELECTRONIC CONTROL MODULE MAINTENANCE
Reference:

Supersede and Destroy
File
Date
Page of

Mail Keys:
Distribution:

Centrifugal FER 68-1

1.0 PURPOSE

To recommend that a protective spray be used on electronic control modules as a routine maintenance procedure and troubleshooting aid.

2.0 MACHINES AFFECTED

19 Series electronic control modules.

3.0 INFORMATION

A protective spray (such as Dry-Kleen, made by G. C. Electronics) should be used on the underside of control modules and in relay and tube sockets. Use of such a spray helps to protect the components from dirt and dust, thus minimizing short circuits and other electrical malfunctions.

FILING INSTRUCTIONS: CENTRIFUGAL FIELD EXPERIENCE REPORTS MANUAL
TAB: CONTROLS-WIRING

Revised to new format, 5/81.

Prepared by:

al Pratt *ppk*

Approved by:

Alan M. Johnson

Date: 5-29-81