



**UNITED
TECHNOLOGIES
CARRIER**

Commercial Division
Carrier Corporation

BULLETIN: CA-SB-19-D-71-56

DATE: 5/7/71

PAGE: 1 OF: 1

SERVICE BULLETIN

SUBJECT:

COOLER AND CONDENSER WATER CAPACITIES, 19DG

SUPERSEDE

BULLETIN:

DATE:

PAGE: OF:

Installation, repair and service and equipment referenced in this Service Bulletin should be undertaken only by qualified persons. Carrier Corporation (1) makes no representations or warranties, expressed or implied, concerning the accuracy, completeness or right to use the information contained herein, and (2) disclaims all liability for injuries, damages, infringements and other losses which may arise on account of, or which may result from, the use or application of any information, method or apparatus disclosed herein.

PURPOSE: To advise of heat exchanger water capacities (water side.)

**MACHINES
AFFECTED:** All 19DG's.

INFORMATION: The table below gives the cooler and condenser water capacities in gallons. This information is useful for acid cleaning to help figure the correct concentrations.

19DG COOLER AND CONDENSER WATER CAPACITIES

MACHINE SIZE	SHELL SIZE	WATER CAPACITY (GALLONS)	
		Cooler	Condenser
100	11	21	22
110	13	22	24
130	15	24	25
145	17	26	27
160	21	33	31
180	23	35	37
200	25	37	39
225	27	40	42
255	31	57	60
285	33	61	64
325	35	65	68
365	37	69	73
400	39	73	77