



**UNITED
TECHNOLOGIES
CARRIER**

Commercial Division
Carrier Corporation

BULLETIN: CA-SB-19-E-71-57
DATE: 5/7/71
PAGE: 1 OF 1

SERVICE BULLETIN

SUBJECT:

COOLER AND CONDENSER WATER CAPACITIES, 19EA

SUPERSEDE
BULLETIN:

DATE:
PAGE: OF:

Installation, repair and service and equipment referenced in this Service Bulletin should be undertaken only by qualified persons. Carrier Corporation (1) makes no representations or warranties, expressed or implied, concerning the accuracy, completeness or right to use the information contained herein, and (2) disclaims all liability for injuries, damages, infringements and other losses which may arise on account of, or which may result from, the use or application of any information, method or apparatus disclosed herein.

PURPOSE: To advise to heat exchanger water capacities (water side.)

**MACHINES
AFFECTED:** All 19EA's.

INFORMATION: The table below gives the cooler and condenser water capacities in gallons. This information is useful for acid cleaning to help figure the correct concentrations.

19EA COOLER AND CONDENSER WATER CAPACITY

MACHINE SIZE	SHELL SIZE	WATER CAPACITY (GALLONS)	
		Cooler	Condenser
400	41	42	55
430	41	42	55
465	42	45	58
500	43	50	64
550	45	54	69
590	46	57	74
630	47	61	78
680	51	87	108
750	52	90	117
825	53	99	129
910	55	110	141
1000	56	119	154
1100	57	132	173