YORK®

File in SJ-2 Manual(s).

SERVICE BULLETIN

Supersedes: Nothing	4/89	Form 160.45-M2 (SB-27)
File with Form: 160.45-M2		

S-28-89

SUBJECT: Transducers for the Centrifugal Smart Panels
(NEW and OLD Styles)

We are receiving phone calls from the field on replacement transducers which are D.O.A. Upon further investigation we found that some field Mechanics are using the New Micro Panel (Keyless Style) transducers on the Old Micro Panel (with Key Switch) and vice versa.

The New Micro Panel tranducers operate on a +5 V.D.C. supply while the Old Style Micro Panel operates on a +12 V.D.C. supply.

NOTE: THE ABOVE TRANSDUCERS CAN NOT BE INTERCHANGED BETWEEN THE PANELS.

You will find below the part numbers for the Old and New Panels:

	OLD STYLE PANEL	NEW STYLE PANEL
COND.	= 025-25127-001	= 025-27517-001
EVAP.	= 025-25127-002	= 025-27517-002
L.O.P.	= 025-25127-003	= 025-27517-003
H.O.P. & PURGE	= 025-25127-004	= 025-27517-004

• Product responsibility on Micro Panels

1. OLD STYLE (with Key Switch on Front Panel) = Keith Stine - PH. #6143
2. NEW STYLE (without Key Switch on Front Panel) = Steve Baer - PH. #6146

K. L. Strine,
ELECTRONIC PRODUCTS SERVICE ENGINEER

F041889KS-1

DPC 2M 489 .04