



File in                      SJ4                      Manual(s).

**SERVICE BULLETIN**

Supersedes:	None	194	Form 160.48-M2 (SB 1)
File with Form:	160.48-M2		

94-3

SUBJECT: FAX 4000 / ANDOVER INTERFACING TO STYLE "F" CENTRIFUGALS

Microcomputer Control Panels supplied on York Style "F" Centrifugal chillers built in the past two years are compatible with FAX 4500 only. Some field offices have overcome this situation by retrofitting the microboard in the panel to the older part number 031-00940-000 board. THIS IS NOT A WARRANTY SITUATION. Warranty claims of this type will be rejected.

If you encounter this situation in the field, your office will need to contact the salesperson who sold the chiller. Any costs to provide FAX4000 / Andover compatibility must be charged to the equipment order. Our marketing department has agreed, that cost of extra hardware and BAS programming support MUST be addressed in the pricing of the original equipment order.

Also be aware that retrofitting panels to the older style of microboard requires very careful attention to compatibility between microboard, EPROM, transducers, 32K/64K jumpers, and the refrigerant used in the system. Compatibility information is found in the parts manuals. If any one of these items is incorrect, the panel will not operate, or will operate incorrectly.

SSP 3M 194 .05  
CODE: SJ4A