



File in Manual(s).

SERVICE BULLETIN

Supersedes:	192	Form 160.48-M2 (SB-2 A)
File with Form:	160.48-M2 (191)	

**SUBJECT: Centrifugal and Screw (125 - 675 TR)
Chiller Microcomputer Control Center -
Micro Board 031-01065-001**

Micro Board 031-01065-001 is now in production. It supersedes Micro Board 031-01065-000.

The Line -001 Board contains triac drivers that have a higher voltage rating than those on the Line -000 Board. This is the only difference. All other circuits, plug connections, program jumpers, etc., are identical to the Line -000 Board. The same troubleshooting procedures apply.

**S. L. Baer - 36BE
ELECTRONIC PRODUCTS SERVICE ENGINEER**

*DRW 3M 292 .05
CODE: SJ*