YORK

File in SJ Manual(s).

SERVICE BULLETIN | Supersedes: | 392 | Form 160.49-O1 (SB- 1

File with Form: 160.49-O1

SUBJECT; R-22 Centrifugal Chiller Microcomputer Control Center - Version C.02S.04 and C.02F.04 EPROMS

The following Enhancement has been included in these EPROMS:

TIMING SEQUENCE

The Vent Line, Liquid Spray and Oil Return Solenoid Valves are energized (opened) 1.83 minutes (110 seconds) after the Start sequence is initiated. They are de-energized (closed) the same as before. Change FIG. 16 of 160.49-01 accordingly.

DAILY SCHEDULE SETPOINT PROGRAMMING

Provision has been made to expedite the programming of the Daily Start / Stop Schedule. After entering the desired Start and Stop times for Monday, this schedule can be repeated for Tuesday thru Friday by pressing only one keypad Key as follows:

1. After gaining access to Program Mode in the usual manner, press the Daily Schedule Setpoint Key.

2. Enter the desired Sunday schedule. Don't press the ENTER Key.

3. Press ADVANCE DAY / SCROLL Key.

4. Enter the desired Monday Schedule. Don't press the ENTER Key.

5. Press ADVANCE DAY / SCROLL Key.

6. "Repeat Mon Schedule MON-FRI ? Yes = 1; No = 0" is displayed. If you want the same Start and Stop times for MON thru FRI, press the 1 Key. If you want different Start and Stop times for MON thru FRI press the 0 Key.

7. If you pressed the 1 Key in the previous step, press ADVANCE DAY / SCROLL Key to advance to SAT. Enter the desired Saturday schedule.

   Press ADVANCE DAY / SCROLL Key to advance to HOL. Enter the desired holiday schedule and press ENTER Key. The entire Start/Stop schedule for the week will be entered.