



File in ^{SJ} Manual(s).

SERVICE BULLETIN

Supersedes:

392

Form 160.49-M2 (SB- 2

File with Form: 160.49-M2

SUBJECT: R-22 Centrifugal Chiller Microcomputer
Control Center - Version C.02S.04 and
C.02F.04 EPROMS

The following Enhancement has been included on these EPROMS:

TIMING SEQUENCE

The vent line, liquid spray and oil return solenoid valves are energized (opened) 1.83 minutes (110 seconds) after the start sequence is initiated. They are de-energized (closed) the same as before. Change FIG. 5 of 160.49-M2 accordingly.

DRW JM 492 .05
CODE: SJ4B