



SERVICE BULLETIN

SERVICE BULLETIN

Supersedes: NOTHING

Form 160.49-M2 (SB13) (697)

File with form 160.49-M2 In SJ4 Manual

SUBJECT: YK CENTRIFUGAL CHILLERS - VENT LINE SOLENOID VALVE

Beginning on/about June 1997, new YK centrifugal chillers will no longer be supplied with the Vent Line Solenoid valve (3SOL).

S.L. Baer
YORK Factory Service