



SERVICE BULLETIN

SERVICE BULLETIN

Supersedes: Nothing

Form 160.49-M2 (SB15) (598)

File With 160.49-M2

SUBJ.: REFRIGERANT LEVEL
SENSOR . LOCATION OF
THE SPAN AND ZERO POTS.

YOU WILL FIND BELOW A PHOTOGRAPH OF THE REFRIGERANT LEVEL SENSOR , SHOWING YOU THE LOCATION OF THE **ZERO** AND **SPAN** POTS WHICH ARE USED WHEN CALIBRATING THE SENSOR:

