



* SUPPLIED WITH HARMONIC FILTER OPTION
** SUPPLIED WITH HIGH FREQUENCY TRAP OPTION

YORK INTERNATIONAL CORPORATION
YORK, PA. 17405

DIMENSIONS ARE IN INCHES DO NOT SCALE TOLERANCES PER ENG. STD. M-282 WELDING PER ENG. STD. M-30 REF. DWG.		LABEL WIRING CONNECTION DIAGRAM VYPER DRIVE 351 HP. V.S.D.		MATERIAL	
NAME DR. J.W. MEDWICK APPR. H.SCHNETZKA SCALE: N.T.S.	DATE 11-30-00 03-27-00	SIZE D	CAGE NO. 66935	DRAWING NUMBER 035-17889-000	
WT. =		LBS.	ORIG. NO.	SHEET 2 OF 2	

REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.
-	NEW		0799			C	10-20-05	SEE SHEET 1 FOR REVISION.	0799	CBH	MST						
A	10-10-01	IDCCT'S WERE DCCTI & 2DCCT'S WERE DCCT2 AT B-2: 3T WAS 4T, 4T WAS 5T & 5T WAS 6T AT C-4: 8T WAS 3T AT D-3: CHANGED CONNECTION TO CIO AT C-6. 5T WAS 3CT, 3T WAS ICT, & 4T WAS 2CT AT C-3.	0799 3073	JWM	SVS	D	10-12-06	CHANGED VSD LOGIC BD. AND ADDED TERMINALS TO 2TB TO INCLUDE MODBUS: ADDED TRANSIENT SUPR. BD. AT D-8.	0799 0087	KSR	MST						
B	04-12-05	ADDED SUPPRESSORS AT C-5.	0799 3074	CBH	MST	E	11-01-07	AT B-2 HARMONIC FILTER LOGIC CONTROL WAS 031-01632-031: ADDED G5, G6 AND G7: TRANSIENT SUPR BD P/N WAS 031-02453-001.	0799 0226	CBH	MWM						