

MVVSD1250R_ -80
 MVVSD1500R_ -80
 MVVSD1750R_ -80

└─ T = YT UNITS
 └─ K = YK UNITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
00	I808JT00	1	MEDIUM VOLTAGE FLOOR MOUNT VFD
01	---	--	----
02	---	--	----
03	I808JT03	0	GROUNDING PROCEDURE
04	---	--	----
05	I808JT05	0	RATING SHEET
06	---	--	----
07	I808JT07	0	ONE-LINE DIAGRAM
08	---	--	----
09	---	--	----
10	I808JT10	0	THREE-LINE DIAGRAM
11	I808JT11	0	MAIN CIRCUIT
12	I808JT12	0	RECTIFIER CIRCUIT
13	---	--	----
14	---	--	----
15	I808JT15	0	CONTROL POWER AND FAN CIRCUITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
16	I808JT16	1	PCB INTERCONNECTION (1)
17	I808JT17	0	PCB INTERCONNECTION (2)
18	I808JT18	0	EXTERNAL I/O (1)
19	I808JT19	0	EXTERNAL I/O (2)
20	I808JT20	0	CONTROL CIRCUIT
21	---	--	----
22	---	--	----
23	---	--	----
24	---	--	----
25	---	--	----
26	---	--	----
27	---	--	----
28	I808JT28	1	CHILLER SYSTEM TERMINAL CONNECTIONS
29	---	--	----
30	I808JT30	0	ENCLOSURE OUTLINE
31	---	--	----

YORK INTERNATIONAL CORPORATION
 YORK, PA .17405

DIMENSIONS ARE IN INCHES DO NOT SCALE TOLERANCES PER ENG. STD. M-282 WELDING PER ENG. STD. M-30 REF. DWG.		MEDIUM VOLTAGE VFD FLOOR MOUNT FRAME 3 2300V		MATERIAL TYPE _____ ENG. STD. _____ PART NO. _____ CUT SIZE _____
DR. _____ APPR. _____ SCALE: _____	NAME _____ DATE _____	SIZE D	CAGE NO _____	DRAWING NUMBER I808JT00
WT. = _____ LBS.		ORIG. NO. _____		SHEET 1 of 15

REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.
6						13						20					
5						12						19					
4						11						18					
3						10						17					
2						9						16					
1	02/05/06	REVISED		OB	AL	8						15					
0	07/19/06	FIRST ISSUE		OB	AL	7						14					

*ALL PROPRIETARY RIGHTS
 IN THE SUBJECT MATTER
 HEREOF ARE RESERVED,
 AND NO PERMISSION IS
 GRANTED TO REPRODUCE
 THIS PRINT IN WHOLE
 OR IN PART, OR DISCLOSE
 ANY OF THE INFORMATION
 UPON IT TO OTHERS
 WITHOUT WRITTEN RELEASE
 BY YORK INTERNATIONAL
 CORPORATION.*