

MVVSD2000R\_ -80  
 MVVSD2250R\_ -80  
 MVVSD2500R\_ -80

└─ T = YT UNITS  
 └─ K = YK UNITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
00	I808JV00	1	MEDIUM VOLTAGE FLOOR MOUNT VFD
01	---	--	----
02	---	--	----
03	I808JV03	0	GROUNDING PROCEDURE
04	---	--	----
05	I808JV05	0	RATING SHEET
06	---	--	----
07	I808JV07	0	ONE-LINE DIAGRAM
08	---	--	----
09	---	--	----
10	I808JV10	0	THREE-LINE DIAGRAM
11	I808JV11	0	MAIN CIRCUIT
12	I808JV12	0	RECTIFIER CIRCUIT
13	---	--	----
14	---	--	----
15	I808JV15	0	CONTROL POWER AND FAN CIRCUITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
16	I808JV16	1	PCB INTERCONNECTION (1)
17	I808JV17	0	PCB INTERCONNECTION (2)
18	I808JV18	0	EXTERNAL I/O (1)
19	I808JV19	0	EXTERNAL I/O (2)
20	I808JV20	0	CONTROL CIRCUIT
21	---	--	----
22	---	--	----
23	---	--	----
24	---	--	----
25	---	--	----
26	---	--	----
27	---	--	----
28	I808JV28	1	CHILLER SYSTEM TERMINAL CONNECTIONS
29	---	--	----
30	I808JV30	0	ENCLOSURE OUTLINE
31	---	--	----

**YORK INTERNATIONAL CORPORATION**  
 YORK, PA .17405

DIMENSIONS ARE IN INCHES DO NOT SCALE TOLERANCES PER ENG. STD. M-282 WELDING PER ENG. STD. M-30 REF. DWG.		MEDIUM VOLTAGE VFD FLOOR MOUNT FRAME 4 2300V		MATERIAL TYPE _____ ENG. STD. _____ PART NO. _____ CUT SIZE _____
DR. _____ APPR. _____ SCALE: _____	NAME _____ DATE _____	SIZE D	CAGE NO _____	DRAWING NUMBER 1808JV00
WT. = _____ LBS.		ORIG. NO. _____		SHEET 1 of 15

REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.
6						13						20					
5						12						19					
4						11						18					
3						10						17					
2						9						16					
1	02/05/06	REVISED		OB	AL	8						15					
0	07/20/06	FIRST ISSUE		OB	AL	7						14					

\*ALL PROPRIETARY RIGHTS  
 IN THE SUBJECT MATTER  
 HEREOF ARE RESERVED,  
 AND NO PERMISSION IS  
 GRANTED TO REPRODUCE  
 THIS PRINT IN WHOLE  
 OR IN PART, OR DISCLOSE  
 ANY OF THE INFORMATION  
 UPON IT TO OTHERS  
 WITHOUT WRITTEN RELEASE  
 BY YORK INTERNATIONAL  
 CORPORATION.\*