

MVVSD0500R_-92
 MVVSD0600R_-92
 MVVSD0700R_-92

└─ T = YT UNITS
 └─ K = YK UNITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
00	I808K200	2	MEDIUM VOLTAGE FLOOR MOUNT VFD
01	---	--	----
02	---	--	----
03	I808K203	0	GROUNDING PROCEDURE
04	---	--	----
05	I808K205	0	RATING SHEET
06	---	--	----
07	I808K207	0	ONE-LINE DIAGRAM
08	---	--	----
09	---	--	----
10	I808K210	1	THREE-LINE DIAGRAM
11	I808K211	0	MAIN CIRCUIT
12	I808K212	0	RECTIFIER CIRCUIT
13	---	--	----
14	---	--	----
15	I808K215	0	CONTROL POWER AND FAN CIRCUITS

NO	DRAWING NO	REV	DRAWING DESCRIPTION
16	I808K216	1	PCB INTERCONNECTION (1)
17	I808K217	0	PCB INTERCONNECTION (2)
18	I808K218	0	EXTERNAL I/O (1)
19	I808K219	0	EXTERNAL I/O (2)
20	I808K220	0	CONTROL CIRCUIT
21	---	--	----
22	---	--	----
23	---	--	----
24	---	--	----
25	---	--	----
26	---	--	----
27	---	--	----
28	I808K228	1	CHILLER SYSTEM TERMINAL CONNECTIONS
29	---	--	----
30	I808K230	0	ENCLOSURE OUTLINE
31	---	--	----

YORK INTERNATIONAL CORPORATION YORK, PA .17405			
DIMENSIONS ARE IN INCHES DO NOT SCALE TOLERANCES PER ENG. STD. M-282 WELDING PER ENG. STD. M-30 REF. DWG.		MEDIUM VOLTAGE VFD FLOOR MOUNT FRAME 0 3300V	
MATERIAL TYPE _____ ENG. STD. _____ PART NO. _____ CUT SIZE _____		DRAWING NUMBER I808K200	
DR. _____ APPR. _____ SCALE: _____	NAME _____ DATE _____ SIZE D	CAGE NO _____	ORIG. NO. _____
WT. = _____ LBS.		SHEET 1 of 15	

REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.	REV. LEV.	DATE	REVISION RECORD	CHG. NO.	DR.	CK.
6						13						20					
5						12						19					
4						11						18					
3						10						17					
2	05/23/08	REVISED				9						16					
1	02/05/08	REVISED				8						15					
0	08/07/06	FIRST ISSUE				7						14					

*ALL PROPRIETARY RIGHTS
 IN THE SUBJECT MATTER
 HEREOF ARE RESERVED,
 AND NO PERMISSION IS
 GRANTED TO REPRODUCE
 THIS PRINT IN WHOLE
 OR IN PART, OR DISCLOSE
 ANY OF THE INFORMATION
 UPON IT TO OTHERS
 WITHOUT WRITTEN RELEASE
 BY YORK INTERNATIONAL
 CORPORATION.*