

Password	York Machine	Password	Other Machines
	Optiview, 1-Line Panel, YT,YK,YR,YS		ABB VFD
9675	Operator	358	
1380	Service		
1397	Prox. Probe, Ack. Fault, Calibration, & HP	12948	???A&B
0368	Surge Map, Clear w/ Switch Off		
4268	Non-Optiview Level		Trane Chillers IPU 2 Panel
1296	?	++--++	Field Start Up
378	Clear Surge Map on New YK	+ - + - + -	Machine Configuration
	YCAV/YCIV	--++--	Refrigerant Monitor
9675	Service w/ Switch Off For AO/DO Control	- + - - + +	Refrigerant Min. Cal.
6140	Programing	+ + - - + -	Or Refig. Min. Cal.
4245	??? Run Fan & Pump		
2878	Feed Valve Set Point		Trane Chiller. CH 530 Panel
		159	Unlock Display Touch Pad
	YCAL / YLAA. w/ IPU Board		
Up-Up-Down-Down	DO Control w/ Switch Off		
Down-Down-Down-Down	Access Bacnet Control Parameters		
	YCAS		Carrier Chillers
1380	General Programing	1 1 1 1	PIC Control Panel
5144	Amps, Refrigeratant		
6140	Recall Defaults		
9675	DO Control w/ Switch Off		
	YPAL		Metasys
9675	Level 1	XMG3-Rel.1	user: metasysagent
9725	Level 2		old version
	Old Receipts Chiller/ YCAJ, etc		York ISN Controls
7396	????		user: