

Punch List for the Refri (YORK) Compressors	
C-1231A	
1. Vendor Items	
A.	Install one ground wire on opposite corner of 5 KV Motor wire size is 2/0
B.	Install Ground wire on both oil pump Motors. Wire size is # 8
C.	Check CT wiring for correct wire size and ring lugs
D.	Check to see if the XO tap on the transformer has been grouded
2. Ckt I D	
C-1231B	
1. Vendor Items	
A.	Install one ground wire on opposite corner of 5 KV Motor wire size is 2/0
B.	Install Ground wire on both oil pump Motors. Wire size is # 8
C.	Check CT wiring for correct wire size and ring lugs
D.	Check to see if the XO tap on the transformer has been grouded
2. Ckt I D	
C-1231C	
1. Vendor Items	
A.	Install one ground wire on opposite corner of 5 KV Motor wire size is 2/0
B.	Install Ground wire on both oil pump Motors. Wire size is # 8
C.	Check CT wiring for correct wire size and ring lugs
D.	Check to see if the XO tap on the transformer has been grouded
2. Ckt I D	
C-1231D	
1. Vendor Items	
A.	Install one ground wire on opposite corner of 5 KV Motor wire size is 2/0
B.	Install Ground wire on both oil pump Motors. Wire size is # 8
C.	Check CT wiring for correct wire size and ring lugs
D.	Check to see if the XO tap on the transformer has been grouded
2. Ckt I D	
C-1231E	
1. Vendor Items	
A.	Install one ground wire on opposite corner of 5 KV Motor wire size is 2/0
B.	Install Ground wire on both oil pump Motors. Wire size is # 8
C.	Check CT wiring for correct wire size and ring lugs
D.	Check to see if the XO tap on the transformer has been grouded
2. Ckt I D	