



Service Information

File In/With:		SI0326	
		New	1016
Equipment Affected:	YVWA		
FLA Settings			

GENERAL

The FLA/OL settings are not in the YVWA IOM manual or Johnson Controls literature.

The FLA settings for the YVWA product are located **inside** the **VSD cabinet** on a **separate label**.

This is true for the one (1) and two (2) compressor YVWA units.

This is a **separate label on the VSD cabinet**.

The labels are located here since the units (VSD's) are different for each customer's design conditions.

The factory places the label inside the VSD before it leaves the plant.

The label location on the VSD can be located at one of the following locations on the VSD cabinet.

1. Inside on the right cabinet on the right wall.
2. Outside on the right cabinet.
3. On the back of the VSD cabinet.

Work on this equipment should only be done by properly trained personnel who are qualified to work on this type of equipment. Failure to comply with this requirement could expose the worker, the equipment and the building and its inhabitants to the risk of injury or property damage.

The instructions on this service bulletin are written assuming the individual who will perform this work is a fully trained HVAC & R journeyman or equivalent, certified in refrigerant handling and recovery techniques, and knowledgeable with regard to electrical lock out/tag out procedures. The individual performing this work should be aware of and comply with all Johnson Controls, national, state and local safety and environmental regulations while carrying out this work. Before attempting to work on any equipment, the individual should be thoroughly familiar with the equipment by reading and understanding the associated service literature applicable to the equipment. If you do not have this literature, you may obtain it by contacting a Johnson Controls Service Office.

Should there be any question concerning any aspect of the tasks outlined in this bulletin, please consult a Johnson Controls Service Office prior to attempting the work. Please be aware that this information may be time sensitive and that Johnson Controls reserves the right to revise this information at any time. Be certain you are working with the latest information.