

Rosemount 485 Annubar[®] Primary Flow Element Flow Test Data Book



Table of Contents

| | |
|----------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SECTION 1 Annubar Technology | Rosemount 485 Annubar Primary Flow Element 1-1 Testing 1-1 Research and Development Testing 1-1 Mechanical and Structural Testing 1-2 In-House Performance Testing 1-2 Independent Laboratory Testing 1-2 On-Site Performance Tests 1-2 Rosemount 485 Flow Element Test Advantages 1-2 |
| SECTION 2 How the Annubar Works | Overview 2-1 Design and Performance 2-2 Rosemount 485 Annubar Sensor Design 2-2 Differential Pressure (DP) Signal 2-2 Impact (High) Pressure Measurement 2-3 Suction (Low) Pressure Measurement 2-3 Surface Texture 2-4 |
| SECTION 3 Flow Coefficient Reynolds Number Independence | Flow Coefficient Overview 3-1 Benefits 3-1 Rosemount 485 Annubar Reynolds Number Ranges 3-2 |
| SECTION 4 Annubar Flow Theory | Nomenclature 4-1 Flow Equation Derivation 4-2 Blockage Equation Derivation 4-3 Conclusion 4-5 |
| SECTION 5 Test Facilities and Procedures | Overview 5-1 Testing Laboratories 5-1 Rosemount Boulder, Colorado Flow Laboratory 5-1 Alden Research Laboratories (ARL) 5-1 SwRI Gas Research Institute (GRI), Meter Research Facility (MRF) 5-1 Gravimetric Procedure 5-2 Sensor Size 1 5-4 Sensor Size 2 5-10 Sensor Size 3 5-26 |
| SECTION 6 References | |

Rosemount 485 Annubar Flow Test Data Book

Reference Manual
00821-0100-4809, Rev AA
June 2003

Rosemount 485 Annubar Primary Flow Element Flow Test Data Book

NOTICE

Read this manual before working with the product. For personal and system safety, and for optimum product performance, make sure to thoroughly understand the contents before installing, using, or maintaining this product.

Customer Central

1-800-999-9307 (7:00 a.m. to 7:00 P.M. CST)

National Response Center

1-800-654-7768 (24 hours a day)
Equipment service needs

International

1-(952) 906-8888


⚠ CAUTION

The products described in this document are NOT designed for nuclear-qualified applications.

Using non-nuclear qualified products in applications that require nuclear-qualified hardware or products may cause inaccurate readings.

For information on Rosemount nuclear-qualified products, contact an Emerson Process Management Sales Representative.

May be protected by one or more of the following U.S. Patent Nos. 4633713, 4717159, 5710370, 5773726, 5969266, 6321166, and 6470755. Other foreign patents issued and pending.

 Fisher-Rosemount satisfies all obligations coming from legislation to harmonize product requirements in the European Union

Section 1 Annubar Technology

| | |
|-------------------------------------------------------------|-----------------|
| Rosemount 485 Annubar Primary Flow Element | page 1-1 |
| Rosemount 485 Flow Element Test Advantages | page 1-2 |

The Rosemount 485 Annubar primary flow element maintains the traditional strengths of Averaging Pitot Tubes (APTs) with improved performance. The strengths of the Rosemount 485 Annubar include:

- Low permanent pressure loss
- A flow coefficient independence of Reynolds number
- Simple installation, including a gear drive insertion and retraction device
- The highest signal to noise ratio of any APT
- $\pm 0.75\%$ accuracy
- Integral temperature measurement
- Direct transmitter mounting capability

ROSEMOUNT 485 ANNUBAR PRIMARY FLOW ELEMENT

The Rosemount 485 Annubar primary flow element is the fifth generation Annubar. This design is comprised of three separate tubes that are drawn to produce a unique geometrical shape that produces a high and low pressure signal and contains an integral thermowell. The geometry change to the sensor required testing to establish a characterization curve and to determine a new flow coefficient.

Testing

Tests performed on the 485 Annubar primary flow element are divided into five major categories:

- Research and development testing
- Mechanical and structural testing
- In-house performance testing
- Independent laboratory testing
- On-site performance testing

All categories are on-going and continue to be a part of the current Rosemount test program for the 485 Annubar primary flow element.

Research and Development Testing

Extensive research was conducted to identify a sensor shape that would create a large differential pressure (DP) signal with minimal signal noise. Once the ideal shape T-shape was identified, tests were conducted to validate the improvements of the new primary flow element.

Parameters such as the impact of using a frontal slot design instead of discrete sensing ports to measure the impact pressure, aspect ratios, and surface texture were tested and optimized.

Mechanical and Structural Testing

Rosemount performed mechanical and structural testing for:

- Material hardness
- Moments of inertia
- Fatigue life
- Fluid loading due to lift and drag forces
- Static bend tests
- Allowable stress limits
- Failure analysis
- Vibration

Material and structural testing at:

- Hauser Laboratories
- MicroMotion Laboratory
- Eden Prairie Flow Laboratory

In-House Performance Testing

Hundreds of flow tests were performed in the Rosemount flow laboratory in 2" to 12" pipeline, using independently certified magnetic meters as primary reference meters. Baseline K-values, signal noise, cavitation, high and low Reynolds number limitations, methods of installations, static modeling, and straight-run requirements are just a few of the in-house performance tests that were performed on the Rosemount 485 Annubar primary.

Independent Laboratory Testing

Rosemount 485 Annubar primary flow element models were tested at three independent laboratories:

- Alden Research Laboratory (ARL)
- Colorado Engineering Experiment Station, Inc. (CEESI)
- Southwest Research Institute (SwRI)

Certified flow-data sheets were supplied from each of these facilities in pipelines ranging from 2" to 24" over a wide range of Reynolds numbers. A representative sample of independent tests conducted at Rosemount and independent laboratories are Section 5: Test Facilities and Procedures.

On-Site Performance Tests

Rosemount has a field service department that performs on-site performance tests and in-line calibrations for customers with unique installations or applications.

Rosemount 485 Flow Element Test Advantages

Rosemount test procedures incorporate the following criteria and advantages:

- Flow test data were collected over a flow turndown range of 10:1 in most cases
- All coefficients are $\pm 0.75\%$ of the published K-value of a particular primary flow element.

Section 2 How the Annubar Works

| | |
|------------------------------|----------|
| Overview | page 2-1 |
| Design and Performance | page 2-2 |

OVERVIEW

The Rosemount 485 is a device used to measure the flow of a liquid, gas or steam fluid that flows through a pipe. It enables flow measurement by creating a differential pressure (DP) that is proportional to the square of the velocity of the fluid in the pipe, in accordance with Bernoulli's theorem. This DP is measured and converted into a flow rate using a secondary device, such as a DP pressure transmitter.

The flow is related to DP through the following relationship.

$$\text{Equation 2-1} \quad Q \propto K \sqrt{DP}$$


where:

- Q = Flow Rate
- K = Annubar Flow Coefficient
- DP = Differential Pressure

For a more complete discussion on the flow equation, refer to Section 4: Annubar Flow Theory.

The Annubar generates a DP by creating blockage in the pipe and acting as an obstruction to the fluid. The velocity of the fluid is decreased and stalled as it reaches the front surface the Annubar sensor, creating the impact/high pressure. The Rosemount 485 Annubar senses the impact pressure by utilizing a frontal slot design, which opens into the high pressure chamber. This high pressure chamber connects directly into the DP transmitter for measurement.

Figure 2-2. Cross Section of the Rosemount 485 Annubar in a Flow Stream



As the fluid continues around the Annubar sensor, it creates a lower velocity profile on the backside of the sensor, creating the low/suction pressure downstream of the 485 Annubar. Individual ports, located on the backside of the Annubar sensor measure this low pressure. Working on the same principle as the high pressure, an average low pressure is maintained in the low pressure chamber that connects directly into the transmitter for measurement.

The resultant differential pressure is the difference between the impact (high) pressure reading and the suction (low) pressure reading as seen below.

$$\text{Equation 2-3} \quad DP = P_H - P_L$$

where:

PH = High Pressure


PL = Low Pressure

DESIGN AND PERFORMANCE

Rosemount 485 Annubar Sensor Design

The 485 Annubar is T-shaped in design and is constructed in three scaled sizes for use in a wide range of pipe diameters. Its design includes a single high-pressure plenum, three common low-pressure plenums, and an integral thermowell.

Figure 2-4. Cross-Section of the
Rosemount 485 Annubar



Differential Pressure (DP) Signal


The T-shaped design of the 485 Annubar generates more differential pressure than any APT. The flat upstream surface of the sensor is perpendicular to the direction of flow, which results in a high and very stable drag coefficient. Since the flow coefficient, or k factor (see Equation 2-1), is a function of the drag coefficient, this produces a large, repeatable and predictable DP signal for a given velocity.

The magnitude of the DP signal is directly related to measurement accuracy and the amount of primary element turndown, particularly at lower flow rates. One traditional limitation of APT technology is that accuracy degrades at lower flow rates as a result of the minimal DP produced. The Rosemount 485 extends the lower range limit that an APT can measure and maintain performance as a result of the additional DP generated.

Impact (High) Pressure Measurement

As mentioned in the “Overview” on page 2-1, the Rosemount 485 Annubar measures the impact (high) pressure with a frontal slot design. The laser cut slots extend across the entire front surface of the sensor to maximize the amount of the velocity flow profile measured and increase the accuracy of the measurement. Multiple slots are used to maintain the structural integrity of the bar. A seal weld is visible around the perimeter of the slots and is used to seal the high pressure chamber from the low pressure chamber to prevent any leakage potential. Testing revealed that the raised surface of the weld does not have any effect on performance so it is not removed.

Figure 2-5. Rosemount 485
Frontal Slot Design




The patented slot design replaces sensing ports used by traditional APTs. This slot “integrates” the velocity flow profile and improves the accuracy of the measurement. By “integrating” the flow profile, a consistent series of data is recorded across the pipe diameter instead of limited samples taken at a few discrete points. By increasing the number of samples taken across the pipe of the actual flow rate, the accuracy of the measurement is improved.

Suction (Low) Pressure Measurement

The Rosemount 485 Annubar measures the suction (low) pressure with sensing ports located in stagnation zones on the backside of the sensor. As the fluid comes into contact with the 485 Annubar sensor and separates from the front edges, the velocity and turbulence level of the fluid in the area directly behind the sensor is greatly decreased. The low velocity and turbulence level in this stagnation zone significantly reduces any pressure variation in this region. Individual sensing ports are drilled in this location to detect the suction (low) pressure.

The number of ports located on the backside of a given sensor is a function of pipe size and mathematically determined by the same Chebyshev principles of previous Annubar designs.

Figure 2-6. Velocity Graph



Surface Texture

As the flow over any surface in the flow stream is increased, the character of the fluid flow near that surface goes through a transition. At a certain critical flow rate, the level of turbulence in this region, termed the boundary layer, increases sharply. This increase in turbulence in the boundary layer on the front surface of the 485 Annubar causes a marked change in the separation of the flow at the edge, which in turn affects the accuracy of the differential pressure signal. The transition from the non-turbulent (laminar) to a turbulent boundary layer condition is an inescapable fact described by the principles of fluid dynamics. However, it has been found that altering the roughness or texture of the surface adjacent to the boundary layer can control the flow at which that transition takes place.

The front surface of the 485 Annubar sensor is tailored to the customer's flow application. In high flow applications (where the maximum expected flow exceeds one million Reynolds number), the surface is textured to increase the level of turbulence at a given flow rate. This ensures that the transition from laminar to turbulent flow in the boundary layer occurs at flows below (and outside) the customer's measurement range. For lower flow applications, the surface is left smooth to maintain a laminar boundary layer forcing the transition to occur above the maximum flow that will be seen in the application.

Section 3 Flow Coefficient Reynolds Number Independence

| | |
|----------------------------------------------------|----------|
| Flow Coefficient Overview | page 3-1 |
| Benefits | page 3-1 |
| Rosemount 485 Annubar Reynolds Number Ranges . . . | page 3-2 |

FLOW COEFFICIENT OVERVIEW

The flow coefficient (K-factor) is the ratio of the actual flow rate to the calculated (theoretical) flow rate. The accuracy of the Rosemount 485 Annubar relates directly to the flow coefficient. The flow coefficient is empirically determined by testing a representative sample of flowmeters to establish the relationship between flowrate and the DP induced across the primary element.

This sampling of flow coefficients is generally plotted as a function of key flow-meter variables. For averaging pitot tubes, flow coefficients are plotted against the meter's pipe blockage.

Curve-fitting techniques are used to generate an equation that best fits the sampling of flow coefficients. This curve-fit equation becomes the basis for a manufacturer's published flow coefficients. These published flow coefficients are used for flowmeters in nearly all untested conditions.

Rosemount has supplemented the flow coefficient equations discussed above with the blockage equation derived in Section 4 of this document. This blockage equation defines a relationship between flow coefficient and blockage that substantiates the results of empirical testing. Extensive APT testing conducted by Rosemount over the past 35 years support the theoretical equation.

BENEFITS

The K-factor of an Annubar is a function of the blockage the probe presents to the flow stream. The flow coefficient of many other primary elements is a function of Reynolds number. This characteristic of Annubar performance offers significant benefits over other primary elements.

K-factor independence can be attributed to a constant separation point at the tips of the primary flow element's T-shape and to the probe's ability to take a proper average. Thus:

- It allows measurement of a wide range of Reynolds numbers without a correction factor for changing Reynolds numbers.
- Any variations in the K-factor with changing Reynolds number are due to scatter and fall within $\pm 0.75\%$ of the published K-value.

The K-to-blockage theoretical link demonstrates a higher degree of confidence in Rosemount 485 Annubar K-factors than shown by flowmeters that use only an empirical database to determine flow coefficients. Rosemount is the first company to identify and use theoretical equations linking self-averaging pitot-tube flow coefficients to pipe blockage.

ROSEMOUNT 485 ANNUBAR REYNOLDS NUMBER RANGES

For a Rosemount 485 Annubar to operate accurately, the flowing media must travel at a velocity sufficient to separate from the edges of the T shape.

Drag coefficients, lift coefficients, separation points, and pressure distributions around bluff bodies are best described by “rod” Reynolds numbers. There is a minimum rod Reynolds number at which the flowing fluid will not properly separate from the edges of the T shape. The rod Reynolds number can be calculated using Equation 3-1.

$$\text{Equation 3-1} \quad R_d = \frac{d \cdot V \cdot \rho}{\mu}$$

where:

d = Probe Width (feet or meters)

V = Velocity of fluid (ft/sec or meters/second)

ρ = Density of fluid (lbm/ft³ or kg/m³)

μ = Viscosity of fluid (lbm/ft-sec or kg/meter-sec)

Minimum rod Reynolds numbers for the Rosemount 485 Annubar can be found in Table 3-1.

Table 3-1. Rod Reynolds Number Lower Limits

| Sensor Size | Minimum Rod Reynolds Number (R _d) | Probe Width (d) | |
|-------------|-----------------------------------------------|-----------------|----------|
| | | feet | meters |
| 1 | 6500 | 0.049167 | 0.014986 |
| 2 | 12500 | 0.088333 | 0.026924 |
| 3 | 25000 | 0.16125 | 0.049149 |

Section 4 Annubar Flow Theory

| | |
|------------------------------------|----------|
| Nomenclature | page 4-1 |
| Flow Equation Derivation | page 4-2 |
| Blockage Equation Derivation | page 4-3 |
| Conclusion | page 4-5 |

Annubar flow equations are built on basic hydraulic principles. The theoretical link to these concepts increases confidence in an Annubar measurement when compared to other measurements that are based solely on empirical data.

NOMENCLATURE

The following symbols are used in the derivation of the flow equation and the blockage equation:

A = cross sectional area of the pipe

B = blockage ratio = $\frac{\text{cross-sectional area of sensor}}{\text{cross-sectional area of pipe}}$

C₁ = integration constant

C₂ = integration constant

f(B) = function of blockage

Δh_B = differential pressure caused by blockage

Δh_S = differential pressure caused by shape of sensor

Δh = total differential pressure = Δh_B + Δh_S

g_c = gravitational constant

K_A = flow coefficient = $\frac{\text{Actual Flow Rate (Q}_A\text{)}}{\text{Theoretical Flow Rate (Q}_{th}\text{)}}$

P = fluid pressure

Q_a = actual flow rate

Q_{th} = theoretical flow rate

V = average fluid velocity

ρ = fluid density

z = height above an arbitrary datum plane

Unless noted otherwise, subscript 1 denotes an upstream condition and subscript 2 denotes a downstream or throat condition.

FLOW EQUATION DERIVATION

The flow equation relates the DP induced across a primary element to the velocity of the fluid in the pipe. As with other differential-pressure flowmeters, Rosemount 485 Annubar equations are based on the Bernoulli equation:

$$\text{Equation 4-1} \quad \frac{V_1^2}{2g_c} + \frac{P_1}{\rho_1} + g_c z_1 = \frac{V_2^2}{2g_c} + \frac{P_2}{\rho_2} + g_c z_2$$

For incompressible fluids $\rho_1 = \rho_2$. Changes in elevation around a primary element are negligible so $z_1 = z_2$.

Also, assume the velocity just within the mouth of the impact-sensing ports is zero, ($V_1 = 0$). While minor circulation may occur within the high pressure chamber of the Rosemount 485 Annubar, this flow is extremely small and may be considered negligible.

Solving for V_2 yields:

$$\text{Equation 4-2} \quad V_2 = \sqrt{2g_c \frac{(P_1 - P_2)}{\rho}}$$

The net differential pressure produced can be rewritten as:

$$\text{Equation 4-3} \quad \Delta h = \frac{P_1 - P_2}{\rho}$$

Substituting Equation 4-3 into Equation 4-2 yields:

$$\text{Equation 4-4} \quad V_2 = \sqrt{2g_c \Delta h}$$

Like the orifice plate and venturi meter, the general equation describing the actual flow in a pipe for the Rosemount 485 is:

$$\text{Equation 4-5} \quad Q_a = K_A A V$$

In Equation 4-4, V_2 is the average velocity of the fluid traveling past the sensor on the downstream side; whereas, in Equation 4-5, V is the average velocity in the pipe. Differences between these two velocities (V_2 and V) are absorbed in the flow coefficient (K_A).

Combining Equation 4-4 and Equation 4-5 yields:

$$\text{Equation 4-6} \quad Q_a = K_A A_1 \sqrt{2g_c \Delta h}$$

Equation 4-6 is the flow equation used to relate differential pressure induced across the primary element to flow rate for the Rosemount 485 Annubar.

BLOCKAGE EQUATION DERIVATION

Because the flow coefficient compensates for the difference between V_2 and V_1 , it must be recognized that (K_A) will be a function of the amount of obstructed area the sensor itself causes in the pipe. More specifically, (K_A) is a function of the sensor's blockage in the pipe.

$$\text{Equation 4-7} \quad K_A = f(B)$$

This is analogous to the velocity-of-approach factor for an orifice plate or a venturi meter. The following derivation uniquely determines $f(B)$ in Equation 4-7. Discussion is limited to fluid flows in the turbulent regime for which Rosemount 485 Annubar flow measurement is intended. Development of the equations applies to primary flow elements that are geometrically similar.

Beginning with Equation 4-6, the differential pressure produced by a primary flow element can be dissected into two parts:

- Differential pressure due to the primary flow element's blockage (Δh_B)
- Differential pressure due to the shape of the primary flow element (Δh_S)

Focusing on the differential pressure contribution due to the primary flow element's blockage (Δh_B), Equation 4-1 can be rearranged:

$$\text{Equation 4-8} \quad \Delta h_B = \frac{(P_1 - P_2)}{\rho} = \frac{1}{2g_c} [V_2^2 - V_1^2]$$

In the derivation of the blockage equation V_1 is defined as the average fluid velocity in the pipe prior to encountering the primary flow element, V_2 equals the accelerated velocity past the primary flow element.

Using the conservation of mass:

$$\text{Equation 4-9} \quad A_1 V_1 \rho_1 = A_2 V_2 \rho_2$$

For incompressible fluids, $\rho_1 = \rho_2$, Equation 4-9 can be simplified:

$$\text{Equation 4-10} \quad V_2 = \frac{A_1}{A_2} V_1$$

Where:

A_1 = Cross-sectional area of the pipe

A_2 = Cross-sectional area of the pipe less the amount blocked by the sensor

A_2 can be rewritten in terms of A and the flow element's blockage:

$$\text{Equation 4-11} \quad A_2 = (1 - B)A_1$$

Substituting into Equation 4-10 yields:

$$\text{Equation 4-12} \quad V_2 = \left(\frac{1}{1 - B} \right) V_1$$

Substituting Equation 4-12 into Equation 4-8:

$$\text{Equation 4-13} \quad \Delta h_B = \frac{V_1^2}{2g_c} \left[\left(\frac{1}{(1-B)^2} \right) - 1 \right]$$

Recall the general equation relating the actual flow in a pipe to the Rosemount 485 Annubar signal (Equation 4-6): $Q_a = K_A \cdot A_1 \cdot \sqrt{2g_c \Delta h}$

Where:

Δh = The total differential pressure produced by the flow element

$\Delta h = \Delta h_B + \Delta h_S$

Substituting into Equation 4-6 and rearranging yields:

$$\text{Equation 4-14} \quad K_A = \frac{Q}{A_1 \sqrt{2g_c \Delta h_B + \Delta h_S}}$$

Differentiate Equation 4-14 with respect to the differential pressure contribution due to the primary flow element's blockage (Δh_B), assuming h_S remains constant.

$$\text{Equation 4-15} \quad \frac{\partial K_A}{\partial h_B} = -\frac{1}{2} \frac{Q_a}{A_1 \sqrt{2g_c} (\Delta h_B + \Delta h_S)^{\frac{3}{2}}}$$

Differentiate Equation 4-13 with respect to the primary flow element's blockage (B).

$$\text{Equation 4-16} \quad \frac{\partial h_B}{\partial B} = \frac{V_1^2}{g_c} (1-B)^{-3}$$

Combine $\frac{\partial K_A}{\partial h_B} = \frac{\partial K_A}{\partial \Delta h_B} \cdot \frac{\partial \Delta h_B}{\partial B}$ with Equation 4-15 and Equation 4-16.

$$\text{Equation 4-17} \quad \frac{\partial K_A}{\partial B} = \left[\left(-\frac{1}{2} \right) \frac{Q_a}{A_1 \sqrt{2g_c} (\Delta h_B + \Delta h_S)^{\frac{3}{2}}} \right] \cdot \left[\frac{V_1^2}{g_c} (1-B)^{-3} \right]$$

Substitute $V_1 = \frac{Q}{A_1}$ and $\Delta h = \Delta h_B + \Delta h_A$ and simplify:

$$\text{Equation 4-18} \quad \frac{\partial K_A}{\partial B} = - \left(\frac{Q_a}{A_1 \sqrt{2g_c \Delta h}} \right)^3 \cdot (1-B)^{-3}$$

Substitute $K_A = \frac{Q_a}{A_1 \sqrt{2g_c \Delta h}}$ and simplify:

$$\text{Equation 4-19} \quad \frac{\partial K_A}{\partial B} = K_A^3 (1-B)^{-3}$$

Rearrange and integrate: $\int - \left(\frac{dK_A}{K_A^3} \right) = \int (1-B)^{-3} dB$

$$\text{Equation 4-20} \quad \frac{1}{2} K_A^{-2} + C_1 = \frac{1}{2} (1-B)^{-2}$$

Where C_1 = constant of integration, solve for K_A , redefining the integration constant C_1 as $2C_1$.

$$\text{Equation 4-21} \quad K_A = \frac{(1-B)}{\sqrt{1-C_1(1-B)^2}}$$

(B) represents the actual blockage in the pipe caused by the Rosemount 485 Annubar. Because downstream pressure is sensed past the flow element's widest cross-section, the effective blockage of the sensor will be a fraction of the actual blockage. Therefore, define an effective blockage as C_2B where C_2 represents a fraction of the actual blockage. Equation 4-21 can be rewritten:

$$\text{Equation 4-22} \quad K_A = \frac{(1-C_2B)}{\sqrt{1-C_1(1-C_2B)^2}}$$

Equation 4-22 shows that there is a direct relationship between a primary flow element flow coefficient K_A and its blockage. As blockage approaches zero, Equation 4-22 becomes:

$$\text{Equation 4-23} \quad K_A \underset{B \rightarrow 0}{=} \frac{1}{\sqrt{1-C_1}}$$

Thus, as blockage approaches zero, the primary flow element flow coefficient approaches a constant value $\frac{1}{\sqrt{1-C_1}}$, the stream-flow coefficient.

This constant value is the primary flow element flow coefficient due only to the primary flow element's shape (Δh_S), and is analogous to placing the primary flow element in an infinitely large pipe with no confining walls.

The constants C_1 and C_2 in Equation 4-22 are determined experimentally. Once determined, Equation 4-22 becomes the theoretical link between the flow coefficient and the flow element blockage.

CONCLUSION

While empirical testing of a flowmeter is the most accurate means of determining the meter's flow coefficient, many flowmeters use untested predicted flow coefficient.

- Untested flow coefficients are based on a representative sample of empirically determined flow coefficients and on theories that link the flow coefficient to physical parameters in the pipe.
- Like an orifice plate or a venturi meter, an averaging pitot tube has a theoretical relationship between its flow coefficient and parameters in the pipe.
- An averaging pitot tube's flow coefficient is related to its blockage in the pipe. This blockage dependency is necessary because the sensor itself reduces the effective pipe flow area.
- For an orifice plate and a venturi meter, the velocity-of-approach factor is the theoretical link between the meter's flow coefficient and its beta ratio. For a Rosemount 485 Annubar, Equation 4-22 describes the theoretical relationship between the sensor's flow coefficient and its blockage in the pipe.
- Using a theoretical basis, in addition to empirical testing, for the prediction of untested flow coefficients provides a much higher degree of confidence in these untested values.

Section 5 Test Facilities and Procedures

| | |
|-----------------------------|-----------|
| Overview | page 5-1 |
| Testing Laboratories | page 5-1 |
| Gravimetric Procedure | page 5-2 |
| Sensor Size 1 | page 5-4 |
| Sensor Size 2 | page 5-10 |
| Sensor Size 3 | page 5-26 |

OVERVIEW

The following descriptions of tests and testing methods are abbreviated versions. For detailed descriptions of the individual laboratories contact the facility in question.

TESTING LABORATORIES

Rosemount Boulder, Colorado Flow Laboratory

The Rosemount 485 Annubar is tested and calibrated in water at Rosemount Inc. Line sizes available for testing range from 0.50 in. to 12 in. A secondary set of reference meters, routinely calibrated against a gravimetric primary standard, provide an uncertainty of 0.25 percent. Calibrations that use the primary-measurement device, gravimetric method, can be calibrated with an uncertainty of 0.1 percent.

Alden Research Laboratories (ARL)

Flowmeters are calibrated at ARL using the gravimetric method. This method has been found to produce a consistent accuracy of $\pm 0.25\%$ over extended periods.

SwRI Gas Research Institute (GRI), Meter Research Facility (MRF)

Flowmeters are tested and calibrated on a recirculating natural gas loop. A sonic nozzle bank provides secondary flow calibration. This permits high repeatability and excellent test accuracies via calibration against the gravimetric primary standards. The sonic nozzle banks produce an accuracy on flow rate of 0.25% of reading.

GRAVIMETRIC PROCEDURE

Piping is selected to match the inside diameter of the flowmeter under test. Carbon steel piping is normally used for these tests. Gaskets between pipe flanges are carefully installed and checked to ensure that they not interfere with the flow. Proper alignment of the flowmeter with the piping is maintained.

After all piping is secured with bolts, couplings, or clamps. Water is gradually introduced into the line. Flows are set to purge air from the system and to bring the flowmeter to steady-state temperature. After operating the system for a period of time, the control valve (at the downstream end of the test line) is closed. Air is then purged from all instrumentation lines, instruments, and the flowmeter.

After air purging, and with the control valve in the closed position, all instrumentation is checked for zero-flow indication. Calibration test runs are not started until all instrumentation reads zero at the no flow condition.

The flow rate is set by adjusting the control valve at the end of the test line to a desired flow. This flow is allowed to stabilize and reach steady-state condition. This condition is achieved when the average flow-meter readout is constant with time. At this point, the calibration run begins.

A calibration run consists of simultaneously recording the flowmeter output while the weighing tank is filled and the filling process is timed. Electronic timers are activated and deactivated by electric eyes on the switch way. Outputs are recorded at 1–15 Hz during this time. The duration of the run is typically between 50 and 100 seconds. For higher flow rates, the limiting factor is the capacity of the weighing tank.

In addition to recording weight and time, the water temperature, air temperature weigh tank, and air temperature adjacent to the readout are recorded. Barometric pressure is also recorded at the start and at the end of the test.

After a run is completed, the control valve is reset to another flow rate and the process is repeated. Runs are normally conducted at 12 different flow rates, approximately equally spaced from the maximum to the minimum flow rates. In some cases, the maximum flow obtainable by the test facility determines the upper flow limit of the test.

The followings tests are provided on the following pages

Sensor Size 1:

- Water, FL-210, 3-in. Schedule 40 (see page 5-4)
- Natural Gas, FL-260, 3-in. Schedule 40 (see page 5-6)
- Natural Gas, FL-261, 3-in. Schedule 40 (see page 5-8)

Sensor Size 2:

- Natural Gas and Water, FL-156, 8-in. Schedule 80 (see page 5-10)
- Water, FL-162, 3-in. Schedule 40 (see page 5-12)
- Water, FL-163, 3-in. Schedule 40 (see page 5-14)
- Water, FL-169, 10-in. Schedule 40 (see page 5-16)
- Natural Gas and Water, FL-178, 8-in. Schedule 80 (see page 5-18)
- Natural Gas and Water, FL-179, 8-in. Schedule 80 (see page 5-20)
- Natural Gas, FL-180, 6-in. Schedule 40 (see page 5-22)
- Natural Gas, FL-181, 6-in. Schedule 40 (see page 5-24)

Sensor Size 3

- Water, FL-307, 24-in. Schedule Standard (see page 5-26)

SENSOR SIZE 1

Test Laboratory: Rosemount Boulder, Colorado Flow Lab

Sensor Size: 1
 Fluid: Water
 Sensor Serial Number: FI-210
 Nominal Pipe Size: 3-in. Schedule 40

Test Date: May 15, 2000
 Pipe I.D.: 3.097-in (78.66 mm)
 Blockage: 24.26%
 K_{pub} : 0.5099




Table 5-1. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity <i>ft/sec.</i> | Differential Pressure | | Temperature | | Pressure | | Viscosity <i>cP</i> | Density <i>lb/ft³</i> | Flow Rate <i>GPM</i> | K |
|-------------------|----------------------|----------------------------|-----------------------|--|-------------|-----------|-------------|------------|------------------------|-------------------------------------|-------------------------|--------|
| | | | <i>in Water</i> | | <i>°F</i> | <i>°C</i> | <i>psig</i> | <i>bar</i> | | | | |
| 1 | 4.70E + 05 | 20.00 | 285.186 | | 66.7 | 19.3 | 38.7 | 2.67 | 1.020 | 62.32 | 469.63 | 0.5115 |
| 2 | 4.75E + 05 | 20.25 | 291.907 | | 66.7 | 19.3 | 38.7 | 2.67 | 1.020 | 62.32 | 475.45 | 0.5118 |
| 3 | 4.25E + 05 | 18.09 | 233.873 | | 66.7 | 19.3 | 39.1 | 2.70 | 1.019 | 62.32 | 424.91 | 0.5110 |
| 4 | 4.29E + 05 | 18.22 | 237.029 | | 66.9 | 19.4 | 39.1 | 2.70 | 1.017 | 62.31 | 427.95 | 0.5113 |
| 5 | 4.05E + 05 | 17.17 | 210.633 | | 67.0 | 19.4 | 39.3 | 2.71 | 1.016 | 62.31 | 403.09 | 0.5108 |
| 6 | 4.14E + 05 | 17.49 | 218.940 | | 67.3 | 19.6 | 39.2 | 2.70 | 1.012 | 62.31 | 410.78 | 0.5106 |
| 7 | 3.70E + 05 | 15.66 | 175.154 | | 67.2 | 19.6 | 39.6 | 2.73 | 1.013 | 62.31 | 367.64 | 0.5109 |
| 8 | 3.68E + 05 | 15.58 | 173.340 | | 67.2 | 19.6 | 39.6 | 2.73 | 1.012 | 62.31 | 365.77 | 0.5110 |
| 9 | 3.16E + 05 | 13.39 | 128.240 | | 67.0 | 19.4 | 36.5 | 2.52 | 1.015 | 62.31 | 314.53 | 0.5108 |
| 10 | 3.20E + 05 | 13.59 | 132.030 | | 67.0 | 19.4 | 36.5 | 2.52 | 1.015 | 62.31 | 319.18 | 0.5109 |
| 11 | 2.99E + 05 | 12.70 | 115.145 | | 67.0 | 19.4 | 36.9 | 2.54 | 1.015 | 62.31 | 298.33 | 0.5113 |
| 12 | 3.04E + 05 | 12.89 | 118.684 | | 67.0 | 19.4 | 36.9 | 2.54 | 1.015 | 62.31 | 302.63 | 0.5109 |
| 13 | 2.76E + 05 | 11.71 | 97.853 | | 67.0 | 19.4 | 37.2 | 2.56 | 1.015 | 62.31 | 274.96 | 0.5112 |
| 14 | 2.80E + 05 | 11.89 | 100.734 | | 67.0 | 19.4 | 37.2 | 2.58 | 1.015 | 62.31 | 279.21 | 0.5117 |
| 15 | 2.24E + 05 | 9.51 | 64.686 | | 67.0 | 19.4 | 37.5 | 2.59 | 1.015 | 62.31 | 223.30 | 0.5107 |
| 16 | 2.30E + 05 | 9.75 | 67.826 | | 67.0 | 19.4 | 37.4 | 2.58 | 1.015 | 62.31 | 228.95 | 0.5113 |
| 17 | 2.04E + 05 | 8.67 | 53.779 | | 67.0 | 19.4 | 37.5 | 2.59 | 1.015 | 62.31 | 203.49 | 0.5103 |
| 18 | 2.09E + 05 | 8.88 | 56.323 | | 67.0 | 19.4 | 37.5 | 2.59 | 1.016 | 62.31 | 208.48 | 0.5109 |
| 19 | 1.02E + 05 | 4.32 | 13.357 | | 66.9 | 19.4 | 35.2 | 2.43 | 1.017 | 62.31 | 101.40 | 0.5103 |
| 20 | 1.07E + 05 | 4.54 | 14.751 | | 66.9 | 19.4 | 35.2 | 2.43 | 1.017 | 62.32 | 106.53 | 0.5102 |
| 21 | 6.06E + 04 | 2.58 | 4.795 | | 66.8 | 19.3 | 35.9 | 2.48 | 1.019 | 62.32 | 60.60 | 0.5090 |
| 22 | 6.56E + 04 | 2.79 | 5.610 | | 66.7 | 19.3 | 35.9 | 2.148 | 1.020 | 62.32 | 65.62 | 0.5096 |
| 23 | 3.86E + 04 | 1.65 | 1.973 | | 66.5 | 19.2 | 25.4 | 1.75 | 1.022 | 62.32 | 38.66 | 0.5062 |
| 24 | 4.49E + 04 | 1.92 | 2.658 | | 66.5 | 19.2 | 25.4 | 1.75 | 1.023 | 62.32 | 45.06 | 0.5083 |

Reynolds Number Low Limit: 31495

Test Laboratory: SwRI Flow Lab

Sensor Size: 1
 Fluid: Natural gas (185 psi)
 Sensor Serial Number: FI-260
 Nominal Pipe Size: 3-in. Schedule 40

Test Date: August 22, 2002
 Pipe I.D.: 3.068-in (77.9 mm)
 Blockage: 24.49%
 K_{pub} : 0.5084




Table 5-2. SwRI Flow Labs, Natural Gas (185 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 000 | 202.5993 | 69.18282 | 0.625256 | 425.7187 | 5170457 | 0.51071 | 0.99523 | 0.59 | 7.782182 |
| 001 | 202.6013 | 69.18553 | 0.625259 | 425.7972 | 5170316 | 0.51066 | 0.99523 | 0.59 | 7.782003 |
| 002 | 202.5994 | 69.15164 | 0.625297 | 425.7294 | 5170481 | 0.51067 | 0.99523 | 0.59 | 7.781837 |
| 003 | 201.5583 | 69.43139 | 0.621619 | 306.1838 | 4374677 | 0.51048 | 0.99655 | 0.59 | 6.586276 |
| 004 | 201.5599 | 69.40691 | 0.621656 | 306.2264 | 4374799 | 0.51042 | 0.99655 | 0.59 | 6.586208 |
| 005 | 201.5369 | 69.3722 | 0.621652 | 306.1974 | 4374683 | 0.5104 | 0.99655 | 0.59 | 6.585636 |
| 006 | 200.8503 | 69.7511 | 0.619006 | 204.6737 | 3578087 | 0.51138 | 0.99768 | 0.59 | 5.389227 |
| 007 | 200.8377 | 69.7335 | 0.618989 | 204.7528 | 3577890 | 0.51125 | 0.99768 | 0.59 | 5.388787 |
| 008 | 200.7973 | 69.67277 | 0.618939 | 204.592 | 3577455 | 0.51135 | 0.99769 | 0.59 | 5.387597 |
| 009 | 200.1507 | 69.95492 | 0.616529 | 123.6027 | 2778837 | 0.51174 | 0.9986 | 0.59 | 4.186452 |
| 010 | 200.1393 | 69.91759 | 0.616541 | 123.5444 | 2778784 | 0.51182 | 0.9986 | 0.59 | 4.186121 |
| 011 | 200.1204 | 69.91065 | 0.616489 | 123.5626 | 2778465 | 0.51174 | 0.9986 | 0.59 | 4.18559 |
| 012 | 199.8453 | 70.4162 | 0.614976 | 63.06322 | 1983918 | 0.51214 | 0.99928 | 0.59 | 2.990931 |
| 013 | 199.8302 | 70.45454 | 0.614873 | 63.04856 | 1983498 | 0.51216 | 0.99928 | 0.59 | 2.990477 |
| 014 | 199.8061 | 70.47626 | 0.61477 | 63.05495 | 1983119 | 0.5121 | 0.99928 | 0.59 | 2.989999 |
| 015 | 199.3174 | 71.82439 | 0.611521 | 22.80306 | 1191144 | 0.51365 | 0.99974 | 0.59 | 1.79961 |
| 016 | 199.2619 | 71.86183 | 0.611299 | 22.77319 | 1190568 | 0.51386 | 0.99974 | 0.59 | 1.798835 |
| 017 | 199.2151 | 71.81538 | 0.61121 | 22.79317 | 1190234 | 0.51349 | 0.99974 | 0.59 | 1.798191 |
| 018 | 199.5703 | 72.70587 | 0.611203 | 2.65138 | 401055 | 0.50791 | 0.99997 | 0.59 | 0.606773 |
| 019 | 199.5145 | 73.05611 | 0.610585 | 2.64952 | 400679 | 0.50814 | 0.99997 | 0.59 | 0.606531 |
| 020 | 199.4588 | 73.31953 | 0.610078 | 2.64417 | 400334 | 0.50863 | 0.99997 | 0.59 | 0.606254 |

Test Laboratory: SwRI Flow Lab

Sensor Size: 1
 Fluid: Natural gas (185 psi)
 Sensor Serial Number: FI-261
 Nominal Pipe Size: 3-in. Schedule 40

Test Date: August 22, 2002
 Pipe I.D.: 3.068-in (77.9 mm)
 Blockage: 24.49%
 K_{pub} : 0.5084




Table 5-3. SwRI Flow Labs, Natural Gas (185 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 022 | 202.8247 | 69.03876 | 0.626134 | 429.9236 | 5170632 | 0.50779 | 0.99519 | 0.59 | 7.780826 |
| 023 | 202.8007 | 69.03179 | 0.626067 | 429.6451 | 5169961 | 0.50791 | 0.99519 | 0.59 | 7.779712 |
| 024 | 202.7756 | 68.96634 | 0.626073 | 429.6553 | 5169905 | 0.50784 | 0.99519 | 0.59 | 7.778808 |
| 025 | 201.6693 | 69.20293 | 0.622241 | 308.8323 | 4373337 | 0.50771 | 0.99652 | 0.59 | 6.581931 |
| 026 | 201.6491 | 69.24744 | 0.622096 | 309.0335 | 4372184 | 0.50751 | 0.99652 | 0.59 | 6.580654 |
| 027 | 201.6101 | 69.23643 | 0.621986 | 308.6848 | 4371092 | 0.5077 | 0.99652 | 0.59 | 6.578869 |
| 028 | 201.1633 | 69.68273 | 0.619948 | 206.8046 | 3578432 | 0.50837 | 0.99766 | 0.59 | 5.389369 |
| 029 | 201.1247 | 69.68246 | 0.619826 | 206.7449 | 3577270 | 0.50833 | 0.99766 | 0.59 | 5.387594 |
| 030 | 201.0782 | 69.66862 | 0.619697 | 206.6449 | 3576206 | 0.50834 | 0.99767 | 0.59 | 5.385848 |
| 031 | 200.505 | 69.53053 | 0.618117 | 124.5604 | 2778664 | 0.50877 | 0.99859 | 0.59 | 4.183545 |
| 032 | 200.4762 | 69.37682 | 0.618224 | 124.5957 | 2778848 | 0.50856 | 0.99859 | 0.59 | 4.182799 |
| 033 | 200.447 | 69.30812 | 0.61822 | 124.5066 | 2778721 | 0.50867 | 0.99859 | 0.59 | 4.182145 |
| 034 | 200.0181 | 69.9976 | 0.615975 | 63.51227 | 1981658 | 0.509 | 0.99928 | 0.59 | 2.985605 |
| 035 | 199.9286 | 70.08919 | 0.615575 | 63.49648 | 1980105 | 0.5089 | 0.99928 | 0.59 | 2.983665 |
| 036 | 199.8472 | 70.19513 | 0.615182 | 63.44048 | 1978503 | 0.50896 | 0.99928 | 0.59 | 2.98172 |
| 037 | 199.1532 | 71.49677 | 0.611342 | 22.84423 | 1186026 | 0.51079 | 0.99974 | 0.59 | 1.790918 |
| 038 | 199.0394 | 71.29086 | 0.611244 | 22.84238 | 1185647 | 0.51052 | 0.99974 | 0.59 | 1.789749 |
| 039 | 198.9264 | 71.09116 | 0.611141 | 22.79827 | 1185285 | 0.51073 | 0.99974 | 0.59 | 1.788623 |
| 040 | 199.3829 | 74.01337 | 0.608892 | 2.64419 | 398073 | 0.50679 | 0.99997 | 0.59 | 0.603472 |
| 041 | 199.241 | 74.74033 | 0.607537 | 2.6376 | 397198 | 0.50743 | 0.99997 | 0.59 | 0.602815 |
| 042 | 199.1592 | 75.24209 | 0.606655 | 2.64077 | 396584 | 0.5071 | 0.99997 | 0.59 | 0.602347 |

SENSOR SIZE 2

Test Laboratory: SwRI Flow Lab and Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Natural gas (350 psi) and Water
 Sensor Serial Number: FI-156
 Nominal Pipe Size: 8-in. Schedule 80

Test Date: February 13, 2001 (SwRI), December 18, 2000 (DSI)
 Pipe I.D.: 7.634-in (193.9 mm)
 Blockage: 17.38%
 K_{pub} : 0.5544




Table 5-4. SwRI Flow Labs, Natural Gas (350 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|---------------------------|-------------|-------------|--------------------------|--------------------------|---------|--------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 000 | 351.05 | 70.420 | 1.16231 | 57.073 | 6860864 | 0.5529 | 0.9995 | 1.042 | 26.083 |
| 001 | 350.97 | 70.117 | 1.16415 | 57.074 | 6866857 | 0.5525 | 0.9995 | 1.042 | 26.086 |
| 002 | 350.94 | 70.140 | 1.16398 | 57.146 | 6866155 | 0.5522 | 0.9995 | 1.042 | 26.084 |
| 003 | 350.91 | 70.133 | 1.16390 | 57.110 | 6865564 | 0.5523 | 0.9995 | 1.042 | 26.082 |
| 004 | 350.53 | 70.182 | 1.16242 | 39.673 | 5718707 | 0.5522 | 0.9996 | 1.042 | 21.725 |
| 005 | 350.49 | 70.187 | 1.16237 | 39.633 | 5718194 | 0.5525 | 0.9996 | 1.042 | 21.723 |
| 006 | 350.50 | 70.172 | 1.16242 | 39.706 | 5718456 | 0.5519 | 0.9996 | 1.042 | 21.724 |
| 007 | 350.10 | 70.182 | 1.16096 | 22.302 | 4294705 | 0.5534 | 0.9998 | 1.042 | 16.314 |
| 008 | 350.07 | 70.175 | 1.16091 | 22.288 | 4294396 | 0.5535 | 0.9998 | 1.042 | 16.313 |
| 009 | 350.07 | 70.201 | 1.16083 | 22.272 | 4294104 | 0.5537 | 0.9998 | 1.042 | 16.313 |
| 010 | 349.91 | 70.141 | 1.16043 | 9.887 | 2863651 | 0.5542 | 0.9999 | 1.042 | 10.877 |
| 011 | 349.88 | 70.136 | 1.16033 | 9.890 | 2863475 | 0.5541 | 0.9999 | 1.042 | 10.877 |
| 012 | 349.82 | 70.139 | 1.16011 | 9.886 | 2863079 | 0.5542 | 0.9999 | 1.042 | 10.875 |
| 019 | 349.19 | 70.415 | 1.15714 | 0.399 | 572224 | 0.5525 | 1.0000 | 1.042 | 2.174 |
| 022 | 349.32 | 70.746 | 1.15670 | 0.395 | 571852 | 0.5547 | 1.0000 | 1.042 | 2.174 |
| 023 | 349.38 | 70.618 | 1.15724 | 0.395 | 572081 | 0.5553 | 1.0000 | 1.042 | 2.174 |
| 026 | 348.77 | 70.058 | 1.15662 | 9.844 | 2853932 | 0.5543 | 0.9999 | 1.042 | 10.837 |
| 027 | 349.61 | 70.138 | 1.15934 | 6.308 | 2288047 | 0.5546 | 0.9999 | 1.042 | 8.691 |
| 028 | 349.57 | 70.130 | 1.15924 | 6.301 | 2287657 | 0.5548 | 0.9999 | 1.042 | 8.689 |
| 029 | 349.54 | 70.099 | 1.15920 | 6.307 | 2287696 | 0.5545 | 0.9999 | 1.042 | 8.689 |
| 030 | 349.50 | 70.131 | 1.15902 | 3.541 | 1713710 | 0.5544 | 1.0000 | 1.042 | 6.509 |
| 031 | 349.46 | 70.159 | 1.15882 | 3.538 | 1713422 | 0.5547 | 1.0000 | 1.042 | 6.508 |
| 032 | 349.44 | 70.157 | 1.15880 | 3.536 | 1713262 | 0.5548 | 1.0000 | 1.042 | 6.507 |
| 033 | 349.58 | 70.125 | 1.15935 | 1.563 | 1141348 | 0.5557 | 1.0000 | 1.042 | 4.335 |
| 034 | 349.53 | 70.091 | 1.15928 | 1.565 | 1141235 | 0.5552 | 1.0000 | 1.042 | 4.334 |
| 035 | 349.51 | 70.057 | 1.15929 | 1.565 | 1141168 | 0.5551 | 1.0000 | 1.042 | 4.334 |
| Forced Zero DP Run | | | | | | | | | |
| 025 | 349.38 | 70.618 | 1.15724 | R2 -0.014 R1 0.001 | 572081 | 0.5553 | 1 | 1.042 | 2.174 |

Table 5-5. Rosemount Boulder, Colorado Flow Lab, Water

| Data Point Number | Pipe Reynolds Number | Velocity | Differential Pressure | | Temperature | | Pressure | Viscosity | Density | Flow Rate | K |
|-------------------|----------------------|----------|-----------------------|-----------|-------------|-------------|----------|-----------|---------|-----------|--------|
| | | | <i>in Water</i> | <i>°F</i> | <i>°C</i> | <i>psig</i> | | | | | |
| 1 | 8.03E + 05 | 14.02 | 118.295 | 66.0 | 18.89 | 22.8 | 1.57 | 1.030 | 62.32 | 2642.15 | 0.5568 |
| 2 | 8.09E + 05 | 14.13 | 119.941 | 66.0 | 18.89 | 22.8 | 1.57 | 1.030 | 62.32 | 2643.91 | 0.5573 |
| 3 | 6.73E + 05 | 11.75 | 83.542 | 66.0 | 18.89 | 24.5 | 1.69 | 1.030 | 62.32 | 2404.31 | 0.5554 |
| 4 | 6.77E + 05 | 11.82 | 83.958 | 66.0 | 18.89 | 24.4 | 1.68 | 1.030 | 62.32 | 2425.52 | 0.5571 |
| 5 | 5.46E + 05 | 9.54 | 54.750 | 66.0 | 18.89 | 27.3 | 2.02 | 1.030 | 62.32 | 1995.94 | 0.5571 |
| 6 | 5.46E + 05 | 9.54 | 55.095 | 66.0 | 18.89 | 27.1 | 1.87 | 1.030 | 62.32 | 2011.41 | 0.5551 |
| 7 | 4.23E + 05 | 7.38 | 32.526 | 66.0 | 18.89 | 29.0 | 2.00 | 1.029 | 62.32 | 1673.09 | 0.5587 |
| 8 | 4.21E + 05 | 7.35 | 32.407 | 66.0 | 18.89 | 29.0 | 2.00 | 1.030 | 62.32 | 1682.18 | 0.5575 |
| 9 | 3.35E + 05 | 5.84 | 20.657 | 66.0 | 18.89 | 31.5 | 2.17 | 1.029 | 62.32 | 1358.43 | 0.5553 |
| 10 | 3.33E + 05 | 5.81 | 20.330 | 66.0 | 18.89 | 31.5 | 2.17 | 1.029 | 62.32 | 1357.83 | 0.5568 |
| 11 | 2.07E + 05 | 3.62 | 7.917 | 66.1 | 18.94 | 33.9 | 2.34 | 1.029 | 62.32 | 1050.11 | 0.5550 |
| 12 | 2.07E + 05 | 3.61 | 7.902 | 66.1 | 18.94 | 33.9 | 2.34 | 1.029 | 62.32 | 1045.96 | 0.5545 |
| 13 | 1.61E + 05 | 2.80 | 4.755 | 66.1 | 18.94 | 35.7 | 2.46 | 1.028 | 62.32 | 831.75 | 0.5550 |
| 14 | 1.67E + 05 | 2.90 | 5.083 | 66.1 | 18.94 | 35.8 | 2.47 | 1.028 | 62.32 | 827.42 | 0.5556 |
| 15 | 1.21E + 05 | 2.10 | 2.685 | 66.2 | 19.00 | 37.6 | 2.59 | 1.027 | 62.32 | 514.62 | 0.5548 |
| 16 | 1.25E + 05 | 2.18 | 2.881 | 66.2 | 19.00 | 37.7 | 2.60 | 1.027 | 62.32 | 513.65 | 0.5543 |

Reynolds Number Low Limit: 91471

Test Laboratory: Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Water
 Sensor Serial Number: FI-162
 Nominal Pipe Size: 3-in. Schedule 40

Test Date: December 19, 2000
 Pipe I.D.: 8.006-in (203.4 mm)
 Blockage: 16.60%
 K_{pub} : 0.5588




Table 5-6. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity <i>ft/sec.</i> | Differential Pressure <i>in Water</i> | Temperature | | Pressure | | Viscosity <i>cP</i> | Density <i>lb/ft³</i> | Flow Rate <i>GPM</i> | K |
|-------------------|----------------------|----------------------------|------------------------------------------|-------------|-----------|-------------|------------|------------------------|-------------------------------------|-------------------------|--------|
| | | | | <i>°F</i> | <i>°C</i> | <i>psig</i> | <i>bar</i> | | | | |
| 1 | 1.05E + 06 | 17.16 | 176.063 | 67.5 | 19.7 | 23.2 | 1.60 | 1.009 | 62.31 | 2692.78 | 0.5586 |
| 2 | 1.04E + 06 | 16.91 | 170.395 | 67.6 | 19.8 | 23.5 | 1.62 | 1.008 | 62.31 | 2653.94 | 0.5596 |
| 3 | 9.52E + 05 | 15.51 | 143.617 | 67.6 | 19.8 | 25.0 | 1.72 | 1.008 | 62.31 | 2432.93 | 0.5588 |
| 4 | 9.56E + 05 | 15.57 | 144.939 | 67.6 | 19.8 | 24.9 | 1.72 | 1.008 | 62.31 | 2442.91 | 0.5585 |
| 5 | 7.86E + 05 | 12.81 | 97.625 | 67.5 | 19.7 | 27.8 | 1.92 | 1.008 | 62.31 | 2009.60 | 0.5598 |
| 6 | 7.90E + 05 | 12.87 | 98.542 | 67.5 | 19.7 | 27.7 | 1.91 | 1.008 | 62.31 | 2018.65 | 0.5597 |
| 7 | 6.57E + 05 | 10.70 | 68.137 | 67.5 | 19.7 | 29.6 | 2.04 | 1.008 | 62.31 | 1679.69 | 0.5601 |
| 8 | 6.61E + 05 | 10.77 | 68.602 | 67.5 | 19.7 | 29.6 | 2.04 | 1.008 | 62.31 | 1689.70 | 0.5615 |
| 9 | 5.29E + 05 | 8.63 | 44.337 | 67.5 | 19.7 | 32.1 | 2.21 | 1.008 | 62.31 | 1353.36 | 0.5594 |
| 10 | 5.29E + 05 | 8.62 | 44.258 | 67.5 | 19.7 | 32.1 | 2.21 | 1.009 | 62.31 | 1352.01 | 0.5594 |
| 11 | 4.10E + 05 | 6.68 | 26.607 | 67.5 | 19.7 | 34.5 | 2.38 | 1.008 | 62.31 | 1048.52 | 0.5595 |
| 12 | 4.09E + 05 | 6.67 | 26.595 | 67.5 | 19.7 | 34.5 | 2.38 | 1.009 | 62.31 | 1047.05 | 0.5588 |
| 13 | 3.24E + 05 | 5.27 | 16.488 | 67.5 | 19.7 | 36.4 | 2.51 | 1.008 | 62.31 | 827.35 | 0.5608 |
| 14 | 3.24E + 05 | 5.29 | 16.780 | 67.5 | 19.7 | 36.4 | 2.51 | 1.008 | 62.31 | 829.84 | 0.5576 |
| 15 | 2.01E + 05 | 3.27 | 6.402 | 67.6 | 19.8 | 38.3 | 2.64 | 1.007 | 62.31 | 513.85 | 0.5590 |
| 16 | 1.99E + 05 | 3.23 | 6.194 | 67.6 | 19.8 | 38.3 | 2.64 | 1.007 | 62.31 | 507.30 | 0.5610 |
| 17 | 1.56E + 05 | 2.54 | 3.866 | 67.7 | 19.8 | 39.1 | 2.70 | 1.007 | 62.31 | 398.49 | 0.5578 |
| 18 | 1.59E + 05 | 2.59 | 4.033 | 67.6 | 19.8 | 39.1 | 2.70 | 1.007 | 62.31 | 406.78 | 0.5575 |
| 19 | 1.19E + 05 | 1.94 | 2.274 | 67.4 | 19.7 | 36.9 | 2.54 | 1.010 | 62.31 | 304.88 | 0.5565 |
| 20 | 1.21E + 05 | 1.97 | 2.365 | 67.4 | 19.7 | 36.9 | 2.54 | 1.010 | 62.31 | 309.76 | 0.5544 |

Reynolds Number Low Limit: 95851

Test Laboratory: Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Water
 Sensor Serial Number: FI-163
 Nominal Pipe Size: 3-in. Schedule 40

Test Date: December 19, 2000
 Pipe I.D.: 8.006-in (203.4 mm)
 Blockage: 16.57%
 K_{pub} : 0.5589




Table 5-7. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity <i>ft/sec.</i> | Differential Pressure <i>in Water</i> | Temperature | | Pressure | | Viscosity <i>cP</i> | Density <i>lb/ft³</i> | Flow Rate <i>GPM</i> | K |
|-------------------|----------------------|----------------------------|------------------------------------------|-------------|-----------|-------------|------------|------------------------|-------------------------------------|-------------------------|--------|
| | | | | <i>°F</i> | <i>°C</i> | <i>psig</i> | <i>bar</i> | | | | |
| 1 | 1.02E + 06 | 16.86 | 168.772 | 66.4 | 19.11 | 23.4 | 1.61 | 1.024 | 62.32 | 2645.00 | 0.5605 |
| 2 | 1.02E + 06 | 16.88 | 169.030 | 66.4 | 19.11 | 23.4 | 1.61 | 1.024 | 62.32 | 2648.52 | 0.5608 |
| 3 | 9.37E + 05 | 15.50 | 142.682 | 66.4 | 19.11 | 24.9 | 1.72 | 1.024 | 62.32 | 2431.94 | 0.5604 |
| 4 | 9.40E + 05 | 15.56 | 144.054 | 66.4 | 19.11 | 24.9 | 1.72 | 1.024 | 62.32 | 2441.24 | 0.5599 |
| 5 | 7.74E + 05 | 12.81 | 97.615 | 66.4 | 19.11 | 27.7 | 1.91 | 1.024 | 62.32 | 2010.45 | 0.5601 |
| 6 | 7.76E + 05 | 12.85 | 98.035 | 66.4 | 19.11 | 27.6 | 1.90 | 1.024 | 62.32 | 2016.53 | 0.5606 |
| 7 | 6.46E + 05 | 10.69 | 67.498 | 66.4 | 19.11 | 29.6 | 2.04 | 1.024 | 62.32 | 1677.80 | 0.5622 |
| 8 | 6.50E + 05 | 10.76 | 68.786 | 66.4 | 19.11 | 29.5 | 2.03 | 1.024 | 62.32 | 1688.54 | 0.5604 |
| 9 | 5.20E + 05 | 8.61 | 44.210 | 66.4 | 19.11 | 32.1 | 2.21 | 1.024 | 62.32 | 1350.52 | 0.5591 |
| 10 | 5.22E + 05 | 8.65 | 44.141 | 66.4 | 19.11 | 32.0 | 2.21 | 1.025 | 62.32 | 1357.34 | 0.5624 |
| 11 | 4.02E + 05 | 6.65 | 26.214 | 66.4 | 19.11 | 34.5 | 2.38 | 1.024 | 62.32 | 1043.95 | 0.5613 |
| 12 | 4.03E + 05 | 6.67 | 26.242 | 66.4 | 19.11 | 34.4 | 2.37 | 1.024 | 62.32 | 1047.24 | 0.5627 |
| 13 | 3.19E + 05 | 5.27 | 16.480 | 66.4 | 19.11 | 36.3 | 2.50 | 1.024 | 62.32 | 827.58 | 0.5612 |
| 14 | 3.20E + 05 | 5.29 | 16.649 | 66.4 | 19.11 | 36.3 | 2.50 | 1.024 | 62.32 | 830.79 | 0.5605 |
| 15 | 1.98E + 05 | 3.28 | 6.340 | 66.5 | 19.12 | 38.2 | 2.63 | 1.022 | 62.32 | 514.15 | 0.5621 |
| 16 | 1.98E + 05 | 3.28 | 6.348 | 66.5 | 19.12 | 38.2 | 2.63 | 1.023 | 62.32 | 514.42 | 0.5620 |
| 17 | 1.53E + 05 | 2.53 | 3.806 | 66.6 | 19.22 | 39.1 | 2.70 | 1.022 | 62.32 | 397.26 | 0.5605 |
| 18 | 1.59E + 05 | 2.62 | 4.047 | 66.5 | 19.12 | 39.0 | 2.69 | 1.022 | 62.32 | 410.80 | 0.5621 |
| 19 | 1.17E + 05 | 1.94 | 2.242 | 66.4 | 19.11 | 37.7 | 2.60 | 1.024 | 62.32 | 304.33 | 0.5594 |
| 20 | 1.19E + 05 | 1.98 | 2.345 | 66.4 | 19.11 | 37.6 | 2.60 | 1.024 | 62.32 | 309.91 | 0.5571 |
| 21 | 8.40E + 04 | 1.39 | 1.178 | 66.5 | 19.12 | 38.8 | 2.68 | 1.023 | 62.32 | 217.69 | 0.5522 |
| 22 | 8.51E + 04 | 1.41 | 1.214 | 66.5 | 19.12 | 38.9 | 2.68 | 1.023 | 62.32 | 220.67 | 0.5513 |

Reynolds Number Low Limit: 96035

Test Laboratory: Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Water
 Sensor Serial Number: FI-169
 Nominal Pipe Size: 10-in. Schedule 40

Test Date: December 14, 2000
 Pipe I.D.: 10.020-in (254.5 mm)
 Blockage: 13.24%
 K_{pub} : 0.5766




Table 5-8. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity <i>ft/sec.</i> | Differential Pressure <i>in Water</i> | Temperature | | Pressure | | Viscosity <i>cP</i> | Density <i>lb/ft³</i> | Flow Rate <i>GPM</i> | K |
|-------------------|----------------------|----------------------------|------------------------------------------|-------------|-----------|-------------|------------|------------------------|-------------------------------------|-------------------------|--------|
| | | | | <i>°F</i> | <i>°C</i> | <i>psig</i> | <i>bar</i> | | | | |
| 1 | 9.40E + 05 | 12.42 | 86.257 | 66.5 | 19.17 | 19.7 | 1.36 | 1.023 | 62.32 | 3053.31 | 0.5777 |
| 2 | 9.44E + 05 | 12.47 | 86.908 | 66.5 | 19.17 | 19.6 | 1.35 | 1.023 | 62.32 | 3065.38 | 0.5778 |
| 3 | 8.92E + 05 | 11.78 | 77.591 | 66.5 | 19.17 | 21.1 | 1.45 | 1.023 | 62.32 | 2895.02 | 0.5775 |
| 4 | 9.00E + 05 | 11.88 | 79.133 | 66.5 | 19.17 | 20.9 | 1.44 | 1.023 | 62.32 | 2920.24 | 0.5768 |
| 5 | 8.31E + 05 | 10.97 | 67.272 | 66.5 | 19.17 | 22.7 | 1.57 | 1.023 | 62.32 | 2697.62 | 0.5779 |
| 6 | 8.36E + 05 | 11.04 | 67.803 | 66.5 | 19.17 | 22.6 | 1.56 | 1.023 | 62.32 | 2714.69 | 0.5793 |
| 7 | 7.36E + 05 | 9.72 | 52.897 | 66.5 | 19.17 | 25.0 | 1.72 | 1.023 | 62.32 | 2389.81 | 0.5774 |
| 8 | 7.35E + 05 | 9.71 | 52.731 | 66.5 | 19.17 | 25.1 | 1.73 | 1.023 | 62.32 | 2386.74 | 0.5775 |
| 9 | 6.52E + 05 | 8.61 | 41.499 | 66.5 | 19.17 | 26.8 | 1.85 | 1.023 | 62.32 | 2115.39 | 0.5770 |
| 10 | 6.55E + 05 | 8.64 | 41.433 | 66.5 | 19.17 | 26.8 | 1.85 | 1.023 | 62.32 | 2124.83 | 0.5800 |
| 11 | 5.23E + 05 | 6.90 | 26.152 | 66.5 | 19.17 | 29.4 | 2.03 | 1.023 | 62.32 | 1696.60 | 0.5829 |
| 12 | 5.23E + 05 | 6.90 | 26.481 | 66.5 | 19.17 | 29.4 | 2.03 | 1.023 | 62.32 | 1696.31 | 0.5792 |
| 13 | 3.99E + 05 | 5.26 | 15.470 | 66.5 | 19.17 | 32.4 | 2.23 | 1.022 | 62.32 | 1293.20 | 0.5777 |
| 14 | 3.98E + 05 | 5.25 | 15.417 | 66.5 | 19.17 | 32.4 | 2.23 | 1.023 | 62.32 | 1290.32 | 0.5774 |
| 15 | 2.76E + 05 | 3.65 | 7.493 | 66.6 | 19.22 | 35.8 | 2.47 | 1.022 | 62.32 | 896.62 | 0.5756 |
| 16 | 2.77E + 05 | 3.66 | 7.518 | 66.6 | 19.22 | 35.8 | 2.47 | 1.022 | 62.32 | 898.83 | 0.5760 |
| 17 | 1.83E + 05 | 2.41 | 3.242 | 66.6 | 19.22 | 37.7 | 2.60 | 1.021 | 62.32 | 593.42 | 0.5791 |
| 18 | 1.89E + 05 | 2.49 | 3.453 | 66.6 | 19.22 | 37.6 | 2.59 | 1.021 | 62.32 | 610.98 | 0.5777 |
| 19 | 1.49E + 05 | 1.96 | 2.153 | 66.7 | 19.28 | 38.4 | 2.65 | 1.020 | 62.32 | 481.46 | 0.5766 |
| 20 | 1.47E + 05 | 1.93 | 2.090 | 66.7 | 19.28 | 38.4 | 2.65 | 1.020 | 62.32 | 474.56 | 0.5767 |

Reynolds Number Low Limit: 120202

Test Laboratory: SwRI Flow Lab and Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Natural gas (400 psi) and Water
 Sensor Serial Number: FI-178
 Nominal Pipe Size: 8-in. Schedule 80

Test Date: August 20, 2002 (SwRI), August 12, 2002 (DSI)
 Pipe I.D.: 7.591-in (192.8 mm)
 Blockage: 17.70%
 K_{pub} : 0.5527




Table 5-9. SwRI Flow Labs, Natural Gas (400 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 000 | 399.2381 | 70.36406 | 1.264664 | 66.712 | 7612648 | 0.55186 | 0.99949 | 1.062 | 29.10727 |
| 001 | 399.2067 | 70.32793 | 1.264664 | 66.68185 | 7612393 | 0.55194 | 0.99949 | 1.062 | 29.10464 |
| 002 | 399.1785 | 70.35466 | 1.264492 | 66.67262 | 7611555 | 0.55197 | 0.99949 | 1.062 | 29.10245 |
| 003 | 401.0847 | 70.26102 | 1.271108 | 56.3852 | 7013626 | 0.55166 | 0.99957 | 1.062 | 26.81987 |
| 004 | 401.0365 | 70.26235 | 1.270862 | 56.38691 | 7012511 | 0.55161 | 0.99957 | 1.062 | 26.81553 |
| 005 | 401.0253 | 70.27148 | 1.270798 | 56.31914 | 7012143 | 0.55193 | 0.99957 | 1.062 | 26.81443 |
| 006 | 399.3239 | 70.3362 | 1.264849 | 37.65638 | 5720938 | 0.55183 | 0.99971 | 1.062 | 21.8737 |
| 007 | 399.3395 | 70.2757 | 1.265077 | 37.74814 | 5721538 | 0.55112 | 0.99971 | 1.062 | 21.87411 |
| 008 | 399.3772 | 70.27707 | 1.265199 | 37.72615 | 5722033 | 0.55131 | 0.99971 | 1.062 | 21.87617 |
| 009 | 398.9396 | 70.29922 | 1.263531 | 19.68531 | 4132344 | 0.55145 | 0.99985 | 1.062 | 15.79815 |
| 010 | 398.9114 | 70.32668 | 1.263357 | 19.68902 | 4131817 | 0.55138 | 0.99985 | 1.062 | 15.7967 |
| 011 | 398.8833 | 70.27533 | 1.263412 | 19.6594 | 4131944 | 0.55176 | 0.99985 | 1.062 | 15.79594 |
| 012 | 399.3192 | 70.55387 | 1.263538 | 7.45387 | 2544265 | 0.55195 | 0.99994 | 1.062 | 9.731082 |
| 013 | 399.2472 | 70.64496 | 1.263034 | 7.45405 | 2542988 | 0.55184 | 0.99994 | 1.062 | 9.727386 |
| 014 | 399.1706 | 70.67073 | 1.262704 | 7.45083 | 2542013 | 0.55184 | 0.99994 | 1.062 | 9.723914 |
| 015 | 399.5884 | 70.81895 | 1.263728 | 1.05499 | 958885 | 0.55309 | 0.99999 | 1.062 | 3.669006 |
| 016 | 399.414 | 70.77697 | 1.263284 | 1.05756 | 958396 | 0.55219 | 0.99999 | 1.062 | 3.666819 |
| 017 | 399.2506 | 70.66026 | 1.263075 | 1.05486 | 958057 | 0.55264 | 0.99999 | 1.062 | 3.664815 |
| 018 | 398.4257 | 69.58176 | 1.263432 | 1.82996 | 1265740 | 0.55333 | 0.99999 | 1.062 | 4.833638 |
| 019 | 398.424 | 69.60608 | 1.263355 | 1.8346 | 1265675 | 0.55264 | 0.99999 | 1.062 | 4.833563 |
| 020 | 398.4658 | 69.5973 | 1.263521 | 1.83347 | 1265838 | 0.55284 | 0.99999 | 1.062 | 4.83415 |

Table 5-10. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity | Differential Pressure | | Temperature | | Viscosity | Density | Flow Rate | K | |
|-------------------|----------------------|----------------|-----------------------|-----------|-------------|-------------|-----------|--------------------------|------------|---------|------------|
| | | | <i>in Water</i> | <i>°F</i> | <i>°C</i> | <i>psig</i> | | | | | <i>bar</i> |
| | | <i>ft/sec.</i> | | | | | <i>cP</i> | <i>lb/ft³</i> | <i>GPM</i> | | |
| 1 | 1.10E + 06 | 18.798 | 218.205 | 67.9 | 19.9 | 23.4 | 1.61 | 1.003 | 62.31 | 2652.10 | 0.5496 |
| 2 | 1.10E + 06 | 18.766 | 217.799 | 68.2 | 20.1 | 23.4 | 1.61 | 0.999 | 62.31 | 2647.54 | 0.5492 |
| 3 | 1.03E + 06 | 17.563 | 189.676 | 68.3 | 20.2 | 24.7 | 1.70 | 0.998 | 62.30 | 2477.85 | 0.5507 |
| 4 | 1.02E + 06 | 17.356 | 185.657 | 68.4 | 20.2 | 24.8 | 1.71 | 0.997 | 62.30 | 2448.66 | 0.5501 |
| 5 | 8.46E + 05 | 14.359 | 127.131 | 68.5 | 20.3 | 27.6 | 1.90 | 0.995 | 62.30 | 2025.88 | 0.5500 |
| 6 | 8.50E + 05 | 14.399 | 128.115 | 68.6 | 20.3 | 27.6 | 1.90 | 0.994 | 62.30 | 2031.52 | 0.5494 |
| 7 | 7.05E + 05 | 11.946 | 88.169 | 68.6 | 20.3 | 29.7 | 2.05 | 0.994 | 62.30 | 1685.45 | 0.5494 |
| 8 | 7.08E + 05 | 11.987 | 88.495 | 68.6 | 20.3 | 29.7 | 2.05 | 0.994 | 62.30 | 1691.21 | 0.5503 |
| 9 | 5.63E + 05 | 9.534 | 56.159 | 68.6 | 20.3 | 32.1 | 2.21 | 0.993 | 62.30 | 1345.12 | 0.5494 |
| 10 | 5.67E + 05 | 9.608 | 56.961 | 68.6 | 20.3 | 32.0 | 2.21 | 0.993 | 62.30 | 1355.48 | 0.5498 |
| 11 | 4.35E + 05 | 7.364 | 33.437 | 68.7 | 20.4 | 34.4 | 2.37 | 0.993 | 62.30 | 1038.89 | 0.5499 |
| 12 | 4.40E + 05 | 7.442 | 34.197 | 68.7 | 20.4 | 34.3 | 2.36 | 0.993 | 62.30 | 1049.99 | 0.5496 |
| 13 | 3.44E + 05 | 5.827 | 20.989 | 68.7 | 20.4 | 36.2 | 2.50 | 0.992 | 62.30 | 822.03 | 0.5492 |
| 14 | 3.47E + 05 | 5.873 | 21.365 | 68.7 | 20.4 | 36.2 | 2.50 | 0.992 | 62.30 | 828.55 | 0.5487 |

Test Laboratory: SwRI Flow Labs and Rosemount Boulder, Colorado Flow Lab

Sensor Size: 2
 Fluid: Natural gas (400 psi) and Water
 Sensor Serial Number: FI-179
 Nominal Pipe Size: 8-in. Schedule 80

Test Date: August 20, 2002 (SwRI), August 12, 2002 (DSI)
 Pipe I.D.: 7.591-in (192.8 mm)
 Blockage: 17.70%
 K_{pub} : 0.5527




Table 5-11. SwRI Flow Labs, Natural Gas (400 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 022 | 400.5934 | 70.09192 | 1.26894 | 67.19104 | 7636204 | 0.55056 | 0.99949 | 1.062 | 29.19194 |
| 023 | 400.5734 | 70.11051 | 1.268819 | 67.15411 | 7634966 | 0.55067 | 0.99949 | 1.062 | 29.18791 |
| 024 | 400.5566 | 70.02399 | 1.269014 | 67.15976 | 7635645 | 0.55058 | 0.99949 | 1.062 | 29.18677 |
| 025 | 400.1057 | 70.14067 | 1.267159 | 56.44205 | 6991771 | 0.55035 | 0.99957 | 1.062 | 26.72838 |
| 026 | 400.0123 | 70.13284 | 1.266849 | 56.37616 | 6989717 | 0.55057 | 0.99957 | 1.062 | 26.71984 |
| 027 | 400.0015 | 70.0372 | 1.267091 | 56.36834 | 6990797 | 0.55056 | 0.99957 | 1.062 | 26.72022 |
| 028 | 400.3373 | 70.21033 | 1.267706 | 37.88483 | 5730654 | 0.55046 | 0.99971 | 1.062 | 21.91022 |
| 029 | 400.269 | 70.10329 | 1.267769 | 37.9004 | 5730493 | 0.55023 | 0.99971 | 1.062 | 21.90594 |
| 030 | 400.1888 | 69.96667 | 1.267898 | 37.90305 | 5731232 | 0.55014 | 0.99971 | 1.062 | 21.90417 |
| 031 | 399.6013 | 69.87253 | 1.266207 | 19.74952 | 4137256 | 0.55034 | 0.99985 | 1.062 | 15.80868 |
| 032 | 399.5592 | 69.84549 | 1.266144 | 19.76687 | 4137037 | 0.55006 | 0.99985 | 1.062 | 15.80713 |
| 033 | 399.5333 | 69.77977 | 1.266249 | 19.73404 | 4137651 | 0.55052 | 0.99985 | 1.062 | 15.80791 |
| 034 | 399.5284 | 70.37971 | 1.26449 | 7.5027 | 2542949 | 0.54953 | 0.99994 | 1.062 | 9.723809 |
| 035 | 399.3698 | 70.32362 | 1.264122 | 7.48151 | 2541621 | 0.55004 | 0.99994 | 1.062 | 9.717724 |
| 036 | 399.2254 | 70.17006 | 1.264083 | 7.46435 | 2540924 | 0.5504 | 0.99994 | 1.062 | 9.712693 |
| 037 | 398.3805 | 69.89757 | 1.262096 | 1.83461 | 1263339 | 0.55212 | 0.99999 | 1.062 | 4.826624 |
| 038 | 398.196 | 69.68668 | 1.262089 | 1.83028 | 1263176 | 0.55252 | 0.99999 | 1.062 | 4.824399 |
| 039 | 398.0698 | 69.56982 | 1.262005 | 1.8311 | 1262935 | 0.5522 | 0.99999 | 1.062 | 4.822573 |
| 040 | 399.5883 | 69.26618 | 1.267972 | 1.06446 | 958785 | 0.54841 | 0.99999 | 1.062 | 3.660332 |
| 041 | 399.4414 | 69.1862 | 1.267713 | 1.06426 | 958549 | 0.54831 | 0.99999 | 1.062 | 3.658928 |
| 042 | 399.3669 | 69.1327 | 1.267599 | 1.06372 | 958345 | 0.54831 | 0.99999 | 1.062 | 3.657825 |

Table 5-12. Rosemount Boulder, Colorado Flow Lab, Water.

| Data Point Number | Pipe Reynolds Number | Velocity | Differential Pressure | | Temperature | | Pressure | | Viscosity | Density | Flow Rate | K |
|-------------------|----------------------|----------------|-----------------------|-----------|-------------|-------------|------------|-------|-----------|--------------------------|------------|---|
| | | | <i>in Water</i> | <i>°F</i> | <i>°C</i> | <i>psig</i> | <i>bar</i> | | | | | |
| | | <i>ft/sec.</i> | | | | | | | <i>cP</i> | <i>lb/ft³</i> | <i>GPM</i> | |
| 1 | 1.09E + 06 | 18.731 | 217.392 | 67.5 | 19.7 | 23.4 | 1.61 | 1.008 | 62.31 | 2642.59 | 0.5487 | |
| 2 | 1.10E + 06 | 18.783 | 218.619 | 67.8 | 19.9 | 23.3 | 1.61 | 1.005 | 62.31 | 2649.95 | 0.5486 | |
| 3 | 1.01E + 06 | 17.333 | 186.289 | 67.9 | 19.9 | 24.8 | 1.71 | 1.004 | 62.31 | 2445.36 | 0.5485 | |
| 4 | 1.02E + 06 | 17.353 | 186.452 | 68.0 | 20.0 | 24.7 | 1.70 | 1.002 | 62.31 | 2448.23 | 0.5489 | |
| 5 | 8.41E + 05 | 14.353 | 126.967 | 68.1 | 20.1 | 27.5 | 1.90 | 1.001 | 62.31 | 2025.02 | 0.5501 | |
| 6 | 8.43E + 05 | 14.362 | 128.085 | 68.2 | 20.1 | 27.5 | 1.90 | 0.999 | 62.31 | 2026.28 | 0.5481 | |
| 7 | 7.02E + 05 | 11.936 | 88.252 | 68.3 | 20.2 | 29.6 | 2.04 | 0.998 | 62.30 | 1683.93 | 0.5487 | |
| 8 | 7.05E + 05 | 11.983 | 88.378 | 68.4 | 20.2 | 29.6 | 2.04 | 0.997 | 62.30 | 1690.66 | 0.5505 | |
| 9 | 5.64E + 05 | 9.567 | 56.423 | 68.5 | 20.3 | 32.0 | 2.21 | 0.995 | 62.30 | 1349.74 | 0.5500 | |
| 10 | 5.65E + 05 | 9.576 | 56.368 | 68.6 | 20.3 | 32.0 | 2.21 | 0.994 | 62.30 | 1351.00 | 0.5508 | |
| 11 | 4.36E + 05 | 7.383 | 33.529 | 68.6 | 20.3 | 34.4 | 2.37 | 0.993 | 62.30 | 1041.66 | 0.5507 | |
| 12 | 4.37E + 05 | 7.410 | 33.805 | 68.6 | 2.3 | 34.3 | 2.36 | 0.994 | 62.30 | 1045.43 | 0.5504 | |
| 13 | 3.44E + 05 | 5.826 | 20.874 | 68.7 | 20.4 | 36.2 | 2.50 | 0.993 | 62.30 | 821.93 | 0.5507 | |
| 14 | 3.46E + 05 | 5.853 | 21.162 | 68.6 | 20.3 | 36.1 | 2.49 | 0.993 | 62.30 | 825.71 | 0.5494 | |
| 15 | 2.17E + 05 | 3.662 | 8.351 | 68.7 | 20.4 | 37.8 | 2.61 | 0.992 | 62.30 | 516.64 | 0.5472 | |
| 16 | 2.18E + 05 | 3.691 | 8.474 | 68.7 | 2.4 | 37.8 | 2.61 | 0.992 | 62.30 | 520.75 | 0.5476 | |

Test Laboratory: SwRI Flow Labs

Sensor Size: 2
 Fluid: Natural gas (400 psi)
 Sensor Serial Number: FI-180
 Nominal Pipe Size: 6-in. Schedule 40

Test Date: August 20, 2002
 Pipe I.D.: 6.059-in (153.9 mm)
 Blockage: 22.17%
 K_{pub} : 0.5257




Table 5-13. SwRI Flow Labs, Natural Gas (400 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 044 | 402.2264 | 69.78825 | 1.275065 | 183.1904 | 9572419 | 0.52261 | 0.99888 | 1.062 | 29.20216 |
| 045 | 402.2249 | 69.78545 | 1.275068 | 183.1652 | 9571925 | 0.52262 | 0.99888 | 1.062 | 29.20053 |
| 046 | 402.2003 | 69.78291 | 1.274993 | 183.2267 | 9571523 | 0.52252 | 0.99888 | 1.062 | 29.19909 |
| 047 | 401.3388 | 69.80605 | 1.272042 | 127.3168 | 7973641 | 0.52258 | 0.99922 | 1.062 | 24.3224 |
| 048 | 401.324 | 69.81554 | 1.271968 | 127.2576 | 7973870 | 0.52273 | 0.99922 | 1.062 | 24.32337 |
| 049 | 401.2841 | 69.82552 | 1.271805 | 127.3385 | 7973102 | 0.52255 | 0.99922 | 1.062 | 24.32124 |
| 050 | 400.6831 | 69.95078 | 1.269517 | 81.63868 | 6380432 | 0.52263 | 0.9995 | 1.062 | 19.46474 |
| 051 | 400.6703 | 69.78475 | 1.269958 | 81.62017 | 6382775 | 0.52267 | 0.9995 | 1.062 | 19.46715 |
| 052 | 400.6707 | 69.83695 | 1.26979 | 81.6921 | 6382281 | 0.52247 | 0.9995 | 1.062 | 19.46712 |
| 053 | 399.7075 | 69.59795 | 1.267281 | 38.66373 | 4391472 | 0.52268 | 0.99976 | 1.062 | 13.38829 |
| 054 | 399.6934 | 69.57008 | 1.267315 | 38.6696 | 4391638 | 0.52263 | 0.99976 | 1.062 | 13.38823 |
| 055 | 399.7024 | 69.64079 | 1.26714 | 38.67824 | 4391271 | 0.52262 | 0.99976 | 1.062 | 13.3885 |
| 056 | 398.9556 | 69.13239 | 1.266025 | 15.53221 | 2790645 | 0.52382 | 0.9999 | 1.062 | 8.501159 |
| 057 | 398.9794 | 69.18728 | 1.265945 | 15.53455 | 2790692 | 0.52385 | 0.9999 | 1.062 | 8.50201 |
| 058 | 398.9846 | 69.26121 | 1.265675 | 15.55648 | 2790406 | 0.52354 | 0.9999 | 1.062 | 8.502069 |
| 059 | 399.77 | 70.43433 | 1.264888 | 2.89146 | 1202055 | 0.52419 | 0.99998 | 1.062 | 3.669187 |
| 060 | 399.5529 | 70.87255 | 1.262895 | 2.8918 | 1200207 | 0.52408 | 0.99998 | 1.062 | 3.665766 |
| 061 | 399.2911 | 71.17313 | 1.261155 | 2.89022 | 1198483 | 0.52404 | 0.99998 | 1.062 | 3.66196 |

Test Laboratory: SwRI Flow Labs

Sensor Size: 2
 Fluid: Natural gas (400 psi)
 Sensor Serial Number: FI-181
 Nominal Pipe Size: 6-in. Schedule 40

Test Date: August 21, 2002
 Pipe I.D.: 6.059-in (153.9 mm)
 Blockage: 22.17%
 K_{pub} : 0.5257




Table 5-14. SwRI Flow Labs, Natural Gas (400 psi)

| File | Pressure | Temperature | Density | DP | Re D | K | Gas Exp. Factor | Probe Width | Mass Flow |
|------|-------------|-------------|--------------------------|--------------------------|---------|---------|-----------------|-------------|-------------|
| | <i>psia</i> | <i>°F</i> | <i>lb/ft³</i> | <i>in H₂O</i> | | | | <i>in.</i> | <i>lb/s</i> |
| 000 | 402.1318 | 70.22332 | 1.273031 | 182.2164 | 9567169 | 0.52445 | 0.99888 | 1.062 | 29.20375 |
| 001 | 402.1396 | 70.23601 | 1.27302 | 182.2515 | 9565927 | 0.52435 | 0.99888 | 1.062 | 29.20053 |
| 002 | 402.1459 | 70.20831 | 1.273122 | 182.2548 | 9566150 | 0.52431 | 0.99888 | 1.062 | 29.20007 |
| 003 | 401.4724 | 70.12239 | 1.271117 | 126.7637 | 7974761 | 0.52422 | 0.99922 | 1.062 | 24.33706 |
| 004 | 401.4468 | 70.15948 | 1.270924 | 126.7554 | 7973279 | 0.5242 | 0.99922 | 1.062 | 24.33376 |
| 005 | 401.4389 | 70.22195 | 1.270708 | 126.6872 | 7971112 | 0.52429 | 0.99922 | 1.062 | 24.32932 |
| 006 | 400.8714 | 70.22616 | 1.268799 | 81.33865 | 6382353 | 0.52412 | 0.9995 | 1.062 | 19.47868 |
| 007 | 400.8555 | 70.18685 | 1.26886 | 81.21389 | 6382646 | 0.5245 | 0.9995 | 1.062 | 19.47842 |
| 008 | 400.7853 | 70.12505 | 1.268806 | 81.24182 | 6382324 | 0.52434 | 0.9995 | 1.062 | 19.4755 |
| 009 | 403.3504 | 69.91417 | 1.278022 | 38.91319 | 4431173 | 0.524 | 0.99976 | 1.062 | 13.52238 |
| 010 | 403.3576 | 69.91348 | 1.278048 | 38.9336 | 4431585 | 0.52391 | 0.99976 | 1.062 | 13.52364 |
| 011 | 403.3601 | 69.92616 | 1.278038 | 38.91548 | 4431612 | 0.52405 | 0.99976 | 1.062 | 13.52397 |
| 012 | 399.7687 | 70.02187 | 1.266071 | 15.51266 | 2794122 | 0.52552 | 0.9999 | 1.062 | 8.523624 |
| 013 | 399.7375 | 69.97731 | 1.266096 | 15.51172 | 2794003 | 0.52547 | 0.9999 | 1.062 | 8.522671 |
| 014 | 399.6968 | 69.91672 | 1.266136 | 15.49649 | 2793974 | 0.52567 | 0.9999 | 1.062 | 8.521782 |
| 015 | 399.6242 | 70.38922 | 1.264523 | 2.87541 | 1202830 | 0.52601 | 0.99998 | 1.062 | 3.671184 |
| 016 | 399.5218 | 70.62444 | 1.2635 | 2.87366 | 1201883 | 0.52614 | 0.99998 | 1.062 | 3.669494 |
| 017 | 399.4349 | 70.80791 | 1.26268 | 2.88596 | 1201079 | 0.52497 | 0.99998 | 1.062 | 3.66797 |

SENSOR SIZE 3

Test Laboratory: Alden Research Labs

Sensor Size: 3
 Fluid: Water
 Sensor Serial Number: FI-307
 Nominal Pipe Size: 24-in. Schedule Standard

Test Date: July 25, 2001
 Pipe I.D.: 23.340-in (592.8 mm)
 Blockage: 10.47%
 K_{pub} : 0.5845




Table 5-15. Alden Research Labs, Water.

| Run Number | Line Temp | | Air Temp | | Net Weight | | Run Duration | mA Square Root Output | Flow | Differential Head | Pipe Reynold Number | K |
|------------|-----------|------|----------|----|------------|-------|--------------|-----------------------|-------|-------------------|---------------------|--------|
| | °F | °C | °F | °C | lb | kg | | | | | | |
| 1 | 107 | 41.5 | 95 | 35 | 97008 | 44002 | 40.024 | 16.7074 | 17592 | 94.790 | 3.6997 | 0.5829 |
| 2 | 107 | 41.5 | 95 | 35 | 96976 | 43987 | 40.017 | 16.7274 | 17590 | 95.088 | 3.7028 | 0.5820 |
| 3 | 107 | 41.5 | 95 | 35 | 97022 | 44008 | 40.093 | 16.6368 | 17565 | 93.741 | 3.6976 | 0.5853 |
| 4 | 107 | 41.5 | 95 | 35 | 96403 | 43727 | 44.924 | 15.2151 | 15576 | 73.852 | 3.2855 | 0.5848 |
| 5 | 107 | 41.5 | 95 | 35 | 96375 | 43715 | 44.969 | 15.2099 | 15557 | 73.784 | 3.2813 | 0.5844 |
| 6 | 107 | 41.5 | 95 | 35 | 96306 | 43684 | 44.876 | 15.2076 | 15578 | 73.754 | 3.2890 | 0.5852 |
| 7 | 107 | 41.5 | 95 | 35 | 95867 | 43485 | 57.724 | 12.6661 | 12056 | 44.124 | 2.5479 | 0.5855 |
| 8 | 107 | 41.5 | 95 | 35 | 96041 | 43564 | 57.810 | 12.6539 | 12060 | 44.000 | 2.5513 | 0.5867 |
| 9 | 107 | 41.5 | 95 | 35 | 95863 | 43483 | 57.746 | 12.6681 | 12051 | 44.144 | 2.5521 | 0.5852 |
| 10 | 107 | 41.5 | 95 | 35 | 95307 | 43231 | 77.732 | 19.7422 | 8901 | 24.253 | 1.8868 | 0.5832 |
| 11 | 108 | 42.2 | 95 | 35 | 95388 | 43267 | 77.879 | 19.6499 | 8892 | 23.970 | 1.8868 | 0.5859 |
| 12 | 108 | 42.2 | 95 | 35 | 95370 | 43259 | 77.865 | 19.7187 | 8892 | 24.180 | 1.8887 | 0.5834 |
| 13 | 108 | 42.2 | 95 | 35 | 94838 | 43017 | 126.452 | 13.5666 | 5445 | 8.969 | 1.1577 | 0.5867 |
| 14 | 108 | 42.2 | 95 | 35 | 94929 | 43059 | 126.555 | 13.6116 | 5446 | 9.053 | 1.1579 | 0.5837 |
| 15 | 108 | 42.2 | 95 | 35 | 94885 | 43039 | 126.432 | 13.5905 | 5449 | 9.014 | 1.1596 | 0.5855 |

Reynolds Number Low Limit: 303906

Section 6 References

ASME, *Fluid Meters*, Sixth Edition 1971, ASME, New York, pages 47-111.

Achenbach, E. *Distribution of Local Pressure & Skin Friction Around a Circular Cylinder in Cross-Flow Up to $RE = 5 \times 10^6$* , J. Fluid Mechanics, March 1968, Volume 34, Part 4, pages 625 - 639.

Schlichting, H., *Boundary Layer Theory*, Fourth Edition 1960, McGraw-Hill Book Co., New York, pages 1 - 40.

Daugherty, R., *Fluid Mechanics with Engineering Applications*, Eight Edition 1985, McGraw-Hill Book Co., New York, Chapter 10.

Hamli, D., *Practical Guide to the Evaluation of the Metering Performance of Differential Producers*, J., Fluids Engineering, March 1973, Volume 95, Series 1, Number 1, pages 127 - 141.

Hoerner, Sighard F., *Fluid-Dynamic Drag*, 1965: Great Britain. Produced in the United States.

Schneider, W. *Experimental Investigations on Bodies With Non-Circular Sections in Compressible Flow (Pressure Distributions)*, Viscous and Interacting Flow Field Effects, May 9 - 10, 1984, pages 132 - 153.

Rosemount 485 Annubar Flow Test Data Book

Reference Manual
00821-0100-4809, Rev AA
June 2003

Index

| | | | |
|----------------------------------------|-----|----------------------------------|------|
| A | | S | |
| Annubar strengths | 1-1 | Sensor Design | 2-2 |
| | | Surface Texture | 2-4 |
| D | | T | |
| Derivation | | Testing | 1-1 |
| Blockage Equation | 4-3 | Development | 1-1 |
| Flow Equation | 4-2 | Independent Laboratory | 1-2 |
| Design and Performance | 2-2 | In-House Performance | 1-2 |
| DP Signal | 2-2 | Laboratories | 5-1 |
| High Pressure Measurement | 2-3 | Rosemount | 5-1 |
| Low Pressure Measurement | 2-3 | SwRI | 5-1 |
| sensor design | 2-2 | Mechanical | 1-2 |
| surface texture | 2-4 | On-Site Performance | 1-2 |
| DP Signal | 2-2 | Research | 1-1 |
| Drawings | | Sensor Size 1 | 5-4 |
| Frontal slot design | 2-3 | FI-210 | 5-4 |
| sensor cross-section | 2-2 | FI-260 | 5-6 |
| Velocity Graph | 2-4 | FI-261 | 5-8 |
| F | | Sensor Size 2 | 5-10 |
| Flow Coefficient | 3-1 | FI-156 | 5-10 |
| Benefits | 3-1 | FI-162 | 5-12 |
| Overview | 3-1 | FI-163 | 5-14 |
| Reynolds Number Ranges | 3-2 | FI-169 | 5-16 |
| Flow Theory | 4-1 | FI-178 | 5-18 |
| Blockage Equation Derivation | 4-3 | FI-179 | 5-20 |
| Conclusion | 4-5 | FI-180 | 5-22 |
| Flow Equation Derivation | 4-2 | FI-181 | 5-24 |
| G | | Sensor Size 3 | 5-26 |
| Gravimetric Procedure | 5-2 | FI-307 | 5-26 |
| H | | Structural | 1-2 |
| High Pressure Measurement | 2-3 | | |
| How the Annubar Works | 2-1 | | |
| L | | | |
| Low Pressure Measurement | 2-3 | | |
| N | | | |
| Nomenclature | 4-1 | | |
| R | | | |
| References | 6-1 | | |

Rosemount 485 Annubar Flow Test Data Book

Reference Manual
00821-0100-4809, Rev AA
June 2003

*Rosemount, the Rosemount logotype, and Annubar are registered trademarks of Rosemount Inc.
PlantWeb is a registered trademark of one of the Emerson Process Management group of companies.
All other marks are the property of their respective owners.*

Emerson Process Management

Rosemount Inc.

8200 Market Boulevard
Chanhassen, MN 55317 USA
T (U.S.) 1-800-999-9307
T (International) (952) 906-8888
F (952) 949-7001

www.rosemount.com

