



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043743 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12151901 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_16 Operator ID: 27538 Calibration Date: 7/22/2009 7:56:51PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-53112	Multimeter	2/20/2010 11:07:00AM
E3-58605	Load Box	10/20/2009 11:36:00AM
P3-54299	Pressure Controller	9/23/2009 3:13:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0012	0.0075	PASS
80.000	160.000 PSI	160.0000 PSI	16.8066	0.0413	PASS
60.000	120.000 PSI	120.0000 PSI	13.6152	0.0950	PASS
40.000	80.000 PSI	80.0000 PSI	10.4184	0.1150	PASS
20.000	40.000 PSI	40.0000 PSI	7.2230	0.1438	PASS
0.000	0.000 PSI	0.0000 PSI	4.0184	0.1150	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043744 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12150683 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_16 Operator ID: 38005 Calibration Date: 7/22/2009 8:39:43PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-53112	Multimeter	2/20/2010 11:07:00AM
E3-58605	Load Box	10/20/2009 11:36:00AM
P3-54299	Pressure Controller	9/23/2009 3:13:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9992	-0.0050	PASS
80.000	160.000 PSI	160.0000 PSI	16.7994	-0.0037	PASS
60.000	120.000 PSI	120.0000 PSI	13.6020	0.0125	PASS
40.000	80.000 PSI	80.0000 PSI	10.4016	0.0100	PASS
20.000	40.000 PSI	40.0000 PSI	7.2002	0.0013	PASS
0.000	0.000 PSI	0.0000 PSI	3.9930	-0.0437	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043745 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12151118 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 38005 Calibration Date: 7/22/2009 8:32:48PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0014	0.0088	PASS
80.000	160.000 PSI	160.0000 PSI	16.8028	0.0175	PASS
60.000	120.000 PSI	120.0000 PSI	13.5984	-0.0100	PASS
40.000	80.000 PSI	80.0000 PSI	10.4002	0.0013	PASS
20.000	40.000 PSI	40.0000 PSI	7.2004	0.0025	PASS
0.000	0.000 PSI	0.0000 PSI	3.9992	-0.0050	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043746 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12150521 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 18290 Calibration Date: 7/22/2009 7:54:36PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9990	-0.0062	PASS
80.000	160.000 PSI	160.0000 PSI	16.8008	0.0050	PASS
60.000	120.000 PSI	120.0000 PSI	13.6042	0.0263	PASS
40.000	80.000 PSI	80.0000 PSI	10.4004	0.0025	PASS
20.000	40.000 PSI	40.0000 PSI	7.1966	-0.0212	PASS
0.000	0.000 PSI	0.0000 PSI	3.9926	-0.0462	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043747 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12150873 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 27538 Calibration Date: 7/22/2009 7:30:56PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0004	0.0025	PASS
80.000	160.000 PSI	160.0000 PSI	16.8090	0.0563	PASS
60.000	120.000 PSI	120.0000 PSI	13.6134	0.0838	PASS
40.000	80.000 PSI	80.0000 PSI	10.4138	0.0863	PASS
20.000	40.000 PSI	40.0000 PSI	7.2114	0.0713	PASS
0.000	0.000 PSI	0.0000 PSI	4.0066	0.0413	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043748 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12150522 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_09 Operator ID: 18290 Calibration Date: 7/22/2009 8:40:33PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56119	Multimeter	5/20/2010 10:03:00AM
E3-58645	Load Box	10/20/2009 7:51:00AM
P3-54855	Pressure Controller	10/9/2009 1:34:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9998	-0.0012	PASS
80.000	160.000 PSI	160.0000 PSI	16.8004	0.0025	PASS
60.000	120.000 PSI	120.0000 PSI	13.6060	0.0375	PASS
40.000	80.000 PSI	80.0000 PSI	10.4058	0.0363	PASS
20.000	40.000 PSI	40.0000 PSI	7.2094	0.0588	PASS
0.000	0.000 PSI	0.0000 PSI	4.0132	0.0825	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043749 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12147159 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 18290 Calibration Date: 7/22/2009 8:41:37PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/28/2009 7:30:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0032	0.0200	PASS
80.000	160.000 PSI	160.0000 PSI	16.8034	0.0213	PASS
60.000	120.000 PSI	120.0000 PSI	13.6020	0.0125	PASS
40.000	80.000 PSI	80.0000 PSI	10.4010	0.0063	PASS
20.000	40.000 PSI	40.0000 PSI	7.2022	0.0138	PASS
0.000	0.000 PSI	0.0000 PSI	4.0014	0.0088	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 1
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043750 Model No: 3051TG4A2B21AE5M5T1Q4S5B4TRD1 Module Serial No: 12150213 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_16 Operator ID: 18290 Calibration Date: 7/22/2009 10:29:38PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-53112	Multimeter	2/20/2010 11:07:00AM
E3-58605	Load Box	10/20/2009 11:36:00AM
P3-54299	Pressure Controller	9/23/2009 3:13:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9988	-0.0075	PASS
80.000	160.000 PSI	160.0000 PSI	16.7986	-0.0087	PASS
60.000	120.000 PSI	120.0000 PSI	13.5962	-0.0237	PASS
40.000	80.000 PSI	80.0000 PSI	10.3974	-0.0162	PASS
20.000	40.000 PSI	40.0000 PSI	7.1958	-0.0262	PASS
0.000	0.000 PSI	0.0000 PSI	3.9956	-0.0275	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 11
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043409 Model No: 3051TA4A2B21AE5M5T1Q4B4TRD1 Module Serial No: 12148680 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 9764 Calibration Date: 7/21/2009 1:32:05PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-53643	Barometer	12/10/2009 6:20:00AM
P3-54258	Vacuum Meter	10/30/2009 10:42:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9997 PSI	19.9964	-0.0225	PASS
80.000	160.000 PSI	159.9997 PSI	16.7966	-0.0212	PASS
60.000	120.000 PSI	119.9997 PSI	13.5950	-0.0312	PASS
40.000	80.000 PSI	79.9997 PSI	10.3950	-0.0312	PASS
20.000	40.000 PSI	40.0000 PSI	7.1970	-0.0187	PASS
0.000	0.001 PSI	0.0010 PSI	4.0032	0.0200	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 11
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043410 Model No: 3051TA4A2B21AE5M5T1Q4B4TRD1 Module Serial No: 12151346 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_03 Operator ID: 9764 Calibration Date: 7/21/2009 1:26:43PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-55641	Multimeter	9/20/2009 8:35:00AM
E3-58650	Load Box	11/20/2009 1:43:00PM
P3-53644	Barometer	9/10/2009 1:59:00PM
P3-54590	Pressure Controller	9/14/2009 2:51:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0004	0.0025	PASS
80.000	160.000 PSI	160.0000 PSI	16.7978	-0.0137	PASS
60.000	120.000 PSI	120.0000 PSI	13.5992	-0.0050	PASS
40.000	80.000 PSI	80.0000 PSI	10.4006	0.0038	PASS
20.000	40.000 PSI	40.0000 PSI	7.2010	0.0063	PASS
0.500	1.000 PSI	1.0000 PSI	4.0848	0.0300	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 11
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043411 Model No: 3051TA4A2B21AE5M5T1Q4B4TRD1 Module Serial No: 12151341 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_02 Operator ID: 9764 Calibration Date: 7/21/2009 2:16:43PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	199.999 PSI	199.9992 PSI	20.0002	0.0013	PASS
80.000	159.999 PSI	159.9992 PSI	16.8034	0.0213	PASS
60.000	119.999 PSI	119.9992 PSI	13.6044	0.0275	PASS
40.000	79.999 PSI	79.9992 PSI	10.4026	0.0163	PASS
20.000	39.999 PSI	39.9992 PSI	7.2036	0.0225	PASS
0.500	1.000 PSI	1.0000 PSI	4.0896	0.0600	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 11
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043412 Model No: 3051TA4A2B21AE5M5T1Q4B4TRD1 Module Serial No: 12113692 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 9764 Calibration Date: 7/21/2009 2:15:52PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-53643	Barometer	12/10/2009 6:20:00AM
P3-54258	Vacuum Meter	10/30/2009 10:42:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9997 PSI	19.9954	-0.0287	PASS
80.000	160.000 PSI	159.9997 PSI	16.7958	-0.0262	PASS
60.000	120.000 PSI	119.9997 PSI	13.5918	-0.0512	PASS
40.000	80.000 PSI	79.9997 PSI	10.3866	-0.0837	PASS
20.000	40.000 PSI	40.0000 PSI	7.1890	-0.0687	PASS
0.000	0.001 PSI	0.0010 PSI	3.9904	-0.0600	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043751 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151347 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 38005 Calibration Date: 7/22/2009 10:38:41PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9997 PSI	20.0014	0.0088	PASS
80.000	160.000 PSI	159.9997 PSI	16.8022	0.0138	PASS
60.000	120.000 PSI	119.9997 PSI	13.6002	0.0013	PASS
40.000	80.000 PSI	79.9997 PSI	10.4012	0.0075	PASS
20.000	40.000 PSI	39.9997 PSI	7.2002	0.0013	PASS
0.500	1.000 PSI	1.0000 PSI	4.0808	0.0050	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043752 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12148623 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 38005 Calibration Date: 7/22/2009 10:36:04PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54290	Multimeter	10/20/2009 12:07:00PM
E3-58611	Load Box	10/20/2009 9:05:00AM
P3-54020	Pressure Controller	10/25/2009 10:55:00AM
P3-54057	Barometer	1/27/2010 11:02:00AM
P3-54297	Pressure Controller	8/15/2009 8:56:00AM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9986	-0.0087	PASS
80.000	160.000 PSI	160.0000 PSI	16.8016	0.0100	PASS
60.000	120.000 PSI	120.0000 PSI	13.6018	0.0113	PASS
40.000	80.000 PSI	80.0000 PSI	10.4030	0.0188	PASS
20.000	39.999 PSI	39.9995 PSI	7.2042	0.0263	PASS
1.500	3.000 PSI	3.0000 PSI	4.2452	0.0325	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043753 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12148660 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 18290 Calibration Date: 7/23/2009 12:09:40AM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-53643	Barometer	12/10/2009 6:20:00AM
P3-54258	Vacuum Meter	10/30/2009 10:42:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9995 PSI	20.0028	0.0175	PASS
80.000	160.000 PSI	159.9995 PSI	16.8034	0.0213	PASS
60.000	120.000 PSI	119.9995 PSI	13.5996	-0.0025	PASS
40.000	79.999 PSI	79.9995 PSI	10.3994	-0.0037	PASS
20.000	40.000 PSI	40.0000 PSI	7.1988	-0.0075	PASS
0.000	0.001 PSI	0.0010 PSI	4.0008	0.0050	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043754 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151348 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_02 Operator ID: 38005 Calibration Date: 7/22/2009 9:14:24PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9996 PSI	19.9972	-0.0175	PASS
80.000	160.000 PSI	159.9996 PSI	16.7988	-0.0075	PASS
60.000	120.000 PSI	119.9996 PSI	13.5988	-0.0075	PASS
40.000	80.000 PSI	79.9996 PSI	10.4004	0.0025	PASS
20.000	40.000 PSI	39.9996 PSI	7.2008	0.0050	PASS
0.500	1.000 PSI	1.0000 PSI	4.0844	0.0275	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043755 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12148664 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_02 Operator ID: 12690 Calibration Date: 7/22/2009 9:58:12PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9999 PSI	19.9976	-0.0150	PASS
80.000	160.000 PSI	159.9999 PSI	16.7954	-0.0287	PASS
60.000	120.000 PSI	119.9999 PSI	13.5944	-0.0350	PASS
40.000	80.000 PSI	79.9999 PSI	10.3948	-0.0325	PASS
20.000	40.000 PSI	39.9999 PSI	7.1950	-0.0312	PASS
0.500	1.000 PSI	1.0000 PSI	4.0748	-0.0325	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043756 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12146566 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_05 Operator ID: 18290 Calibration Date: 7/22/2009 7:19:51PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56230	Multimeter	12/20/2009 9:28:00AM
E3-58652	Load Box	8/20/2009 2:23:00PM
P3-53225	Pressure Controller	8/26/2009 7:30:00AM
P3-53643	Barometer	12/10/2009 6:20:00AM
P3-54258	Vacuum Meter	10/30/2009 10:42:00AM
P3-54318	Pressure Controller	9/4/2009 1:47:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	199.999 PSI	199.9994 PSI	20.0010	0.0063	PASS
80.000	159.999 PSI	159.9994 PSI	16.7990	-0.0062	PASS
60.000	119.999 PSI	119.9994 PSI	13.5940	-0.0375	PASS
40.000	79.999 PSI	79.9994 PSI	10.3938	-0.0387	PASS
20.000	40.000 PSI	40.0000 PSI	7.1930	-0.0437	PASS
0.000	0.001 PSI	0.0010 PSI	3.9994	-0.0037	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043757 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151336 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 27538 Calibration Date: 7/22/2009 7:05:09PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54290	Multimeter	10/20/2009 12:07:00PM
E3-58611	Load Box	10/20/2009 9:05:00AM
P3-54020	Pressure Controller	10/25/2009 10:55:00AM
P3-54057	Barometer	1/27/2010 11:02:00AM
P3-54297	Pressure Controller	8/15/2009 8:56:00AM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9974	-0.0162	PASS
80.000	160.000 PSI	160.0000 PSI	16.7970	-0.0187	PASS
60.000	120.000 PSI	120.0000 PSI	13.5958	-0.0262	PASS
40.000	80.000 PSI	80.0000 PSI	10.3932	-0.0425	PASS
20.000	40.000 PSI	39.9998 PSI	7.1904	-0.0600	PASS
1.500	3.000 PSI	3.0000 PSI	4.2302	-0.0612	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043758 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151342 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 27538 Calibration Date: 7/22/2009 6:42:58PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	199.999 PSI	199.9991 PSI	20.0004	0.0025	PASS
80.000	159.999 PSI	159.9991 PSI	16.7976	-0.0150	PASS
60.000	119.999 PSI	119.9991 PSI	13.6000	0.0000	PASS
40.000	79.999 PSI	79.9990 PSI	10.4002	0.0013	PASS
20.000	39.999 PSI	39.9991 PSI	7.1996	-0.0025	PASS
0.500	1.000 PSI	1.0000 PSI	4.0790	-0.0062	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043759 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151337 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_02 Operator ID: 27538 Calibration Date: 7/22/2009 6:55:59PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:58:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	199.999 PSI	199.9994 PSI	20.0004	0.0025	PASS
80.000	159.999 PSI	159.9994 PSI	16.8020	0.0125	PASS
60.000	119.999 PSI	119.9994 PSI	13.6020	0.0125	PASS
40.000	79.999 PSI	79.9994 PSI	10.4038	0.0238	PASS
20.000	39.999 PSI	39.9994 PSI	7.2008	0.0050	PASS
0.500	1.000 PSI	1.0000 PSI	4.0820	0.0125	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043760 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12148641 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_02 Operator ID: 27538 Calibration Date: 7/22/2009 6:27:43PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54818	Multimeter	12/20/2009 6:39:00AM
E3-58712	Load Box	9/20/2009 11:30:00AM
P3-53642	Barometer	9/10/2009 1:56:00PM
P3-54451	Pressure Controller	9/5/2009 1:35:00PM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	199.9998 PSI	19.9978	-0.0137	PASS
80.000	160.000 PSI	159.9998 PSI	16.8016	0.0100	PASS
60.000	120.000 PSI	119.9998 PSI	13.5990	-0.0062	PASS
40.000	80.000 PSI	79.9998 PSI	10.3964	-0.0225	PASS
20.000	40.000 PSI	39.9999 PSI	7.1986	-0.0087	PASS
0.500	1.000 PSI	1.0000 PSI	4.0772	-0.0175	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043761 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151340 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 27538 Calibration Date: 7/22/2009 6:26:25PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54290	Multimeter	10/20/2009 12:07:00PM
E3-58611	Load Box	10/20/2009 9:05:00AM
P3-54020	Pressure Controller	10/25/2009 10:55:00AM
P3-54057	Barometer	1/27/2010 11:02:00AM
P3-54297	Pressure Controller	8/15/2009 8:56:00AM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	19.9986	-0.0087	PASS
80.000	160.000 PSI	160.0000 PSI	16.8010	0.0063	PASS
60.000	120.000 PSI	120.0000 PSI	13.5980	-0.0125	PASS
40.000	80.000 PSI	80.0000 PSI	10.3980	-0.0125	PASS
20.000	40.000 PSI	39.9997 PSI	7.1980	-0.0125	PASS
1.500	3.000 PSI	3.0000 PSI	4.2382	-0.0112	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 16
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043762 Model No: 3051TA4A2B21AS5E5M5T1Q4B4TRD1 Module Serial No: 12151339 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_04 Operator ID: 27538 Calibration Date: 7/22/2009 6:44:16PM

Attached Models

0306RT22AA11

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54290	Multimeter	10/20/2009 12:07:00PM
E3-58611	Load Box	10/20/2009 9:05:00AM
P3-54020	Pressure Controller	10/25/2009 10:55:00AM
P3-54057	Barometer	1/27/2010 11:02:00AM
P3-54297	Pressure Controller	8/15/2009 8:56:00AM

Calibration Data

Range: 0.000 TO 200.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	200.000 PSI	200.0000 PSI	20.0040	0.0250	PASS
80.000	160.000 PSI	160.0000 PSI	16.8054	0.0338	PASS
60.000	120.000 PSI	120.0000 PSI	13.6022	0.0138	PASS
40.000	80.000 PSI	80.0000 PSI	10.4010	0.0063	PASS
20.000	40.000 PSI	39.9996 PSI	7.2010	0.0063	PASS
1.500	3.000 PSI	3.0000 PSI	4.2412	0.0075	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043437 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258590 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_15 Operator ID: 17540 Calibration Date: 7/21/2009 11:04:54AM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54292	Multimeter	4/20/2010 7:49:00AM
E3-58598	Load Box	10/20/2009 11:39:00AM
P3-54296	Pressure Controller	8/8/2009 2:40:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	1386.490 InH2O@68degF	50.0000 PSI	19.9998	-0.0012	PASS
80.000	1109.192 InH2O@68degF	40.0000 PSI	16.8004	0.0025	PASS
60.000	831.894 InH2O@68degF	30.0000 PSI	13.6016	0.0100	PASS
40.000	554.596 InH2O@68degF	20.0000 PSI	10.4012	0.0075	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.2008	0.0050	PASS
0.000	0.000 InH2O@68degF	0.0000 PSI	3.9998	-0.0012	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043438 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261300 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_15 Operator ID: 17540 Calibration Date: 7/21/2009 12:23:15PM

Attached Models

0305RC52B11B4

Equipment Used


EqNumber:	EqName:	CalDueDate:
E3-54292	Multimeter	4/20/2010 7:49:00AM
E3-58598	Load Box	10/20/2009 11:39:00AM
P3-54296	Pressure Controller	8/6/2009 2:40:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	1386.490 InH2O@68degF	50.0000 PSI	19.9996	-0.0025	PASS
80.000	1109.192 InH2O@68degF	40.0000 PSI	16.7998	-0.0012	PASS
60.000	831.894 InH2O@68degF	30.0000 PSI	13.6012	0.0075	PASS
40.000	554.596 InH2O@68degF	20.0000 PSI	10.4010	0.0063	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.2002	0.0013	PASS
0.000	0.000 InH2O@68degF	0.0000 PSI	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043439 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258545 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 13016 Calibration Date: 7/21/2009 5:31:06PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM
P3-54837	Pressure Controller	10/2/2009 5:11:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	50.000 PSI	50.0000 PSI	20.0000	0.0000	PASS
80.000	40.000 PSI	40.0000 PSI	16.7998	-0.0012	PASS
60.000	30.000 PSI	30.0000 PSI	13.6006	0.0038	PASS
40.000	20.000 PSI	20.0000 PSI	10.4002	0.0013	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.1996	-0.0025	PASS
0.000	0.000 PSI	0.0000 PSI	3.9996	-0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043440 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261303 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_08 Operator ID: 13016 Calibration Date: 7/21/2009 5:39:11PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56118	Multimeter	1/20/2010 1:26:00PM
E3-58637	Load Box	12/20/2009 3:17:00PM
P3-52846	Pressure Controller	9/29/2009 12:58:00PM
P3-54050	Pressure Controller	8/24/2009 8:57:00AM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	50.000 PSI	50.0000 PSI	19.9978	-0.0137	PASS
80.000	40.000 PSI	40.0000 PSI	16.7996	-0.0025	PASS
60.000	30.000 PSI	30.0000 PSI	13.6004	0.0025	PASS
40.000	554.590 InH2O@68degF	19.9996 PSI	10.4024	0.0150	PASS
19.999	277.290 InH2O@68degF	9.9997 PSI	7.2016	0.0100	PASS
0.000	0.000 PSI	0.0000 PSI	3.9998	-0.0012	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043441 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261564 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 13016 Calibration Date: 7/21/2009 5:16:37PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM
P3-54837	Pressure Controller	10/2/2009 5:11:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	50.000 PSI	50.0000 PSI	20.0004	0.0025	PASS
80.000	40.000 PSI	40.0000 PSI	16.8000	0.0000	PASS
60.000	30.000 PSI	30.0000 PSI	13.6008	0.0050	PASS
40.000	20.000 PSI	20.0000 PSI	10.4004	0.0025	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.2000	0.0000	PASS
0.000	0.000 PSI	0.0000 PSI	3.9996	-0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043442 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261813 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 13016 Calibration Date: 7/21/2009 5:38:07PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM
P3-54837	Pressure Controller	10/2/2009 5:11:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	50.000 PSI	50.0000 PSI	19.9996	-0.0025	PASS
80.000	40.000 PSI	40.0000 PSI	16.7994	-0.0037	PASS
60.000	30.000 PSI	30.0000 PSI	13.6010	0.0063	PASS
40.000	20.000 PSI	20.0000 PSI	10.4010	0.0063	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.1998	-0.0012	PASS
0.000	0.000 PSI	0.0000 PSI	3.9994	-0.0037	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043443 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258316 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_03 Operator ID: 13016 Calibration Date: 7/21/2009 5:56:36PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-55641	Multimeter	9/20/2009 8:35:00AM
E3-58650	Load Box	11/20/2009 1:43:00PM
P3-54590	Pressure Controller	9/14/2009 2:51:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	50.000 PSI	50.0000 PSI	19.9996	-0.0025	PASS
80.000	40.000 PSI	40.0000 PSI	16.7998	-0.0012	PASS
60.000	30.000 PSI	30.0000 PSI	13.6012	0.0075	PASS
40.000	20.000 PSI	20.0000 PSI	10.4008	0.0050	PASS
20.000	10.000 PSI	10.0000 PSI	7.2000	0.0000	PASS
0.000	0.000 PSI	0.0000 PSI	3.9996	-0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 26
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043444 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4251142 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_15 Operator ID: 13016 Calibration Date: 7/21/2009 5:46:02PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-54292	Multimeter	4/20/2010 7:49:00AM
E3-58598	Load Box	10/20/2009 11:39:00AM
P3-54296	Pressure Controller	8/6/2009 2:40:00PM

Calibration Data

Range: 0.000 TO 50.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	1386.490 InH2O@68degF	50.0000 PSI	19.9998	-0.0012	PASS
80.000	1109.192 InH2O@68degF	40.0000 PSI	16.8002	0.0013	PASS
60.000	831.894 InH2O@68degF	30.0000 PSI	13.6016	0.0100	PASS
40.000	554.596 InH2O@68degF	20.0000 PSI	10.4016	0.0100	PASS
20.000	277.298 InH2O@68degF	10.0000 PSI	7.2006	0.0038	PASS
0.000	0.000 InH2O@68degF	0.0000 PSI	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043445 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258551 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_16 Operator ID: 12740 Calibration Date: 7/21/2009 3:27:11PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-53112	Multimeter	2/20/2010 11:07:00AM
E3-58605	Load Box	10/20/2009 11:36:00AM
P3-54299	Pressure Controller	9/23/2009 3:13:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	19.9998	-0.0012	PASS
80.000	240.000 PSI	240.0000 PSI	16.7992	-0.0050	PASS
60.000	180.000 PSI	180.0000 PSI	13.5988	-0.0075	PASS
40.000	120.000 PSI	120.0000 PSI	10.3992	-0.0050	PASS
20.000	60.000 PSI	60.0000 PSI	7.1992	-0.0050	PASS
0.000	0.000 PSI	0.0000 PSI	4.0002	0.0013	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043446 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258578 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 9764 Calibration Date: 7/21/2009 2:35:24PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0000	0.0000	PASS
80.000	240.000 PSI	240.0000 PSI	16.8000	0.0000	PASS
60.000	180.000 PSI	180.0000 PSI	13.5996	-0.0025	PASS
40.000	120.000 PSI	120.0000 PSI	10.4004	0.0025	PASS
20.000	60.000 PSI	60.0000 PSI	7.1978	-0.0137	PASS
0.000	0.000 PSI	0.0000 PSI	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043447 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258529 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 9764 Calibration Date: 7/21/2009 2:12:18PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0004	0.0025	PASS
80.000	240.000 PSI	240.0000 PSI	16.8004	0.0025	PASS
60.000	180.000 PSI	180.0000 PSI	13.5998	-0.0012	PASS
40.000	120.000 PSI	120.0000 PSI	10.4008	0.0050	PASS
20.000	60.000 PSI	60.0000 PSI	7.1980	-0.0125	PASS
0.000	0.000 PSI	0.0000 PSI	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043448 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258531 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 9764 Calibration Date: 7/21/2009 1:58:57PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0004	0.0025	PASS
80.000	240.000 PSI	240.0000 PSI	16.8002	0.0013	PASS
60.000	180.000 PSI	180.0000 PSI	13.5996	-0.0025	PASS
40.000	120.000 PSI	120.0000 PSI	10.4000	0.0000	PASS
20.000	60.000 PSI	60.0000 PSI	7.1974	-0.0162	PASS
0.000	0.000 PSI	0.0000 PSI	3.9996	-0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043449 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261263 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_09 Operator ID: 13462 Calibration Date: 7/21/2009 12:37:24PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56119	Multimeter	5/20/2010 10:03:00AM
E3-58645	Load Box	10/20/2009 7:51:00AM
P3-54855	Pressure Controller	10/9/2009 1:34:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	19.9994	-0.0037	PASS
80.000	240.000 PSI	240.0000 PSI	16.7998	-0.0012	PASS
60.000	180.000 PSI	180.0000 PSI	13.5988	-0.0075	PASS
40.000	120.000 PSI	120.0000 PSI	10.3996	-0.0025	PASS
20.000	60.000 PSI	60.0000 PSI	7.2000	0.0000	PASS
0.000	0.000 PSI	0.0000 PSI	4.0004	0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043450 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261275 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_08 Operator ID: 13462 Calibration Date: 7/21/2009 12:47:10PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56118	Multimeter	1/20/2010 1:26:00PM
E3-58637	Load Box	12/20/2009 3:17:00PM
P3-52846	Pressure Controller	9/29/2009 12:58:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0004	0.0025	PASS
80.000	240.000 PSI	240.0000 PSI	16.8004	0.0025	PASS
60.000	180.000 PSI	180.0000 PSI	13.6002	0.0013	PASS
40.000	120.000 PSI	120.0000 PSI	10.4004	0.0025	PASS
20.000	60.000 PSI	60.0000 PSI	7.2002	0.0013	PASS
0.000	0.000 PSI	0.0000 PSI	4.0004	0.0025	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043451 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4261791 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_07 Operator ID: 9764 Calibration Date: 7/21/2009 1:01:00PM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56234	Multimeter	11/20/2009 10:01:00AM
E3-58646	Load Box	12/20/2009 3:10:00PM
P3-54834	Pressure Controller	9/19/2009 4:15:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0002	0.0013	PASS
80.000	240.000 PSI	240.0000 PSI	16.8006	0.0038	PASS
60.000	180.000 PSI	180.0000 PSI	13.5998	-0.0012	PASS
40.000	120.000 PSI	120.0000 PSI	10.4008	0.0050	PASS
20.000	60.000 PSI	60.0000 PSI	7.1984	-0.0100	PASS
0.000	0.000 PSI	0.0000 PSI	3.9998	-0.0012	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

A handwritten signature in black ink, appearing to read 'Tim Layer', written in a cursive style.

Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 36
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 2043452 Model No: 3051CD4A02A1AS5E5M5T1Q4TRD1 Module Serial No: 4258530 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: XMTR_CAL_16 Operator ID: 17540 Calibration Date: 7/21/2009 10:41:23AM

Attached Models

0305RC52B11B4

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-53112	Multimeter	2/20/2010 11:07:00AM
E3-58605	Load Box	10/20/2009 11:36:00AM
P3-54299	Pressure Controller	9/23/2009 3:13:00PM

Calibration Data

Range: 0.000 TO 300.000 PSI

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
100.000	299.999 PSI	299.9990 PSI	20.0000	0.0000	PASS
80.000	240.000 PSI	240.0000 PSI	16.8000	0.0000	PASS
60.000	180.000 PSI	180.0000 PSI	13.5992	-0.0050	PASS
40.000	120.000 PSI	120.0000 PSI	10.4002	0.0013	PASS
20.000	60.000 PSI	60.0000 PSI	7.2000	0.0000	PASS
0.000	0.000 PSI	0.0000 PSI	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 56
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635833 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 31411 Calibration Date: 7/22/2009 11:53:50AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire -50.00 TO 150.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.989	149.978 DEG F	149.947 DEG F	19.9947 mA	-0.0221	PASS
74.996	99.992 DEG F	99.963 DEG F	15.9976 mA	-0.0110	PASS
50.019	50.037 DEG F	50.067 DEG F	12.0030 mA	0.0003	PASS
24.983	-0.034 DEG F	-0.022 DEG F	7.9969 mA	-0.0024	PASS
0.008	-49.984 DEG F	-49.954 DEG F	4.0019 mA	0.0039	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 56
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635834 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/22/2009 11:25:58AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire -50.00 TO 150.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.062	150.123 DEG F	150.105 DEG F	20.0091 mA	-0.0046	PASS
75.056	100.113 DEG F	100.122 DEG F	16.0085 mA	-0.0034	PASS
50.006	50.012 DEG F	50.008 DEG F	11.9999 mA	-0.0066	PASS
25.016	0.032 DEG F	0.006 DEG F	7.9996 mA	-0.0185	PASS
0.022	-49.956 DEG F	-50.020 DEG F	3.9999 mA	-0.0226	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 56
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635835 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 31411 Calibration Date: 7/22/2009 11:24:48AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire -50.00 TO 150.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.989	149.978 DEG F	149.958 DEG F	19.9953 mA	-0.0184	PASS
74.996	99.992 DEG F	99.945 DEG F	15.9968 mA	-0.0160	PASS
50.019	50.039 DEG F	50.071 DEG F	12.0022 mA	-0.0057	PASS
24.983	-0.033 DEG F	-0.033 DEG F	7.9967 mA	-0.0041	PASS
0.008	-49.984 DEG F	-49.962 DEG F	4.0015 mA	0.0014	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 56
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635836 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 31411 Calibration Date: 7/22/2009 11:49:06AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire -50.00 TO 150.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.997	149.994 DEG F	149.955 DEG F	19.9971 mA	-0.0151	PASS
74.989	99.977 DEG F	99.950 DEG F	15.9962 mA	-0.0122	PASS
50.054	50.108 DEG F	50.091 DEG F	12.0062 mA	-0.0152	PASS
25.032	0.064 DEG F	0.038 DEG F	8.0022 mA	-0.0182	PASS
0.037	-49.926 DEG F	-49.934 DEG F	4.0041 mA	-0.0114	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 61
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635837 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/22/2009 11:54:04AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 300.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.041	300.124 DEG F	300.148 DEG F	20.0059 mA	-0.0045	PASS
75.045	225.134 DEG F	225.120 DEG F	16.0072 mA	0.0003	PASS
50.041	150.123 DEG F	150.117 DEG F	12.0061 mA	-0.0029	PASS
25.034	75.103 DEG F	75.069 DEG F	8.0039 mA	-0.0100	PASS
0.010	0.031 DEG F	-0.016 DEG F	3.9997 mA	-0.0122	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 61
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635838 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 15032 Calibration Date: 7/22/2009 12:49:58PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 300.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.041	300.123 DEG F	300.122 DEG F	20.0051 mA	-0.0091	PASS
75.045	225.134 DEG F	225.112 DEG F	16.0057 mA	-0.0090	PASS
50.041	150.124 DEG F	150.103 DEG F	12.0043 mA	-0.0145	PASS
25.035	75.104 DEG F	75.096 DEG F	8.0035 mA	-0.0128	PASS
0.010	0.031 DEG F	-0.013 DEG F	3.9997 mA	-0.0122	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 61
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635839 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 15032 Calibration Date: 7/22/2009 12:56:08PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 300.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.990	299.970 DEG F	300.012 DEG F	19.9987 mA	0.0019	PASS
74.996	224.989 DEG F	224.970 DEG F	15.9990 mA	-0.0026	PASS
49.993	149.978 DEG F	149.971 DEG F	11.9986 mA	-0.0014	PASS
24.990	74.969 DEG F	74.953 DEG F	7.9979 mA	-0.0028	PASS
-0.011	-0.034 DEG F	-0.007 DEG F	3.9972 mA	-0.0062	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



23 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 61
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0635840 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 15032 Calibration Date: 7/22/2009 1:26:56PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 300.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.042	300.125 DEG F	300.127 DEG F	20.0068 mA	0.0008	PASS
75.045	225.135 DEG F	225.134 DEG F	16.0059 mA	-0.0081	PASS
50.041	150.124 DEG F	150.103 DEG F	12.0049 mA	-0.0107	PASS
25.035	75.104 DEG F	75.126 DEG F	8.0053 mA	-0.0015	PASS
0.010	0.031 DEG F	-0.004 DEG F	4.0001 mA	-0.0097	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636428 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/30/2009 9:57:45AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.103 DEG F	200.120 DEG F	20.0072 mA	-0.0065	PASS
75.062	150.123 DEG F	150.091 DEG F	16.0072 mA	-0.0165	PASS
50.057	100.113 DEG F	100.113 DEG F	12.0086 mA	-0.0027	PASS
25.006	50.012 DEG F	50.004 DEG F	7.9996 mA	-0.0085	PASS
0.016	0.032 DEG F	-0.020 DEG F	3.9997 mA	-0.0179	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636429 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 31411 Calibration Date: 7/30/2009 9:57:43AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.987	199.974 DEG F	200.005 DEG F	19.9968 mA	-0.0070	PASS
74.989	149.978 DEG F	149.952 DEG F	15.9953 mA	-0.0184	PASS
49.996	99.992 DEG F	99.970 DEG F	11.9978 mA	-0.0097	PASS
25.019	50.039 DEG F	50.063 DEG F	8.0039 mA	0.0049	PASS
-0.017	-0.034 DEG F	-0.028 DEG F	3.9969 mA	-0.0024	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636430 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 31411 Calibration Date: 7/30/2009 10:06:46AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.996	199.992 DEG F	199.987 DEG F	19.9985 mA	-0.0054	PASS
74.989	149.978 DEG F	149.966 DEG F	15.9975 mA	-0.0046	PASS
49.988	99.977 DEG F	99.964 DEG F	11.9966 mA	-0.0097	PASS
25.045	50.089 DEG F	50.069 DEG F	8.0063 mA	-0.0051	PASS
0.033	0.066 DEG F	0.033 DEG F	4.0023 mA	-0.0186	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

<p>Customer Information</p> <p>Name: YORK INTERNATIONAL CORP PO: 4500404358</p>	<p>Manufacturer Information</p> <p>Sales Order: 2363234 Line: 49</p>
<p>Device Information</p> <p>Device Type: Temperature Transmitter Tag No: 294100</p> <p>Serial No: 0636431 Model No: 3144PD1A1E5M5B5T1C4Q4</p> <p>Output: Linear</p>	<p>Calibration Information</p> <p>Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 31411 Calibration Date: 7/30/2009 10:38:11AM</p>

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.994	199.988 DEG F	199.971 DEG F	19.9977 mA	-0.0084	PASS
74.990	149.980 DEG F	149.969 DEG F	15.9973 mA	-0.0069	PASS
49.987	99.974 DEG F	99.929 DEG F	11.9957 mA	-0.0139	PASS
25.045	50.090 DEG F	50.101 DEG F	8.0055 mA	-0.0106	PASS
0.028	0.056 DEG F	0.039 DEG F	4.0019 mA	-0.0161	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636432 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/30/2009 10:37:54AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.103 DEG F	200.084 DEG F	20.0075 mA	-0.0046	PASS
75.062	150.124 DEG F	150.092 DEG F	16.0090 mA	-0.0057	PASS
50.057	100.113 DEG F	100.116 DEG F	12.0100 mA	0.0060	PASS
25.006	50.012 DEG F	50.036 DEG F	8.0016 mA	0.0040	PASS
0.016	0.032 DEG F	-0.007 DEG F	4.0008 mA	-0.0110	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636433 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/30/2009 11:06:46AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.102 DEG F	200.097 DEG F	20.0080 mA	-0.0010	PASS
75.061	150.123 DEG F	150.089 DEG F	16.0079 mA	-0.0121	PASS
50.056	100.112 DEG F	100.098 DEG F	12.0086 mA	-0.0023	PASS
25.006	50.012 DEG F	50.011 DEG F	8.0009 mA	-0.0004	PASS
0.016	0.031 DEG F	-0.011 DEG F	4.0007 mA	-0.0111	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636434 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 31411 Calibration Date: 7/30/2009 11:06:30AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.987	199.975 DEG F	200.017 DEG F	19.9990 mA	0.0063	PASS
74.989	149.978 DEG F	149.961 DEG F	15.9967 mA	-0.0096	PASS
49.996	99.993 DEG F	99.973 DEG F	11.9971 mA	-0.0146	PASS
25.019	50.039 DEG F	50.073 DEG F	8.0031 mA	-0.0001	PASS
-0.017	-0.033 DEG F	-0.017 DEG F	3.9970 mA	-0.0022	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636435 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 31411 Calibration Date: 7/30/2009 11:57:31AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.103 DEG F	200.128 DEG F	20.0098 mA	0.0098	PASS
75.062	150.123 DEG F	150.101 DEG F	16.0078 mA	-0.0127	PASS
50.056	100.113 DEG F	100.131 DEG F	12.0058 mA	-0.0202	PASS
25.006	50.011 DEG F	50.023 DEG F	7.9985 mA	-0.0149	PASS
0.016	0.031 DEG F	-0.009 DEG F	3.9963 mA	-0.0261	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636436 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 31411 Calibration Date: 7/30/2009 11:57:10AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.987	199.975 DEG F	199.967 DEG F	19.9978 mA	-0.0012	PASS
74.989	149.978 DEG F	149.945 DEG F	15.9969 mA	-0.0084	PASS
49.996	99.992 DEG F	99.963 DEG F	11.9992 mA	-0.0010	PASS
25.019	50.038 DEG F	50.048 DEG F	8.0031 mA	0.0004	PASS
-0.017	-0.033 DEG F	-0.008 DEG F	3.9973 mA	-0.0004	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 49
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636437 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 15068 Calibration Date: 7/30/2009 2:22:17PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.102 DEG F	200.120 DEG F	20.0074 mA	-0.0047	PASS
75.062	150.123 DEG F	150.082 DEG F	16.0083 mA	-0.0096	PASS
50.056	100.112 DEG F	100.129 DEG F	12.0083 mA	-0.0041	PASS
25.006	50.012 DEG F	50.011 DEG F	7.9995 mA	-0.0091	PASS
0.015	0.031 DEG F	-0.007 DEG F	4.0004 mA	-0.0130	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 50
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636424 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 13730 Calibration Date: 7/29/2009 10:18:20PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.001	200.002 DEG F	199.976 DEG F	19.9986 mA	-0.0097	PASS
74.989	149.977 DEG F	149.964 DEG F	15.9972 mA	-0.0060	PASS
49.985	99.969 DEG F	99.945 DEG F	11.9947 mA	-0.0176	PASS
25.051	50.103 DEG F	50.095 DEG F	8.0061 mA	-0.0134	PASS
0.027	0.054 DEG F	0.048 DEG F	4.0031 mA	-0.0076	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
 Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 50
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636425 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 13730 Calibration Date: 7/29/2009 10:12:04PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.987	199.975 DEG F	199.969 DEG F	19.9978 mA	-0.0012	PASS
74.989	149.978 DEG F	149.963 DEG F	15.9966 mA	-0.0102	PASS
49.996	99.991 DEG F	99.974 DEG F	11.9978 mA	-0.0092	PASS
25.019	50.038 DEG F	50.084 DEG F	8.0032 mA	0.0010	PASS
-0.017	-0.035 DEG F	-0.028 DEG F	3.9959 mA	-0.0081	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

<p>Customer Information</p> <p>Name: YORK INTERNATIONAL CORP PO: 4500404358</p>	<p>Manufacturer Information</p> <p>Sales Order: 2363234 Line: 50</p>
<p>Device Information</p> <p>Device Type: Temperature Transmitter Tag No: 294100</p> <p>Serial No: 0636426 Model No: 3144PD1A1E5M5B5T1C4Q4</p> <p>Output: Linear</p>	<p>Calibration Information</p> <p>Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 13730 Calibration Date: 7/29/2009 10:24:31PM</p>

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.051	200.102 DEG F	200.068 DEG F	20.0063 mA	-0.0116	PASS
75.062	150.123 DEG F	150.088 DEG F	16.0067 mA	-0.0196	PASS
50.056	100.112 DEG F	100.128 DEG F	12.0073 mA	-0.0104	PASS
25.006	50.011 DEG F	49.997 DEG F	7.9984 mA	-0.0155	PASS
0.015	0.031 DEG F	-0.029 DEG F	3.9995 mA	-0.0186	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



30 July, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1 or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500404358	Manufacturer Information Sales Order: 2363234 Line: 50
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0636427 Model No: 3144PD1A1E5M5B5T1C4Q4 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 13730 Calibration Date: 7/29/2009 10:26:52PM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.987	199.973 DEG F	200.014 DEG F	19.9993 mA	0.0091	PASS
74.989	149.978 DEG F	149.964 DEG F	15.9971 mA	-0.0071	PASS
49.996	99.991 DEG F	99.959 DEG F	11.9979 mA	-0.0086	PASS
25.019	50.038 DEG F	50.103 DEG F	8.0048 mA	0.0110	PASS
-0.017	-0.035 DEG F	-0.042 DEG F	3.9960 mA	-0.0075	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



24 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 35
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0641475 Model No: 3144PD1A1E5M5T1C4Q4XA Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn2 Operator ID: 35453 Calibration Date: 9/23/2009 6:29:07AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.988	199.975 DEG F	200.000 DEG F	19.9984 mA	0.0025	PASS
74.990	149.980 DEG F	149.953 DEG F	15.9973 mA	-0.0069	PASS
49.997	99.994 DEG F	99.957 DEG F	11.9975 mA	-0.0126	PASS
25.020	50.040 DEG F	50.028 DEG F	8.0001 mA	-0.0194	PASS
-0.016	-0.032 DEG F	-0.027 DEG F	3.9958 mA	-0.0102	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



24 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 35
Device Information Device Type: Temperature Transmitter Tag No: 294100 Serial No: 0641476 Model No: 3144PD1A1E5M5T1C4Q4XA Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 31411 Calibration Date: 9/23/2009 6:45:06AM

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.992	199.984 DEG F	199.989 DEG F	19.9990 mA	0.0018	PASS
74.994	149.987 DEG F	149.951 DEG F	15.9950 mA	-0.0247	PASS
49.988	99.977 DEG F	99.954 DEG F	11.9969 mA	-0.0079	PASS
25.051	50.101 DEG F	50.099 DEG F	8.0072 mA	-0.0055	PASS
0.038	0.076 DEG F	0.031 DEG F	4.0038 mA	-0.0142	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

<p>Customer Information</p> <p>Name: YORK INTERNATIONAL CORP PO: 4500416518</p>	<p>Manufacturer Information</p> <p>Sales Order: 2385817 Line: 37</p>
<p>Device Information</p> <p>Device Type: Temperature Transmitter Tag No: 294100</p> <p>Serial No: 0641477 Model No: 3144PD1A1E5M5T1C4Q4XA</p> <p>Output: Linear</p>	<p>Calibration Information</p> <p>Factory: CHANHASSEN, MN, USA Station Name: FinalStn3 Operator ID: 35453 Calibration Date: 9/23/2009 6:07:53AM</p>

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
100.050	200.101 DEG F	200.082 DEG F	20.0070 mA	-0.0067	PASS
75.061	150.122 DEG F	150.090 DEG F	16.0083 mA	-0.0091	PASS
50.056	100.111 DEG F	100.124 DEG F	12.0089 mA	0.0001	PASS
25.005	50.011 DEG F	50.035 DEG F	8.0012 mA	0.0020	PASS
0.015	0.030 DEG F	-0.033 DEG F	3.9977 mA	-0.0294	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

<p>Customer Information</p> <p>Name: YORK INTERNATIONAL CORP PO: 4500416518</p>	<p>Manufacturer Information</p> <p>Sales Order: 2385817 Line: 37</p>
<p>Device Information</p> <p>Device Type: Temperature Transmitter Tag No: 294100</p> <p>Serial No: 0641478 Model No: 3144PD1A1E5M5T1C4Q4XA</p> <p>Output: Linear</p>	<p>Calibration Information</p> <p>Factory: CHANHASSEN, MN, USA Station Name: FinalStn6 Operator ID: 31411 Calibration Date: 9/23/2009 5:28:38AM</p>

Calibration Data

Sensor 1 Pt100 00385 3 Wire 0.00 TO 200.00 DEG F

% of Range	Measured Input	Digital Output	Analog Output	% Span Error	Pass/Fail
99.993	199.986 DEG F	199.981 DEG F	19.9967 mA	-0.0136	PASS
74.992	149.984 DEG F	149.941 DEG F	15.9964 mA	-0.0145	PASS
49.991	99.983 DEG F	99.945 DEG F	11.9953 mA	-0.0209	PASS
25.049	50.098 DEG F	50.066 DEG F	8.0065 mA	-0.0084	PASS
0.031	0.061 DEG F	0.088 DEG F	4.0043 mA	-0.0036	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 17
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 0037114 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI Module Serial No: 4347945 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 13257 Calibration Date: 9/30/2009 6:56:37AM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-58158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9856	-0.0062	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7886	-0.0337	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5932	0.0963	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3952	0.0625	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.1978	0.0325	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
 Vice-President of Global Quality



30 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 18
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 0037113 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI Module Serial No: 4355594 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 36299 Calibration Date: 9/29/2009 9:51:13PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9890	0.0150	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7926	-0.0087	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5782	0.0025	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3920	0.0425	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.1940	0.0088	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	3.9968	-0.0200	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

<p>Customer Information</p> <p>Name: YORK INTERNATIONAL CORP PO: 4500416518</p>	<p>Manufacturer Information</p> <p>Sales Order: 2385817 Line: 19</p>
<p>Device Information</p> <p>Device Type: Pressure Transmitter Tag No: 294100</p> <p>Serial No: 0037112 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI</p> <p>Module Serial No: 4348539 Output: Linear</p>	<p>Calibration Information</p> <p>Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 38131 Calibration Date: 9/29/2009 6:49:50PM</p>

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9876	0.0063	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7918	-0.0137	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5934	0.0975	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3948	0.0600	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.1978	0.0325	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	4.0002	0.0013	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.



Tim Layer
Vice-President of Global Quality



30 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 20
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 0037111 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI Module Serial No: 4348543 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 13257 Calibration Date: 9/30/2009 8:26:02AM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9854	-0.0075	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7906	-0.0212	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5934	0.0975	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3946	0.0588	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.1970	0.0275	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 21
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 0037109 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI Module Serial No: 4355597 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 36299 Calibration Date: 9/29/2009 11:44:16PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9876	0.0063	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7886	-0.0337	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5818	0.0250	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3968	0.0725	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.2008	0.0513	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	4.0048	0.0300	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality



30 September, 2009

Emerson Process Management
 Rosemount Inc.
 8200 Market Blvd
 Chanhassen, MN U.S. 55317-9786

Calibration Data Sheet Consistent with ISO 10474 3.1B or EN 10204 3.1

Customer Information Name: YORK INTERNATIONAL CORP PO: 4500416518	Manufacturer Information Sales Order: 2385817 Line: 21
Device Information Device Type: Pressure Transmitter Tag No: 294100 Serial No: 0037110 Model No: 3051SFADG120DCHLS2A100051AA1A2Q4K5M5T1D1 RI Module Serial No: 4348535 Output: Linear	Calibration Information Factory: CHANHASSEN, MN, USA Station Name: DPFLW_CAL_01 Operator ID: 38131 Calibration Date: 9/29/2009 8:46:34PM

Equipment Used

EqNumber:	EqName:	CalDueDate:
E3-56158	Multimeter	10/20/2009 11:55:00AM
E3-58639	Load Box	12/20/2009 10:04:00AM
P3-54917	Pressure Controller	11/12/2009 12:56:00PM

Calibration Data

Range: 0.000 TO 18.761 InH2O@68degF

% of Range	Applied Pressure	Requested Applied Pressure	Analog Output (mA)	% Span Error	Pass/Fail
99.917	0.676 PSI	18.7453 InH2O@68degF	19.9858	-0.0050	PASS
79.963	0.541 PSI	15.0018 InH2O@68degF	16.7874	-0.0412	PASS
59.861	0.405 PSI	11.2306 InH2O@68degF	13.5912	0.0838	PASS
39.908	0.270 PSI	7.4871 InH2O@68degF	10.3932	0.0500	PASS
19.954	0.135 PSI	3.7435 InH2O@68degF	7.1968	0.0263	PASS
0.000	0.000 PSI	0.0000 InH2O@68degF	4.0000	0.0000	PASS

This is to certify that the listed product meets the applicable Rosemount Specifications. Measuring and test equipment used in the manufacture and inspection of the listed product are traceable to the National Institute of Standards and Technology. The calibration system was designed to meet the intent of ANSI Z540-1-1994.

Tim Layer
 Vice-President of Global Quality