



AIR-COOLED SCREW LIQUID CHILLERS

INSTALLATION, OPERATION, MAINTENANCE

Supersedes: 201.18-NM7 (701)

Form 201.18-NM7 (916)

YCAS AIR-COOLED LIQUID CHILLERS YCAS0098EB through YCAS0208EB



28971AR

60 Hz

YCAS 2 SYSTEM EPROM

031-01798-001

(STANDARD, BRINE & METRIC MODELS COMBINED)



Issue Date:
September 30, 2016



IMPORTANT!

READ BEFORE PROCEEDING!

GENERAL SAFETY GUIDELINES

This equipment is a relatively complicated apparatus. During rigging, installation, operation, maintenance, or service, individuals may be exposed to certain components or conditions including, but not limited to: heavy objects, refrigerants, materials under pressure, rotating components, and both high and low voltage. Each of these items has the potential, if misused or handled improperly, to cause bodily injury or death. It is the obligation and responsibility of rigging, installation, and operating/service personnel to identify and recognize these inherent hazards, protect themselves, and proceed safely in completing their tasks. Failure to comply with any of these requirements could result in serious damage to the equipment and the property in

which it is situated, as well as severe personal injury or death to themselves and people at the site.

This document is intended for use by owner-authorized rigging, installation, and operating/service personnel. It is expected that these individuals possess independent training that will enable them to perform their assigned tasks properly and safely. It is essential that, prior to performing any task on this equipment, this individual shall have read and understood the on-product labels, this document and any referenced materials. This individual shall also be familiar with and comply with all applicable industry and governmental standards and regulations pertaining to the task in question.

SAFETY SYMBOLS

The following symbols are used in this document to alert the reader to specific situations:




Indicates a possible hazardous situation which will result in death or serious injury if proper care is not taken.



Identifies a hazard which could lead to damage to the machine, damage to other equipment and/or environmental pollution if proper care is not taken or instructions are not followed.



Indicates a potentially hazardous situation which will result in possible injuries or damage to equipment if proper care is not taken.



Highlights additional information useful to the technician in completing the work being performed properly.



External wiring, unless specified as an optional connection in the manufacturer's product line, is not to be connected inside the control cabinet. Devices such as relays, switches, transducers and controls and any external wiring must not be installed inside the micro panel. All wiring must be in accordance with Johnson Controls' published specifications and must be performed only by a qualified electrician. Johnson Controls will NOT be responsible for damage/problems resulting from improper connections to the controls or application of improper control signals. Failure to follow this warning will void the manufacturer's warranty and cause serious damage to property or personal injury.

TABLE OF CONTENTS

SECTION 1 GENERAL CHILLER INFORMATION & SAFETY

Introduction	7
Warranty	7
Safety	7
Standards for Safety	7
Responsibility for Safety	8
About this Manual	8
Misuse of Equipment	8
Suitability for Application	8
Structural Support	8
Mechanical Strength	8
General Access	8
Pressure Systems	8
Electrical	8
Rotating Parts	9
Sharp Edges	9
Refrigerants and Oils	9
High Temperature and Pressure Cleaning	9
Emergency Shutdown	9
Material Safety Data	10

SECTION 2 PRODUCT DESCRIPTION

Introduction	14
General Description	14
Compressor	14
Evaporator	15
Condenser	15
Oil Separator / System	16
Oil Cooling	16
Capacity Control	16
Power and Control Panel	16
Microprocessor Controls	17
Motor Current Protection	17
Motor Protection Module	18
Current Overload	18
Thermal Overload	19
Current Imbalance	19
Improper Phase Sequence	19
Motor Protector Dip Switch Settings	20
Motor Starting	22
Keypad Controls	22
Display	22
Entry	23
Setpoints	23
Clock	23
Print	23
Program	23
Accessories and Options	23
Multiple Point Power Connection (Standard)	23

Single-Point Power Connection with Individual Circuit Protection	23
Single-Point Power Connection with Combined Circuit Protection	23
Single-Point Power Connection without Circuit Protection	23
Control Circuit Terminal Block	23
Building Automation System (BAS) Interface	23
Condenser Coil Protection	23
DX Cooler Options	24
300 PSIG (21 bar) Waterside Design Working Pressure	24
1-1/2" (38 mm) Insulation	24
Flange Accessory	24
Remote DX Cooler	24
Flow Switch Accessory	24
Star-Delta Compressor Motor Starter	24
Unit Enclosures	24
Fans	24
Sound Reduction Options	24
Vibration Isolation	24
Unit Nomenclature & Nameplate	
Engineering Data	25
Basic Part Number	25
Options Section of Part Number	26

SECTION 3 HANDLING AND STORAGE

Delivery and Storage	27
Inspection	27
Moving the Chiller	27
Lifting Weights	27
Unit Rigging	28

SECTION 4 INSTALLATION

Location Requirements	29
Outdoor Installations	29
Indoor Installations	29
Location Clearances	29
Installation of Vibration Isolators	30
Installation	30
Shipping Braces	30
Pipework Connection	30
General Requirements	30
Water Treatment	31
Pipework Arrangement	32
Connection Types & Sizes	32
Cooler Connections	32
Option Flanges	32
Refrigerant Relief Valve Piping	32
Ductwork Connection	32

TABLE OF CONTENTS (CONT'D)

General Requirements	32	Optional Single-Point Power Supply	
Electrical Connection	33	Connection to Factory Circuit Breaker.....	56
Power Wiring	33	Compressor Data	57
Standard Units with Multi Point Power Supply		Fan Data.....	57
Wiring	33	Electrical Notes	58
Units with Single-Point Power Supply Wiring.....	33	Wiring Diagram – Across-the-Line Start	60
115VAC Control Supply Transformer	33	Elementary Diagram – Across-the-Line Start	62
Remote Emergency Stop Device	34	Wiring Diagram – Wye-Delta Start	64
Control Panel Wiring	34	Elementary Diagram – Wye-Delta Start	66
Volts Free Contacts	34	Control Panel Component Locations	68
Chilled Liquid Pump Starter.....	34	Power Panel Component Locations	69
Run Contact	34	Connection Diagram	70
Alarm Contacts	34	Connection Diagram (System Wirng)	72
System Inputs	34	Compressor Terminal Box	73
Flow Switch.....	34	Dimensions	76
Remote Run / Stop	34	YCAS0098EB - 0118EB (English)	76
Remote Print.....	34	YCAS0098EB - 0118EB (SI)	78
Remote Setpoint Offset – Temperature	34	YCAS0128EB (English)	80
Remote Setpoint Offset – Current	34	YCAS0128EB (SI).....	82
Power and Control Panel Layouts		YCAS00138EB (English)	84
(Wye-Delta Typical)	35	YCAS00138EB (SI)	86
Option Panel Layout (Typical)	36	YCAS0148EB - 0178EB (English)	88
Logic Section Layout	37	YCAS0148EB - 0178EB (SI).....	90
Logic Section Layout with Control		YCAS0198EB - 0208EB (English)	92
Panel Layout	38	YCAS0198EB - 0208EB (SI).....	94
Customer Connections	39	Clearances	96
SECTION 5 COMMISSIONING		Operating Weights – Alum. Fin & Black Fin Coils ...	97
Preparation	41	Isolation Selection – Alum. Fin & Black Fin Coils ...	98
Preparation – Power Off.....	41	Weight Distribution and Isolator Mounting	
First Time Start-up	43	Positions (Alum. Fin & Black Fin Cond. Coils)....	99
SECTION 6 OPERATION		Operating Weights – Copper Fin Condenser Coils.	
General Description	44	(or Aluminum Fin with Optional Silencer Kits)	102
Start-up	44	Isolation Selection – Copper Fin CondenserCoil (or	
Normal Running and Cycling	44	Aluminum Fin with Optional Silencer Kits).....	103
Shutdown	44	Operating Weights – Copper Fin Condenser Coils	
SECTION 7 TECHNICAL DATA		with Optional Silencer Kits	104
Flow Rate and Pressure Drop Charts.....	45	Isolation Selection – Copper Fin Condenser Coils	
Glycol Correction Factors	45	with Optional Silencer Kits	105
Temperature and Flows	46	Installation Instructions for VMC Series	
Physical Data (English Units).....	47	AWR/AWMR and CP Restrained Mountings....	106
Physical Data (SI Units).....	48	Refrigerant Flow Diagram	107
Operating Limitations & Sound Power Data	49	Process and Instrumentation Diagram	108
Electrical Data	50	Component Locations	109
Multiple Point Power Supply Connection.....	50	Compressor Components	110
Optional Single-Point Power Supply Connection		System Start-up Checklist	116
and Individual System Circuit Breakers.....	52	Unit Checks	116
Optional Single-Point Power Supply Connection		Panel Checks	117
with Field Supplied Circuit Protection	54	Programmed Values	117
		Initial Start-up	118
		Checking Subcooling and Superheat	118
		Checking Economizer Superheat	119
		Leak Checking	119

TABLE OF CONTENTS (CONT'D)

SECTION 8	MICRO PANEL CONTENTS	120
	Chiller Control Panel Programming and Data Access Keys	120
	Display and Status Information Keys.....	120
	ON / OFF Rocker Switch	120
	Program & Setup Keys	120
1.	INTRODUCTION & PHYSICAL DESCRIPTION	121
1.1	General 121	
1.2	Keypad & Display	121
1.3	Unit (Chiller) On / OFF Switch	122
1.4	Microprocessor Board	122
1.5	Ancillary Circuit Boards	122
1.6	Circuit Breakers	123
1.7	Current Transformers (C.T.)	123
1.8	Transformers	123
1.9	Motor Protection Modules	124
1.10	EMS/BAS Controls	126
1.11	Microprocessor Board Layout	128
1.12	Logic Section Layout.....	129
1.13	Anti-Recycle Timer	130
1.14	Anti-Coincidence Timer	130
1.15	Evaporator Pump Control	130
1.16	Compressor Heater Control	130
1.17	Evaporator Heater Control.....	130
1.18	Pumpdown (LLSV) Control	130
1.19	Alarms 130	
1.20	Run Status (Chiller).....	131
1.21	Lead / Lag Compressor Selection.....	131
2.	STATUS KEY: GENERAL STATUS MESSAGES & FAULT WARNINGS.....	132
2.1	General 132	
2.2	General Status Messages	132
2.3	Unit Warnings	133
2.4	Anticipation Control Status Messages	134
2.5	Unit Fault Status Messages.....	135
2.6	System Fault (Safety) Status Messages	136
2.7	Printout on Fault Shutdown	139
3.	DISPLAY KEYS & OPTION SWITCHES	140
3.1	General 140	
3.2	Chilled Liquid Temps Key.....	140
3.3	System # Data Keys.....	141
3.4	Ambient Temp Key.....	141
3.5	Motor Current Key	142
3.6	Operating HRS / Start Counter Key	142
3.7	Options Key & Dip Switch Settings	142
3.8	Function Key	144
4.	PRINT KEYS	145
4.1	General 145	
4.2	Oper Data Key	145
4.3	Operating Data – Local Display Messages.....	145
4.4	Operating Data – Remote Printout	146
4.5	History Key.....	148
4.6	Fault History Data – Local Display Messages	148
4.7	Fault History Data – Remote Printout	151

TABLE OF CONTENTS (CONT'D)

5. ENTRY KEYS	152
5.1 General	152
5.2 Numerical Keypad	152
5.3 Enter Key	152
5.4 Cancel Key	152
5.5 ↑ ↓ Keys	152
6. SETPOINTS KEYS & CHILLED LIQUID CONTROL	153
6.1 General	153
6.2 Chilled Liquid Temperature Control	153
6.3 Local Cooling Setpoints Key	156
6.4 Remote Cooling Setpoints Key	156
7. CLOCK KEYS	157
7.1 General	157
7.2 Set Time Key	157
7.3 Set Schedule / Holiday Key	158
7.4 Manual Override Key	159
8. PROGRAM KEY	160
8.1 General	160
8.2 Program Key – User Programmable Values	160
8.3 Programming “Default” Values	164
8.4 4 Condenser Fan Control	165
SECTION 9 MAINTENANCE	169
General Requirements	169
Daily Maintenance	169
Scheduled Maintenance	169
Chiller/Compressor Operating Log	169
Compressor Unit Operation	170
Maintenance Requirements	171
General Periodic Maintenance Checks – Standard Units	172
SECTION 10 SPARE PARTS	173
Recommended Spares	173
Recommended Compressor Oils	173
Associated Drawings	173
SECTION 11 TROUBLESHOOTING	174
Competent Persons Troubleshooting Guide	174
Sensor Calibration Charts	176
Limited Warranty Applied Systems	177
Temperature Conversion Chart	178

GENERAL CHILLER INFORMATION & SAFETY

INTRODUCTION

YORK YCAS chillers are manufactured to the highest design and construction standards to ensure high performance, reliability and adaptability to all types of air conditioning installations.

The unit is intended for cooling water or glycol solutions and is not suitable for purposes other than those specified in this manual.

This manual and the Microprocessor Operating Instructions contain all the information required for correct installation and commissioning of the unit, together with operating and maintenance instructions. The manuals should be read thoroughly before attempting to operate or service the unit.

All procedures detailed in the manuals, including installation, commissioning and maintenance tasks must only be performed by suitably trained and qualified personnel.

The manufacturer will not be liable for any injury or damage caused by incorrect installation, commissioning, operation or maintenance resulting from a failure to follow the procedures and instructions detailed in the manuals.

WARRANTY

York International warrants all equipment and materials against defects in workmanship and materials for a period of one year from initial start-up, or eighteen months from delivery (whichever occurs first) unless extended warranty has been agreed upon as part of the contract.

The warranty is limited to parts only replacement and shipping of any faulty part, or sub-assembly which has failed due to poor quality or manufacturing errors. All claims must be supported by evidence that the failure has occurred within the warranty period, and that the unit has been operated within the designed parameters specified.

All warranty claims must specify the unit model, serial number, order number and run hours/starts. These details are printed on the unit identification plate.

The unit warranty will be void if any modification to the unit is carried out without prior written approval from York International.

For warranty purposes, the following conditions must be satisfied:

- The initial start of the unit must be carried out by trained personnel from an Authorized YORK Service Center. See Commissioning, page 41.
- Only genuine YORK approved spare parts, oils and refrigerants must be used. Recommendations on spare parts can be found on page 173.
- All the scheduled maintenance operations detailed in this manual must be performed at the specified times by suitably trained and qualified personnel. See Maintenance Section, page 169.
- Failure to satisfy any of these conditions will automatically void the warranty. See Warranty Policy, page 177.

SAFETY

Standards for Safety

YCAS chillers are designed and built within an ISO 9002 accredited design and manufacturing organization. The chillers comply with the applicable sections of the following Standards and Codes:

- ANSI/ASHRAE Standard 15, Safety Code for Mechanical Refrigeration
- ANSI/NFPA Standard 70, National Electrical Code (N.E.C.)
- ASME Boiler and Pressure Vessel Code, Section VIII Division 1
- ARI Standard 550/590-98, Centrifugal and Rotary Screw Water Chilling Packages

In addition, the chillers conform to Underwriters Laboratories (U.L.) for construction of chillers and provide U.L./cU.L. listing label.

RESPONSIBILITY FOR SAFETY

Every care has been taken in the design and manufacture of the unit to ensure compliance with the safety requirements listed above. However, the individual operating or working on any machinery is primarily responsible for:

- Personal safety, safety of other personnel, and the machinery.
- Correct utilization of the machinery in accordance with the procedures detailed in the manuals.

ABOUT THIS MANUAL


The following terms are used in this document to alert the reader to areas of potential hazard.



A **Warning** is given in this document to identify a hazard which could lead to personal injury. Usually an instruction will be given, together with a brief explanation and the possible result of ignoring the instruction.



A **Caution** identifies a hazard which could lead to damage to the machine, damage to other equipment and/or environmental pollution. Usually an instruction will be given, together with a brief explanation and the possible result of ignoring the instruction.



A **Note** is used to highlight additional information which may be helpful to you but where there are no special safety implications.

The contents of this manual include suggested best working practices and procedures. These are issued for guidance only, and they do not take precedence over the above stated individual responsibility and/or local safety regulations.

This manual and any other document supplied with the unit, are the property of YORK which reserves all rights. They may not be reproduced, in whole or in part, without prior written authorization from an authorized YORK representative.

MISUSE OF EQUIPMENT

Suitability for Application

The unit is intended for cooling water or glycol solutions and is not suitable for purposes other than those specified in these instructions. Any use of the equipment other than its intended use, or operation of the equipment contrary to the relevant procedures may result in injury to the operator, or damage to the equipment.

The unit must not be operated outside the design parameters specified in this manual.

Structural Support

Structural support of the unit must be provided as indicated in these instructions. Failure to provide proper support may result in injury to the operator, or damage to the equipment and/or building.

Mechanical Strength

The unit is not designed to withstand loads or stresses from adjacent equipment, pipework or structures. Additional components must not be mounted on the unit. Any such extraneous loads may cause structural failure and may result in injury to the operator, or damage to the equipment.

General Access

There are a number of areas and features which may be a hazard and potentially cause injury when working on the unit unless suitable safety precautions are taken. It is important to ensure access to the unit is restricted to suitably qualified persons who are familiar with the potential hazards and precautions necessary for safe operation and maintenance of equipment containing high temperatures, pressures and voltages.

Pressure Systems

The unit contains refrigerant vapor and liquid under pressure, release of which can be a danger and cause injury. The user should ensure that care is taken during installation, operation and maintenance to avoid damage to the pressure system. No attempt should be made to gain access to the component parts of the pressure system other than by suitably trained and qualified personnel.

Electrical

The unit must be grounded. No installation or maintenance work should be attempted on the electrical equipment with out first switching OFF, isolating and locking-off the power supply. Work on live equipment

must only be carried out by suitably trained and qualified personnel. No attempt should be made to gain access to the control panel or electrical enclosures during normal operation of the unit.

Rotating Parts

Fan guards must be fitted at all times and not removed unless the power supply has been isolated. If ductwork is to be fitted, requiring the wire fan guards to be removed, alternative safety measures must be taken to protect against the risk of injury from rotating fans.

Sharp Edges

The finning on the air cooled condenser coils has sharp metal edges. Reasonable care should be taken when working in contact with the coils to avoid the risk of minor abrasions and lacerations. The use of gloves is recommended.

Refrigerants and Oils

Refrigerants and oils used in the unit are generally non-toxic, non-flammable and non-corrosive, and pose no special safety hazards. Use of gloves and safety glasses are, however, recommended when working on

the unit. The build up of refrigerant vapor, from a leak for example, does pose a risk of asphyxiation in confined or enclosed spaces and attention should be given to good ventilation. For more comprehensive information on safety precautions for use of refrigerants and oils, refer to the Materials Safety Data tables provided on pages 10 through 13.

High Temperature and Pressure Cleaning

High temperature and pressure cleaning methods (e.g. steam cleaning) should not be used on any part of the pressure system as this may cause operation of the pressure relief device(s). Detergents and solvents which may cause corrosion should also be avoided.

EMERGENCY SHUTDOWN

In case of emergency the electrical option panel is fitted with an emergency stop switch CB3 (Circuit Breaker 3). Separate Circuit Breakers, CB1 (System 1) and CB2 (System 2), can also be used to stop the respective system in an emergency. When operated, it removes the electrical supply from the control system, thus shutting down the unit.

MATERIAL SAFETY DATA

REFRIGERANT DATA:

SAFETY DATA	R407C
Toxicity	Low.
In contact with skin	Liquid splashes or spray may cause freeze burns. Unlikely to be hazardous by skin absorption. Thaw affected areas with water. Remove contaminated clothing carefully – may adhere to skin in case of freeze burns. Wash affected areas with plenty of warm water. If symptoms occur (irritation or blistering) obtain medical attention.
In contact with eyes	Vapor has no effect. Liquid splashes or spray may cause freeze burns. Immediately irrigate with eyewash solution or clean water for at least 10 minutes. Obtain immediate medical attention.
Ingested	Highly unlikely to occur – but should this occur freeze burn will occur. Do not induce vomiting. Provided patient is conscious, wash mouth with water and give about 250 ml (0.5 pint) to drink. Obtain immediate medical attention.
Inhalation	High atmospheric concentrations may have an anaesthetic effect, including loss of consciousness. Very high exposures may cause an abnormal heart rhythm and prove suddenly fatal. At higher concentration there is a danger from asphyxiation due to reduced oxygen content of atmosphere. Remove patient to fresh air, keep warm and at rest. Administer oxygen if necessary. Apply artificial respiration if breathing has ceased or shows signs of failing. In event of cardiac arrest apply external cardiac massage. Obtain immediate medical attention.
Further medical	Symptomatic and supportive therapy is indicated. Cardiac sensitization has been described advice which may, in the presence of circulating catecholamines such as adrenaline, give rise to cardiac arrhythmia's and subsequent arrest following exposure to high concentrations.
Long-term exposure	A lifetime inhalation study in rats has shown that exposure to 50,000 ppm resulted in benign tumors of the testis. This is not considered to be of relevance to humans exposed to concentrations at or below the occupational exposure limit.
Occupational exposure limits	Recommended limit: 1000 ppm v/v - 8 hr TWA.
Stability	Not specified.
Conditions to avoid	Use in presence of naked flames, red hot surfaces and high moisture levels.
Hazardous reactions	May react violently with sodium, potassium, barium and other alkali and alkaline earth metals. Incompatible materials: Magnesium and alloys containing more than 2% magnesium.
Hazardous decomposition products	Halogen acids by thermal decomposition and hydrolysis.
General precautions	Avoid inhalation of high concentrations of vapors. Atmospheric concentrations should be minimized and kept as low as reasonably practicable below the occupational exposure limit. The vapor is heavier than air and collects at low level and in confined areas. Ventilate by extraction at lowest levels.
Respiratory protection	Where doubt exists on atmospheric concentration, HSE approved breathing apparatus should be worn. This should be self contained or of the long breather type.
Storage	Keep containers dry and in a cool place away from fire risk, direct sunlight, and all sources of heat such as radiators. Keep at temperatures not exceeding 45°C.
Protective clothing	Wear overalls, impervious gloves and goggles/face protection.
Spill/leak procedure	Ensure suitable personal protective clothing and respiratory protection is worn. Provided it is safe to do so, isolate the source of the leak. Allow small spillage's to evaporate provided there is suitable ventilation. Large spillages: Ventilate area. Contain spillage's with sand, earth or any suitable absorbent material. Prevent liquid from entering drains, sewers, basements and work pits since vapor may create a suffocating atmosphere.
Disposal	Best to recover and recycle. If this is not possible, destruction is to be in an approved facility which is equipped to absorb and neutralize acids and other toxic processing products.
Fire extinguishing data	Non-flammable at atmospheric conditions.
Containers	Fire exposed containers should be kept cool with water sprays. Containers may burst if over-heated.
Fire fighting protective equipment	Self contained breathing apparatus and protective clothing must be worn in fire conditions.

MATERIAL SAFETY DATA

1

REFRIGERANT OIL DATA:

SAFETY DATA	YORK "L" OIL
Classification	Non-hazardous
In contact with skin	Minimally irritating. No first aid necessary. Exercise reasonable personal cleanliness including cleansing exposed skin areas several times daily with soap and water. Launder soiled work clothes at least weekly.
In contact with eyes	Flush eyes with eyewash solution or clean water for 15 minutes and consult a physician.
Ingested	May cause nausea and diarrhea. Obtain immediate medical attention.
Inhalation	If oil mist is inhaled, remove to fresh air and consult a physician.
Occupational exposure limits	Not determined.
Stability	Stable but hygroscopic - store in sealed containers.
Conditions to avoid	Strong oxidizers, caustic or acid solutions, excessive heat. May degrade some paints and rubber materials.
Hazardous decomposition	Not fully, Analogous compounds evolve carbon monoxide, carbon dioxide and other unidentified fragments when burned. Burning may evolve irritating/noxious fumes.
Respiratory protection	Use in well ventilated areas - ventilate locally.
Protective clothing	Goggles or face shield should be worn. Gloves not necessary, but recommended, especially for prolonged exposure.
Spill / Leak procedure	Wear suitable protective equipment. Especially goggles. Stop source of spill. Use absorbent materials to soak up fluid (i.e. sand, sawdust and commercially available materials).
Disposal	Incinerate the oil and all associated wastes in an approved facility in accordance with local laws and regulations governing oily wastes.
Fire extinguishing data	Flash point over 300°C. Use dry chemical, carbon dioxide or foam. Spraying water on hot or burning liquid may cause frothing or splashing. If a leak or spill has not ignited use water spray to disperse the vapors and to provide protection for persons attempting to stop the leak.
Containers	Fire exposed containers should be kept cool with water sprays.
Fire fighting protective equipment	Self contained breathing apparatus should be worn in fire conditions.

MATERIAL SAFETY DATA

Section 1 – PRODUCT NAME AND INFORMATION

Product (Trade Name and Synonyms): YORK "L" Oil
Chemical Name: Ester
Chemical Family: Polyol Ester
Formula: Proprietary
CAS#: Proprietary

Section 2 – COMPONENTS AND HAZARD STATEMENT

This product is non-hazardous. The product contains no known carcinogens. No special warning labels are required under OSHA 29 CFR 1910.1200.

Section 3 – SAFE HANDLING AND STORAGE

Handling - Do not take internally. Avoid contact with skin, eyes, and clothing. Upon contact with skin, wash with soap and water. Flush eyes with water for 15 minutes and consult physician. Wash contaminated clothing before reuse.

Storage - Keep container tightly sealed when not in use. Product is hygroscopic. Storage under nitrogen highly recommended.

Section 4 – PHYSICAL DATA

Appearance:	Clear liquid, gray to yellow or light brown tint
Boiling Point:	> 650°F
Vapor Pressure:	<0.01 mmHg @ 20°C
Specific Gravity (water=1):	0.94-0.97
Volatiles, Percent by Volume:	0%
Odor:	Mild, distinct
Solubility in Water:	Negligible
Evaporation Rate (butyl acetate=1):	Nil

Section 5 – FIRE AND EXPLOSION HAZARDS

Flash Point (by Cleveland Open Cup):	230-300°C
Flammable Limits:	Not Established
Auto-Ignition Temperature:	no data
HMIS Ratings:	
Health:	0
Flammability:	1
Reactivity:	0
Extinguishing Media:	Dry chemical; CO ₂ foam; water fog (see below)
Unusual Fire and Explosion Hazards:	None
Special Fire Fighting Techniques:	Burning fluid may evolve irritating/noxious fumes. Firefighters should use NIOSH/MNSA-approved self-contained breathing apparatus. Use water fog to cool fire-exposed containers. USE WATER CAREFULLY NEAR EXPOSED/BURNING LIQUIDS. May cause frothing and splashing of hot materials.

Section 6 – REACTIVITY DATA

Stability: Stable

Hazardous Polymerization: Will not occur

Incompatible Materials: Strong oxidizers, caustic or acidic solutions

Conditions to Avoid: Excessive heat

Hazardous Decomposition Products: Analogous compounds evolve carbon monoxide, carbon dioxide, and other unidentified fragments when burned. See Section 5.

This product may degrade some paints and rubber materials.

Section 7 – HEALTH HAZARD DATA

Threshold Limit Value: Not established

Situations to Avoid: Avoid breathing oil mists

First Aid Procedures:

Ingestion: Consult physician at once. May cause nausea and diarrhea.

Inhalation: Product is not toxic by inhalation. If oil mist is inhaled, remove to fresh air and consult physician.

To the best of our knowledge, the toxicological properties of these compounds have not been fully investigated. Analogous compounds are considered to be essentially non-toxic.

Section 8 – PERSONAL PROTECTION INFORMATION

Respiratory Protection: Use in well ventilated area

Ventilation: Local exhaust

Protective Gloves: Strongly recommended, especially for prolonged exposure.

Eye/Face Protection: Goggles

Firefighters should use NIOSH/MNSA-approved self-contained breathing apparatus. Use water fog to cool fire-exposed containers. USE WATER CAREFULLY NEAR EXPOSED/BURNING LIQUIDS. May cause frothing and splashing of hot material.

Section 9 – SPILL OR LEAK PROCEDURES

In Case of Spill: Wear suitable protective equipment, especially goggles. Stop source of spill. Dike spill area. Use absorbent materials to soak up fluid (i.e. sand, sawdust, and commercially available materials). Wash spill area with large amounts of water. Properly dispose of all materials.

Section 10 – WASTE DISPOSAL METHODS

Incinerate this product and all associated wastes in a licensed facility in accordance with Federal, State, and local regulations.

The information in this material safety data sheet should be provided to all who use, handle, store, transport, or are otherwise exposed to this product. YORK believes the information in this document to be reliable and up to date as of the date of publication, but makes no guarantee that it is.

PRODUCT DESCRIPTION




FIG. 1 – COMPONENT LOCATIONS

INTRODUCTION

YORK YCAS chillers are designed for water or water-glycol cooling. All units are designed to be located outside on the roof of a building or at ground level.

The units are completely assembled with all interconnecting refrigerant piping and internal wiring, ready for field installation.

Prior to delivery, the unit is pressure tested, evacuated, and fully charged with refrigerant and oil in each of the two independent refrigerant circuits. After assembly, an operational test is performed with water flowing through the cooler to ensure that each refrigerant circuit operates correctly.

The unit structure is manufactured from heavy gauge, galvanized steel. All external structural parts are coated with “Desert Sand” baked-on enamel powder paint. This provides a finish which, when subjected to ASTM B117, 500 hour, 5% salt spray conditions, shows breakdown of less than 1/8” either side of a scribed line (equivalent to ASTM D1654 rating of “6”).

All exposed power wiring is to be routed through liquid-tight, non-metallic conduit.

General Description

The Air Cooled Screw Chiller utilizes many components which are the same or nearly the same as a standard reciprocating chiller of a similar size. This includes modular frame rails, condenser, fans and evaporator.

The chiller consists of 2 screw compressors in a corresponding number of separate refrigerant circuits, a single shell and tube DX counterflow evaporator, economizers, an air cooled condenser, and expansion valves.

Compressor


The semi-hermetic rotary twin-screw compressor is designed for industrial refrigeration applications and ensures high operational efficiencies and reliable performance. Capacity control is achieved through a single slide valve. The compressor is a positive displacement type characterized by two helically grooved rotors which are manufactured from forged steel. The 60 Hz motor operates at 3550 RPM to direct drive the male rotor which in turn drives the female rotor on a light film of oil.

Refrigerant gas is injected into the void created by the unmeshing of the five lobed male and seven lobed female rotor. Further meshing of the rotors closes the rotor threads to the suction port and progressively compresses the gas in an axial direction to the discharge port. The gas is compressed in volume and increased in pressure before exiting at a designed volume at the discharge end of the rotor casing. Since the intake and discharge cycles overlap, a resulting smooth flow of gas is maintained.

The rotors are housed in a cast iron compressor housing precision machined to provide optimal clearances for the rotors. Contact between the male and female rotor is primarily rolling on a contact band on each of the rotor's pitch circle. This results in virtually no rotor wear and increased reliability, a trademark of the screw compressor.

The compressor incorporates a complete anti-friction bearing design for reduced power input and increased reliability. Four separated, cylindrical, roller bearings handle radial loads. Angular-contact ball bearings handle axial loads. Together they maintain accurate rotor positioning at all pressure ratios, thereby minimizing leakage and maintaining efficiency. A springless check valve is installed in the compressor discharge housing to prevent compressor rotor backspin due to system refrigerant pressure gradients during shutdown.

Motor cooling is provided by suction gas from the evaporator flowing across the motor. Redundant overload protection is provided using both thermistor and current overload protection.



00485VIP

FIG. 2 – SCREW COMPRESSOR

The compressor is lubricated by removing oil from the refrigerant using an external oil separator. The pressurized oil is then cooled in the condenser coils and piped back to the compressor for lubrication. The compressor design working pressure is 450 PSIG (31 bar). Each chiller receives a 300 PSIG (21 bar) low side and a 450 PSIG (31 bar) high side factory test. A 350 watt (115-1-60) cartridge heater is located in the compressor. The heater is temperature activated to prevent refrigerant condensation.

The following items are also included:

- Internal discharge check valve to prevent rotor backspin or shutdown.
- An acoustically tuned, internal discharge muffler to minimize noise, while operating flow for maximum performance.
- Discharge and suction shutoff valves.
- A rain-tight terminal box.
- A suction gas screen and serviceable, 0.5 micron full flow oil filter within the compressor housing.

Evaporator

The system uses a high efficiency Shell and Tube type Direct Expansion Evaporator. Each of the 2 refrigerant circuits consists of 4 passes with the chilled liquid circulating back and forth across the tubes from one end to the other.

The design working pressure of the cooler on the shell side is 150 PSIG (10 bar), and 350 PSIG (24 bar) for the tube (refrigerant side). The water baffles are fabricated from galvanized steel to resist corrosion. Removable heads are provided for access to internally enhanced, seamless, copper tubes. Water vent and drain connections are included.

The cooler is equipped with a thermostatically controlled heater for protection to -20°F (-29°C) ambient and insulated with 3/4" (19 mm) flexible closed-cell foam.

The water nozzles are provided with grooves for mechanical couplings and should be insulated by the contractor after pipe installation.

Condenser

The fin and tube condenser coils are manufactured from seamless, internally enhanced, high condensing coefficient, corrosion resistant copper tubes arranged in stag-

gered rows and mechanically expanded into corrosion resistant aluminum alloy fins with full height fin collars. They have a design working pressure of 450 PSIG (31 bar). Each coil is rested to 495 PSIG (34 bar).

Multiple fans move air through the coils. They are dynamically and statically balanced, direct drive with corrosion resistant glass fiber reinforced composite blades molded into low noise, full airfoil cross section, providing vertical air discharge from extended orifices for efficiency and low sound. Each fan is located in a separate compartment to prevent cross flow during fan cycling. Guards of heavy gauge, PVC coated galvanized steel are provided.

The fan motors are high efficiency, direct drive, 6-pole, 3-phase, Class- "F," current overload protected, totally enclosed (TEAO) type with double sealed, permanently lubricated ball bearings.

Oil Separator/System

The external oil separator, with no moving parts and designed for minimum oil carry-over, is mounted in the discharge line of the compressor. The high pressure discharge gas is forced around a 90 degree bend. Oil is forced to the outside of the separator through centrifugal action and captured on wire mesh where it drains to the bottom of the oil separator and into the compressor.

The oil (YORK "L" oil – a POE oil used for all refrigerant applications), which drains back into the compressor through a replaceable 0.5 - 3.0 micron oil filter, and oil supply solenoid, is at high pressure. This high pressure "oil injection" forces the oil into the compressor where it is gravity fed to the gears and bearings for lubrication. After lubricating the gears and bearings, it is injected through orifices on a closed thread near the suction end of the rotors. The oil is automatically injected because of the pressure difference between the discharge pressure and the reduced pressure at the suction end of the rotors. This lubricates the rotors as well as provides an oil seal against leakage around the rotors to assure refrigerant compression (volumetric efficiency). The oil also provides cooling by transferring much of the heat of compression from the gas to the oil keeping discharge temperatures down and reducing the chance for oil breakdown. Oil injected into the rotor cage flows

into the rotors at a point about 1.2x suction. This assures that a required minimum differential of at least 30 PSID (2.1 bar) exists between discharge and 1.2x suction, to force oil into rotor case, a minimum of 10 PSID (0.6 bar) is all that is required to assure protection of the compressor. Oil pressure safety is monitored as the difference between suction and the pressure of the oil entering the rotor case.

Maximum working pressure of the oil separator is 450 PSIG (31 bar). A relief valve is installed in the oil separator piping. This will soon be incorporated into the oil separator. Oil level should be above the midpoint of the "lower" oil sight glass when the compressor is running. Oil level should not be above the top of the "upper" sight glass. Oil temperature control is provided through liquid injection activated by the microprocessor, utilizing a discharge temperature sensor, and a solenoid valve.

Oil Cooling

Oil cooling is provided by routing oil from the oil separator through several of the top rows of the condenser coils and back to the compressor.

Capacity Control

The compressors will start at the minimum load position and provide a capacity control range from 10% - 100% of the full unit load using a continuous function slide valve. The microprocessor modulates the current signal to a 3-way pressure regulating capacity control valve which controls command compressor capacity, independent of system pressures, and balances the compressor capacity with the cooling load. Loading is accomplished by varying pressure through the pressure regulating capacity control valve to move the slide valve against the spring pressure to promote stable smooth loading.

Automatic spring return of the slide valve to the minimum load position will ensure compressor starting at minimum motor load.

Power and Control Panel

All controls and motor starting equipment are factory wired and function tested. The panel enclosures are designed to IP55 and are manufactured from powder painted galvanized steel.

The Power and Control Panel are divided into power sections for each compressor and associated fans, a control section and an electrical options section. The power and control sections have separate hinged, latched, and gasket sealed doors equipped with wind struts.

Each power compartment contains:

Compressor and fan starting contactors, fan motor external overloads, control circuit serving compressor capacity control, compressor and fan contactor coils and compressor motor overloads.

The current transformers for the compressor motor overloads sense each phase, as an input to the microprocessor. This protects the compressor motors from damage due to: low current input, high input current, unbalanced current, single phasing, phase reversal, and compressor locked rotor.

The control section contains:

ON/OFF switch, microcomputer keypad and display, microprocessor board, I/O expansion board, relay boards and power supply board.

The options sections contain:

A control circuit transformer complete with service switch providing 115/1/60 Hz power to the unit control system.

Electrical options as described in “Accessories and Options.”

Microprocessor Controls

The microprocessor has the following functions and displays:

- A liquid crystal 40 character display with text provided on two lines and light emitting diode back-lighting outdoor viewing.
- A color coded, 35 button, sealed keypad with sections for Display, Entry, Setpoints, Clock, Print, Program and Unit ON/OFF.

The standard controls shall include: brine chilling, thermal storage, automatic pump down, run signal contacts, demand load limit from external building automation system input, remote reset liquid temperature reset input, unit alarm contacts, chilled liquid pump control, automatic reset after power failure, automatic system optimization to match operating conditions.

The software is stored in non-volatile memory (EPROM) to eliminate chiller failure due to AC power failure. The Programmed Setpoint is stored in lithium battery backed memory.

Motor Current Protection

The microprocessor motor protection provides high current protection to assure that the motor is not damaged due to voltage, excess refrigerant, or other problems that could cause excessive motor current. This is accomplished by sending 3-phase current signals proportional to motor current from the Motor Protector module to the Power Supply Board where the signals are conditioned and routed to the I/O Expansion board to be multiplexed and sent to the Microprocessor Board. If the motor current exceeds the 115% FLA trip point after 3 seconds of operation on either Wye-Delta or ACL starters, the micro will shut the system down and lock it out after one fault. A manual reset of the respective system switch is required to clear the fault and restart the system. A thorough check of the motor, wiring, and refrigerant system should be done before restarting a system that has faulted on high motor current.

The micro also provides low motor current protection when it senses a motor current less than 10% FLA. The micro will shut the system down whenever low motor current is sensed and will lock out a system if three faults occur in 90 minutes. Low motor current protection is activated 4 seconds after start on both Wye-Delta and ACL starters to assure the motor starts, the system doesn't run without refrigerant, the motor protector is not tripped, and the mechanical high pressure cut-out is not tripped. Once the system is locked out on Low Motor Current, it must be manually reset with the system switch. See also Motor Protection Module section below.

The micro senses low motor current whenever a HPCO or Motor Protector contact opens. This occurs because the MP and HPCO contacts are in series with the motor contactor. Whenever either of these devices are open, the contactor de-energizes and the motor shuts down. Since the micro is sending a run signal to the contactor, it senses the low motor current below 10% FLA and shuts the system down.

Motor Protection Module

The mechanical motor protector is a Texas Instruments 2ACE Three Phase Protection Module (Fig. 45, page 125) thermal and current motor overload protection. This module protects against phase to phase current imbalance, over current, under current, and phase rotation. The module, mounted in the power panel, utilizes a 7 segment display which provides operating status and fault diagnostic information. The 7 segment display will display either a stationary or a flashing alphanumeric value which can be decoded by the operator. A list of the codes follows:

HAXXX	Normal motor OFF display. Sequentially sweeps through the motor protection dip switch setting.
0	Normal - no fault detected (Running)
Flashing "0"	Motor off or unloaded < 5A (Running) AC current level.
1	High current fault.
2	Loaded phase to phase current imbalance $\geq 17\%$.
3	Unloaded phase to phase current imbalance $\geq 25\%$.
4	Improper incoming phase rotation.
5	High motor temperature. Trip point = 13kW, reset = 3.25kW.
6	Communication error.
7	Unload imbalance ($\geq 50\%$)
8	Phase Loss ($> 60\%$)
E	Out of range of RLA calibration.
Other symbols	Defective module or supply voltage.
Working voltage 18 - 30 VAC, 224 VAC nominal.	
Low voltage trip = 15 VAC.	

Whenever a motor protector trips, the motor protector contacts wired in series with the motor contacts opens and the motor contactor de-energizes allowing the motor to stop. The micro senses the low motor current and shuts the system down. The micro will try two more starts before locking the system out. The system locks out because the motor protector is a manual reset device. After the first start the modules' contacts

will be open preventing the motor contactors from energizing. Power must be removed and reapplied to reset the module.


Current Overload

The 2ACE module design uses one integral current transformer per phase to provide protection against rapid current overload conditions. The module responds to changes in current and must be calibrated using DIP switches located on the module. Integral trip curves allow for in-rush currents during Wye-Delta, part wind, or ACL starts without nuisance tripping.

To check the factory setting of the 2ACE module current overload trip value. See Table 1 (pages 20 and 21).

For the location of the dip switches and determining the ON position refer to the "Note" below and Figure 45.


For the location of the dip switches and determining the ON side of the switches, refer to Figure 45, page 125. As indicated, to place a switch in the ON position requires pushing the switch to the left.



A switch must be pushed to the left to place the switch in the ON position.



It is recommended that an YORK Service Technician or the YORK factory be consulted before changing these settings for any reason, since damage to the compressor could result. Changes should never be made unless it is verified that the settings are incorrect.



Anytime a dip switch change is made, power must be cycled off and on to the module to reprogram the module to the new valve.

Thermal Overload

Three PTC (positive temperature coefficient) thermistors in the motor windings of each phase provides thermal protection. The sensor resistance stays relatively constant at $1k\Omega$ until a temperature of 266°F (130°C) is sensed. The sensor experiences a rapid rise in resistance beyond this temperature. Whenever the resistance of one of the sensors reaches $13k\Omega$, the 2ACE module trips, which ultimately de-energizes the motor's pilot circuit. Reset is manual after the motor cools and the sensor resistance drops to $3.25k\Omega$.

Current Imbalance (Loaded & Unloaded)/

Loss of Phase

A 2 second delay at start-up allows for any imbalances resulting during normal starting conditions. After this initial delay, the 2ACE module compares the "Operating Current" to the measured half line current. The "Operating Current" is given by $0.65 \times$ factory overload current setting.

An *unloaded compressor condition* occurs when any measured half line current is less than the "Operating

Current." A current imbalance exceeding an unloaded level of 25% will result in the motor pilot circuit being de-energized.

A *loaded compressor condition* occurs when any measured half line current is greater than or equal to the "Operating Current." A current imbalance exceeding a loaded level of 17% will result in the motor pilot circuit being de-energized.

Imbalance is defined as

$(\text{High Phase} - \text{Low Phase}) / \text{High Phase}$

Improper Phase Sequence

The 2ACE module calculates the phase sequence at start-up using the three current transformers to determine whether the three phase sequence on the load side of the main contactor is miswired. Upon detection of a miswired motor load, the module will de-energize the main contactor pilot circuit within 50 millisecond response time.

TABLE 1 – MOTOR PROTECTOR DIP SWITCH SETTING

YCAS STYLE F, ACROSS-THE-LINE – 60 HZ												
MODEL NO.	VOLT CODE	CHILLER NAMEPLATE RLA	NO. LEADS PER PHASE SET	MOTOR PROTECTOR								
				MP OL VALUE 128	DIP SWITCH SETTINGS ON MP ("1" INDICATED ON)							
					64	32	16	8	4	2	1	
0098	17	168	*2	113	0	1	1	1	0	0	0	1
	28	146	2	197	1	1	0	0	0	1	0	1
	40	89	1	120	0	1	1	1	1	0	0	0
	46	73	1	99	0	1	1	0	0	0	1	1
	58	59	1	80	0	1	0	1	0	0	0	0
0118 SYS 1	17	255	*2	172	1	0	1	0	1	1	0	0
	28	222	*2	150	1	0	0	1	0	1	1	0
	40	134	2	181	1	0	1	1	0	1	0	1
	46	111	1	150	1	0	0	1	0	1	1	0
	58	90	1	122	0	1	1	1	1	0	1	0
0118 SYS 2.	17	168	*2	113	0	1	1	1	0	0	0	1
	28	146	2	197	1	1	0	0	0	1	0	1
	40	88	1	119	0	1	1	1	0	1	1	1
	46	73	1	99	0	1	1	0	0	0	1	1
	58	59	1	80	0	1	0	1	0	0	0	0
0128 SYS 1	17	233	*2	157	1	0	0	1	1	1	0	1
	28	203	*2	137	1	0	0	0	1	0	0	1
	40	122	1	165	1	0	1	0	0	1	0	1
	46	101	1	136	1	0	0	0	1	0	0	0
	58	81	1	109	0	1	1	0	1	1	0	1
0128 SYS 2	17	159	2	215	1	1	0	1	0	1	1	1
	28	139	2	188	1	0	1	1	1	1	0	0
	40	84	1	113	0	1	1	1	0	0	0	1
	46	69	1	93	0	1	0	1	1	1	0	1
	58	56	1	0	1	0	0	1	1	0	0	
0138	17	232	*2	157	1	0	0	1	1	1	0	1
	28	202	*2	136	1	0	0	0	1	0	0	0
	40	122	1	165	1	0	1	0	0	1	0	1
	46	101	1	136	1	0	0	0	1	0	0	0
	58	81	1	109	0	1	1	0	1	1	0	1
0148	17	233	*2	157	1	0	0	1	1	1	0	1
	28	203	*2	137	1	0	0	0	1	0	0	1
	40	122	1	165	1	0	1	0	0	1	0	1
	46	101	1	136	1	0	0	0	1	0	0	0
	58	81	1	109	0	1	1	0	1	1	0	1

* Indicates one lead/phase through motor protector.

TABLE 1 – MOTOR PROTECTOR DIP SWITCH SETTING (CONT'D)

YCAS STYLE F, WYE-DELTA START– 60 HZ												
MODEL NO.	VOLT CODE	CHILLER NAMEPLATE RLA	NO. LEADS PER PHASE SET	MOTOR PROTECTOR								
				MP OL VALUE 128	DIP SWITCH SETTINGS ON MP ("1" INDICATED ON)							
					64	32	16	8	4	2	1	
0158 SYS 1	17	320	*4	108	0	1	1	0	1	1	0	0
	28	278	*2	188	1	0	1	1	1	1	0	0
	40	168	*2	113	0	1	1	1	0	0	0	1
	46	140	2	189	1	0	1	1	1	1	0	1
	58	111	1	150	1	0	0	1	0	1	1	0
0158 SYS 2.	17	233	*2	157	1	0	0	0	1	1	0	1
	28	203	*2	137	1	0	0	0	1	0	0	1
	40	122	1	165	1	0	1	0	0	1	0	1
	46	101	1	136	1	0	0	0	1	0	0	0
	58	81	1	109	0	1	1	0	1	1	0	1
0178	17	320	*4	108	0	1	1	0	1	1	0	0
	28	278	*2	188	1	0	1	1	1	1	0	0
	40	169	*2	114	0	1	1	1	0	0	1	0
	46	140	2	189	1	0	1	1	1	1	0	1
	58	111	1	150	1	0	0	1	0	1	1	0
0198 SYS 1.	17	375	*4	127	0	1	1	1	1	1	1	1
	28	327	*4	110	0	1	1	0	1	1	1	0
	40	198	*2	134	1	0	0	0	0	1	1	0
	46	164	2	221	1	1	0	1	1	1	0	1
	58	131	2	177	1	0	1	1	0	0	0	1
0198 SYS 2.	17	297	*2	200	1	1	0	0	1	0	0	0
	28	258	*2	174	1	0	1	0	1	1	1	0
	40	156	2	211	1	1	0	1	0	0	1	1
	46	129	2	174	1	0	1	0	1	1	1	0
	58	103	1	139	1	0	0	0	0	0	1	1
0208	17	376	*4	127	0	1	1	1	1	1	1	1
	28	326	*4	110	0	1	1	0	1	1	1	0
	40	198	*2	134	1	0	0	0	0	1	1	0
	46	164	2	221	1	1	0	1	1	1	0	1
	58	131	2	177	1	0	1	1	0	0	0	1

* Indicates one lead/phase through motor protector

MOTOR STARTING

Two types of compressor motor starting are available: Across-the-Line and optional Wye-Delta Open Transition Starter.

Across-the-Line starters will utilize one contactor and one start relay per compressor. The optional Wye-Delta starter utilizes 4 motor contactors, a transition delay relay, a start relay, and a start-wye relay.


The Wye-Delta start allows inrush current to be limited to approximately 33% LRA for the first 4 to 10 seconds, with current increasing to normal running current when the Delta connection is completed.

When the micro initiates a start signal at Relay Output Board #1 (SYS 1) Terminal 20 or Relay Output Board #2 (SYS 2) Terminal 20 to run a compressor, the 1CR (SYS 1) or 2CR (SYS 2) relay is energized. The transition of the 1CR (SYS 1) or 2CR (SYS 2) relay contacts energizes the 1S (SYS 1) or 2S (SYS 2) relay approx. 16ms later. The 1S/2S contacts in turn energize the 1M (SYS 1) or 3M (SYS 2) motor contacts 16ms later. This completes the “WYE” connection of the motor start. At the same time, the normally closed 1S/2S auxiliary interlock contact opens preventing the 2M (SYS 1) or 4M (SYS 2) motor contactors from energizing. Auxiliary contacts from 1M (SYS 1) or 3M (SYS 2) close, interlocking the 1M (SYS 1) or 3M (SYS 2) contactors, keeping them energized in parallel with 1S (SYS 1) or 2S (SYS 2).

The “WYE” connection of the motor start is enabled for 4 to 10 seconds depending upon motor current as sensed by the microprocessor. Normally, the transition to Delta takes 10 seconds if current is below 125% FLA. If motor current exceeds 125% FLA, the transition is made to Delta as long as the WYE has been enabled for at least 4 seconds.

After the “WYE” connection is enabled for 4 to 10 seconds, the 1TR (SYS 1) or 2TR (SYS 2) transition delay relay is enabled by the microprocessor from Relay Output Board #1 Terminal 8 (SYS 1) or Relay Output Board #2 Terminal 6 (SYS 2). The 1TR (SYS 1) or 2TR (SYS 2) contacts open, de-energizing 1S (SYS 1) or 2S (SYS 2). 1M (SYS 1) or 3M (SYS 2) remain energized through interlocking contacts 1M (SYS 1) or 3M (SYS 2). Opening of the 1TR (SYS 1) or 2TR (SYS 2) contacts deenergizes 1S/2S and closes the normally closed 1S (SYS 1) or 2S (SYS 2) contacts, energizing motor

contactor 2M (SYS 1) or 4M (SYS 2), completing the “DELTA” connection of the motor.



1 TR and 2TR are NOT “timing” relays. These devices are simply pilot relays identical to 1CR and 2CR.

KEYPAD CONTROLS

Display

Parameters are displayed in English (°F and PSIG) or Metric (°C and Bars) units, and for each circuit, the following items can be displayed:

- Return and leaving chilled liquid, and ambient temperature.
- Day, date and time. Daily start/stop times. Holiday and Manual Override status.
- Compressor operating hours and starts. Automatic or manual lead/lag. Lead compressor identification.
- Run permissive status. No cooling load condition. Compressor run status.
- Anti-recycle timer and anti-coincident start timer status per compressor.
- System suction (and suction superheat), discharge, and oil pressures and temperatures.
- Percent full load compressor motor current per phase and average per phase. Compressor capacity control valve input steps.
- Cutout status and setpoints for: supply fluid temperature, low suction pressure, high discharge pressure and temperature, high oil temperature, low and high ambient, phase rotation safety, and low leaving liquid temperature.
- Unloading limit setpoints for high discharge pressure and compressor motor current.
- Liquid pull-down rate sensitivity (0.5°F to 5°F [0.3°C to 2.8°C] /minute in 0.1° increments).
- Status of: evaporator heater, condenser fans, load and unload timers, chilled water pump.
- “Out of range” message.
- Up to 6 fault shut down conditions.

The standard display language is English, with 4 other languages available.

Entry – Used to confirm Set Point changes, cancel inputs, advance day, and change AM/PM.

Setpoints – For setting chilled liquid temperature, chilled liquid range, remote reset temperature range.

Clock – Used to set time, daily or holiday start/stop schedule and manual override for servicing.

Print – Used to display or print operating data or system fault shutdown history for last six faults. Printouts through an RS-232 port via a separate printer.

Program

For setting low leaving liquid temperature cutout, 300 to 600 second anti-recycle timer, average motor current unload point, liquid temperature setpoint reset signal from YORK ISN or building automation system.

Additional functions (password protected) for programming by a qualified service technician:

Cutouts for low and high ambient, low suction pressure and high discharge pressure, refrigerant type, high discharge pressure unload setpoint.

ACCESSORIES AND OPTIONS

Multiple Point Power Connection (Standard)

Standard field power wiring connection on all models is Multiple Point Power Connection. Field provided power supply circuits, with appropriate branch circuit protection, are connected to factory provided terminal blocks, non-fused disconnect switches or circuit breakers with lockable external handles located in the two power compartments.

Single-Point Power Connection with Individual Circuit Protection

A single-point supply circuit with field provided protection is connected to a factory provided terminal block or non-fused disconnect switch located in the options compartment. Factory wiring is provided from the terminal block or disconnect switch to factory supplied internal branch circuit breakers with lockable external handles in the power compartments.

Single-Point Power Connection with Combined Circuit Protection

A single-point supply circuit with field provided protection is connected to a factory provided circuit breaker with lockable external handle located in the options compartment. Factory wiring is provided from the circuit breaker to factory supplied terminal blocks in the power compartments.

Single-Point Power Connection without Circuit Protection

A single-point supply circuit with field provided protection is connected to a factory provided terminal block or non-fused disconnect switch located in the options compartment. Factory wiring is provided from the terminal block or disconnect switch to factory supplied terminal blocks in the power compartments.

Control Circuit Terminal Block

A 120V, 20A control circuit power terminal strip located in the control panel to accept a field provided control power supply, rather than the standard factory mounted control circuit transformer. The supply with appropriate branch circuit protection in accordance with applicable Local codes, provides the unit control circuit power supply via the panel mounted Emergency Stop Switch.

Building Automation System (BAS) Interface

Provides a means to reset the leaving chilled liquid temperature or percent full load amps (current limiting) from the BAS (Factory-mounted):

Printed circuit board to accept 4 to 20mA, 0 to 10VDC, or dry contact closure input from the BAS.

A YORK ISN Building Automation System can provide a Pulse Width Modulated (PWM) signal direct to the standard control panel via the standard on-board RS485 port.

Condenser Coil Protection

The standard condenser coils have Aluminum fins, copper tubes, and galvanized steel supports for generally adequate corrosion resistance. However, these materials are not adequate for all environments.

The following options provide added protection:

Black fin condenser coils – Condenser coils constructed using black epoxy coated Aluminum fin stock for corrosion resistance comparable to copper fin coils in typical seashore locations.

Copper fin condenser coils – Coils constructed with corrosion resistant copper fins. Not recommended in areas where units may be exposed to acid rain.

Phenolic coated condenser coils – Completed condenser coil assemblies are covered with a cured Phenolic coating. Probably the most suitable selection for seashore locations where salt spray may come into contact with the fins, and other corrosive applications except: strong alkalis, oxidizers, and wet bromine, chlorine, and fluorine in concentrations greater than 100 PPM.

DX COOLER OPTIONS

300 PSIG (21 bar) Waterside Design Working Pressure – The DX cooler waterside is designed and constructed for 300 PSIG (21 bar) working pressure. (Factory-mounted)

1-1/2" (38 mm) Insulation – Double thickness insulation provided for enhanced efficiency.

Flange Accessory – Consists of raised face flanges to convert grooved water nozzles to flanged cooler connections. Includes companion flanges for field-mounting.

Remote DX Cooler – Includes the main condensing unit less the cooler, refrigerant and liquid line devices. The insulated cooler and field accessory kits per refrigerant circuit are supplied separately. The condensing unit is shipped with an R-22 holding charge and the cooler is shipped with a nitrogen holding charge.

Flow Switch Accessory – Johnson Controls model F61MG-1C Vapor-proof SPDT, NEMA 4X switch, 150 PSIG (10 bar) DWP, -20°F to 250°F (-29°C to 121°C), with 1" NPT (IPS) connection for upright mounting in horizontal pipe. A flow switch must be field installed with each unit.

Star-Delta Compressor Motor Starter – Provides approximately 65% reduced inrush current compared to across-the-line start (Factory-mounted).

UNIT ENCLOSURES

Wire enclosure – Heavy gauge welded wire mesh guards mounted on the exterior of the unit (Factory- or field-mounted).

Louvered panels and wired guards – Louvered panels mounted over the exterior condenser coil faces, and heavy gauge welded wire mesh guards mounted around the bottom of the unit (Factory- or field-mounted).

Louvered panels (condenser coils only) – Louvered panels are mounted over the exterior condenser coil faces on the sides of the unit to visually screen and protect the coils (Factory- or field-mounted).

Louvered panels (full unit) enclosure – Louvered panels over condenser coils and around the bottom of the unit (Factory- or field-mounted).

FANS

High static fans: Fans and motors suitable for High External Static conditions to 100 Pa.

SOUND REDUCTION OPTIONS

Low speed fans – Reduced RPM fan motors and alternative fan selection for low noise applications.

Compressor sound enclosures – Acoustically treated metal compressor enclosures. Includes a compressor mounted temperature transducer to prevent overheating.

VIBRATION ISOLATION

Neoprene pad isolation – Recommended for normal installations. (Field-mounted)

1" (25 mm) spring isolators – Level adjustable, spring and cage type isolators for mounting under the unit base rails (Field-mounted).

2" (51 mm) seismic spring isolators – Restrained Spring-Flex Mountings incorporate welded steel housing with vertical and horizontal limit stops. Housings designed to withstand a minimum 1.0 g accelerated force in all directions to 2" (51 mm). Level adjustable, deflection may vary slightly by application. (Field-mounted).

UNIT NOMENCLATURE
NAMEPLATE ENGINEERING DATA

BASIC PART NUMBER

YCAS0158EB40YFA

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
BASE PRODUCT TYPE				NOMINAL CAPACITY				UNIT DESIGNATOR	REFRIGERANT	VOLTAGE/STARTER		DESIGN/DEVELOPMENT LEVEL		
Y	C	A	S	#	#	#	#	E	B	+	8	+	F	A
								High Efficiency	R-22	2	8	.200 / 3/ 60		Design Series F
									R-407C	4	0	.230 / 3/ 60		Engineering Change
										4	6	.380 / 3/ 60		or PIN Level
										8		.460 / 3/ 60		
									5			.575 / 3/ 60		
								Y				Wye (Star) Delta		
												X		Across the Line

UNIT NOMENCLATURE
NAMEPLATE ENGINEERING DATA

OPTIONS SECTION OF PART NUMBER

16 17 18 19	20 21 22 23 24 25 26 27 28	29 30 31 32 33 34 35 36
37 POWER FIELD FIELD : MP NF Disconnect Switches : MP Supply w/ Ind. Sys. Brkr & L. Ext. Handles : SP Supply TB w/ Ind. Sys. Brkr. & L. Ext. Handles : SP NF Discont. w/ Ind. Sys. Brkr & L. Ext. Handles : SP Supply TB : SP NF Disconnect Switch : SP Circuit Breaker w/ Lockable Handle : Control Circuit Power Terminal Strip : No Option C X	CONTROLS FIELD X Y C B M S F G X L C X P R S	COMPRESSOR/ PIPING : Low Temp Brine (LBrt) : Thermal Storage : Chicago Relief Code : Mechanical Gauge Kit # T S C G

MP = Multiple Point
SP = Single Point
NF = Non-Fused
TB = Terminal Block
Ser. = Service
Ind. Sys. Brkr. & L. Ext. Handles = Individual System Breaker & Lockable External Handle

38 39 40 41 42 43 44	45 46 47	48 49 50 51 52 53 54
EVAP. FIELD 3 D W V S M A S F T I P R X	CONDENSER FIELD X C B P X : Aluminum : Copper : BlackFin : Phenolic : TEAO Fan Motors : Multinat'l Vessel & Assoc. Safety Codes : ASME Pressure Vessel & Associated Codes (American) : AS 1210 Vessel & Associated Codes (Australian) : French Vessel & Associated Codes (DRIRE) : German TUV Vessel & Associated Codes (A. D. Merkblatter) : Italian Vessel & Associated Codes (ISPESL) : Polish Vessel & Associated Codes : Remote DX Cooler : No Option	CABINET FIELD 1 2 3 4 5 6 7 8 : Wire (Full Unit) Enc. Panels (factory) : Wire (Full Unit) Enc. Panels (field) : Wire/Louvered Enc. Panels (factory) : Wire/Louvered Enc. Panels (field) : Louvered (Cond. Only) Enc. Panels (factory) : Louvered (Cond. Only) Enc. Panels (field) : Louvered (Full Unit) Enc. Panels (factory) : Louvered (Full Unit) Enc. Panels (field) : Compressor Sound Enclosure : No Option : Acoustic Sound Blanket : Low Sound Fans : High Static Fans : Final Overspray Paint 1 : 1" Deflection S : Seismic N : Neoprene Pads

NOTES:
1. Q :DENOTES SPECIAL / S.Q.
2. # :DENOTES STANDARD
3. X :w/in OPTIONS FIELD, DENOTES NO OPTION SELECTED

HANDLING AND STORAGE

DELIVERY AND STORAGE

To ensure consistent quality and maximum reliability, all units are tested and inspected before leaving the factory. Units are shipped completely assembled and containing refrigerant under pressure. Units are shipped without export crating unless this has been specified on the Sales Order.

If the unit is to be put into storage, prior to installation, the following precautions should be observed:

- **Unit must be “blocked” so that the base is not permitted to sag or bow.**
- Ensure that all openings, such as water connections, are securely capped.
- Do not store where exposed to ambient air temperatures exceeding 110°F (43°C).
- The condensers should be covered to protect the fins from potential damage and corrosion, particularly where building work is in progress.
- The unit should be stored in a location where there is minimal activity in order to limit the risk of accidental physical damage.
- To prevent inadvertent operation of the pressure relief devices the unit must not be steam cleaned.
- It is recommended that the control panel keys are removed and deposited with a responsible person on-site.
- It is recommended that the unit is periodically inspected during storage.

INSPECTION

Remove any transit packing and inspect the unit to ensure that all components have been delivered and that no damage has occurred during transit. If any damage is evident, it should be noted on the carrier's freight bill and a claim entered in accordance with the instructions given on the advice note.

Major damage must be reported immediately to your local YORK representative.

MOVING THE CHILLER

Prior to moving the unit, ensure that the installation site is suitable for installing the unit and is capable of supporting the weight of the unit and all associated services.

The units are designed to be lifted using cables. A spreader bar or frame 88” (2250 mm) wide should be used in order to prevent damage to the unit from the lifting chains (See Figures 3 and 4).

Units are provided with lifting eyes extending from the sides of the base frame which can be attached to directly using shackles or safety hooks (See Figure 4).


The unit must only be lifted by the base frame at the points provided. Never move the unit on rollers, or lift the unit using a forklift truck.

Care should be taken to avoid damaging the condenser cooling fins when moving the unit.

Lifting Weights


For details of weights and weight distribution refer to the Technical Data Section.

UNIT RIGGING



LD03514A

FIG. 3 – UNIT RIGGING



LD03515

FIG. 4 – LIFTING LUGS

INSTALLATION

LOCATION REQUIREMENTS

To achieve optimum performance and trouble-free service, it is essential that the proposed installation site meets with the location and space requirements for the model being installed. For dimensions, weight and space requirements, including service access details, refer to the Technical Data Section.

It is important to ensure that the minimum service access space is maintained for cleaning and maintenance purposes.

OUTDOOR INSTALLATIONS

The units can be installed at ground level, or on a suitable rooftop location. In both cases an adequate supply of air is required. Avoid locations where the sound output and air discharge from the unit may be objectionable.

The location should be selected for minimum sun exposure and away from boiler flues and other sources of airborne chemicals that could attack the condenser coils and steel parts of the unit.

If located in an area which is accessible to unauthorized persons, steps must be taken to prevent access to the unit by means of a protective fence. This will help to prevent the possibility of vandalism, accidental damage, or possible harm caused by unauthorized removal of protective guards or opening panels to expose rotating or high voltage components.

For ground level locations, the unit must be installed on a suitable flat and level concrete base that extends to fully support the two side channels of the unit base frame. A one-piece concrete slab, with footings extending below the frost line is recommended. To avoid noise and vibration transmission the unit should not be secured to the building foundation.

On rooftop locations, choose a place with adequate structural strength to safely support the entire operating weight of the unit and service personnel. The unit can be mounted on a concrete slab, similar to ground floor locations, or on steel channels of suitable strength. The channels should be spaced at the same centres as the vibration mounting holes in the unit base frame and must

be at least 4-3/4" (120 mm) wide at the contact points. This will allow vibration isolators to be fitted if required.

Any ductwork or attenuators fitted to the unit must not have a total static pressure resistance, at full unit airflow, exceeding the capability of the fans installed in the unit.

INDOOR INSTALLATIONS

The unit can be installed in an enclosed plant room providing the floor is level and of suitable strength to support the full operating weight of the unit. It is essential that there is adequate clearance for airflow to the unit. The discharge air from the top of the unit must be ducted away to prevent recirculation of air within the plant room. If common ducts are used for fans, non-return dampers must be fitted to the outlet from each fan.

The discharge ducting must be properly sized with a total static pressure loss, together with any intake static pressure loss, less than the available static pressure capability for the type of fan fitted.

The discharge air duct usually rejects outside the building through a louver. The outlet must be positioned to prevent the air being drawn directly back into the air intake for the condenser coils, as such recirculation will affect unit performance.

LOCATION CLEARANCES

Adequate clearances around the unit(s) are required for the unrestricted airflow for the air-cooled condenser coils and to prevent recirculation of warm discharge air back onto the coils. If clearances given are not maintained, airflow restriction or recirculation will cause a loss of unit performance, an increase in power consumption and may cause the unit to malfunction. Consideration should also be given to the possibility of down drafts, caused by adjacent buildings, which may cause recirculation or uneven unit airflow.

For locations where significant cross winds are expected, such as exposed roof tops, an enclosure of solid or louver type is recommended to prevent wind turbulence interfering with the unit airflow.

When units are installed in an enclosure, the enclosure height should not exceed the height of the unit on more than one side. If the enclosure is of louvered construction the same requirement of static pressure loss applies as for ducts and attenuators stated above.

Where accumulation of snow is likely, additional height must be provided under the unit to ensure normal airflow to the unit.



The clearance dimensions given are necessary to maintain good airflow and ensure correct unit operation. It is also necessary to consider access requirements for safe operation and maintenance of the unit and power and control panels. Local health and safety regulations, or practical considerations for service replacement of large components, may require larger clearances than those given in the Technical Data Section, (page 96).

INSTALLATION OF VIBRATION ISOLATORS


Optional sets of vibration isolators can be supplied loose with each unit.

Using the Isolator tables, refer to the Technical Data Section (pages 97 - 106), identify each mount and its correct location on the unit.

Installation

Place each mount in its correct position and lower the unit carefully onto the mounts ensuring the mount engages in the mounting holes in the unit base frame.

On adjustable mounts, transfer the unit weight evenly to the springs by turning the mount adjusting nuts (located just below the top plate of the mount) counter-clockwise to raise and clockwise to lower. This should be done two turns at a time until the top plates of all mounts are between 1/4" and 1/2" (6 and 12 mm) clear of top of their housing and the unit base is level.



A more detailed installation instruction is provided on page 106.


SHIPPING BRACES

The chiller's modular design does not require shipping braces.

PIPEWORK CONNECTION

General Requirements

The following piping recommendations are intended to ensure satisfactory operation of the unit(s). Failure to follow these recommendations could cause damage to the unit, or loss of performance, and may invalidate the warranty.



The maximum flow rate and pressure drop for the cooler must not be exceeded at any time. Refer to the Technical Data Section for details.

The liquid must enter the cooler by the inlet connection. The inlet connection for the cooler is at the far end of the unit when viewed from the power and control panels.

A flow switch must be installed in the customer pipework at the outlet of the cooler and wired back to the control panel using shielded cable. There should be a straight run of piping of at least 5 pipe diameters on either side. The flow switch should be wired to Terminals 13 and 14 (see Figs. 12 and 13, pages 39 and 40). A flow switch is required prevent damage to the cooler caused by the unit operating without adequate liquid flow.

The flow switch used must have gold plated contacts for low voltage/current operation. Paddle type flow switches suitable for 150 PSIG (10 bar) working pressure and having a 1" N.P.T. connection can be obtained from YORK as an accessory for the unit. Alternatively a differential pressure switch sited across an orifice plate may be used, preferably of the high/low limit type.

The chilled liquid pump(s) installed in the pipework system(s) should discharge directly into the unit cooler section of the system. The pump(s) may be controlled external to the unit - but an override must be wired to the control panel so that the unit can start the pump in the event that the liquid temperature falls below the minimum setting. For details refer to "Electrical Connection."

Pipework and fittings must be separately supported to prevent any loading on the cooler. Flexible connections are recommended which will also minimize transmission of vibrations to the building. Flexible connections must be used if the unit is mounted on anti-vibration mounts as some movement of the unit can be expected in normal operation.

Pipework and fittings immediately next to the cooler should be readily de-mountable to enable cleaning before operation, and to facilitate visual inspection of the exchanger nozzles.

The cooler must be protected by a strainer, preferably of 30 mesh, fitted as close as possible to the liquid inlet connection, and provided with a means of local isolation.

The cooler must not be exposed to flushing velocities or debris released during flushing. It is recommended that a suitably sized by-pass and valve arrangement is installed to allow flushing of the pipework system. The by-pass can be used during maintenance to isolate the heat exchanger without disrupting flow to other units.

Thermometer and pressure gauge connections should be provided on the inlet and outlet connections of each cooler.

Drain and air vent connections should be provided at all low and high points in the pipework to permit drainage of the system and to vent any air in the pipes.

Liquid systems at risk of freezing, due to low ambient temperatures, should be protected using insulation and heater tape and/or a suitable glycol solution. The liquid pump(s) must also be used to ensure liquid is circulated when the ambient temperature approaches freezing point. Insulation should also be installed around the cooler nozzles. Heater tape of 21 watts per meter under the insulation is recommended, supplied independently and controlled by an ambient temperature thermostat set to switch on at 37°F (21°C) above the freezing temperature of the liquid.

The liquid circulation pump must be controlled by the unit. This will ensure that when the liquid temperature falls within 3° or 5°F (2° or 3°C) of freezing the pump will start.

The cooler is protected by heater mats under the insulation which are supplied from the unit control system power supply. During risk of freezing the control system should be left switched on to provide the freeze protection function unless the liquid systems have been drained.



Any debris left in the water pipework between the strainer and cooler could cause serious damage to the tubes in the cooler and must be avoided. The installer/user must also ensure that the quality of the water in circulation is adequate, without any dissolved gases which can cause oxidation of steel parts within the cooler.

WATER TREATMENT

The unit performance given in the Design Guide is based on a fouling factor of 0.00025 ft²hr°F/Btu (0.044m²/hr °C/kW). Dirt, scale, grease and certain types of water treatment will adversely affect the heat exchanger surfaces and therefore unit performance. Foreign matter in the water system(s) can increase the heat exchanger pressure drop, reducing the flow rate and causing potential damage to the heat exchanger tubes.

Aerated, brackish or salt water is not recommended for use in the water system(s). YORK recommends that a water treatment specialist is consulted to determine that the proposed water composition will not affect the evaporator materials of carbon steel and copper. The pH value of the water flowing through the cooler must be kept between 7 and 8.5.




FIG. 5 – PIPEWORK ARRANGEMENT

PIPEWORK ARRANGEMENT


The following is a suggested pipework arrangement for single unit installations. For multiple unit installations, each unit should be piped as shown.

CONNECTION TYPES & SIZES

For connection sizes relevant to individual models refer to the Technical Data Section.

COOLER CONNECTIONS

Standard chilled liquid connections on all coolers are of the Victaulic Groove type.




LD03521


FIG. 6 – VICTAULIC GROOVE

Option Flanges

One of two types of flanges may be fitted depending on the customer or local Pressure Vessel Code requirements. These are Victaulic-Adapter flanges, normally supplied loose, or weld flanges which may be supplied loose or ready fitted. Victaulic-Adapter and weld flange dimensions are to ISO 7005 - NP10.



Weld Flange



Victaulic Adapter

LD03523

FIG. 7 – FLANGE ATTACHMENTS

REFRIGERANT RELIEF VALVE PIPING

Coolers and oil separators are each protected against internal refrigerant overpressure by refrigerant relief valves. For coolers, a pressure relief valve is mounted on each of the main refrigerant lines connecting the cooler to the compressors. On oil separators the pressure relief valve is mounted on the side near top of the vessel body.

It is recommended that a piece of pipe is fitted to each valve and directed so that when the valve is activated the release of high pressure gas and liquid cannot be a danger or cause injury. For indoor installations pressure relief valves should be piped to the exterior of the building.

The size of any pipework attached to a relief valve must be of sufficient diameter so as not to cause resistance to the operation of the valve. Unless otherwise specified by local regulations, table internal diameter depends on the length of pipe required and is given by the following formula:

$$D^5 = 1.447 \times L$$

Where:

D = minimum pipe internal diameter

L = length of pipe in meters

If relief pipework is common to more than one valve its cross sectional area must be at least the total required by each valve. Valve types should not be mixed on a common pipe. Precautions should be taken to ensure that the outlet of relief valves/vent pipe remain clear of obstructions at all times.

DUCTWORK CONNECTION

General Requirements

The following ductwork recommendations are intended to ensure satisfactory operation of the unit. Failure to follow these recommendations could cause damage to the unit, or loss of performance, and may invalidate the warranty.

When ducting is to be fitted to the fan discharge it is recommended that the duct should be the same cross sectional area as the fan outlet and straight for at least three feet (1 meter) to obtain static regain from the fan. Ductwork should be suspended with flexible hangers to prevent noise and vibration being transmitted to the structure. A flexible joint is also recommended between the duct attached to the fan and the next section for the same reason. Flexible connectors should not be allowed to concertina.

The unit is not designed to take structural loading. No significant amount of weight should be allowed to rest on the fan outlet flange, deck assemblies or condenser coil module. No more than 3 feet (1 meter) of light construction ductwork should be supported by the unit. Where cross winds may occur, any ductwork must be supported to prevent side loading on the unit.

If the ducts from two or more fans are to be combined into a common duct, back-flow dampers should be fitted in the individual fan ducts. This will prevent recirculation of air when only one of the fans is running.

Units are supplied with outlet guards for safety and to prevent damage to the fan blades. If these guards are removed to fit ductwork, adequate alternative precautions must be taken to ensure persons cannot be harmed or put at risk from rotating fan blades.

ELECTRICAL CONNECTION

The following connection recommendations are intended to ensure safe and satisfactory operation of the unit. Failure to follow these recommendations could cause harm to persons, or damage to the unit, and may invalidate the warranty.



No additional controls (relays, etc.) should be mounted in the control panel. Power and control wiring not connected to the control panel should not be run through the control panel. If these precautions are not followed it could lead to a risk of electrocution. In addition, electrical noise could cause malfunctions or damage the unit and its controls.



After connection do not switch on mains power to the unit. Some internal components are live when mains is switched on and this must only be done by Authorized persons.

POWER WIRING

All electrical wiring should be carried out in accordance with local regulations. Route properly sized cables to cable entries on both sides of the unit.

In accordance with U.L. Standard it is the responsibility of the user to install overcurrent protection devices between the supply conductors and the power supply terminals on the unit.

To ensure that no eddy currents are set up in the power panel, the cables forming each 3-phase power supply must enter via the same cable entry.



All sources of supply to the unit must be taken via a common point of isolation (not supplied by YORK).

STANDARD UNITS WITH MULTI POINT POWER SUPPLY WIRING

Standard units require two 3-phase separately fused 3- wire supplies plus a ground per refrigerant system. One supply to be connected to each of the power panels.

Connect each of the main 3-phase supplies to the circuit breakers, non-fused disconnect switches or terminal boards located in the power panels using lug sizes detailed in the Technical Data Section.

Connect the ground wires to the main protective ground terminals in each power panel.

Units with Single-Point Power Supply Wiring

Units require only one 3-phase plus ground.


Connect the 3-phase supplies to the terminal block or non-fused disconnect switch located in the options panel using lug sizes detailed in the Technical Data Section.

Connect a ground wire to the main protective ground terminal.

115VAC CONTROL SUPPLY TRANSFORMER

A 3-wire high voltage to 115VAC supply transformer is standard in the chiller. This transformer is mounted in the Options Cabinet and steps down the high voltage supply to 115VAC to be used by the Micro Panel, Power Panel components, solenoids, heaters, etc.

The high voltage for the transformer primary is taken from the chiller input to one of the systems. Fusing is provided for the transformer.



It is important to check that the correct primary tapping has been used and that it conforms to the site high voltage supply.



Removing high voltage power to the chiller will remove the 115VAC supply voltage to the microprocessor circuitry and the evaporator heater. In cold weather, this could cause serious damage to the chiller due to evaporator freeze-up. Do not remove power unless alternate means are taken to assure operation of the evaporator heater.

Remote Emergency Stop Device

If required, a remote emergency stop device can be wired into the unit. The device should be wired into terminals 31 and 32 (Figs. 12 and 13, pages 39 and 40). in the microprocessor control panel.

CONTROL PANEL WIRING

All wiring to the control panel terminal block is nominal 30VDC and must be run in shielded cable, with the shield grounded at the panel end only. Run shielded cable separately from mains cable to avoid electrical noise pick-up. Use the control panel cable entry to avoid the power cables.

The voltage free contacts must be suitable for 30VDC (gold contacts recommended). If the voltage free contacts form part of a relay or contactor, the coil of the device must be suppressed using a standard R/C suppressor. The above precautions must be taken to avoid electrical noise which could cause a malfunction or damage to the unit and its controls.

The length of cable to these terminals must not exceed 25 ft. (7.5 m) unless an optional input isolator kit is fitted. The optional input isolator kit uses 15VDC (not 30VDC).

VOLTS FREE CONTACTS

Chilled Liquid Pump Starter

Terminals 25 and 26 (Figs. 12 and 13, pages 39 and 40) close to start the chilled liquid pump. This contact can be used as a master start/stop for the pump in conjunction with the daily start/stop schedule.

Run Contact

Terminals 29 and 30 (Figs. 12 and 13, pages 39 and 40) close to indicate that a system is running.

Alarm Contacts

Each system has a voltage-free change over contact which will operate to signal an alarm condition whenever a system locks out, or there is a power failure. To obtain system alarm signal, connect the alarm circuit to volt free terminals 23 and 24 (Figs. 12 and 13, pages 39 and 40) for No. 1 System and to terminals 27 and 28 (Figs. 12 and 13, pages 39 and 40) for No. 2 System.

SYSTEM INPUTS

Flow Switch

A chilled liquid flow switch of suitable type must be connected to terminals 13 and 14 (Figs. 12 and 13, pages 39 and 40) to provide adequate protection against loss of liquid flow.

Remote Run / Stop

Connect remote switch(es) in series with the flow switch to provide remote run/stop control if required.

Remote Print

Closure of suitable contacts connected to terminals 13 and 18 (Figs. 12 and 13, pages 39 and 40) will cause a hard copy printout of Operating Data/Fault History to be made if an optional printer is connected to the RS 232 port.


Remote Setpoint Offset – Temperature

Timed closure of suitable contacts connected to terminals 13 and 17 (PWM contacts) will provide remote offset function of the chilled liquid set point if required. See Figs. 12 and 13, pages 39 and 40 for contact location.

Remote Setpoint Offset – Current

Timed contact closure of a suitable contact connected to terminals 13 and 16 (PWM contacts) will provide remote offset of EMS% CURRENT LOAD LIMIT. See Figs. 12 and 13, pages 39 and 40 for contact location.


POWER AND CONTROL PANEL LAYOUTS (WYE-DELTA TYPICAL)



00263VIP

FIG. 8 – POWER PANEL SECTION

OPTION PANEL LAYOUT (TYPICAL)




00246VIP

FIG. 9 – OPTION PANEL SECTION

LOGIC SECTION LAYOUT

60 Hz Models:



**PHOTOGRAPH OF
60 HZ MODEL LOGIC SECTION**

ITEM	DESCRIPTION
1	Microprocessor Board
2	Back of Keypad
3	Back of Display
4	I/O Expansion Board #1
5	Power Supply Board
6	Relay Output Board #1
7	Relay Output Board #2
8	Flow Switch & Customer Connection Terminals
9	Circuit Breakers

FIG. 10 – LOGIC SECTION LAYOUT


LOGIC SECTION LAYOUT WITH CONTROL PANEL LAYOUT



00248VIP

FIG. 11 – LOGIC SECTION LAYOUT WITH CONTROL PANEL LAYOUT

CUSTOMER CONNECTIONS



TERMINALS 23-38

00249VIP




FIG. 12 – CUSTOMER CONNECTIONS

LD03502A

CUSTOMER CONNECTIONS





FIG. 13 – CUSTOMER CONNECTIONS

COMMISSIONING

PREPARATION



Commissioning of this unit should only be carried out by YORK Authorized personnel.

The Millennium Microcomputer Control System Operating Instructions must be read in conjunction with this section.

PREPARATION – POWER OFF

The following checks should be made with the customer supply/supplies to the unit switched OFF.

Inspection

Inspect unit for installation damage. If found take action and/or repair as appropriate.

Refrigerant Charge

Units are normally shipped as standard with a full refrigerant operating charge. Check that refrigerant pressure is present in both systems and that no leaks are apparent. If no pressure is present a leak test must be undertaken, the leak(s) located and repaired. Repaired systems and units supplied with a nitrogen holding charge must be evacuated with a suitable vacuum pump/recovery unit as appropriate to below 100 microns.

Do not liquid charge with static water in the cooler. Care must also be taken to liquid charge slowly to avoid excessive thermal stress at the charging point. Once the vacuum is broken, charge into the condenser coils with the full operating charge as given in the Technical Data Section.

Valves

Open each compressor suction, economizer, and discharge valves fully (counter-clockwise) then close one turn of the stem to ensure operating pressure is fed to the pressure transducers. Open the liquid line service valve fully and ensure the oil return line ball valve is open in each system.

Compressor Oil

To add oil to a circuit - connect a YORK hand oil pump (Part No. 470-10654-000) to the 1/4" oil charging valve on the oil separator piping with a length of clean hose

or copper line, but do not tighten the flare nut. Using clean oil of the correct type ("L" oil), pump oil until all air has been purged from the hose then tighten the nut. Stroke the oil pump to add oil to the oil system. The oil level should be between the middle of the lower and middle of the upper sight glasses of the oil separator. Approximately 5 gallons is present in the entire chiller system, with 1-2 gallons in the oil separator.

Fans

Check that all fans are free to rotate and are not damaged. Ensure blades are at the same height when rotated. Ensure fan guard is securely fixed.

Isolation/Protection

Verify that all sources of electrical supply to the unit are taken from a single point of isolation. Check that the maximum recommended fuse sizes given in the Technical Data Section have not been exceeded.

Control Panel

Check the panel to see that it is free of foreign materials (wire, metal chips, etc.) and clean out if required.

Power Connections

Check the customer power cables are connected correctly. Ensure that connections of power cables within the panels to the circuit breakers, terminal blocks or switch disconnectors are tight.

Grounding

Verify that the unit's protective terminal(s) are properly connected to a suitable grounding point. Ensure that all unit internal ground connections are tight.

Overloads

Ensure that the fan overloads settings are correct for the type of fan fitted.

Supply Voltage

Verify that the site voltage supply corresponds to the unit requirement and is within the limits given in the Technical Data Section.

Control Transformer

The 3-wire control transformer is mounted in the options panel. It is important to check that the correct primary tapping has been used:

With the supply to the unit isolated remove the lid to the transformer box.

Check that the tapping used conforms to the site supply voltage.

Switch Settings

Ensure that the unit Auto/OFF switch on the display door and the micro board system switches S2 and S5 are set to “0” (OFF). Set the red handled emergency stop device on the options panel to “1” (ON). For units fitted with door interlocked circuit breakers the power panel doors must be closed and the devices set to “1” (ON). The customer’s disconnection devices can now be set to ON.



The machine is now live!

The unit is fitted with an under voltage relay in each panel and it may take between 5 to 10 seconds for its contacts to close and energize the unit’s electronics, including the display on the main panel.

Crankcase Heaters

Verify the compressor crankcase heaters are energized. If the ambient temperature is above 96°F (36°C) the compressor crankcase heaters must be on for at least 8 hours before start-up to ensure all refrigerant liquid is driven out of the oil. If the ambient temperature is below 86°F (30°C) then allow 24 hours.

Water System

Verify that the chilled liquid system has been installed correctly, and has been commissioned with the correct direction of water flow through the cooler. The inlet should be at the refrigerant pipework connection end of the cooler. Purge air from the top of the cooler using the plugged air vent mounted on the top of the cooler body. Flow rates and pressure drops must be within the limits given in the Technical Data Section. Operation outside of these limits is undesirable and could cause damage.

Flow Switch

Verify a chilled water flow switch is correctly fitted in the customer’s pipework on the cooler outlet, and wired into the control panel correctly using shielded cable. There should be a straight run of at least 5 pipe diameters on

either side of the flow switch. The flow switch should be connected to terminals 13 and 14 in the micro panel (Figs. 12 and 13, pages 39 and 40).

Temperature sensor(s)

Ensure the leaving liquid temperature sensor is coated with heat conductive compound (part no. 013-00890-000) and is inserted in the water outlet sensor pocket of the cooler. This sensor also acts as the freeze protection thermostat sensor and must always be in the water OUTLET sensor pocket.

Control Supply

Verify the control panel display is illuminated.

Programmed Options

Verify that the options factory programmed into the Microcomputer Control Center are in accordance with the customer’s order requirements by pressing the ‘Options’ key on the keypad and reading the settings from the display.

Programmed Settings

Ensure the system cut-out and operational settings are in accordance with the instructions provided in Section 8 (page 160) and with the general chiller operational requirements by pressing the ‘Program’ key. The chilled liquid temperature control settings need to be set according to the unit model and required operating conditions.

Date and Time

Program the date and time by first ensuring that the CLK jumper J18 on the microprocessor board is in the ON position (top two pins). Then press the ‘Clock Set Time’ key and set the date and time. (See Section 7.)


Start/Stop Schedule

Program the daily and holiday start/stop by pressing the ‘Set Schedule/Holiday’ key. (See Section 7.)

Setpoint and Remote Offset

Set the required leaving chilled liquid temperature setpoint and control range. If remote temperature reset (offset) is to be used, the maximum reset must be programmed by pressing the ‘Remote Reset Temp’ key. (See Section 6.)

FIRST TIME START-UP



During the commissioning period there should be sufficient heat load to run the unit under stable full load operation to enable the unit controls, and system operation to be set up correctly and a commissioning log taken. Be sure that the Micro Panel is properly programmed (page 160) and the System Start-up Checklist (page 116) is completed.

Interlocks

Verify that liquid is flowing through the cooler and that heat load is present. Ensure that any remote run interlocks are in the run position and that the run schedule requires the unit to run or is overridden.

System Switches

Place the 'Sys 1' switch on the microprocessor board to the 'ON' position – see loading/unloading sequence (Fig. 46, page 148).

Start-up

Remove the locking device from the unit Auto/OFF switch which prevents unauthorized starting of the unit before commissioning. Press the 'Status' key, then turn the unit switch to the "1" position to start the unit (there may be a few seconds delay before the first compressor starts because of the anti-recycle timer). Be ready when each compressor starts, to switch the unit OFF immediately if any unusual noises or other adverse conditions develop. Use the appropriate emergency stop device if necessary.

Oil Pressure

When a compressor starts, press the relevant 'System Pressures' key and verify that oil differential pressure develops immediately. If oil pressure does not develop, the automatic controls will shut down the compressor. Under no circumstances should a restart attempt be made on a compressor which does not develop oil pressure immediately. Switch the unit switch to the '0' position (OFF).

Refrigerant Flow

When a compressor starts a flow of liquid refrigerant will be seen in the liquid line sight glass. After several minutes operation and providing a full charge of refrigerant is in the system, the bubbles will disappear and be replaced by a solid column of liquid.

Fan Rotation

As discharge pressure rises, the condenser fans operate in stages to control the pressure. Verify that the fan operation is correct for the type of unit.

Suction Superheat

Check suction superheat at steady full compressor load only. Measure suction temperature on the copper line about 6" (150 mm) before the compressor suction service valve. Measure suction pressure at the compressor service valve. Superheat should be 10°F to 12°F (7 to 8°C).

Expansion Valve Adjustment

The expansion valves are factory set and should not need adjustment. If any superheat values are out of range, however, the expansion valve adjusting screw should be adjusted no more than 1 turn at a time ('in' to increase superheat, 'out' to decrease superheat), allowing at least 10 minutes for the valve to stabilize before rechecking the value of superheat.

Economizer Superheat

(Not all models are equipped with economizers)

Check economizer superheat at steady full compressor load only. Measure gas temperature on the economizer outlet pipe next to the expansion valve bulb. Measure gas pressure at the back seat port of the economizer service valve. Superheat as measured should be 10°F to 12°F (-7°C to -6°C).

Subcooling

Check liquid subcooling at steady full compressor load only. It is important that all fans are running for the system. Measure liquid line temperature on the copper line beside the main liquid line service valve. Measure liquid pressure at the liquid line service valve. Subcooling should be 12°F to 15°F (-8°C to -7°C). No bubbles should show in the sight glass. If subcooling is out of range add or remove refrigerant as required. Do not overcharge the unit. The liquid flow to the main cooler TXV is subcooled further by the economizer, increasing subcooling to between 22°F and 28°F (-15°C and -12°C).

General Operation

After completion of the above checks for System 1, stop the unit, switch OFF the 'SYS 1' switch on the main panel microprocessor board and repeat the process for each subsequent system. When all run correctly, stop the unit, switch all applicable switches to the 'ON' position and restart the unit.

OPERATION

GENERAL DESCRIPTION

The units are designed to work independently, or in conjunction with other equipment via a YORK ISN building management system or other automated control system. When operating, the unit controls monitor the chilled liquid system temperature at the unit and take the appropriate action to maintain this temperature within desired limits. This action will involve running one or more compressors at a suitable load step to match the cooling effect of the refrigerating systems to the heat load on the liquid system. The heat removed from the chilled liquid is then rejected from the air cooled condenser coils.

The following sections give an overview of the operation of the unit. For detailed information, reference should be made to the Chiller Control Panel Programming and Data Access Operating Instructions for the unit (pages 120 - 168).

START-UP

Check the main power supplies to the unit are 'ON', all refrigerant service valves are open (counter-clockwise one turn short of fully open) and chilled liquid flow has been established (unless the unit chilled liquid pump start control is being used, in which case just ensure the pump supply is on). Ensure only the correct system switches (SYS 1-2) on the microprocessor circuit board are in the 'ON' position.

Press the 'STATUS' key on the keypad and then switch the unit ON/OFF switch below the keypad to the ON position.

The controller will perform a pre-check to ensure that the daily/holiday schedule and any remote interlocks will allow the unit to run, all safety cut-outs are satisfied and that cooling load is required (i.e. that the chilled liquid temperature is outside the set limits). Any problems found by the pre-check will be displayed if present. If no problems are present and cooling duty is required the lead compressor will start.

The display will show the anti-coincidence timer status for the lag compressor, followed by 'NO COOL LOAD' until it is called to operate by the control system.

NORMAL RUNNING AND CYCLING

Once the unit has been started, all operations are fully automatic. After an initial period at minimum capacity on the lead compressor, the control system will adjust the unit load depending on the chilled liquid temperature and rate of temperature change. If high heat load is present, the controller will increase the capacity of the lead compressor and/or start-up the other compressor.

If very little heat load is present, the lead compressor will continue at minimum capacity or may simply stop again to avoid overcooling the liquid. If the latter is the case, one compressor will restart automatically should the liquid temperature rise again.

Once a compressor is running, discharge pressure rises as refrigerant is pumped into the air cooled condenser coils. This pressure is controlled by stages of fans to ensure maximum unit efficiency while maintaining sufficient pressure for correct operation of the condensers and expansion valves.

When a compressor is running the controller monitors oil pressure, motor current, and various other system parameters such as discharge pressure, chilled liquid temperature, etc. Should any problems occur, the control system will immediately take appropriate action and display the nature of the fault (Section 2, page 132).

SHUTDOWN


The unit can be stopped at any time by switching the unit ON/OFF switch just below the keypad to the OFF position. The compressor and oil separator heaters will energize to prevent refrigerant condensing in the compressor rotors and to prevent the compressor oil becoming saturated with refrigerant. If ambient temperatures are low, the cooler heater mats will also energize to prevent the possibility of liquid freezing in the vessels. The mains power to the unit should not normally be switched OFF, even when the unit is not required to run.

If mains power must be switched OFF, (for extended maintenance or a shutdown period), the compressor suction, discharge and motor cooling service stop valves should be closed (clockwise) and if there is a possibility of liquid freezing due to low ambient temperatures, the coolers should be drained. Valves should be opened and power must be switched on for at least 8 Hours (36 Hours if ambient temperature is over 86°F [30°C]) before the unit is restarted.

TECHNICAL DATA

FLOW RATE AND PRESSURE DROP CHARTS


COOLER WATER PRESSURE DROP (ENGLISH UNITS)



LD05825A

MODEL NUMBER YCAS	COOLER
0098, 0118, 0138	C1
0128, 0148, 0158, 0178, 0198, 0208	C2

COOLER WATER PRESSURE DROP (SI UNITS)



LD05884A

MODEL NUMBER YCAS	COOLER
0098, 0118, 0138	C1
0128, 0148, 0158, 0178, 0198, 0208	C2

FIG. 14 – FLOW RATE AND PRESSURE DROP CHARTS

GLYCOL CORRECTION FACTORS


The cooler is designed in accordance with ARI-590-92 which allows for an increase in pressure drop of up to 15% above the design value given above. Debris in the water may also cause additional pressure drop.

When using glycol solutions, pressure drops are higher than with water (see correction factors to be applied when using glycol solutions). Special care must be taken not to exceed the maximum allowed.

A = Correction Factor

B = Mean Temperature through Cooler

C = Concentration W/W



Excessive flow, above the max GPM, will damage the evaporator.





FIG. 15 – GLYCOL CORRECTION FACTORS

TEMPERATURE AND FLOWS (ENGLISH UNITS)

MODEL NUMBER YCAS	LEAVING WATER TEMPERATURE (°F)		COOLER FLOW (GPM) ³		AIR ON CONDENSER (°F)	
	MIN. ¹	MAX. ²	MIN.	MAX.	MIN.	MAX
0098	40	55	141	403	0	125
0118	40	55	141	403	0	125
0128	40	55	180	768	0	125
0138	40	55	141	403	0	125
0148	40	55	180	768	0	125
0158	40	55	180	768	0	125
0178	40	55	180	768	0	125
0198	40	55	180	768	0	125
0208	40	55	180	768	0	125

NOTES:

1. For leaving brine temperature below 40°F, contact your nearest YORK office for application requirements.
2. For leaving water temperature higher than 5.5°F, contact the nearest YORK office for application guidelines.
3. The evaporator is protected against freeze-up to -20°F with an electrical heater as standard.



*Excessive flow, above the max GPM,
will damage the evaporator.*

TEMPERATURE AND FLOWS (SI UNITS)

MODEL NUMBER YCAS	LEAVING WATER TEMPERATURE (°C)		COOLER FLOW (L/S) ³		AIR ON CONDENSER (°C)	
	MIN. ¹	MAX. ²	MIN.	MAX.	MIN.	MAX
0098	4.4	12.8	8.9	25.4	-17.7	50
0118	4.4	12.8	8.9	25.4	-17.7	50
0128	4.4	12.8	11.3	48.5	-17.7	50
0138	4.4	12.8	8.9	25.4	-17.7	50
0148	4.4	12.8	11.3	48.5	-17.7	50
0158	4.4	12.8	11.3	48.5	-17.7	50
0178	4.4	12.8	11.3	48.5	-17.7	50
0198	4.4	12.8	11.3	48.5	-17.7	50
0208	4.4	12.8	11.3	48.5	-17.7	50

NOTES:

1. For leaving brine temperature below 5°C, contact your nearest YORK office for application requirements.
2. For leaving water temperature higher than 13°C, contact the nearest YORK office for application guidelines.
3. The evaporator is protected against freeze-up to -28.8°C with an electrical heater as standard.

PHYSICAL DATA

ENGLISH UNITS

Refrigerant R-407C Optimized	MODEL NUMBER YCAS								
	0098EB	0118EB	0128EB	0138EB	0148EB	0158EB	0178EB	0198EB	0208EB
General Unit Data									
Unit Capacity at 44°F water & 95°F ambient, TR	87.3	106.7	112.1	126.8	130.5	145.5	164.2	178.1	192.8
Number of Independent Refrigerant Circuits	2	2	2	2	2	2	2	2	2
Refrigerant Charge, R-407C, Ckt.-1/Ckt.-2, lbs.	165/165	172/165	187/180	187/187	187/187	194/187	194/194	220/213	220/220
Oil Charge, Ckt.-1/Ckt.-2, gal.	4/4	4/4	4/4	4/4	4/4	4/4	4/4	4/4	4/4
Shipping Weight:									
Aluminum Fin Coils, lbs.	7,694	8,295	10,291	9,995	10,769	10,843	11,165	12,255	12,619
Copper Fin Coils, lbs.	8,648	9,234	11,562	11,261	12,042	12,114	12,427	13,856	14,209
Operating Weight:									
Aluminum Fin Coils, lbs.	8,014	8,615	11,056	10,315	11,534	11,608	11,930	13,020	13,384
Copper Fin Coils, lbs.	8,968	9,554	12,327	11,581	12,807	12,879	13,192	14,621	14,974
Compressors, DXS Semihermetic Twin Screw									
Quantity per Chiller	2	2	2	2	2	2	2	2	2
Nominal Size, Ckt.-1 / Ckt.-2	45/45	63/45	63/45	63/63	63/63	82/63	82/82	100/82	100/100
Condensers, High Efficiency Fin / Tube with Integral Subcooler									
Total Chiller Coil Face Area, ft ²	192	192	256	256	256	256	256	320	320
Number of Rows	3	3	3	3	3	3	3	3	3
Fins per inch	13	13	13	13	13	13	13	13	13
Condenser Fans									
Number, Ckt.-1/Ckt.-2	3/3	3/3	4/4	4/4	4/4	4/4	4/4	5/5	5/5
Standard Fans									
Fan Motor, HP / kW	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8
Fan & Motor Speed, revs./min.	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0
Fan Diameter, inches	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4
Fan Tip Speed, ft./min.	10,575	10,575	10,575	10,575	10,575	10,575	10,575	10,575	10,575
Total Chiller Airflow, CFM	84,600	84,600	112,800	112,800	112,800	112,800	112,800	141,000	141,000
Low Noise Fans									
Fan Motor, HP / kW	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53
Fan & Motor Speed, revs./min.	850	850	850	850	850	850	850	850	850
Fan Diameter, inches	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4
Fan Tip Speed, ft./min.	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884	7,884
Total Chiller Airflow, CFM	82,800	82,800	110,400	110,400	110,400	110,400	110,400	138,000	138,000
High External Static Fans									
Fan Motor, HP / kW	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3
Fan & Motor Speed, revs./min.	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0	1140.0
Fan Diameter, inches	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4
Fan Tip Speed, ft./min.	10,575	10,575	10,575	10,575	10,575	10,575	10,575	10,575	10,575
Total Chiller Airflow, CFM (at 0.4 in. of H ₂ O external static)	84,600	84,600	112,800	112,800	112,800	112,800	112,800	141,000	141,000
Evaporator, Direct Expansion									
Water Volume, gals.	38.4	38.4	91.7	38.4	91.7	91.7	91.7	91.7	91.7
Maximum ¹ Water Side Pressure, PSIG	150	150	150	150	150	150	150	150	150
Maximum Refrigerant Side Pressure, PSIG	350	350	350	350	350	350	350	350	350
Minimum Chilled Water Flow Rate, gpm	141	141	180	141	180	180	180	180	180
Maximum Chilled Water Flow Rate, gpm	403	403	768	403	768	768	768	768	768
Water Connections, inches	6	6	8	6	8	8	8	8	8

NOTE:
¹ Optional 300 PSIG waterside available

PHYSICAL DATA

SI UNITS

Refrigerant R-407C Optimized	MODEL NUMBER YCAS								
	0098EB	0118EB	0128EB	0138EB	0148EB	0158EB	0178EB	0198EB	0208EB
General Unit Data									
Unit Capacity at 7°C water & 35°C ambient, kW	310	379	398	444	466	517	583	632	685
Number of Independent Refrigerant Circuits	2	2	2	2	2	2	2	2	2
Refrigerant Charge, R-407C, Ckt.-1/Ckt.-2, kg.	75/75	78/75	85/82	85/85	85/85	88/85	88/88	100/97	100/100
Oil Charge, Ckt.-1/Ckt.-2, liters	15/15	15/15	15/15	15/15	15/15	15/15	15/15	15/15	15/15
Shipping Weight:									
Aluminum Fin Coils, kg.	3,490	3,763	4,668	4,534	4,885	4,918	5,064	5,559	5,724
Copper Fin Coils, kg.	3,922	4,189	5,245	5,108	5,462	5,495	5,637	6,285	6,445
Operating Weight:									
Aluminum Fin Coils, kg.	3,635	3,908	5,015	4,679	5,232	5,265	5,411	5,906	6,071
Copper Fin Coils, kg.	4,068	4,334	5,591	5,253	5,809	5,842	5,984	6,632	6,792
Compressors, DXS Semihermetic Twin Screw									
Quantity per Chiller	2	2	2	2	2	2	2	2	2
Nominal Size, Ckt.-1 / Ckt.-2	175/175	225/175	225/175	225/225	225/225	285/225	285/285	335/285	335/335
Condensers, High Efficiency Fin / Tube with Integral Subcooler									
Total Chiller Coil Face Area, m ²	17.84	17.84	23.78	23.78	23.78	23.78	23.78	29.73	29.73
Number of Rows	3	3	3	3	3	3	3	3	3
Fins per meter	512	512	512	512	512	512	512	512	512
Condenser Fans									
Number, Ckt.-1/Ckt.-2	3/3	3/3	4/4	4/4	4/4	4/4	4/4	5/5	5/5
Standard Fans									
Fan Motor, HP / kW	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8	2/1.8
Fan & Motor Speed, revs./sec.	19.0	19.0	19.0	19.0	19.0	19.0	19.0	19.0	19.0
Fan Diameter, mm	900	900	900	900	900	900	900	900	900
Fan Tip Speed, m/sec.	53.7	53.7	53.7	53.7	53.7	53.7	53.7	53.7	53.7
Total Chiller Airflow, l/sec.	39,930	39,930	53,240	53,240	53,240	53,240	53,240	66,550	66,550
Low Noise Fans									
Fan Motor, HP / kW	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53	2/1.53
Fan & Motor Speed, revs./sec.	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2	14.2
Fan Diameter, mm	900	900	900	900	900	900	900	900	900
Fan Tip Speed, m/sec.	40	40	40	40	40	40	40	40	40
Total Chiller Airflow, l/sec.	39,300	39,300	52,400	52,400	52,400	52,400	52,400	65,500	65,500
High External Static Fans									
Fan Motor, HP / kW	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3	5/3.3
Fan & Motor Speed, revs./sec.	19.0	19.0	19.0	19.0	19.0	19.0	19.0	19.0	19.0
Fan Diameter, mm	900	900	900	900	900	900	900	900	900
Fan Tip Speed, m/sec.	53.7	53.7	53.7	53.7	53.7	53.7	53.7	53.7	53.7
Total Chiller Airflow, l/sec. (at 100 Pa external static)	39,930	39,930	53,240	53,240	53,240	53,240	53,240	66,550	66,550
Evaporator, Direct Expansion									
Water Volume, liters	145.3	145.3	347.1	145.3	347.2	347.2	347.2	347.2	347.2
Maximum ¹ Water Side Pressure, Bar	10	10	10	10	10	10	10	10	10
Maximum Refrigerant Side Pressure, Bar	24	24	24	24	24	24	24	24	24
Minimum Chilled Water Flow Rate, l/s	8.90	8.90	11.30	8.90	11.30	11.30	11.30	11.30	11.30
Maximum Chilled Water Flow Rate, l/s	25.43	25.43	48.45	25.43	48.45	48.45	48.45	48.45	48.45
Water Connections, inches	6	6	8	6	8	8	8	8	8

NOTE:

¹ Optional 21 Bar Waterside available

OPERATING LIMITATIONS AND SOUND POWER DATA

OPERATING LIMITATIONS – ENGLISH UNITS

		MIN	MAX
LEAVING CHILLED LIQUID TEMP (°F)		40.1	59
CHILLED WATER TEMP DIFFERENCE (°F)		5.5	18
WATER SIDE PRESSURE (PSIG)			150
REFRIGERANT SIDE PRESSURE (PSIG)			300
MODEL YCAS		COOLER FLOW GALLONS/MINUTE	
		MIN.	MAX.
0098EB		141	403
0118EB		141	403
0128EB		180	769
0138EB		141	403
0148EB		180	768
0158EB		180	768
0178EB		180	768
0198EB		180	768
0208EB		180	768
AIR ENTERING CONDENSER (°F) FAN	STANDARD FANS	0	115*
	HIGH PRESS. FANS	0	115*
	SLOW SPEED FANS	0	115
	STANDARD FANS		20
AVAILABLE STATIC PRESSURE (Pa)	HIGH PRESS. FANS	OPTION 1	85
	HIGH PRESS. FANS	OPTION 2	150
	SLOW SPEED FANS		10
ELECTRICAL THREE PHASE 60 Hz (V)		200	
		230	
		380	
		460	
		575	440


* Maximum Ambient w/ High Ambient Kit is 130°F.

OPERATING LIMITATIONS – SI UNITS

		MIN	MAX
LEAVING CHILLED LIQUID TEMP (°C)		4.5	15
CHILLED WATER TEMP DIFFERENCE (°C)		3	10
WATER SIDE PRESSURE (BAR)		–	10
REFRIGERANT SIDE PRESSURE (BAR)		–	20
MODEL YCAS		COOLER FLOW LITERS/SECOND	
		MIN.	MAX.
0098EB		8.9	25.43
0118EB		8.9	25.43
0128EB		11.3	48.45
0138EB		8.9	25.43
0148EB		11.3	48.45
0158EB		11.3	48.45
0178EB		11.3	48.45
0198EB		11.3	48.45
0208EB		11.3	48.45
AIR ENTERING CONDENSER (°C) FAN	STANDARD FANS	–18	46
	HIGH PRESS. FANS	–18	46
	SLOW SPEED FANS	–18	46
	STANDARD FANS		20
AVAILABLE STATIC PRESSURE (Pa)	HIGH PRESS. FANS	OPTION 1	85
	HIGH PRESS. FANS	OPTION 2	150
	SLOW SPEED FANS		10
ELECTRICAL THREE PHASE 60 Hz (V)		200	
		230	
		380	
		460	
		575	

* Maximum Ambient w/ High Ambient Kit is 54°C.

ELECTRICAL DATA



MULTIPLE POINT POWER SUPPLY CONNECTION

Suitable for:
Y - Δ Start and
Across-The-Line-Start

Each of the two field provided power supply circuits to the unit with individual branch circuit protection. Field Power Wiring connections to factory provided, Non-Fused Disconnect Switches (Opt), or Terminal Blocks (Opt) in the Option Box.

See page 56 for notes.

MULTIPLE POINT POWER SUPPLY CONNECTION - 2 COMPRESSOR UNITS

(Two Field Provided Power Supply Circuits To The Chiller. Field Connections to Factory Provided Terminal Block (Std), Disconnects (Opt), or Individual System Circuit Breakers (Opt) in each of the two Motor Control Centers.)


MODEL YCAS	VOLTS	SYSTEM #1 FIELD-SUPPLIED WIRING													
		FIELD PROVIDED POWER SUPPLY					FACTORY PROVIDED (LUGS) WIRE RANGE ⁷			COMPRESSOR #1			FANS ^{11, 12}		
		MCA ¹	MIN NF DISC SW ^{2, 9}	OVER-CURRENT PROTECTION											
				MIN. ^{3, 5}	MAX. ^{4, 6}	STD. TERMINAL BLOCK	OPT. NF. DISC SW.	OPT. C.B.	RLA	Y-D-LRA	XL-LRA	QTY	FLA (EA.)	LRA (EA.)	
0098EB	200	235	250	300	400	1/0 - 300	#6 - 350	(2) 3/0 - 250	168	404	1257	3	8.2	33.0	
	230	206	200	250	350	1/0 - 300	#4 - 300	#6 - 350	146	354	1103	3	7.8	38.0	
	380	125	150	150	200	# 2 - 1/0 *	#4 - 300	#4 - 300	89	219	681	3	4.8	23.0	
	460	103	100	125	150	# 6 - 1/0	#14 - 1/0	#4 - 300	73	174	542	3	4.0	19.0	
	575	83	100	100	125	# 6 - 1/0	#14 - 1/0	#14 - 1/0	59	138	431	3	3.1	15.2	
0118EB	200	344	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	255	591	1866	3	8.2	33.0	
	230	301	400	350	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	222	481	1518	3	7.8	38.0	
	380	182	200	225	300	# 2 - 4/0	#4 - 300	#4 - 300	134	285	900	3	4.8	23.0	
	460	151	150	200	250	# 2 - 4/0	#4 - 300	#4 - 300	111	228	719	3	4.0	19.0	
	575	121	150	150	200	# 6 - 1/0	#4 - 300	#4 - 300	90	182	574	3	3.1	15.2	
0128EB	200	324	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	233	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	203	481	1518	4	7.8	38.0	
	380	172	200	250	250	# 2 - 4/0	#4 - 300	#4 - 300	122	285	900	4	4.8	23.0	
	460	143	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	113	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0138EB	200	323	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	232	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	202	481	1518	4	7.8	38.0	
	380	172	200	225	250	# 2 - 4/0	#4 - 300	#4 - 300	122	285	900	4	4.8	23.0	
	460	142	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	113	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0148EB	200	324	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	233	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	203	481	1518	4	7.8	38.0	
	380	172	200	225	250	# 2 - 4/0	#4 - 300	#4 - 300	122	285	900	4	4.8	23.0	
	460	143	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	113	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0158EB	200	433	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	320	708	2256	4	8.2	33.0	
	230	379	400	450	600	(2) # 2-4/0	(2) 3/0 - 250	(3) 2/0 - 400	278	642	2045	4	7.8	38.0	
	380	230	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	168	343	1093	4	4.8	23.0	
	460	190	200	225	300	# 2 - 4/0	#4 - 300	#4 - 300	140	280	893	4	4.0	19.0	
	575	151	150	200	250	# 2 - 4/0	#4 - 300	#6 - 350	111	224	714	4	3.1	15.2	
0178EB	200	433	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	320	708	2256	4	8.2	33.0	
	230	378	400	450	600	(2) 1/0 - 300	(2) 3/0 - 250	(3) 2/0 - 400	278	642	2045	4	7.8	38.0	
	380	230	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	169	343	1093	4	4.8	23.0	
	460	191	200	225	300	# 2 - 4/0	#4 - 300	#4 - 300	140	280	893	4	4.0	19.0	
	575	151	150	200	250	# 2 - 4/0	#4 - 300	#6 - 350	111	224	714	4	3.1	15.2	
0198EB	200	510	600	600	800	(2) 2/0 - 500	(3) 2/0 - 400	(3) 2/0 - 400	375	708	2256	5	8.2	33.0	
	230	447	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	327	642	2045	5	7.8	38.0	
	380	271	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	198	343	1093	5	4.8	23.0	
	460	225	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	164	280	893	5	4.0	190.0	
	575	179	200	225	300	# 2 - 4/0	#6 - 350	#6 - 350	131	224	714	5	3.1	15.2	
0208EB	200	510	600	700	800	(2) 2/0 - 500	(3) 2/0 - 400	(3) 2/0 - 400	376	708	2256	5	8.2	33.0	
	230	447	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	326	642	2045	5	7.8	38.0	
	380	271	250	350	450	2/0 - 500	#6 - 350	(2) 3/0 - 250	198	343	1093	5	4.8	23.0	
	460	225	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	164	280	893	5	4.0	19.0	
	575	179	200	225	300	# 2 - 4/0	#6 - 350	#6 - 350	131	224	714	5	3.1	15.2	

See page 58 for Electrical Data footnotes.

ELECTRICAL DATA

MODEL YCAS	VOLTS	SYSTEM #2 FIELD-SUPPLIED WIRING													
		FIELD PROVIDED POWER SUPPLY					FACTORY PROVIDED (LUGS) WIRE RANGE ⁷			COMPRESSOR #2			FANS ^{11, 12}		
		MCA ¹	MIN NF DISC SW ^{2, 9}	OVER-CURRENT PROTECTION											
				MIN. ^{3, 5}	MAX. ^{4, 6}	STD. TERMINAL BLOCK	OPT. NF. DISC SW.	OPT. C.B.	RLA	Y-D-LRA	XL-LRA	QTY	FLA (EA.)	LRA (EA.)	
0098EB	200	235	250	300	400	1/0 - 300	#6 - 350	(2) 3/0 - 250	168	404	1257	3	8.2	33.0	
	230	206	200	250	350	1/0 - 300	#4 - 300	#6 - 350	146	354	1103	3	7.8	38.0	
	380	125	150	150	200	# 2 - 1/0 *	#4 - 300	#4 - 300	89	219	681	3	4.8	23.0	
	460	103	100	125	150	# 6 - 1/0	#14 - 1/0	#4 - 300	73	174	542	3	4.0	19.0	
	575	83	100	100	125	# 6 - 1/0	#14 - 1/0	#14 - 1/0	59	138	431	3	3.1	15.2	
0118EB	200	234	250	300	400	1/0 - 300	#4 - 300	(2) 3/0 - 250	168	404	1257	3	8.2	33.0	
	230	206	200	250	350	1/0 - 300	#4 - 300	#6 - 350	146	354	1103	3	7.8	38.0	
	380	125	150	150	200	# 6 - 1/0	#4 - 300	#4 - 300	88	219	681	3	4.8	23.0	
	460	103	100	125	150	# 6 - 1/0	#4 - 300	#4 - 300	73	174	542	3	4.0	19.0	
	575	83	100	100	125	# 6 - 1/0	#14 - 1/0	#14 - 1/0	59	138	431	3	3.1	15.2	
0128EB	200	232	250	300	350	1/0 - 300	#4 - 300	(2) 3/0 - 250	159	404	1257	4	8.2	33.0	
	230	205	200	250	300	1/0 - 300	#4 - 300	#6 - 350	139	354	1103	4	7.8	38.0	
	380	124	150	150	200	# 6 - 1/0	#4 - 300	#4 - 300	84	219	681	4	4.8	23.0	
	460	102	100	125	150	# 6 - 1/0	#4 - 300	#4 - 300	69	174	542	4	4.0	19.0	
	575	82	100	100	125	# 6 - 1/0	#14 - 1/0	#14 - 1/0	56	138	431	4	3.1	15.2	
0138EB	200	323	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	232	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	202	481	1518	4	7.8	38.0	
	380	172	200	225	250	# 2 - 4/0	#4 - 300	#4 - 300	122	285	900	4	4.8	23.0	
	460	142	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	113	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0148EB	200	324	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	233	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	203	481	1518	4	7.8	38.0	
	380	172	200	225	250	# 2 - 4/0	#4 - 300	#4 - 300	122	285	900	4	4.8	23.0	
	460	143	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	113	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0158EB	200	324	400	400	500	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	233	591	1866	4	8.2	33.0	
	230	284	400	350	450	2/0 - 500	(2) 3/0 - 250	(2) 3/0 - 250	203	481	1518	4	7.8	38.0	
	380	172	200	225	250	# 2 - 4/0	#6 - 350	#4 - 300	122	285	900	4	4.8	23.0	
	460	143	150	175	225	# 2 - 4/0	#4 - 300	#4 - 300	101	228	719	4	4.0	19.0	
	575	114	150	150	175	# 6 - 1/0	#4 - 300	#4 - 300	81	182	574	4	3.1	15.2	
0178EB	200	433	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	320	708	2256	4	8.2	33.0	
	230	378	400	450	600	(2) 1/0 - 300	(2) 3/0 - 250	(3) 2/0 - 400	278	642	2045	4	7.8	38.0	
	380	230	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	169	343	1093	4	4.8	23.0	
	460	191	200	225	300	# 2 - 4/0	#4 - 300	#4 - 300	140	280	893	4	4.0	19.0	
	575	151	150	200	250	# 2 - 4/0	#4 - 300	#6 - 350	111	224	714	4	3.1	15.2	
0198EB	200	412	400	500	700	(2) 2/0 - 300	(2) 3/0 - 250	(3) 2/0 - 400	297	708	2256	5	8.2	33.0	
	230	361	400	450	600	(2) # 2 - 4/0	(2) 3/0 - 250	(3) 2/0 - 400	258	642	2045	5	7.8	38.0	
	380	219	250	300	350	1/0 - 300	(2) 3/0 - 500	(2) 3/0 - 250	156	343	1093	5	4.8	23.0	
	460	182	200	225	300	# 2 - 4/0	#6 - 350	#4 - 300	129	280	893	5	4.0	19.0	
	575	144	150	175	225	# 2 - 4/0	#6 - 350	#6 - 350	103	224	714	5	3.1	15.2	
0208EB	200	510	600	700	800	(2) 2/0 - 500	(3) 2/0 - 400	(3) 2/0 - 400	376	708	2256	5	8.2	33.0	
	230	447	600	600	700	(2) 1/0 - 300	(3) 2/0 - 400	(3) 2/0 - 400	326	642	2045	5	7.8	38.0	
	380	271	250	350	450	2/0 - 500	#6 - 350	(2) 3/0 - 250	198	343	1093	5	4.8	23.0	
	460	225	250	300	350	1/0 - 300	#6 - 350	(2) 3/0 - 250	164	280	893	5	4.0	19.0	
	575	179	200	225	300	# 2 - 4/0	#6 - 350	#6 - 350	131	224	714	5	3.1	15.2	

ELECTRICAL DATA



OPTIONAL SINGLE-POINT POWER SUPPLY CONNECTION AND INDIVIDUAL SYSTEM CIRCUIT BREAKERS

Suitable for:

Y - Δ Start and

Across-The-Line-Start

One field provided power supply circuit to the unit with circuit protection. Field connections to factory provided Non-Fused Disconnect Switch (Opt), or Terminal Block (Opt) in the Options Panel. Factory connections to Terminal Blocks in each of the two Power Panels.

See page 56 for notes.

OPTIONAL SINGLE-POINT POWER SUPPLY WITH INDIVIDUAL SYSTEM CIRCUIT BREAKERS – 2 COMPRESSOR UNITS

(One Field Provided Power Supply Circuit to the chiller. Field connections to Factory Provided Terminal Block (standard) or Non-Fused Disconnect (option) in 'Option Panel'. Individual System Circuit Breakers in each Motor Control Center¹⁰)


CHILLER MODEL YCAS	VOLTS	FIELD-SUPPLIED WIRING					
		FIELD PROVIDED POWER SUPPLY				FACTORY PROVIDED (LUGS) WIRE RANGE ⁷	
		MCA ¹	MIN NF DISC SW ^{2,9}	OVER-CURRENT PROTECTION ¹³		STANDARD TERMINAL BLOCK	OPTIONAL NF DISC. SWITCH
				MIN. ^{3,5}	MAX. ^{4,6}		
0098EB	200	427	600	500	500	(2) 1/0 - 300	(2) 250 - 500
	230	376	400	450	500	(2) # 2 - 4/0	(2) 3/0 - 250
	380	228	250	250	300	1/0 - 300	# 6 - 350
	460	188	200	225	250	# 2 - 4/0	# 6 - 350
	575	151	200	175	200	1/0 - 300	# 6 - 350
0118EB	200	536	600	700	800	(2) 2/0 - 500	(2) 250 - 500
	230	471	600	600	700	(2) 1/0 - 300	(2) 250 - 500
	380	285	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	236	250	300	350	1/0 - 300	# 6 - 350
	575	189	200	225	250	1/0 - 300	# 6 - 350
0128EB	200	516	600	600	700	(2) 2/0 - 500	(2) 250 - 500
	230	454	600	600	600	(2) 1/0 - 300	(2) 250 - 500
	380	275	400	350	350	2/0 - 500	(2) 3/0 - 250
	460	228	250	300	300	1/0 - 300	# 6 - 350
	575	182	200	225	250	1/0 - 300	# 6 - 350
0138EB	200	589	800	700	800	(2) 2/0 - 500	(3) 2/0 - 400
	230	517	600	600	700	(2) 2/0 - 500	(2) 250 - 500
	380	313	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	259	400	300	350	2/0 - 500	(2) 3/0 - 250
	575	206	250	250	250	1/0 - 300	# 6 - 350
0148EB	200	590	800	700	800	(2) 2/0 - 500	(3) 2/0 - 400
	230	518	600	600	700	(2) 2/0 - 500	(2) 250 - 500
	380	313	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	260	400	300	350	2/0 - 500	(2) 3/0 - 250
	575	207	250	225	250	1/0 - 300	# 6 - 350
0158EB	200	699	800	800	1000	(3) 1/0 - 300	(3) 2/0 - 400
	230	613	800	700	800	(2) 2/0 - 500	(3) 2/0 - 400
	380	371	400	450	500	(2) # 2 - 4/0	(2) 3/0 - 250
	460	308	400	350	400	2/0 - 500	(2) 3/0 - 250
	575	244	250	300	350	2/0 - 500	# 6 - 350
0178EB	200	786	1000	1000	1000	(3) 2/0 - 500	(4) 250 - 500
	230	688	800	800	800	(3) 1/0 - 300	(3) 2/0 - 400
	380	418	600	500	500	(2) 1/0 - 300	(2) 250 - 500
	460	347	400	400	450	(2) # 2 - 4/0	(2) 3/0 - 250
	575	275	400	350	350	2/0 - 500	(2) 3/0 - 250
0198EB	200	848	1000	1000	1200	(3) 2/0 - 500	(4) 250 - 500
	230	744	800	1000	1000	(3) 1/0 - 300	(3) 2/0 - 400
	380	451	600	600	600	(2) 1/0 - 300	(2) 250 - 500
	460	374	400	450	500	(2) # 2 - 4/0	(2) 3/0 - 250
	575	297	400	350	400	2/0 - 500	(2) 3/0 - 250
0208EB	200	927	1000	1200	1200	(3) 2/0 - 500	(4) 250 - 500
	230	812	1000	1000	1200	(3) 2/0 - 500	(4) 250 - 500
	380	493	600	600	600	(2) 1/0 - 300	(2) 250 - 500
	460	408	600	500	500	(2) 1/0 - 300	(2) 250 - 500
	575	325	400	400	400	2/0 - 500	(2) 3/0 - 250

See page 58 for Electrical Data footnotes.

ELECTRICAL DATA

MODEL YCAS	VOLTS	SYSTEM #1						SYSTEM #2					
		COMPRESSOR #1			FAN DATA ^{11, 12}			COMPRESSOR #2			FAN DATA ^{11, 12}		
		RLA	Y-D-LRA	XL-LRA	QTY	FLA (EA.)	LRA (EA)	RLA	Y-D-LRA	XL-LRA	QTY	FLA (EA)	LRA (EA)
0098EB	200	168	404	1257	3	8.2	33.0	168	404	1257	3	8.2	33.0
	230	146	354	1103	3	7.8	38.0	146	354	1103	3	7.8	38.0
	380	89	219	681	3	4.8	23.0	89	219	681	3	4.8	23.0
	460	73	174	542	3	4.0	19.0	73	174	542	3	4.0	19.0
	575	59	138	431	3	3.1	15.2	59	138	431	3	3.1	15.2
0118EB	200	255	591	1866	3	8.2	33.0	168	404	1257	3	8.2	33.0
	230	222	481	1518	3	7.8	38.0	146	354	1103	3	7.8	38.0
	380	134	285	900	3	4.8	23.0	88	219	681	3	4.8	23.0
	460	111	228	719	3	4.0	19.0	73	174	542	3	4.0	19.0
	575	90	182	574	3	3.1	15.2	59	138	431	3	3.1	15.2
0128EB	200	233	591	1866	4	8.2	33.0	159	404	1257	4	8.2	33.0
	230	203	481	1518	4	7.8	38.0	139	354	1103	4	7.8	38.0
	380	122	285	900	4	4.8	23.0	84	219	681	4	4.8	23.0
	460	101	228	719	4	4.0	19.0	69	174	542	4	4.0	19.0
	575	81	182	574	4	3.1	15.2	56	138	431	4	3.1	15.2
0138EB	200	232	591	1866	4	8.2	33.0	232	591	1866	4	8.2	33.0
	230	202	481	1518	4	7.8	38.0	202	481	1518	4	7.8	38.0
	380	122	285	900	4	4.8	23.0	122	285	900	4	4.8	23.0
	460	101	228	719	4	4.0	19.0	101	228	719	4	4.0	19.0
	575	81	182	574	4	3.1	15.2	81	182	574	4	3.1	15.2
0148EB	200	233	591	1866	4	8.2	33.0	233	591	1866	4	8.2	33.0
	230	203	481	1518	4	7.8	38.0	203	481	1518	4	7.8	38.0
	380	122	285	900	4	4.8	23.0	122	285	900	4	4.8	23.0
	460	101	228	719	4	4.0	19.0	101	228	719	4	4.0	19.0
	575	81	182	574	4	3.1	15.2	81	182	574	4	3.1	15.2
0158EB	200	320	708	2256	4	8.2	33.0	233	591	1866	4	8.2	33.0
	230	278	642	2045	4	7.8	38.0	203	481	1518	4	7.8	38.0
	380	168	343	1093	4	4.8	23.0	122	285	900	4	4.8	23.0
	460	140	280	893	4	4.0	19.0	101	228	719	4	4.0	19.0
	575	111	224	714	4	3.1	15.2	81	182	574	4	3.1	15.2
0178EB	200	320	708	2256	4	8.2	33.0	320	708	2256	4	8.2	33.0
	230	278	642	2045	4	7.8	38.0	278	642	2045	4	7.8	38.0
	380	169	343	1093	4	4.8	23.0	169	343	1093	4	4.8	23.0
	460	140	280	893	4	4.0	19.0	140	280	893	4	4.0	19.0
	575	111	224	714	4	3.1	15.2	111	224	714	4	3.1	15.2
0198EB	200	375	708	2256	5	8.2	33.0	297	708	2256	5	8.2	33.0
	230	327	642	2045	5	7.8	38.0	258	642	2045	5	7.8	38.0
	380	198	343	1093	5	4.8	23.0	156	343	1093	5	4.8	23.0
	460	164	280	893	5	4.0	19.0	129	280	893	5	4.0	19.0
	575	131	224	714	5	3.1	15.2	103	224	714	5	3.1	15.2
0208EB	200	376	708	2256	5	8.2	33.0	376	708	2256	5	8.2	33.0
	230	326	642	2045	5	7.8	38.0	326	642	2045	5	7.8	38.0
	380	198	343	1093	5	4.8	23.0	198	343	1093	5	4.8	23.0
	460	164	280	893	5	4.0	19.0	164	280	893	5	4.0	19.0
	575	131	224	714	5	3.1	15.2	131	224	714	5	3.1	15.2

ELECTRICAL DATA



OPTIONAL SINGLE-POINT POWER SUPPLY CONNECTION WITH FIELD SUPPLIED CIRCUIT PROTECTION

Suitable for:
Y - Δ Start and
Across-The-Line-Start

One field provided power supply circuit to the unit with field supplied circuit protection. Field connections to factory provided Non-Fused Disconnect Switch (Opt), or Terminal Block (Opt) in the Options Panel. Factory connections to Terminal Blocks in each of the two Power Panels.

See page 56 for notes.

OPTIONAL SINGLE-POINT POWER SUPPLY CONNECTION – 2 COMPRESSOR UNITS

(One Field Provided Power Supply Circuit to the Chiller. Field connections to Factory Provided Terminal Block (Standard) or Non-Fused Disconnect (option) in the 'Options' Panel. No Internal Branch Circuit Protection (Breakers) per Motor Control Center¹⁰)


CHILLER MODEL YCAS	VOLTS	FIELD-SUPPLIED WIRING					
		FIELD PROVIDED POWER SUPPLY			FACTORY PROVIDED (LUGS) WIRE RANGE ⁷		
		MCA ¹	MIN NF DISC SW ^{2, 9}	OVER-CURRENT PROTECTION ¹⁰		STANDARD TERMINAL BLOCK	OPTIONAL NF DISC. SWITCH
				MIN ^{3, 5}	MAX ^{4, 6}		
0098EB	380	228	250	250	300	1/0 - 300	# 6 - 350
	460	188	200	225	250	# 2 - 4/0	# 6 - 350
	575	151	200	175	200	1/0 - 300	# 6 - 350
0118EB	380	285	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	236	250	300	350	1/0 - 300	# 6 - 350
	575	189	200	225	250	1/0 - 300	# 6 - 350
0128EB	380	275	400	350	350	2/0 - 500	(2) 3/0 - 250
	460	228	250	300	300	1/0 - 300	# 6 - 350
	575	182	200	225	250	1/0 - 300	# 6 - 350
0138EB	380	313	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	259	400	300	350	2/0 - 500	(2) 3/0 - 250
	575	206	250	250	250	1/0 - 300	# 6 - 350
0148EB	380	313	400	350	400	2/0 - 500	(2) 3/0 - 250
	460	260	400	300	350	2/0 - 500	(2) 3/0 - 250
	575	207	250	250	250	1/0 - 300	# 6 - 350
0158EB	380	371	400	450	500	(2) # 2 - 4/0	(2) 3/0 - 250
	460	308	400	350	400	2/0 - 500	(2) 3/0 - 250
	575	244	250	300	350	2/0 - 500	# 6 - 350
0178EB	380	418	600	500	500	(2) 1/0 - 300	(2) 250 - 500
	460	347	400	400	450	(2) # 2 - 4/0	(2) 3/0 - 250
	575	275	400	350	350	2/0 - 500	(2) 3/0 - 250
0198EB	380	451	600	600	600	(2) 1/0 - 300	(2) 250 - 500
	460	374	400	450	500	(2) # 2 - 4/0	(2) 3/0 - 250
	575	297	400	350	400	2/0 - 500	(2) 3/0 - 250
0208EB	380	493	600	600	600	(2) 1/0 - 300	(2) 250 - 500
	460	408	600	500	500	(2) 1/0 - 300	(2) 250 - 500
	575	325	400	350	400	2/0 - 500	(2) 3/0 - 250

See page 58 for Electrical Data footnotes.

ELECTRICAL DATA

MODEL YCAS	VOLTS	SYSTEM #1					SYSTEM #2				
		COMPRESSOR #1		FAN DATA ^{11, 12}			COMPRESSOR #2		FAN DATA ^{11, 12}		
		RLA	XL-LRA	QTY	FLA (EA.)	LRA (EA)	RLA	XL-LRA	QTY	FLA (EA)	LRA (EA)
0098EB	380	89	681	3	4.8	23.0	89	681	3	4.8	23.0
	460	73	542	3	4.0	19.0	73	542	3	4.0	19.0
	575	59	431	3	3.1	15.2	59	431	3	3.1	15.2
0118EB	380	134	900	3	4.8	23.0	88	681	3	4.8	23.0
	460	111	719	3	4.0	19.0	73	542	3	4.0	19.0
	575	90	574	3	3.1	15.2	59	431	3	3.1	15.2
0128EB	380	122	900	4	4.8	23.0	84	681	4	4.8	23.0
	460	101	719	4	4.0	19.0	69	542	4	4.0	19.0
	575	81	574	4	3.1	15.2	56	431	4	3.1	15.2
0138EB	380	122	900	4	4.8	23.0	122	900	4	4.8	23.0
	460	101	719	4	4.0	19.0	101	719	4	4.0	19.0
	575	81	574	4	3.1	15.2	81	574	4	3.1	15.2
0148EB	380	122	900	4	4.8	23.0	122	900	4	4.8	23.0
	460	101	719	4	4.0	19.0	101	719	4	4.0	19.0
	575	81	574	4	3.1	15.2	81	574	4	3.1	15.2
0158EB	380	168	1093	4	4.8	23.0	122	900	4	4.8	23.0
	460	140	893	4	4.0	19.0	101	719	4	4.0	19.0
	575	111	714	4	3.1	15.2	81	574	4	3.1	15.2
0178EB	380	169	1093	4	4.8	23.0	169	1093	4	4.8	23.0
	460	140	893	4	4.0	19.0	140	893	4	4.0	19.0
	575	111	714	4	3.1	15.2	111	714	4	3.1	15.2
0198EB	380	198	1093	5	4.8	23.0	156	1093	5	4.8	23.0
	460	164	893	5	4.0	19.0	129	893	5	4.0	19.0
	575	131	714	5	3.1	15.2	103	714	5	3.1	15.2
0208EB	380	198	1093	5	4.8	23.0	198	1093	5	4.8	23.0
	460	164	893	5	4.0	19.0	164	893	5	4.0	19.0
	575	131	714	5	3.1	15.2	131	714	5	3.1	15.2

ELECTRICAL DATA



OPTIONAL SINGLE-POINT POWER SUPPLY CONNECTION TO FACTORY CIRCUIT BREAKER

Suitable for:
Across-The-Line-Start

One field provided power supply circuit to the unit with circuit protection. Field connections to factory provided Circuit Breaker in the Options Panel. Factory connections to Terminal Blocks in each of the two Power Panels.

See below for notes.

OPTIONAL SINGLE-POINT POWER SUPPLY CONNECTION TO FACTORY CIRCUIT BREAKER – 2 COMPRESSOR UNITS

(One Field Provided Power Supply Circuit to the chiller. Field Connections to Factory Provided Circuit Breaker in the 'Options Panel'. No Internal Branch Circuit Protection (Breakers) per Motor Control Center¹⁰.)

MODEL YCAS	VOLTS	FIELD SUPPLIED WIRING			SYSTEM #1					SYSTEM #2				
		MCA ¹	FACTORY SUPPLIED BREAKER		COMPRESSOR #1		FANS ^{11, 12}			COMPRESSOR #2		FANS ^{11, 12}		
			RATING ²	WIRE RANGE ⁷ (LUGS)	RLA	XL-LRA	QTY	FLA(ea)	LRA(ea)	RLA	XL-LRA	QTY	FLA(ea)	LRA(ea)
0098EB	380	228	250	# 6 - 350	89	681	3	4.8	23.0	89	681	3	4.8	23.0
	460	188	250	# 6 - 350	73	542	3	4.0	19.0	73	542	3	4.0	19.0
	575	151	250	# 6 - 350	59	431	3	3.1	15.2	59	431	3	3.1	15.2
0118EB	380	285	400	(2) 3/0 - 250	134	900	3	4.8	23.0	88	681	3	4.8	23.0
	460	236	400	(2) 3/0 - 250	111	719	3	4.0	19.0	73	542	3	4.0	19.0
	575	189	250	# 6 - 350	90	574	3	3.1	15.2	59	431	3	3.1	15.2
0128EB	380	275	400	(2) 3/0 - 250	122	900	4	4.8	23.0	84	681	4	4.8	23.0
	460	228	400	(2) 3/0 - 250	101	719	4	4.0	19.0	69	542	4	4.0	19.0
	575	182	250	# 6 - 350	81	574	4	3.1	15.2	56	431	4	3.1	15.2
0138EB	380	313	400	(2) 3/0 - 250	122	900	4	4.8	23.0	122	900	4	4.8	23.0
	460	259	400	(2) 3/0 - 250	101	719	4	4.0	19.0	101	719	4	4.0	19.0
	575	206	250	# 6 - 350	81	574	4	3.1	15.2	81	574	4	3.1	15.2
0148EB	380	313	400	(2) 3/0 - 250	122	900	4	4.8	23.0	122	900	4	4.8	23.0
	460	260	400	(2) 3/0 - 250	101	719	4	4.0	19.0	101	719	4	4.0	19.0
	575	207	250	# 6 - 350	81	574	4	3.1	15.2	81	574	4	3.1	15.2
0158EB	380	371	600	(2) 250 - 500	168	1093	4	4.8	23.0	122	900	4	4.8	23.0
	460	308	400	(2) 3/0 - 250	140	893	4	4.0	19.0	101	719	4	4.0	19.0
	575	244	400	(2) 3/0 - 250	111	714	4	3.1	15.2	81	574	4	3.1	15.2
0178EB	380	418	600	(2) 250 - 500	169	1093	4	4.8	23.0	169	1093	4	4.8	23.0
	460	347	400	(2) 3/0 - 250	140	893	4	4.0	19.0	140	893	4	4.0	19.0
	575	275	400	(2) 3/0 - 250	111	714	4	3.1	15.2	111	714	4	3.1	15.2
0198EB	380	451	600	(2) 250 - 500	198	1093	5	4.8	23.0	156	1093	5	4.8	23.0
	460	374	600	(2) 250 - 500	164	893	5	4.0	19.0	129	893	5	4.0	19.0
	575	297	400	(2) 3/0 - 250	131	714	5	3.1	15.2	103	714	5	3.1	15.2
0208EB	380	493	600	(2) 250 - 500	198	1093	5	4.8	23.0	198	1093	5	4.8	23.0
	460	408	600	(2) 250 - 500	164	893	5	4.0	19.0	164	893	5	4.0	19.0
	575	325	400	(2) 3/0 - 250	131	714	5	3.1	15.2	131	714	5	3.1	15.2

NOTES: Wye-Delta Compressor Start not available with this option.

See page 58 for Electrical Data footnotes.

NOTES:

1. ----- Dashed Line indicates Field Provided Wiring.
2. The above recommendations are based on the National Electric Code and using copper connectors only. Field wiring must also comply with local codes.

ELECTRICAL DATA

TABLE 2 – COMPRESSOR DATA

MAXIMUM kW AND AMPERAGE VALUES FOR DXST COMPRESSORS																		
	COMPRESSOR MODEL AND VOLTAGE CODE																	
	DXS45LA – MOTOR CODE A						DXS36LA – MOTOR CODE A						DXS24LA – MOTOR CODE (TBD)					
	(B5N, B5E, B6N, B6E)						(A5N, A5E, A6N, A6E)						(C5N, C5E, C6N, C6E)					
VOLTAGE CODE	-17	-28	-40	-46	-50	-58	-17	-28	-40	-46	-50	-58	-17	-28	-40	-46	-50	-58
MAX kW	150	150	150	150	113	150	150	150	150	150	113	150	105	105	105	105	80	105
MAX AMPS	492	428	259	214	193	171	492	428	259	214	193	171	338	294	178	147	135	118

TABLE 3 – FAN DATA (-46)

FAN TYPE	NOMINAL POWER (kW)	FULL LOAD AMPS (FLA)	LOCKED ROTOR AMPS (LRA)
STANDARD	1.57	4.4	18.0
HIGH PRESSURE	3.7	6.8	46.3

ELECTRICAL NOTES

NOTES & LEGEND

(for pages 50 - 56)

LEGEND

ACR-LINE	ACROSS THE LINE START
C.B.	CIRCUIT BREAKER
D.E.	DUAL ELEMENT FUSE
DISC SW	DISCONNECT SWITCH
FACT CB	FACTORY-MOUNTED CIRCUIT BREAKER
FLA	FULL LOAD AMPS
HZ	HERTZ
MAX	MAXIMUM
MCA	MINIMUM CIRCUIT AMPACITY
MIN	MINIMUM
MIN NF	MINIMUM NON-FUSED
RLA	RUNNING LOAD AMPS
S.P. WIRE	SINGLE-POINT WIRING
Y-Δ	WYE-DELTA START
X-LRA	ACROSS-THE-LINE INRUSH LOCKED ROTOR AMPS
Y-LRA	WYE-DELTA INRUSH LOCKED ROTOR AMPS

VOLTAGE CODE

-17	= 200-3-60
-28	= 230-3-60
-40	= 380-3-60
-46	= 460-3-60
-58	= 575-3-60

CONTROL POWER SUPPLY (UNITS WITHOUT STANDARD CONTROL CIRCUIT TRANSFORMER)

NO. OF COMPRESSORS	CONTROL POWER SUPPLY	MCA (MAX LOAD CURRENT)	MAX DUAL ELEMENT FUSE SIZE	NON-FUSED DISCONNECT SWITCH SIZE
2	115V-1Ø	20A	20A	20A

NOTES (for pages 50 - 56)


- Minimum circuit ampacity (MCA) is based on 125% of the rated load amps for the largest motor plus 100% of the rated load amps for all other loads included in the circuit, per N.E.C. Article 430-24. If a Factory Mounted Control Transformer is provided, add the following to the system #1 MCA values in the YCAS Tables: -17, add 10A; -28, add 9A; -40, add 5A; -46, add 4A; -58, add 3A.
- The recommended disconnect switch is based on a minimum of 115% of the summation rated load amps of all the loads included in the circuit, per N.E.C. 440 - 12A1.
- Minimum fuse size is based on 150% of the largest motor RLA plus 100% of the remaining RLAs (U.L. Standard 1995, Section 36.1). Minimum fuse rating = $(1.5 \times \text{largest compressor RLA}) + \text{other compressor RLAs} + (\# \text{ fans} \times \text{each fan motor FLA})$.
- Maximum dual element fuse size is based on 225% maximum plus 100% of the rated load amps for all other loads included in the circuit, per N.E.C. 440-22. Maximum fuse rating = $(2.25 \times \text{largest compressor RLA}) + \text{other compressor RLAs} + (\# \text{ fans} \times \text{each fan motor FLA})$.
- Minimum circuit breaker is 150% maximum plus 100% of rated load amps included in the circuit, per circuit per U.L. 1995 Fig. 36.2. Minimum circuit breaker rating = $(1.5 \times \text{largest compressor RLA}) + \text{other compressor RLAs} + (\# \text{ fans} \times \text{each fan motor FLA})$.
- Maximum circuit breaker is based on 225% maximum plus 100% of the rated load amps for all loads included in the circuit, per circuit, per U.L. 1995 Fig. 36.2. Maximum circuit breaker rating = $(2.25 \times \text{largest compressor RLA}) + \text{other compressor RLAs} + (\# \text{ fans} \times \text{each fan motor FLA})$.
- The Incoming Wire Range is the minimum and maximum wire size that can be accommodated by unit wiring lugs. The (1), (2), or (3) indicate the number of termination points or lugs which are available per phase. Actual wire size and number of wires per phase must be determined based on ampacity and job requirements using N.E.C. wire sizing information. The above recommendations are based on the National Electric Code and using copper connectors only. Field wiring must also comply with local codes.
- A ground lug is provided for each compressor system to accommodate field grounding conductor per N.E.C. Article 250-54. A control circuit grounding lug is also supplied. Incoming ground wire range is #6 - 350 MCM.
- The field supplied disconnect is a "Disconnecting Means" as defined in N.E.C. 100.B, and is intended for isolating the unit from the available power supply to perform maintenance and troubleshooting. This disconnect is not intended to be a Load Break Device.
- Two-compressor machines with Single-Point power connection, and equipped with Star-Delta compressor motor start, must also include factory provided circuit breakers in each motor control center. All 3 & 4 compressor machines equipped with Star-Delta compressor motor start must also include factory provided circuit breakers in each motor control center.
- Consult factory for Electrical Data on units equipped with "High Static Fan" Option. 60 Hz High Static Fans are 3.8 kW each, 50 Hz 3.5 kW each.
- FLA for "Low Noise Fan" motors: 200V = 8.0A, 230V = 7.8A, 380V = 4.4A, 460V = 3.6A, 575V = 2.9A, 380V/50 Hz = 4.1A.
- Group Rated breaker must be HACR type for cU.L. Machines.

This page intentionally left blank.


WIRING DIAGRAM ACROSS-THE-LINE START

NOTES:

1. Field wiring to be in accordance with the current edition of the National Electrical Code as well as all other applicable codes and specifications.
2. Numbers along the right side of a diagram are line identification numbers. The numbers at each line indicate the line number location of relay contacts. An unlined contact location signifies a normally closed contact. Numbers adjacent to circuit lines are the circuit identification numbers.
3. Any customer supplied contacts must be suitable for switching 24VDC. (Gold contacts recommended.) Control Wiring must not be run in the same conduit with any line voltage wiring.
4. To cycle unit on and off automatically with contact shown, install a cycling device in series with the flow switch (FSLW). See Note 3 for contact rating and wiring specifications. Also refer to cautions on page 63.
5. To stop unit (Emergency Stop) with contacts other than those shown, install the stop contact between 5 and 1. If a stop device is not installed, a jumper must be connected between terminals 5 and 1. Device must have a minimum contact rating of 100VA at 115 volts A.C.
6. Alarm contacts are for annunciating alarm/unit malfunction. Contacts are rated at 115V, 100VA, resistive load only, and must be suppressed at load by user.
7. See Installation, Operation and Maintenance Manual when optional equipment is used.
8. Control panel to be securely connected to earth ground.
9. Use 2KVA transformer in optional transformer kit unless there are optional oil separator sump heaters which necessitates using a 3KVA transformer.



LD06991



LD06992A

LEGEND

T S	Transient Voltage Suppression
	Terminal Block for Customer Connections
	Terminal Block for Customer Low Voltage (Class 2) Connections. See Note 2
	Terminal Block for YORK Connections Only
	Wiring and Components by YORK
	Optional Equipment
	Wiring and/or Components by Others

FIG. 16 – WIRING DIAGRAM – ACROSS-THE-LINE START

ELEMENTARY DIAGRAM





FIG. 18 – ELEMENTARY DIAGRAM – ACROSS-THE-LINE START

ELEMENTARY DIAGRAM

**CAUTION:**

No Controls (relays, etc.) should be mounted in the Smart Panel enclosure or connected to power supplies in the control panel. Additionally, control wiring not connected to the Smart Panel should not be run through the cabinet. This could result in nuisance faults.

CAUTION:

Any inductive devices (relays) wired in series with the flow switch for start/stop, into the Alarm circuitry, or pilot relays for pump starters wired through motor contactor auxiliary contacts must be suppressed with YORK P/N 031-00808-000 suppressor across the relay/contact coil.

Any contacts connected to flow switch inputs or BAS inputs on terminals 13 - 19 or TB3, or any other terminals, must be suppressed with a YORK P/N 031-00808-000 suppressor across the relay/contact coil.

CAUTION:

Control wiring connected to the control panel should never be run in the same conduit with power wiring.

CONTROL POWER SUPPLY


UNIT VOLTAGE	CONTROL POWER SUPPLY	MIN CIRCUIT AMP.	MAX DUAL ELEMENT FUSE SIZE	NON-FUSED SWITCH SIZE
ALL MODELS W/O TRANS.	115-1-50/60	20A	20A 250V	30A 240V
MODELS WITH TRANS.	-17 200-1-60	15A	15A 250V	30A 240V
	-28 230-1-60	15A	15A 250V	30A 240V
	-46 400-1-60	8A	8A 600V	30A 480V
	-58 575-1-60	8A	8A 600V	30A 600V

* All primary and secondary wiring between transformer and control panel included.


WIRING DIAGRAM WYE-DELTA START

NOTES:

1. Field wiring to be in accordance with the current edition of the National Electrical Code as well as all other applicable codes and specifications.
2. Numbers along the right side of a diagram are line identification numbers. The numbers at each line indicate the line number location of relay contacts. An unlined contact location signifies a normally closed contact. Numbers adjacent to circuit lines are the circuit identification numbers.
3. Any customer supplied contacts must be suitable for switching 24VDC. (Gold contacts recommended.) Control Wiring must not be run in the same conduit with any line voltage wiring.
4. To cycle unit on and off automatically with contact shown, install a cycling device in series with the flow switch (FSLW). See Note 3 for contact rating and wiring specifications. Also refer to cautions on page 67.
5. To stop unit (Emergency Stop) with contacts other than those shown, install the stop contact between 5 and 1. If a stop device is not installed, a jumper must be connected between terminals 5 and 1. Device must have a minimum contact rating of 100VA at 115 volts A.C.
6. Alarm contacts are for annunciating alarm/unit malfunction. Contacts are rated at 115V, 100VA, resistive load only, and must be suppressed at load by user.
7. See Installation, Operation and Maintenance Manual when optional equipment is used.
8. Control panel to be securely connected to earth ground.
9. Use 2KVA transformer in optional transformer kit unless there are optional oil separator sump heaters which necessitates using a 3KVA transformer.



LD06991



LD06992A

LEGEND

T S	Transient Voltage Suppression
	Terminal Block for Customer Connections
	Terminal Block for Customer Low Voltage (Class 2) Connections. See Note 2
	Terminal Block for YORK Connections Only
	Wiring and Components by YORK
	Optional Equipment
	Wiring and/or Components by Others

FIG. 19 – WIRING DIAGRAM – WYE-DELTA START




FIG. 20 – ELEMENTARY DIAGRAM – WYE-DELTA START

ELEMENTARY DIAGRAM




FIG. 21 – ELEMENTARY DIAGRAM – WYE-DELTA START

785
790
795
800
805
810
815
820
825
830
840
850
855
860
865
870
875
880
885
890
895
900
905
910
915
920
925
930
935
940
945
950

LD003279

No Controls (relays, etc.) should be mounted in the Smart Panel enclosure or connected to power supplies in the control panel. Additionally, control wiring not connected to the Smart Panel should not be run through the cabinet. This could result in nuisance faults.

Any inductive devices (relays) wired in series with the flow switch for start/stop, into the Alarm circuitry, or pilot relays for pump starters wired through motor contactor auxiliary contacts must be suppressed with YORK P/N 031-00808-000 suppressor across the relay/contact coil.

Any contacts connected to flow switch inputs or BAS inputs on terminals 13 - 19 or TB3, or any other terminals, must be suppressed with a YORK P/N 031-00808-000 suppressor across the relay/contactors coil.

Control wiring connected to the control panel should never be run in the same conduit with power wiring.

UNIT VOLTAGE		CONTROL POWER SUPPLY	MIN CIRCUIT AMP.	MAX DUAL ELEMENT FUSE SIZE	NON-FUSED DISC. SWITCH SIZE
ALL MODELS W/O TRANS.		115-1-50/60	20A	20A 250V	30A 240V
MODELS WITH TRANS. *	-17	200-1-60	15A	15A 250V	30A 240V
	-28	230-1-60	15A	15A 250V	30A 240V
	-46	400-1-60	8A	8A 600V	30A 480V
	-58	575-1-60	8A	8A 600V	30A 600V

67




ELECTRONIC PANEL
(FRONT INSIDE VIEW)

FIG. 22B – POWER PANEL COMPONENT LOCATION

LEGEND





1CR THRU 4CR, 9CR/ -K1 THRU -K4, -K9	-CONTROL RELAYS	1M, 3M/ 1-KLC OR 1-KALC, 2-KLC OR 2-KALC	-COMPRESSOR CONTACTORS	2T, 3T, 4T/ -T2, -T3, -T4	-MICRO PANEL TRANSFORMERS
CB1, CB2, CB3/ -QCB1, -QCB2, -QCB3	-CIRCUIT BREAKERS	2M, 4M/ 1-KDC, 2-KDC	-COMPRESSOR CONTACTORS	1TR, 2TR/ -K10, -K11	-TIMER RELAYS
9CB THRU 14CB	-OVERLOAD CIRCUIT BREAKERS (SYS. #1)	1S, 2S/ 1-KSC, 2-KSC	-COMPRESSOR CONTACTORS	TS/-ES	-TRANSIENT SUPPRESSORS
15CB THRU 20CB	-OVERLOAD CIRCUIT BREAKERS (SYS. #2)	9M THRU 14M/ -KF9 THRU -KF14	-CONDENSER FAN CONTACTORS (SYS. #1)	PTB1, PTB2/ 1-XTB, 2-XTB	-POWER TERMINAL BLOCK
9 OL THRU 14 OL	-MOTOR OVERLOADS (SYS. #1)	15M THRU 20M/ -KF15 THRU -KF20	-CONDENSER FAN CONTACTORS (SYS. #2)	MCB1, MCB2/ 1-QCB, 2-QCB	-MOTOR CIRCUIT BREAKER
15 OL THRU 20 OL	-MOTOR OVERLOADS (SYS. #2)	1MP/1-FMP	-MOTOR PROTECTOR (SYS. #1)	DSW1, DSW2/ 1-QSD, 2-QSD	-DISCONNECT SERVICE SWITCH
-QFCB9 THRU -QFCB14	-MOTOR OVERLOADS W/OVERLOAD CIRCUIT BREAKERS (SYS. #1)	2MP/2-FMP	-MOTOR PROTECTOR (SYS. #2)		-WIRING BY YORK
-QFCB15 THRU -QFCB20	-MOTOR OVERLOADS W/OVERLOAD CIRCUIT BREAKERS (SYS. #2)	1T/-T1	-CONTROL TRANSFORMER 2KVA (OPTIONAL)		-WIRING BY OTHERS
3FU, 4FU/ -F3, -F4	-TRANSFORMER FUSE (OPTIONAL)				-OPTIONAL WIRING AND/OR COMPONENTS

CONNECTION DIAGRAM, ELEC. BOX DXST DIRECT DRIVE

J1, J2, J3, J4, J5, J6, J7, J8, P7 & P8 — POWER PANEL

P1, P2, P3, P4, P5, & P6 — ELECTRONIC (MICRO) PANEL

NOTE: WIRE NUMBERS IDENTIFIED IN (PARENTHESIS) INDICATE THE ACTUAL HARNESS CODE STAMPED ON THE WIRE.



PLUG NO.	WIRE NO.	PLUG PIN NO.
P1	21	1
	2	2
	22	3
	31	4
	32	5

PLUG NO.	WIRE NO.	PLUG PIN NO.
P2	21	1
	2	2
	22	3
	33	4
	34	5

PLUG NO.	WIRE NO.	PLUG PIN NO.
P3	2	1
	GRD	2
	129	5
	127	6
	121	11

PLUG NO.	WIRE NO.	PLUG PIN NO.
P4	2	1
	GRD	2
	227	4
	229	5
	221	11

PLUG NO.	WIRE NO.	PLUG PIN NO.
P5	130	1
	131	2
	132	3
	148	4
	118	6

PLUG NO.	WIRE NO.	PLUG PIN NO.
P6	230	1
	231	2
	232	3
	248	4
	218	6

PLUG NO.	WIRE NO.	PLUG PIN NO.
P7	125	1
	2	2
	123	3
	140	4
	141	5
	142	6
	32	7

PLUG NO.	WIRE NO.	PLUG PIN NO.
P8	225	1
	2	2
	223	3
	240	4
	241	5
	242	6
	34	7

PLUG NO.	WIRE NO.	PLUG PIN NO.
J1	21	1
	2	2
	22	3
	3Y	4
	3X	5

PLUG NO.	WIRE NO.	PLUG PIN NO.
J2	21	1
	2	2
	22	3
	3Y	4
	3X	5

PLUG NO.	WIRE NO.	PLUG PIN NO.
J3	2	1
	GRD	2
	125	4
	129	5
	127	6
	121	11
	122	12

PLUG NO.	WIRE NO.	PLUG PIN NO.
J4	2	1
	GRD	2
	225	3
	227	4
	229	5
	221	11
	122	12

PLUG NO.	WIRE NO.	PLUG PIN NO.
J5	30	1
	31	2
	32	3
	48	4
	18	6

PLUG NO.	WIRE NO.	PLUG PIN NO.
J6	30	1
	31	2
	32	3
	48	4
	18	6

PLUG NO.	WIRE NO.	PLUG PIN NO.
J7	25	1
	2	2
	23	3
	40	4
	41	5
	42	6
	3X	7

PLUG NO.	WIRE NO.	PLUG PIN NO.
J8	25	1
	2	2
	23	3
	40	4
	41	5
	42	6
	3X	7

LD03281

NOTES:


1. FIELD WIRING TO BE IN ACCORDANCE WITH THE CURRENT EDITION OF THE NATIONAL ELECTRICAL CODE AS WELL AS ALL OTHER APPLICABLE CODES AND SPECIFICATIONS.
2. CONTACTS MUST BE SUITABLE FOR SWITCHING 24VDC. (GOLD CONTACTS RECOMMENDED). WIRING SHALL NOT BE RUN IN THE SAME CONDUIT WITH ANY LINE VOLTAGE (CLASS 1) WIRING.
3. TO CYCLE UNIT ON AND OFF AUTOMATICALLY WITH CONTACT SHOWN, INSTALL A CYCLING DEVICE IN SERIES WITH THE FLOW SWITCH. SEE NOTE 2 FOR CONTACT RATING AND WIRING SPECIFICATIONS.
4. TO STOP UNIT (EMERGENCY STOP) WITH CONTACTS OTHER THAN THOSE SHOWN, INSTALL THE STOP CONTACT BETWEEN TERMINALS 5 AND 1. IF A STOP DEVICE IS NOT INSTALLED, A JUMPER MUST BE CONNECTED BETWEEN TERMINALS 5 AND 1. DEVICE MUST HAVE A MINIMUM CONTACT RATING OF 6A AT 115VOLTS A.C.
5. CONTACTS ARE RATED AT 115V, 100VA, RESISTIVE LOAD ONLY, AND MUST BE SUPPRESSED AT LOAD BY USER.
6. SEE INSTALLATION, OPERATION AND MAINTENANCE MANUAL WHEN OPTIONAL EQUIPMENT IS USED.

LD03282

LEGEND

TS	TRANSIENT VOLTAGE SUPPRESSION
	TERMINAL BLOCK FOR CUSTOMER CONNECTIONS
	TERMINAL BLOCK FOR CUSTOMER LOW VOLTAGE (CLASS 2) CONNECTIONS. SEE NOTE 2.
	TERMINAL BLOCK FOR YORK CONNECTIONS ONLY
	WIRING AND COMPONENTS BY YORK
	OPTIONAL EQUIPMENT
	WIRING AND/OR COMPONENTS BY OTHERS

LD03283




DETAIL "A"

LD03284

CONNECTION DIAGRAM (SYSTEM WIRING)

CONNECTION DIAGRAM SYSTEM WIRING
YCAS098-208
(STYLE F)




LD06256

LEGEND


- 1 HPCO SYS. No.1 HIGH PRESS. CUTOUT
- 2 HPCO SYS. No.2 HIGH PRESS. CUTOUT
- 1 HTR SYS. No.1 COMPR. CRANKCASE HEATER
- 2 HTR SYS. No.2 COMPR. CRANKCASE HEATER
- 3 HTR COOLER HEATER
- 1 LLSV SYS. No.1 LIQUID LINE SOLENOID VALVE (UNIT IDENT)
- 2 LLSV SYS. No.2 LIQUID LINE SOLENOID VALVE (UNIT IDENT)
- 1 ESV ECONOMIZER SOLENOID VALVE (UNIT IDENT)
- 2 ESV ECONOMIZER SOLENOID VALVE (UNIT IDENT)
- TXV 1 SYS. No.1 THERMAL EXPANSION VALVE (UNIT IDENT)
- TXV 2 SYS. No.2 THERMAL EXPANSION VALVE (UNIT IDENT)

COOLER







LD03231

COMPRESSORS (SYSTEMS 1 & 2)



LD03232



COMPRESSOR TERMINAL BOX



LD03233



LD03285




DETAIL "C"


SEE ENGINEERING GUIDE OR INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR NUMBER OF CONDENSER FANS FOR CHILLER MODEL.

LD06840A

DIMENSIONS – YCAS0098EB - YCAS0118EB (ENGLISH)



LD06996a



POWER: MULTIPLE POINT WITH TERMINAL BLOCKS


LD05399B

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 6'; rear to wall - 6'; control panel end to wall - 4'; top - no obstructions allowed; distance between adjacent units - 10'. No more than one adjacent wall may be higher than the unit.

FIG. 23 – MODEL YCAS0098EB - 0118EB DIMENSIONS (ENGLISH)


DIMENSIONS – YCAS0098EB - YCAS0118EB (ENGLISH)


CENTER OF GRAVITY (Alum.)

YCAS	X	Y	Z
0098	95.3	46.4	38.5
0118	93.5	47.6	37.5


CENTER OF GRAVITY (Copper)

YCAS	X	Y	Z
0098	95.2	46.1	41.2
0118	93.6	47.2	40.2




DIMENSIONS – YCAS0098EB - YCAS0118EB (SI)

All dimensions
are in mm unless
otherwise noted.



LD05826A



POWER: MULTIPLE POINT WITH TERMINAL BLOCKS


LD05827A

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 2m; rear to wall - 2m; control panel end to wall - 1.2m; top - no obstructions allowed; distance between adjacent units - 3m. No more than one adjacent wall may be higher than the unit.

FIG. 24 – MODEL YCAS0098EB - 0118EB DIMENSIONS (SI)


DIMENSIONS – YCAS0098EB - YCAS0118EB (SI)



LD05828A


CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0098	2421	1179	978
0118	2375	1209	953

CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0098	2418	1171	1046
0118	2377	1199	1021




LD05829A

DIMENSIONS – YCAS0128EB (ENGLISH)



LD06999A



POWER: MULTIPLE POINT WITH TERMINAL BLOCKS


LD07000A

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 6'; rear to wall - 6'; control panel end to wall - 4'; top - no obstructions allowed; distance between adjacent units - 10'. No more than one adjacent wall may be higher than the unit.

FIG. 25 – MODEL YCAS0128EB DIMENSIONS (ENGLISH)


DIMENSIONS – YCAS0128EB (ENGLISH)



LD07001A

CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0128	110.0	43.0	33.0


CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0128	110.0	43.0	36.0




LD07002A

DIMENSIONS – YCAS0128EB (SI)

*All dimensions
are in mm unless
otherwise noted.*



LD05830A



LD05831A


POWER: MULTIPLE POINT WITH TERMINAL BLOCKS

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 2m; rear to wall - 2m; control panel end to wall - 1.2m; top - no obstructions allowed; distance between adjacent units - 3m. No more than one adjacent wall may be higher than the unit.


FIG. 26 – MODEL YCAS0128EB DIMENSIONS (SI)

DIMENSIONS – YCAS0128EB (SI)




CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0128	2794	1092	838

CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0128	2819	1092	914




LD05833A

DIMENSIONS – YCAS0138EB (ENGLISH)



LD05641A



LD05642A


POWER: MULTIPLE POINT WITH TERMINAL BLOCKS

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 6'; rear to wall - 6'; control panel end to wall - 4'; top - no obstructions allowed; distance between adjacent units - 10'. No more than one adjacent wall may be higher than the unit.


FIG. 27 – MODEL YCAS0138EB DIMENSIONS (ENGLISH)

DIMENSIONS – YCAS0138EB (ENGLISH)




CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0138	109.0	44.0	38.0

CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0138	110.0	44.4	40.7




DIMENSIONS – YCAS0138EB (SI)

*All dimensions
are in mm unless
otherwise noted.*



LD05834A



VIEW A-A


LD05835A

NOTES: POWER: MULTIPLE POINT WITH TERMINAL BLOCKS

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 2m; rear to wall - 2m; control panel end to wall - 1.2m; top - no obstructions allowed; distance between adjacent units - 3m. No more than one adjacent wall may be higher than the unit.


FIG. 28 – MODEL YCAS0138EB DIMENSIONS (SI)

DIMENSIONS – YCAS0138EB (SI)




CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0138	2769	1118	965


CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0138	2794	1128	1034



DIMENSIONS – YCAS0148EB - YCAS0178EB (ENGLISH)



LD07005A



VIEW A-A

POWER: MULTIPLE POINT WITH TERMINAL BLOCKS

LD07006A

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 6'; rear to wall - 6'; control panel end to wall - 4'; top - no obstructions allowed; distance between adjacent units - 10'. No more than one adjacent wall may be higher than the unit.

FIG. 29 – MODEL YCAS0148EB - 0178EB DIMENSIONS (ENGLISH)

JOHNSON CONTROLS





CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0148	111.1	42.8	36.4
0158	111.2	43.0	36.4
0178	110.9	43.1	36.3



DIMENSIONS – YCAS0148EB - YCAS0178EB (SI)

*All dimensions
are in mm unless
otherwise noted.*



POWER: MULTIPLE POINT WITH TERMINAL BLOCKS


LD05839A

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 2m; rear to wall - 2m; control panel end to wall - 1.2m; top - no obstructions allowed; distance between adjacent units - 3m. No more than one adjacent wall may be higher than the unit.


FIG. 30 – MODEL YCAS0148EB - 0178EB DIMENSIONS (SI)

DIMENSIONS – YCAS0148EB - YCAS0178EB (SI)




CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0148	2802	1085	848
0158	2804	1087	846
0178	2797	1092	846


CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0148	2822	1087	925
0158	2824	1092	925
0178	2817	1095	922



DIMENSIONS – YCAS0198EB - YCAS0208EB (ENGLISH)



LD07009A



POWER: SINGLE POINT WITH CIRCUIT BREAKER


LD07010A

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 6'; rear to wall - 6'; control panel end to wall - 4'; top - no obstructions allowed; distance between adjacent units - 10'. No more than one adjacent wall may be higher than the unit.


FIG. 31 – MODEL YCAS0198EB - 0208EB DIMENSIONS (ENGLISH)

DIMENSIONS – YCAS0198EB - YCAS0208EB (ENGLISH)




CENTER OF GRAVITY (Alum.)			
YCAS	X	Y	Z
0198	110.2	43.2	33.2
0208	123.5	43.4	34.8

CENTER OF GRAVITY (Copper)			
YCAS	X	Y	Z
0198	110.8	43.4	36.1
0208	125.6	43.4	38.0




DIMENSIONS – YCAS0198EB - YCAS0208EB (SI)

*All dimensions
are in mm unless
otherwise noted.*



LD05842A



LD05843A


POWER: MULTIPLE POINT WITH TERMINAL BLOCKS

NOTES:

1. Placement on a level surface free of obstructions (including snow, for winter operation) or air recirculation ensures rated performance, reliable operation and ease of maintenance. Site restrictions may compromise minimum clearances indicated below, resulting in unpredictable air flow patterns and possible diminished performance. YORK's unit controls will optimize operation without nuisance high pressure safety cutout; however, the system designer must consider potential performance degradation. Access to the unit control center assumes the unit is no higher than on spring isolators. Recommended minimum clearances: Side to wall - 2m; rear to wall - 2m; control panel end to wall - 1.2m; top - no obstructions allowed; distance between adjacent units - 3m. No more than one adjacent wall may be higher than the unit.

FIG. 32 – MODEL YCAS0198EB - 0208EB DIMENSIONS (SI)

DIMENSIONS – YCAS0198EB - YCAS0208EB (SI)




CENTER OF GRAVITY (Alum.)


YCAS	X	Y	Z
0198	2799	1097	843
0208	3137	1102	884

CENTER OF GRAVITY (Copper)

YCAS	X	Y	Z
0198	2814	1102	917
0208	3190	1102	965



TECHNICAL DATA CLEARANCES



LD07011A

NOTES:

1. No obstructions allowed above the unit.
2. Only one adjacent wall may be higher than the unit.
3. Adjacent units should be 10 feet (3 meters) apart.

FIG. 33 – CLEARANCES

OPERATING WEIGHTS – ALUMINUM & BLACK FIN COILS

ALUMINUM & BLACK FIN WEIGHT DISTRIBUTION BY MODEL (lbs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	2,070	1,640	1,211	1,986	1,573	1,161	—	—	—	—	—	—	—	—	—	—	9,641
YCAS0118	2,173	1,701	1,230	2,078	1,627	1,176	—	—	—	—	—	—	—	—	—	—	9,985
YCAS0128	1,798	1,643	1,488	1,334	1,914	1,749	1,584	1,420	—	—	—	—	—	—	—	—	12,930
YCAS0138	1,861	1,665	1,469	1,272	1,762	1,576	1,390	1,204	—	—	—	—	—	—	—	—	12,200
YCAS0148	1,830	1,686	1,542	1,398	1,932	1,781	1,629	1,477	—	—	—	—	—	—	—	—	13,275
YCAS0158	1,826	1,678	1,529	1,381	1,928	1,772	1,615	1,458	—	—	—	—	—	—	—	—	13,187
YCAS0178	1,852	1,706	1,560	1,414	1,944	1,791	1,638	1,485	—	—	—	—	—	—	—	—	13,391
YCAS0198	1,740	1,759	1,777	1,796	1,803	1,823	1,842	1,861	—	—	—	—	—	—	—	—	14,401
YCAS0208	1,758	1,780	1,802	1,825	1,813	1,836	1,859	1,882	—	—	—	—	—	—	—	—	14,555

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ALUMINUM & BLACK FIN WEIGHT DISTRIBUTION BY MODEL (kgs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	939	744	549	901	714	527	—	—	—	—	—	—	—	—	—	—	4,373
YCAS0118	986	772	558	943	738	533	—	—	—	—	—	—	—	—	—	—	4,529
YCAS0128	816	745	675	605	868	793	718	644	—	—	—	—	—	—	—	—	5,865
YCAS0138	844	755	666	577	799	715	630	546	—	—	—	—	—	—	—	—	5,534
YCAS0148	830	765	699	634	876	808	739	670	—	—	—	—	—	—	—	—	6,021
YCAS0158	828	761	694	626	875	804	733	661	—	—	—	—	—	—	—	—	5,982
YCAS0178	840	774	708	641	882	812	743	674	—	—	—	—	—	—	—	—	6,074
YCAS0198	789	798	806	815	818	827	836	844	—	—	—	—	—	—	—	—	6,532
YCAS0208	797	807	817	828	822	833	843	854	—	—	—	—	—	—	—	—	6,602

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ALUMINUM & BLACK FIN, SEISMIC ISOLATOR SELECTIONS - VMC MODEL # AWMR-X-XXX (See Table 2)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	1-553	1-551	1-531	1-553	1-551	1-531	—	—	—	—	—	—	—	—	—	—
YCAS0118	1-553	1-552	1-531	1-553	1-551	1-531	—	—	—	—	—	—	—	—	—	—
YCAS0128	1-552	1-551	1-532	1-532	1-553	1-552	1-551	1-532	—	—	—	—	—	—	—	—
YCAS0138	1-552	1-551	1-532	1-531	1-552	1-551	1-532	1-531	—	—	—	—	—	—	—	—
YCAS0148	1-552	1-552	1-551	1-532	1-553	1-552	1-551	1-532	—	—	—	—	—	—	—	—
YCAS0158	1-552	1-552	1-551	1-532	1-553	1-552	1-551	1-532	—	—	—	—	—	—	—	—
YCAS0178	1-552	1-552	1-551	1-532	1-553	1-552	1-551	1-532	—	—	—	—	—	—	—	—
YCAS0198	1-552	1-552	1-552	1-552	1-552	1-552	1-552	1-552	—	—	—	—	—	—	—	—
YCAS0208	1-552	1-552	1-552	1-552	1-552	1-552	1-552	1-552	—	—	—	—	—	—	—	—

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ISOLATOR SELECTION – ALUMINUM & BLACK FIN COILS

ALUMINUM & BLACK FIN, 1" ISOLATOR SELECTIONS - VMC TYPE CP-2-XX (See Table 3)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	2-31	2-28	2-27	2-31	2-28	2-26	—	—	—	—	—	—	—	—	—	—
YCAS0118	2-31	2-28	2-27	2-31	2-28	2-26	—	—	—	—	—	—	—	—	—	—
YCAS0128	2-28	2-28	2-27	2-27	2-31	2-28	2-28	2-27	—	—	—	—	—	—	—	—
YCAS0138	2-31	2-28	2-27	2-27	2-28	2-28	2-27	2-27	—	—	—	—	—	—	—	—
YCAS0148	2-31	2-28	2-28	2-27	2-31	2-28	2-28	2-27	—	—	—	—	—	—	—	—
YCAS0158	2-31	2-28	2-28	2-27	2-31	2-28	2-28	2-27	—	—	—	—	—	—	—	—
YCAS0178	2-31	2-28	2-28	2-27	2-31	2-28	2-28	2-27	—	—	—	—	—	—	—	—
YCAS0198	2-28	2-28	2-28	2-28	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0208	2-28	2-28	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—

*CP-4-XX

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ALUMINUM & BLACK FIN, NEOPRENE MOUNT SELECTION - VMC TYPE RD-4 (See Table 1)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	-4 RED	-4 RED	-4 BLK	-4 RED	-4 RED	-4 BLK	—	—	—	—	—	—	—	—	—	—
YCAS0118	-4 RED	-4 RED	-4 BLK	-4 RED	-4 RED	-4 BLK	—	—	—	—	—	—	—	—	—	—
YCAS0128	-4 RED	-4 RED	-4 BLK	-4 BLK	-4 RED	-4 RED	-4 BLK	-4 BLK	—	—	—	—	—	—	—	—
YCAS0138	-4 RED	-4 RED	-4 BLK	-4 BLK	-4 RED	-4 RED	-4 BLK	-4 BLK	—	—	—	—	—	—	—	—
YCAS0148	-4 RED	-4 RED	-4 RED	-4 BLK	-4 RED	-4 RED	-4 RED	-4 BLK	—	—	—	—	—	—	—	—
YCAS0158	-4 RED	-4 RED	-4 RED	-4 BLK	-4 RED	-4 RED	-4 RED	-4 BLK	—	—	—	—	—	—	—	—
YCAS0178	-4 RED	-4 RED	-4 RED	-4 BLK	-4 RED	-4 RED	-4 RED	-4 BLK	—	—	—	—	—	—	—	—
YCAS0198	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0208	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—

*VMC Type RD-3


Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

WEIGHT DISTRIBUTION AND ISOLATOR MOUNTING POSITIONS

Aluminum Fin and Black Fin Condenser Coils

ISOLATOR DETAILS



LD01089

FIG. 34 – CP-2-XX

ISOLATOR TYPE & SIZE	MAX LOAD		DEFL.		SPRING COLOR
	lbs.	kg	in.	mm	
CP-2-26	1200	544.3	1.17	29.7	Purple
CP-2-27	1500	680.4	1.06	26.9	Orange
CP-2-28	1800	816.4	1.02	25.9	Green
CP-2-31	2200	997.9	0.83	21.0	Gray
CP-2-32	2600	1179.3	0.74	18.7	White

WEIGHT DISTRIBUTION AND ISOLATOR MOUNTING POSITIONS

Aluminum Fin and Black Fin Condenser Coils

60 HERTZ, ALUMINUM & BLACK FINNS, NEOPRENE MOUNT

SELECTIONS – VMC TYPE RD-4

YCAS	A	B	C	D	E	F
0090	BLACK	BLACK	GRAY*	RED	BLACK	GRAY*
0100	BLACK	BLACK	GRAY*	RED	BLACK	BLACK
0110	RED	BLACK	BLACK	RED	BLACK	BLACK
0120	RED	BLACK	BLACK	RED	BLACK	BLACK

NEW DESIGN FOR TYPE RD-4 NEOPRENE MOUNTINGS.



**TYPE R OR RD
NO BOLTING IS
PREFERRED—**

Type R or RD mountings are may be used without bolting under machines having no lateral or severe vertical motion.


29518A

TYPE RD-3




**TYPE R OR RD
IF BOLTING IS PREFERRED—**
Type R or RD mountings are furnished with a tapped hole in the center. This enables the equipment to be bolted securely to the mounting.

29517A



LD04034



LD04033

TYPE	COLOR CODE	MAX. LOAD		DEFLECTION ins. (mm)	
		lbs.	(kg)	R	RD
R-3 OR RD-3	BLACK	250	(113.5)	0.25 (6.3)	0.50 (12.7)
	RED	525	(238.3)		
	GREEN	750	(340.5)		
	GRAY	1100	(499.4)		
R-4 OR RD-4	BLACK	1500	(681.0)	0.25 (6.3)	0.50 (12.7)
	RED	2250	(1021.5)		
	GREEN	3000	(1362.0)		
	GRAY	4000	(1816.0)		

DIMENSIONS: ins. (mm)


TYPE	L	W	H	*HD	A	B	C	D	E
R-3 OR RD-3	5-1/2" (139.7)	3-3/8" (85.8)	1-3/4" (44.4)	2-7/8" (73.2)	2-1/2" (63.5)	1/2" (12.7)	4-1/8" (104.8)	9/16" (14.4)	1/4" (6.3)
R-4 OR RD-4	6-1/4" (158.7)	4-5/8" (117.6)	1-5/8" (41.4)	2-3/4" (69.8)	3" (76.2)	1/2" (12.7)	5" (127.0)	9/16" (14.4)	3/8" (9.6)

* HD dimension applies to double deflection Type RD mountings only.

WEIGHT DISTRIBUTION AND ISOLATOR MOUNTING POSITIONS


Aluminum Fin and Black Fin Condenser Coils

ISOLATOR TYPE & SIZE	MAX LOAD		DEFL.	
	lbs.	kg	in.	mm
AWMR-1-530	1150	521.6	2	51
AWMR-1-531	1276	578.8	2	51
AWMR-1-532	1500	680.4	2	51
AWMR-1-551	1676	760.2	2	51
AWMR-1-552	1900	861.8	2	51
AWMR-1-553	2200	997.9	2	51
AWMR-2-531	2552	1157.6	2	51



AWMR-1-XXX

LD02973



AWMR-2-XXX

LD02974

DIMENSIONS - In.

	A	B	C	D	E	F	G	H	I	J	K	L	M	N/X
AWMR-1 50-553	10-1/2	6	3	5/8 11NC	3/4	3-1/2	1-3/4	1/2	9	5/8	8-1/2	4-1/4	10-1/2	3/4 5/8
AWMR-2 50-553	15	6	3	3/4 10NC	1	7-1/2	3-3/4	1/2	9-1/2	5/8	14-1/2	7-1/4	17	3/4 5/8

FIG. 35 – ISOLATOR DETAILS

OPERATING WEIGHTS

COPPER FIN COILS (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT)

COPPER FIN (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT) WEIGHT DISTRIBUTION BY MODEL (lbs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	2,263	1,790	1,318	2,179	1,723	1,268	—	—	—	—	—	—	—	—	—	—	10,541
YCAS0118	2,347	1,851	1,356	2,252	1,777	1,302	—	—	—	—	—	—	—	—	—	—	10,885
YCAS0128	1,921	1,789	1,657	1,526	2,033	1,894	1,755	1,615	—	—	—	—	—	—	—	—	14,190
YCAS0138	1,981	1,810	1,639	1,468	1,884	1,722	1,559	1,396	—	—	—	—	—	—	—	—	13,459
YCAS0148	1,953	1,832	1,711	1,591	2,052	1,925	1,799	1,672	—	—	—	—	—	—	—	—	14,535
YCAS0158	1,949	1,823	1,698	1,573	2,048	1,917	1,785	1,654	—	—	—	—	—	—	—	—	14,447
YCAS0178	1,975	1,852	1,730	1,607	2,064	1,936	1,808	1,680	—	—	—	—	—	—	—	—	14,651
YCAS0198	1,884	1,934	1,983	2,033	1,946	1,997	2,048	2,100	—	—	—	—	—	—	—	—	15,925
YCAS0208	1,902	1,955	2,008	2,061	1,956	2,011	2,065	2,120	—	—	—	—	—	—	—	—	16,079

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FIN (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT) WEIGHT DISTRIBUTION BY MODEL (kgs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	1,026	812	598	988	782	575	—	—	—	—	—	—	—	—	—	—	4,781
YCAS0118	1,065	840	615	1,021	806	591	—	—	—	—	—	—	—	—	—	—	4,937
YCAS0128	871	811	752	692	922	859	796	733	—	—	—	—	—	—	—	—	6,436
YCAS0138	899	821	743	666	855	781	707	633	—	—	—	—	—	—	—	—	6,105
YCAS0148	886	831	776	722	931	873	816	758	—	—	—	—	—	—	—	—	6,593
YCAS0158	884	827	770	714	929	870	810	750	—	—	—	—	—	—	—	—	6,553
YCAS0178	896	840	785	729	936	878	820	762	—	—	—	—	—	—	—	—	6,646
YCAS0198	855	877	899	922	883	906	929	953	—	—	—	—	—	—	—	—	7,223
YCAS0208	863	887	911	935	887	912	937	962	—	—	—	—	—	—	—	—	7,293

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FINS (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT), SEISMIC ISOLATOR SELECTIONS - VMC MODEL # AWMR-X-XXX – (See Table 2)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	2-531	1-553	1-551	2-531	1-553	1-532	—	—	—	—	—	—	—	—	—	—
YCAS0118	2-531	1-553	1-551	2-531	1-553	1-532	—	—	—	—	—	—	—	—	—	—
YCAS0128	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0138	1-553	2-53	1-552	1-552	2-53	1-552	1-552	1-552	—	—	—	—	—	—	—	—
YCAS0148	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0158	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0178	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0198	1-553	1-553	2-530	2-531	1-553	2-530	2-530	2-531	—	—	—	—	—	—	—	—
YCAS0208	1-553	1-553	2-530	2-531	1-553	2-530	2-530	2-531	—	—	—	—	—	—	—	—

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ISOLATOR SELECTION

COPPER FIN COILS (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT)

COPPER FINS (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT), 1" ISOLATOR SELECTIONS - VMC TYPE CP-2-XX – (See Table 3)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	2-32	2-31	2-28	2-32	2-31	2-27	—	—	—	—	—	—	—	—	—	—
YCAS0118	2-32	2-31	2-28	2-32	2-31	2-27	—	—	—	—	—	—	—	—	—	—
YCAS0128	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0138	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0148	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0158	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0178	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	—	—	—	—	—	—	—	—
YCAS0198	2-31	2-31	2-32	2-32	2-31	2-32	2-32	2-32	—	—	—	—	—	—	—	—
YCAS0208	2-31	2-31	2-32	2-32	2-31	2-32	2-32	2-32	—	—	—	—	—	—	—	—

*CP-4-XX

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FINS (OR ALUMINUM FIN WITH OPTIONAL SILENCER KIT), NEOPRENE MOUNT SELECTION- VMC TYPE RD-4 (See Table 1)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	-4 GRN	-4 RED	-4 RED	-4 GRN	-4 RED	-4 BLK	—	—	—	—	—	—	—	—	—	—
YCAS0118	-4 GRN	-4 RED	-4 RED	-4 GRN	-4 RED	-4 BLK	—	—	—	—	—	—	—	—	—	—
YCAS0128	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0138	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0148	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0158	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0178	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	-4 RED	—	—	—	—	—	—	—	—
YCAS0198	-4 RED	-4 RED	-4 RED	-4 GRN	-4 RED	-4 RED	-4 GRN	-4 GRN	—	—	—	—	—	—	—	—
YCAS0208	-4 RED	-4 RED	-4 RED	-4 GRN	-4 RED	-4 RED	-4 GRN	-4 GRN	—	—	—	—	—	—	—	—

VMC Type RD-3

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

OPERATING WEIGHTS COPPER FIN COILS WITH OPTIONAL SILENCER KIT

COPPER FIN WITH OPTIONAL SILENCER KIT WEIGHT DISTRIBUTION BY MODEL (lbs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	2,446	1,980	1,515	2,364	1,913	1,463	—	—	—	—	—	—	—	—	—	—	11,681
YCAS0118	2,529	2,041	1,554	2,437	1,967	1,497	—	—	—	—	—	—	—	—	—	—	12,025
YCAS0128	2,062	1,941	1,820	1,699	2,165	2,038	1,911	1,784	—	—	—	—	—	—	—	—	15,421
YCAS0138	2,045	1,951	1,857	1,764	1,955	1,865	1,776	1,686	—	—	—	—	—	—	—	—	14,899
YCAS0148	2,023	1,975	1,928	1,881	2,116	2,067	2,017	1,968	—	—	—	—	—	—	—	—	15,975
YCAS0158	2,019	1,967	1,915	1,863	2,112	2,058	2,004	1,949	—	—	—	—	—	—	—	—	15,887
YCAS0178	2,044	1,995	1,946	1,897	2,129	2,077	2,026	1,975	—	—	—	—	—	—	—	—	16,091
YCAS0198	2,079	2,144	2,208	2,273	2,140	2,207	2,274	2,340	—	—	—	—	—	—	—	—	17,665
YCAS0208	2,097	2,165	2,233	2,302	2,150	2,220	2,290	2,360	—	—	—	—	—	—	—	—	17,819

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FIN WITH OPTIONAL SILENCER KIT WEIGHT DISTRIBUTION BY MODEL (lbs.)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Total
YCAS0098	1,109	898	687	1,072	868	664	—	—	—	—	—	—	—	—	—	—	5,298
YCAS0118	1,147	926	705	1,105	892	679	—	—	—	—	—	—	—	—	—	—	5,454
YCAS0128	935	880	826	771	982	924	867	809	—	—	—	—	—	—	—	—	6,995
YCAS0138	928	885	843	800	887	846	805	765	—	—	—	—	—	—	—	—	6,758
YCAS0148	918	896	875	853	960	938	915	893	—	—	—	—	—	—	—	—	7,246
YCAS0158	916	892	869	845	958	933	909	884	—	—	—	—	—	—	—	—	7,206
YCAS0178	927	905	883	860	966	942	919	896	—	—	—	—	—	—	—	—	7,299
YCAS0198	943	973	1,002	1,031	971	1,001	1,031	1,061	—	—	—	—	—	—	—	—	8,013
YCAS0208	951	982	1,013	1,044	975	1,007	1,039	1,070	—	—	—	—	—	—	—	—	8,083

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FIN WITH OPTIONAL SILENCER KIT, SEISMIC ISOLATOR SELECTIONS - VMC MODEL # AWMR-X-XXX – (See Table 2)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	2-531	1-553	1-551	2-531	1-553	1-532	—	—	—	—	—	—	—	—	—	—
YCAS0118	2-531	1-553	1-551	2-531	1-553	1-532	—	—	—	—	—	—	—	—	—	—
YCAS0128	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0138	1-553	2-53	1-552	1-552	2-53	1-552	1-552	1-552	—	—	—	—	—	—	—	—
YCAS0148	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0158	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0178	1-553	1-553	1-553	1-552	1-553	1-553	1-553	1-553	—	—	—	—	—	—	—	—
YCAS0198	1-553	1-553	2-530	2-531	1-553	2-530	2-530	2-531	—	—	—	—	—	—	—	—
YCAS0208	1-553	1-553	2-530	2-531	1-553	2-530	2-530	2-531	—	—	—	—	—	—	—	—

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

ISOLATOR SELECTION

COPPER FIN COILS WITH OPTIONAL SILENCER KIT

COPPER FINNS WITH OPTIONAL SILENCER KIT, 1" ISOLATOR SELECTIONS - VMC TYPE CP-2-XX – (See Table 3)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	2-32	2-31	2-28	2-32	2-31	2-27	---	---	---	---	---	---	---	---	---	---
YCAS0118	2-32	2-31	2-28	2-32	2-31	2-27	---	---	---	---	---	---	---	---	---	---
YCAS0128	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	---	---	---	---	---	---	---	---
YCAS0138	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	---	---	---	---	---	---	---	---
YCAS0148	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	---	---	---	---	---	---	---	---
YCAS0158	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	---	---	---	---	---	---	---	---
YCAS0178	2-31	2-31	2-31	2-31	2-31	2-31	2-31	2-31	---	---	---	---	---	---	---	---
YCAS0198	2-31	2-31	2-32	2-32	2-31	2-32	2-32	2-32	---	---	---	---	---	---	---	---
YCAS0208	2-31	2-31	2-32	2-32	2-31	2-32	2-32	2-32	---	---	---	---	---	---	---	---

*CP-4-XX

Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

COPPER FINNS WITH OPTIONAL SILENCER KIT, NEOPRENE MOUNT SELECTION- VMC TYPE RD-4 (See Table 1)

60 Hz	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
YCAS0098	4 GRN	4 RED	4 RED	4 GRN	4 RED	4 BLK	---	---	---	---	---	---	---	---	---	---
YCAS0118	4 GRN	4 RED	4 RED	4 GRN	4 RED	4 BLK	---	---	---	---	---	---	---	---	---	---
YCAS0128	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	---	---	---	---	---	---	---	---
YCAS0138	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	---	---	---	---	---	---	---	---
YCAS0148	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	---	---	---	---	---	---	---	---
YCAS0158	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	---	---	---	---	---	---	---	---
YCAS0178	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	4 RED	---	---	---	---	---	---	---	---
YCAS0198	4 RED	4 RED	4 RED	4 GRN	4 RED	4 RED	4 GRN	4 GRN	---	---	---	---	---	---	---	---
YCAS0208	4 RED	4 RED	4 RED	4 GRN	4 RED	4 RED	4 GRN	4 GRN	---	---	---	---	---	---	---	---

VMC Type RD-3


Note:

Refer to dimension drawings, pages 76 through 95 for weight distribution and isolator locations.

INSTALLATION INSTRUCTIONS FOR VMC SERIES AWR/AWMR AND CP RESTRAINED MOUNTINGS

1. Floor should be level and smooth.
2. For indoor applications, isolators do not normally require bolting. If necessary, anchor isolators to floor through bolt holes in base plate. **IMPORTANT: Isolators must be bolted to substructure and equipment to isolators when used under outdoor equipment exposed to wind forces.**
3. Lubricate threads of adjusting bolt. Loosen hold down bolts to allow for isolator adjustment.
4. Block the equipment 1/4" higher than the specified free height of the isolator. To use the isolator as blocking for the equipment, insert a 1/4" shim between the upper load plate and vertical uprights. Lower the equipment on the blocking or shimmed isolators.
5. Complete piping and fill equipment with water, refrigerant, etc.
6. Turn leveling bolt of first isolator four full revolutions and proceed to each mount in turn.
7. Continue turning leveling bolts until equipment is fully supported by all mountings and equipment is raised free of the spacer blocks or shims. Remove blocks or shims.
8. Turn leveling bolt of all mountings in either direction in order to level the installation.
9. Tighten nuts on hold down bolts to permit a clearance of 1/8" between resilient washer and underside of channel cap plate.
10. Installation is now complete.

REFRIGERANT FLOW DIAGRAM




Low pressure liquid refrigerant enters the cooler and is evaporated and superheated by the heat energy absorbed from the chilled water passing through the cooler shell. Low pressure vapor enters the compressor where pressure and superheat are increased. High pressure vapor is passed through the oil separator where compressor oil is removed and recirculated to the compressor via the oil cooler. The high pressure oil-free vapor is fed to the air cooled condenser coil and fans where the heat is removed. The fully condensed liquid enters the economizer.

A small percentage of the of the liquid passes through an expansion valve, into the other side of the economizer where it is evaporated. This low pressure liquid subcools the major part of the refrigerant. Medium pressure vapor then returns to the compressor. The subcooled refrigerant then passes through the expansion valve where pressure is reduced and further cooling takes place before returning to the cooler.

FIG. 36 – REFRIGERANT FLOW DIAGRAM

PROCESS AND INSTRUMENTATION DIAGRAM



SYSTEM COMPONENTS

- EXPANSION VALVE, THERMOSTATIC
- SOLENOID VALVE
- BALL VALVE
- RELIEF VALVE
- STOP VALVE ANGLE, ACCESS
- PURGE VALVE
- PLUG
- PRESSURE SENSOR
- TEMPERATURE SENSOR
- REPLACEABLE CORE FILTER DRYER
- SIGHT GLASS
- FLOW SWITCH (option)
- PRESSURE SWITCH
- ELECTRIC HEATER

MAJOR COMPONENTS

- | | |
|------|-----------------|
| COMP | COMPRESSOR |
| CDR | CONDENSER COIL |
| CLR | COOLER |
| OC | OIL COOLER COIL |
| OS | OIL SEPARATOR |


MICROPROCESSOR CONTROL FUNCTIONS

- | | |
|-----|--------------------------------|
| CHT | CHILLED LIQUID THERMOSTAT |
| DIF | DIFFERENTIAL PRESSURE CUTOFF |
| DFP | DISCHARGE PRESSURE FAN CONTROL |
| DV | DISPLAY VALUE |
| HPL | HIGH PRESSURE LOAD LIMITING |
| HTC | HIGH TEMPERATURE CUTOFF |
| LPC | LOW PRESSURE CUTOFF |
| LTC | LOW TEMPERATURE CUTOFF |
| SHV | SUPERHEAT VALVE |

LD06972A

FIG. 37 – PROCESS AND INSTRUMENTATION DIAGRAM


COMPONENT LOCATIONS



LD07012A

FIG. 38 – COMPONENT LOCATIONS


COMPRESSOR COMPONENTS



LD03668

FIG. 39 – COMPRESSOR COMPONENTS


COMPRESSOR COMPONENTS – CONT'D



LD03669

FIG. 40 – COMPRESSOR COMPONENTS

COMPRESSOR COMPONENTS – CONT'D



LD03670

FIG. 41 – COMPRESSOR COMPONENTS

COMPRESSOR COMPONENTS – CONT'D






FIG. 42 – COMPRESSOR COMPONENTS

COMPRESSOR COMPONENTS – CONT'D




NO.	PART NAME
1	O-RING
2	SUCTION COVER
3	SUCTION STRAINER
4	ROTOR SCREW
5	ROTOR LOCK WASHER
6	ROTOR CLAMP WASHER
7	ROTOR
8	STATOR
9	MALE INLET BEARING
10	MALE ROTOR RETAINING RING
11	MALE ROTOR
12	ROTOR CASE
13	O-RING
14	DOWEL PIN
15	DISCHARGE CASE
16	LIP SEAL
17	DISCHARGE RADIAL BEARING
18	SPACER SHIM
19	THRUST BEARINGS
20	THRUST SPACE SHIM
21	REVERSE THRUST BEARING
22	BEARING CLAMP NUT
23	BEARING SPACER SLEEVE
24	BEARING PRELOAD SPRING
25	O-RING
26	BEARING BORE PLUG
27	DISCHARGE COVER
28	BEARING BORE PLUG
29	BEARING PRELOAD SPRING
30	BEARING SPACER SLEEVE
31	BEARING CLAMP NUT
32	REVERSE THRUST BEARING
33	THRUST SPACER SHIM
34	THRUST BEARINGS
35	SPACER SHIM
36	DISCHARGE RADIAL BEARING
37	LIP SEAL
38	DOWEL PIN
39	SUPPORT RING
40	ECONOMIZER PLUG
41	SUPPORT RING
42	FEMALE ROTOR RETAINING RING
43	FEMALE INLET BEARING

LD03673

FIG. 43 – COMPRESSOR COMPONENTS

COMPRESSOR COMPONENTS – CONT'D



LD03672

FIG. 44 – COMPRESSOR COMPONENTS

SYSTEM STARTUP CHECKLIST

JOB NAME: _____
SALES ORDER #: _____
LOCATION: _____
SOLD BY: _____
INSTALLING CONTRACTOR: _____
START-UP TECHNICIAN/ COMPANY: _____
START-UP DATE : _____


CHILLER MODEL #: _____
SERIAL #: _____

COMPRESSOR #1
MODEL#: _____
SERIAL #: _____
COMPRESSOR #2
MODEL#: _____
SERIAL #: _____

Unit Checks (No Power)

Check the system 24 hours prior to initial start

- ☐ 1. Inspect the unit for shipping or installation damage.
- ☐ 2. Assure that all piping has been completed.
- ☐ 3. Check that the unit is properly charged and that there are no piping leaks.
- ☐ 4. Open each compressor suction service valve, discharge service valve, economizer service valve, liquid line stop valve, and oil line ball valves.
- ☐ 5. The compressor oil level should be maintained so that an oil level is visible in either of the two oil separator sight glasses. In other words, oil




In actual operation, due to splashing, an oil level may be seen in both sight glasses. Run the compressor for a few minutes, shut the system down, and assure there is an oil level showing in the bottom or top sight glass with the compressor off.

level should always be maintained, running or not, above the bottom of the lower sight glass and below the top of the upper sight glass.

If it is necessary to add oil, connect a YORK oil pump to the charging valve on the oil separator, but do not tighten the flare nut on the delivery tubing. With the bottom (suction end) of the pump submerged in oil to avoid entrance of air, operate the pump until oil drips from the flare nut joint, allowing the air to be expelled, and tighten the flare nut. Open the oil charging valve on the oil separator and pump in oil until it reaches the proper level as described above.

- ☐ 6. Assure water pumps are on. Check and adjust water pump flow rate and pressure drop across the cooler.



Excessive flow may cause catastrophic damage to the evaporator.

- ☐ 7. Check the control panel to assure it is free of foreign material (wires, metal chips, etc.).
- ☐ 8. Visually inspect wiring (power and control). Wiring MUST meet N.E.C. and local codes. See Fig. 8 and 9, pages 35 and 36.
- ☐ 9. Check tightness of power wiring inside the power panel on both sides of the motor contactors and inside the motor terminal boxes.
- ☐ 10. Check for proper size fuses in main and control circuits.
- ☐ 11. Verify that field wiring matches the 3-phase power requirements of the compressor. See chiller nameplate (Pages 25 - 26).
- ☐ 12. Assure 115VAC Control Power has 30A minimum capacity. See Fig. 13, page 40.
- ☐ 13. Be certain all water temp sensors are inserted completely in their respective wells and are coated with heat conductive compound.
- ☐ 14. Assure that evaporator TXV bulbs are strapped onto the suction lines at 4 or 8 o'clock positions.
- ☐ 15. Assure that the 15 ton economizer TXV bulbs are strapped onto the compressor economizer supply lines at 4 or 8 o'clock positions.

Panel Checks

(Power ON – Both System Switches “OFF”)


- ☐ 1. Apply 3-phase power and verify its value (See Fig. 8 and 9 pages 35 and 36).
- ☐ 2. Apply 115VAC and verify its value on the terminal block in the lower left of the Power Panel. Make the measurement between terminals 5 and 2 (See Fig. 13, page 40). The voltage should be 115VAC +/- 10%.
- ☐ 3. Assure the heaters on each compressor are on. Allow the compressor heaters to remain on a minimum of 24 hours before start-up. This is important to assure that no refrigerant is in the compressor oil at start-up!
- ☐ 4. Program the dip switches on the microprocessor board for the desired operating requirements. See Fig. 49, Page 143. OPEN = Left side of switch pushed down. CLOSED = Right side of switch pushed down.

SWITCH	SWITCH “OPEN” SETTING	SWITCH “CLOSED” SETTING
1	Water Cooling	Brine Cooling
2	Standard Ambient Control	Low Ambient Control
3	Refrigerant R-407C	Refrigerant R-22

Verify the selections by pressing the OPTIONS Key on the control panel. Check them off.



Damage to the chiller could result if switches are improperly programmed.



Dip switches 4 through 8 are spares and have no function.

- ☐ 5. Program the required operating values into the micro for cut-outs, safeties, etc. and record them in the chart below. See Page 160 for details.

If Default Values are desired for programming convenience, press the PROGRAM key, 6140, and ENTER. This loads default values. Record these values in the chart below.

PROGRAMMED VALUES

Refrigerant Type = _____

Dischg Press Cutout = _____ PSIG (kPa)

Disch Press Unld = _____ PSIG (kPa)

Suction Press Cutout = _____ PSIG (kPa)

High Amb Cutout = _____ °F (°C)

Low Amb Cutout = _____ °F (°C)

Leaving Chilled Liquid Temp Cutout = _____ °F (°C)

High Motor Current Unload = _____ % FLA

Anti-Recycle Time = _____ Secs

- ☐ 6. Program the Chilled Liquid Setpoint/Range and record:

Setpoint = _____ °F (°C)

Range = _____ to _____ °F (°C)

Keep in mind that the Target temperature displayed by the micro should equal the desired leaving water temperature.

- ☐ 7. Assure that the CLK jumper J18 on the Micro-processor Board is in the ON position (Top 2 pins).
- ☐ 8. Set the Time and Date.
- ☐ 9. Program the Daily Schedule start and stop times.

INITIAL START-UP

After the control panel has been programmed and the compressor heater has been on for 24 hours prior to start-up, the chiller may be placed into operation.

- ❑ 1. Place the System Switches on the Microprocessor Board to the ON position.
- ❑ 2. The compressor will start and a flow of refrigerant will be noted in the sight glass. After several minutes of operation, the bubbles in the sight glass will disappear and there will be a solid column of liquid when the TXV stabilizes. After the water temperature stabilizes at desired operating conditions, the oil should be clear.
- ❑ 3. Allow the compressor to run a short time, being ready to stop it immediately if any unusual noise or adverse conditions develop. Immediately at start-up, the compressor will make sounds different from its normal high pitched sound. This is due to the compressor coming up to speed and lubrication changing from liquid refrigerant to oil. This should be of no concern and lasts for only a short time.
- ❑ 4. Check the system operating parameters. Do this by selecting various displays such as pressures and temperatures. Compare these to test gauge readings.

CHECKING SUBCOOLING AND SUPERHEAT

The subcooling should always be checked when charging the system with refrigerant and/or before setting the superheat.

When the refrigerant charge is correct, there will be no bubbles in the liquid sight glass with the system operating under full load conditions, and there will be 10 - 15°F (6 - 8°C) subcooled liquid leaving the condenser. An overcharged system should be guarded against. Evidences of overcharge are as follows:

- a. If a system is overcharged, the discharge pressure will be higher than normal. (Normal discharge/condensing pressure can be found in the refrigerant temperature/pressure chart; use entering air temperature +30°F (17°C) for normal condensing temperature.
- b. The temperature of the liquid refrigerant out of the condenser should be not be more than 15°F (8°C) less than the condensing temperature (The temperature corresponding to the condensing pressure from the refrigerant temperature/pressure chart).

The subcooling temperature of each system should be calculated by recording the temperature of the liquid line at the outlet of the condenser and subtracting it from the recorded liquid line pressure at the liquid stop valve, converted to temperature from the temperature/pressure chart.

Example:

$$\begin{array}{rcl}
 \text{Liquid line pressure} & = & \\
 202 \text{ PSIG converted to} & 102^\circ\text{F} & (39^\circ\text{C}) \\
 \text{minus liquid line temp.} & \underline{- 87^\circ\text{F}} & (31^\circ\text{C}) \\
 \text{SUBCOOLING} & = & 15^\circ\text{F} \quad (8^\circ\text{C})
 \end{array}$$

The subcooling should be adjusted to 12 - 15°F (7 - 8°C).

- ❑ 1. Record the liquid line pressure and its corresponding temperature, liquid line temperature and subcooling below:

	SYS 1	SYS 2		
Liq Line Press =	_____	_____	PSIG	(kPa)
Temp =	_____	_____	°F	(°C)
Liq Line Temp =	_____	_____	°F	(°C)
Subcooling =	_____	_____	°F	(°C)

After the subcooling is set, the suction superheat should be checked. The superheat should be checked only after steady state operation of the chiller has been established, the leaving water temperature has been pulled down to the required leaving water temperature, and the unit is running in a fully loaded condition. Correct superheat setting for a system is 10 - 12°F (6 - 7°C).

The superheat is calculated as the difference between the actual temperature of the returned refrigerant gas in the suction line entering the compressor and the temperature corresponding to the suction pressure as shown in a standard pressure/temperature chart.

Example:

$$\begin{array}{rcl}
 \text{Suction Temp} & = & 46^\circ\text{F} \quad (8^\circ\text{C}) \\
 \text{minus Suction Press} & & \\
 60 \text{ PSIG converted} & & \\
 \text{to Temp} & \underline{- 34^\circ\text{F}} & (1^\circ\text{C}) \\
 & & 12^\circ\text{F} \quad (7^\circ\text{C})
 \end{array}$$

The suction temperature should be taken 6" (13 mm) before the compressor suction service valve, and the suction pressure is taken at the compressor suction service valve.

Normally, the thermal expansion valve need not be adjusted in the field. If, however, adjustment needs to be made, the expansion valve adjusting screw should be turned not more than one turn at a time, allowing sufficient time (approximately 15 minutes) between adjustments for the system and the thermal expansion valve to respond and settle out. Assure that superheat is set at 10 - 15°F (6 - 8°C).

- ☐ 2. Record the suction temperature, suction pressure, suction pressure converted to temperature, and superheat of each system below:

	SYS 1	SYS 2		
Suction Temp =	_____	_____	PSIG	(kPa)
Suction Temp =	_____	_____	°F	(°C)
Temp =	_____	_____	°F	(°C)
Superheat =	_____	_____	°F	(°C)

CHECKING ECONOMIZER SUPERHEAT (IF APPLICABLE) (15 TON TXV)

The economizer superheat should be checked to assure proper economizer operation and motor cooling. Correct superheat setting is approx. 10 - 12°F (6 - 7°C).

The superheat is calculated as the difference between the pressure at the Economizer Service Valve on the compressor converted to the corresponding temperature in a standard pressure/temperature chart and temperature of the gas at the bulb on the entering piping to the motor housing.


Example:

Motor Gas Temp =	90°F	(32°C)
minus Economizer Press		
139 PSIG converted		
to Temp	- 78°F	(26°C)
	12°F	(6°C)

Normally, the thermal expansion valve need not be adjusted in the field. If however, adjustment needs to be made, the expansion valve adjusting screw should be turned not more than one turn at a time, allowing sufficient time (approximately 15 minutes) between adjustments for the system and the thermal expansion valve to respond and settle out. Assure that superheat is set between 10 - 12°F (6 - 7°C).

- ☐ 1. Record the motor gas temperature, economizer pressure, economizer pressure converted to temperature, and economizer superheat below:

	SYS 1	SYS 2		
Motor Gas Temp =	_____	_____	PSIG	(kPa)
Economizer Press =	_____	_____	°F	(°C)
Temp =	_____	_____	°F	(°C)
Superheat =	_____	_____	°F	(°C)



This superheat should only be checked in an ambient above 90°F (32°C). Otherwise, mid-range adjustment (factory setting) is acceptable.

LEAK CHECKING

- ☐ 1. Leak check compressors, fittings, and piping to assure no leaks.

If the unit is functioning satisfactorily during the initial operating period, no safeties trip and the compressors load and unload to control water temperature, the chiller is ready to be placed into operation.

CHILLER CONTROL PANEL PROGRAMMING AND DATA ACCESS KEYS



DISPLAY AND STATUS INFORMATION KEYS

Status Key - see Section 2

This key provides a display of the current operational and/or fault status of the chiller or individual refrigerant systems.

Display Keys - see Section 3

Each key provides a real time display of commonly required information about the chiller and individual system operating conditions and settings.

Print Keys - see Section 4

These keys allow control panel display or remote print-out of both current real-time operating and programmed data as well as fault history data from recent safety shutdowns.

ON / OFF ROCKER SWITCH

This switch shuts down the entire chiller when placed in the OFF position. The switch must be ON for the chiller to operate.

PROGRAM & SETUP KEYS

Entry Keys - see Section 5

The numeric and associated keys are used for entering data required for programming the chiller. The ENTER and $\uparrow\downarrow$ keys are also used for scrolling through information available after pressing certain keys.

Setpoints Keys - see Section 6

These keys are used for display and programming of the local and remote offset chilled liquid temperature setpoints.

Clock Keys - see Section 7

These keys are used for display and programming of the clock and operating schedule for the chiller.

Program Key - see Section 8

This key is used for display and programming of the chiller operational settings and limits.

1. INTRODUCTION & PHYSICAL DESCRIPTION



29023A

1.1 GENERAL

The YORK Screw Chiller Control Panel is a microprocessor based control system fitted to YCAS liquid chillers. It is capable of multi-refrigerant system control to maintain chilled liquid temperature within programmed limits and to provide safety control of the chiller. The microprocessor monitors leaving chilled liquid temperature deviation from setpoint and the rate of change of this temperature to start, stop, load and unload compressors as required.

User interface is via a touch keypad and a liquid crystal display allowing access to operating and programmed data. Information can be displayed in English (Imperial) units or SI (Metric) units (Section 8.1). Conversion tables are provided at the back of this manual.

A master ON/OFF rocker switch is provided on the chiller control panel to activate or deactivate the complete chiller, while switches to activate or deactivate individual refrigerant systems are provided on the Microprocessor Board(s).

External interface is available for control of the chiller via a YORK ISN System or YORK Remote Control Center. In addition, EMS/BAS System connections are

provided for remote cycling, current limiting, remote temperature setpoint reset and alarm annunciation.

YCAS chillers each have a single split circuit evaporator serving 2 independent refrigerant systems. YCAS 2 system chillers are configured as a single self contained section with a single control panel controlling the two refrigerant systems.

1.2 KEYPAD & DISPLAY

An operator keypad allows complete control of the chiller from a central location. The keypad offers a multitude of commands available to access displays, program setpoints, and initiate system commands. Keys are grouped and color coded for clarity and ease of use.

A 40 Character Liquid Crystal Display (2 lines of 20 characters) is used for displaying system parameters and operator messages. The display has a lighted background for night viewing as well as a special feature which intensifies the display for viewing in direct sunlight.

Displays will be updated every two seconds by the microprocessor.

1.3 UNIT (CHILLER) ON / OFF SWITCH

A master UNIT (Chiller) ON / OFF switch is located just below the keypad. This switch allows the operator to turn the entire chiller OFF, if desired. The switch must be placed in the ON position for the chiller to operate. Any time the switch is in the OFF position, a Status message indication will be displayed. See page 120 for the location of this switch.

1.4 MICROPROCESSOR BOARD

The Microprocessor Board controls and makes decisions for the chiller. Information inputs from transducers and sensors around the chiller are either connected directly to the Microprocessor Board or are connected to the I/O Expansion Board and multiplexed before being sent to the Microprocessor Board. The Microprocessor Board circuitry multiplexes all of these analog inputs, digitizes them, and constantly scans them to monitor chiller operating conditions. Based on this information, the Microprocessor issues commands to the Relay Boards to activate and deactivate contactors, solenoids, etc. for chilled liquid, operating control, and safety control.

Commands are sent from the Microprocessor Board to the I/O Expansion Board to control the slide valves for chilled liquid control.

Keypad commands are acted upon by the micro to change setpoints, cutouts, scheduling, operating requirements, and to provide displays.

A +12VDC REG supply voltage from the Power Supply Board is converted to +5V REG by a voltage regulator located on the Microprocessor Board. This voltage is used to operate the integrated circuitry on the board.

System Switches 1 - 4

System Switches for each system are located on the Microprocessor Board (Section 1.11, Item 5). These switches allow the operator to selectively turn a given system on or off as desired.

Internal Clock & Memory Backup Battery

The Microprocessor Board contains a Real Time Clock integrated circuit chip (Section 1.11, Item 2) with an internal battery backup. The battery backup assures that any programmed values (setpoints, clock, cutouts, etc.) are not lost during a power failure or shutdown period regardless of the time involved.

The battery is a 10 year lithium type, but life will depend upon whether the Real Time Clock's internal clock circuit is energized. With the clock OFF, a rated life of approximately 10 years can be expected. With the clock ON, approximately 5 years. The clock is enabled and disabled using a jumper on the microprocessor board.

If the chiller is shut down or power failure is expected for extended periods, it may be desirable to disable the clock to save battery life. The clock can then be reactivated and reprogrammed when the chiller is returned to service. This will not affect the maintenance of programmed values and stored data by the backup battery.

While a chiller is operating, the clock must be ON (Section 1.11, Item 1) or the internal clock on the microprocessor will not be active and the micro cannot keep track of time, although all other functions will operate normally. Failure to turn the Clock ON could result in the chiller not starting due to the time "frozen" on the clock falling outside the Start/Stop time programmed in the Daily Schedule, see Section 7.3.

1.5 ANCILLARY CIRCUIT BOARDS

Power Supply Board

The on-board switching power supply is fuse protected and converts 24VAC from the logic transformer 2T to +12V REG which is supplied to the Microprocessor Board, Relay Output Boards, and the 40 character display to operate the integrated circuitry.

24VAC is filtered, but not regulated, to provide unregulated +24VDC to supply the flow switch, PWM remote temperature reset, PWM remote current reset, lead / lag select, and remote print circuitry which may be utilized with user supplied contacts.

24VAC is also filtered and regulated to +24VDC to be used by the optional EMS/BAS Circuit Boards for remote temperature or remote current reset.

Individual rectifier and filtering circuits are present which receive the Current Transformer signals for each phase of motor current on each compressor. These circuits rectify and filter the signals to variable DC. A phase rotation circuit for each compressor is also present to assure that the screw compressors do not run in the wrong direction. All of these signals are sent to the I/O Expansion Board which multiplexes them and then feeds them to the Microprocessor Board.

I/O Expansion Board

The I/O Expansion Board provides multiplexing to allow additional inputs to be connected to the Microprocessor Board via a single data line. The additional inputs are multiplexed according to the selection made by the Microprocessor through address lines.

Signals routed through the I/O Expansion Board include Discharge Temperature, Current Transformer outputs (motor current signals), and Oil Temperature.

Included on the I/O Expansion Board are the outputs for the slide valve control. This control consists of a Digital to Analog Converter (DAC) and power transistors to modulate current through the slide valve solenoids.

Relay Output Boards

One Relay Output Board per system operates the motor contactors/starters, solenoid valves, and heaters which control system operation.

The relay boards are located in the logic section of the control panel(s). The boards convert 0 - 12VDC logic levels outputs from the Microprocessor Board to 115VAC levels used by the contactors, valves, etc.

The common side of all relays on the Relay Output Board is connected to +12VDC REG. The open collector outputs of the Microprocessor Board energize the DC relays or triacs by pulling the other side of the relay coil to 0VDC. When not energized, both sides of the relay coils or triacs will be at +12VDC potential.

1.6 CIRCUIT BREAKERS

Three Circuit Breakers are provided for the 115VAC controls.

- CB1 allows removal of control power from System 1 for control system circuitry servicing: specifically, the 115VAC feed to Relay Output Board 1 which energizes contactors and solenoids.
- CB2 allows removal of control power from System 2 for control system circuitry servicing: specifically, the 115VAC feed to Relay Output Board 2 which energizes contactors and solenoids.

- CB3 allows removal of control power to the Microprocessor Board, Power Supply Board, I/O Expansion Board, and Evaporator Heater.



The Circuit Breakers remove 115VAC control power only. High voltage circuitry will still be energized from the high voltage supply.



REMOVING 115VAC power to CB3 or opening CB3 removes power from the evaporator heaters. This could cause evaporator freeze-up in low ambient temperatures.

1.7 CURRENT TRANSFORMERS (C.T.)

C.T.s, located internally in the Motor Protection Modules on each of the 3 phases of the power wiring of each compressor motor, send AC signals proportional to motor current to the Power Supply Board which rectifies and filters the signals to variable DC Voltage (analog). These analog levels are then fed to the Microprocessor Board via the I/O Expansion Board allowing the microprocessor to monitor motor currents for low current, high current, unbalanced current, and single phasing.

1.8 TRANSFORMERS

3 Transformers (2T, 3T, and 4T) are located in the Control Panel. These transformers convert the 115VAC Control Power Input to 24VAC to operate the microprocessor circuitry.

2T: This 75VA transformer supplies the 24VAC microprocessor power supply.

3T: Supplies the I/O Expansion Board # 1 voltage for slide valve control.

4T: Supplies power to the Motor Protector Modules.

1.9 MOTOR PROTECTION MODULES

A Motor Protection Module for each compressor is located in the Control Panel. These modules supply motor over-temperature protection, 3-phase current protection, phase imbalance, phase rotation, and a programming and troubleshooting 7 segment display.


The motor over-temperature protection is supplied by 3 temperature sensors imbedded in the motor windings 120 degrees apart. The module monitors these sensors, allowing it to sense a hot winding and shut down the compressor if motor cooling is inadequate.

The on-board C.T.s provide 3-phase current protection which look at 3 of the 6 motor legs and send an analog signal proportional to average motor current to I/O Expansion board and on to the microprocessor board for microprocessor low/high current protection and current display. This allows the micro to monitor current and shut a system down if low or high motor current is sensed. This is a non-adjustable protection circuit electronically sized to a system's motor specifications.

Internally, the on-board 3 C.T.s and internal circuitry allow the Motor Protection Module to protect against high motor current as programmed on the Motor Protector dip switches. These switches are set at the factory according to motor specifications.

The module also provides phase rotation protection to assure the screw compressor does not rotate backwards. A single phase protection circuit located in the module also monitors for a phase imbalance. If current imbalance exceeds 17% of the average motor current in one of the phases, the Motor Protector will recognize it and shut the system down.

Whenever the Motor Protection Module senses a fault, internal contacts will open, and shut the system down. These contacts are wired in series with the compressor motor contactor. When the contact opens, the micro will attempt to start the system 2 more times. Since the motor contactor signal path from the Relay Output Board to the motor contactor is broken by the Motor Protection Module contacts, it will lock the system out after 3 faults. The Motor Protection Module must then be reset by removing 115VAC power from the Control Panel. After the Motor Protector is reset, the individual system SYS switch must be switched OFF and then ON to reset the microprocessor to allow restart of the system.



Anytime the module faults, a thorough investigation of the problem should be performed before attempting to return the system to operation. Failure to perform this investigation could lead to motor or compressor failure. Additional details on the Motor Protection Module can be found on page 16.






FIG. 45 – MOTOR PROTECTION MODULE

1.10 EMS/BAS CONTROLS


The microprocessor system can accept remote signals to Start/Stop the chiller, to adjust maximum allowable running current for each compressor, and to adjust the chilled liquid leaving temperature setpoint. These functions can easily be controlled by connecting user supplied “dry” contacts to the customer terminals in the control panel. In addition, Alarm Contacts are provided to remotely signal a fault with the chiller.

Remote Start/Stop

Remote Start/Stop can be accomplished using a time clock, manual contact or other “dry” contact in series with the flow switch (Terminals 13 and 14 of TB4) connected to terminals in the logic section of the control panel. The contact must be closed to allow the chiller to run. Any time the contact opens, the chiller will shut down and the NO RUN PERM message will be displayed. The location of the flow switch connection is shown in Section 1.12.



Never bypass a flow switch. This will cause damage to the chiller and void any warranties.



Wiring from remote “dry” contacts (for stop/start reset functions) should not exceed 25 ft. (8 m) and should be run in grounded conduit that does not carry any wiring other than control wiring or shielded cable. If an inductive device (relay, contactor) is supplying these contacts, the coil of the device must be suppressed with a suppressor YORK Part Number 031-00808-000 across the inductive coil.

Remote Current Reset

The maximum allowable running current for each compressor can be adjusted remotely to a lower value using repeated timed closure of “dry” contacts connected to Terminals 13 and 16 at the bottom center of the Microprocessor Panel (See Section 1.12) in the logic section of the control panel. The duration of the contact closure will determine the amount of adjustment. Generally, this input is used for purposes of demand limit and operates as follows:

Closing the input contact for a defined period of time allows reset of the % Current Limit downward. Contact closure of 1 - 11 seconds will allow % Current Limiting to be adjusted downward from 105% by a maximum of 75%, i.e. to a minimum value of 30% FLA. EMS Current Limiting operates independently of the High Average Current Unload (See Section 8.2). The micro will always look at the two Current Limit Setpoints and choose the lower as the controlling value, whenever Remote Current Limiting is utilized. Contact closures of less than 1 second will be ignored. A closure of 11 seconds is the maximum allowable closure and provides a Current Limit reduction of 75%. The remote reset current can be calculated as follows:


REMOTE

$$\text{RESET} = 105\% \text{ FLA} - \frac{\{(\text{Contact Closed Time} - 1\text{sec}) \times (75\% \text{ FLA})\}}{10 \text{ sec}}$$


For example, after a 4 second pulse, the offset would equal:

$$\begin{aligned} \text{Remote Reset Curr} &= 105\% \text{ FLA} - \frac{\{(4\text{sec} - 1 \text{ sec}) \times (75\% \text{ FLA})\}}{10 \text{ sec}} \\ &= 105\% - \frac{225\% \text{ FLA sec}}{10 \text{ sec}} \\ &= 82.5\% \text{ FLA} \end{aligned}$$


To maintain a given offset, the contact closure signal must be repeated at not more than 30 minute intervals but not less than 30 seconds from the end of the each PWM signal. After 30 minutes, if no refresh is provided, the setpoint will change back to its original value.



After an offset signal, the new Remote Current Limit may be viewed on the Remote EMS Limiting Display under the Motor Current Key (see Section 3.5). However, if this display is being viewed when the reset pulse occurs, the setpoint will not change on the display. To view the new offset, first press any other display key on the keypad and then press the Remote EMS Limiting Display.



Remote EMS Reset will not operate when a Remote Control Center Option Kit is connected to the micro. The Remote Control Center will always determine the setpoint.



Wiring from remote “dry” contact (for reset functions) should not exceed 25 ft. (8 m) and should be run in grounded conduit that does not carry any wiring other than control wiring or shielded cable. If an inductive device (relay, contactor) is supplying these contacts, the coil of the device must be suppressed with a suppressor YORK Part Number 031-00808-000 across the inductive coil.

Remote Setpoint Reset

The chilled liquid leaving temperature setpoint programmed into the micro can be remotely adjusted to a higher value using repeated timed closure of “dry” contacts connected to Terminals 13 and 17 of TB4 in the logic section of the control panel (See Section 1.12). The duration of the contact closure will decide the amount of adjustment. This is achieved as follows:

The maximum allowable reset value can be programmed from 2°F - 40°F (1°C - 22°C), as appropriate to the application - see Section 6.4. Once the maximum reset is programmed, an input contact closure of 11 seconds provides the maximum reset. Closure for less than 11 seconds will provide a smaller reset. For noise immunity, the micro will ignore closures of less than 1 second. To compute the necessary contact closure time to provide a required Reset, use the following steps:

$$\text{Reset Temp} = \left\{ \frac{(\text{Contact Closure} - 1 \text{ sec}) \times \text{Programmed Max Reset}}{10 \text{ sec}} \right\}$$

For example, with a programmed setpoint of 44°F (7°C), after a 4 second pulse and a programmed maximum offset of 40°F (22°C), the temperature offset would equal:


$$\text{Reset Temp} = \frac{(4 \text{ sec} - 1 \text{ sec}) \times 40^\circ\text{F}}{10 \text{ sec}}$$

$$\text{Reset Temp} = \frac{120^\circ\text{Fsec}}{10 \text{ sec}}$$


$$= 12^\circ\text{F} (6^\circ\text{C})$$

To determine the new setpoint, add the reset to the setpoint programmed into memory. In the example above, if the programmed setpoint = 44°F (7°C), the new setpoint after the 4 second contact closure would be 44°F (7°C) + 12°F (6°C) = 56°F (13°C). This new setpoint can be viewed on the display by pressing the Remote Reset Temperature/Range key.


To maintain a given offset, the contact closure signal must be repeated every 30 seconds - 30 minutes. The refresh is not accepted sooner than 30 seconds from the end of the last PWM signal, but must be refreshed before 30 minutes has elapsed. After 30 minutes, if no refresh is provided, the setpoint will change back to its original value.



After an offset signal, the new Remote Setpoint may be viewed on the Remote Reset Temperature Range display. However, if this display is being viewed when the reset pulse occurs, the setpoint will not change on the display. To view the new offset, first press any other display key on the keypad and then press the Remote Reset Temperature Range key. The new setpoint will then appear.




Remote Setpoint Reset will not operate when a Remote Control Center Option Kit is connected to the Micro. The Remote Control Center will always determine the setpoint.



Wiring from remote “dry” contact (for reset functions) should not exceed 25 ft. (8 m) and should be run in grounded conduit that does not carry any wiring other than control wiring or shielded cable. If an inductive device (relay, contactor) is supplying these contacts, the coil of the device must be suppressed with a suppressor YORK Part Number 031-00808-000 across the inductive coil.

1.11 MICROPROCESSOR BOARD LAYOUT



26001A


ITEM	DESIGNATION	DESCRIPTION
1	J18	Clock Enable/Disable Jump Contact
2	RTC (U13)	Real Time Clock and Battery Backup I.C.
3	EPROM	Microprocessor I.C. (label shows version) <i>NOTE : Dimple is positioned at top edge</i>
4	S1	Dip Switch Set (8 switches)
5	S2 to S5	System Switches S2 = System 1 S3 = System 2 S4 = System 3 S5 = System 4

FIG. 46 – COMPONENT LAYOUT

1.12 LOGIC SECTION LAYOUT

60 Hz Models :

8



00262VIP

**PHOTOGRAPH OF
60 HZ MODEL LOGIC SECTION**

ITEM	DESCRIPTION
1	Microprocessor Board
2	Back of Keypad
3	I/O Expansion Board # 1
4	Power Supply Board
5	Relay Output Board #1
6	Relay Output Board #2
7	Flow Switch & Customer Connection Terminals (TB4)

FIG. 47 – LOGIC SECTION LAYOUT

1.13 ANTI-RECYCLE TIMER

The programmable Anti-Recycle Timer allows the user to select the compressor anti-recycle time to best suit their needs. Motor heating is a result of inrush current when the motor is started. This heat must be dissipated before another start takes place or motor damage may result. The anti-recycle timer assures that the motor has sufficient time to cool before it is restarted.

An adjustable timer allows for the motor cooling, but gives the user the ability to extend the anti-recycle timer to cut down on cycling. In some applications, faster compressor start response is necessary and shorter anti-recycle times are required. These needs should be kept in mind but whenever possible the timer should be adjusted for the longest period of time tolerable. 600 seconds is recommended, although 300 seconds provides adequate motor cooling time. Longer periods will allow more heat dissipation, reduce cycling, and possibly increase motor life. See Section 8.2, page 163 for programming of the anti-recycle timer.

1.14 ANTI-COINCIDENCE TIMER

The Anti-Coincidence Timer assures that 2 systems do not start simultaneously. This assures that inrush current is kept to a minimum. A 60 second time delay will always separate motor starts. This timer is not programmable.

1.15 EVAPORATOR PUMP CONTROL

Dry contacts are provided which transition (close) when the Daily Schedule is calling for chiller operation and power has been applied to the Micro Panel for 30 seconds. If for some reason the evaporator pump contacts have been closed to run the pump and a power loss or Daily Schedule shuts the pump down (contacts open), the contacts will not reclose for any reason until 30 seconds has elapsed after power re-application or 30 seconds have elapsed between a Daily Schedule shutdown and restart.

1.16 COMPRESSOR HEATER CONTROL

Each compressor has its own heater. The heater will be off whenever the compressor is running. As soon as the compressor shuts off, the heater will turn on and stay on for 5 minutes. After 5 minutes has elapsed, the heater will shut off if the discharge temperature rises above 150 °F (66°C) and will turn on when the discharge temperature is equal to or less than 150 °F (66°C).

1.17 EVAPORATOR HEATER CONTROL

The evaporator heater is controlled by ambient temperature. When the ambient temperature drops below 40°F (4°C), the heater is turned on when the compressors are turned off. When the temperature rises above 45°F (7°C), the heater is turned off. An undervoltage condition will keep the heater off until full voltage is restored to the system. The heater will provide freeze protection to -20°F (-28°C).



115VAC power must remain “ON” through CB3 for freeze protection. Otherwise, the evaporator must be drained.

1.18 PUMPDOWN (LLSV) CONTROL

Each compressor undergoes a pump down cycle on start-up and shutdown. This assures that liquid refrigerant does not enter the compressor on start-up, eliminating the need for recycling pump down, saving energy and reducing compressor starts and wear.

On start-up, the controls unload the compressor and the system either pumps down to the low suction pressure cutout setting or pumps down for 15 seconds, whichever comes first, after which the Liquid Line Solenoid Valve is energized and normal operation commences.

On shutdown, the microprocessor controls unload the compressor and the Liquid Line Solenoid Valve and Economizer/Motor Cooling Liquid Supply Solenoid Valve are de-energized. The compressor continues to operate until it either pumps down to the low suction pressure cutout setting or for 180 seconds, whichever comes first. Pump down occurs on “normal” shutdowns where cooling demand has been satisfied or when a system switch is turned off, a flow switch opens, run permissive is lost or a Daily Schedule or a Remote Shutdown is called for.

No pumpdown will occur on a safety shutdown. See page 134 for the pumpdown display message.


1.19 ALARMS

Internal contacts are provided in the Power Panel (See Section 1.12) which can be used to remotely signal a warning whenever a fault lockout occurs on any system or if power is lost to the control panel. The internal contacts are normally open (N.O.) and will close when


control power is applied to the panel, if no fault conditions are present. When a fault occurs which locks out a system the respective contacts open. If chiller power is lost or a unit fault occurs, such as a Low Water Temp fault, contacts for all systems will open.

Contacts for SYS 1 are located on the bottom right of the microprocessor panel, terminals 23 and 24. SYS 2 contacts are located on terminals 27 and 28. See Fig. 12, Page 39 for the location of these terminals.

A 28VDC or 120VAC (60 Hz models) or up to 240VAC (50 Hz models) external alarm circuit (supplied by others) may be connected to these contacts. The contacts are rated at 125VA.



If any inductive load devices (relay or contactor) supplied by the user are in the electrical circuit connected to the dry alarm contacts, the device must be suppressed at the load with a RC suppressor YORK Part Number 031-00808-000 across the inductive coil. (Typically, several are supplied loose with the panel). Failure to install suppressors will result in nuisance faults and possible damage to the chiller.



If the alarm circuit is applied in an application used for critical duty (such as process duty or cooling other critical equipment) and the alarm circuit should fail to function, YORK will not be liable for damages.

1.20 RUN STATUS (CHILLER)

Chiller Run Status contacts between Terminal 28 and 29 close whenever one of the systems is running. These contacts are located on the bottom right of the Microprocessor Board and are rated (voltage and current) the same as the alarm contacts (Section 1.19). Also use a suppressor, same as alarm contacts (Section 1.19). Individual system "Run Status" is not available.

1.21 LEAD / LAG COMPRESSOR SELECTION


The chiller may be set up for AUTO or MANUAL Lead/Lag. This is accomplished by programming the option under the Program Key. Details for programming the Manual/Auto Lead/Lag Selection are discussed in Program Key Section 8, page 163.

When AUTO Lead/Lag is utilized, the micro attempts to balance run time between the two compressors. A number of conditions can occur which will prevent this from happening. Factors determining lead/lag selection and the resulting lead/lag determination are:

1. The micro automatically defaults the lead to SYS 1 and the lag to SYS 2 if both compressors are ready to start (Anti-recycle Timers timed out) and compressors have equal run time.
2. If all compressors are ready to start (Anti-recycle timers timed out), the compressor with the lowest run hours will start first.
3. If all compressors are waiting to start (Anti-recycle timers have not timed out), the micro will assign the lead to the compressor with the shortest anti-recycle time in an effort to provide cooling quickly.
4. If the lead compressor is locked out, faulted and waiting to restart, SYS switch on the microboard is off, or a run permissive is keeping an individual system from running, the lag compressor is swapped to the lead. This is true regardless of whether the lag compressor is ON or OFF.

MANUAL Lead/Lag selection will be automatically overridden by the micro to allow the lag compressor to automatically become the lead anytime the selected lead compressor shuts down due to a lock-out, lead system faults and is waiting to restart, lead switch on the micro board is in the OFF position, or if a run permissive is keeping the lead of the system off. Automatic switchover in MANUAL mode is provided to try to maintain chilled liquid temperature as close to setpoint as possible.

2. STATUS KEY: GENERAL STATUS MESSAGES & FAULT WARNINGS



29023A

2.1 GENERAL

Pressing the Status key displays the current chiller or individual system operational status. The messages displayed include running status, cooling demand, fault status, external cycling device status, load limiting, and anti-recycle timer status. The display will show one message relating to the “highest priority” information as determined by the microprocessor.

For individual system status or fault messages, the display shows information for up to two refrigerant systems.

The main categories of messages available using the Status key are:

- 2.2 General Status Messages
- 2.3 Unit Warnings
- 2.4 Anticipation Control Status Messages
- 2.5 Chiller Fault Status Messages
- 2.6 System Fault Status Messages

These messages are described in detail below, with examples of each display. In each example “#” is used as applicable to represent the system number where messages apply to individual systems.

2.2 GENERAL STATUS MESSAGES

Unit Switch OFF:

UNIT SWITCH OFF
SHUT DOWN

This message indicates that the Chiller ON / OFF Switch on the Control Panel is in the OFF position which will not allow the chiller to run.

Schedule Shutdown:

DAILY SCHEDULE
SHUT DOWN

This message indicates that the chiller has been shut down by the daily schedule programmed into the Clock - Set Schedule / Holiday system (Section 7.3).

Remote Controlled Shutdown:

REMOTE CONTROLLED
SHUT DOWN

This message indicates that either an ISN or RCC (Remote Control Center) has turned the unit OFF through the RS-485 port.

Compressors Running:

SYS # COMP RUNNING
SYS # COMP RUNNING

This message indicates that the respective compressor is running due to demand.

System Switches OFF:

SYS	#	DSCH	LIMITING
SYS	#	DSCH	LIMITING

This message indicates that the system switch on the Microprocessor Board for the respective system is in the OFF position. A system can only run if the system switch is in the ON position. The switch for System 1 and System 2 should normally be in the ON position for all models. See Section 1.11, Figure 46, page 128 for the location of the system switches.

Anti-Recycle Timers:

SYS	#	AR	TIMER	0	S
SYS	#	AR	TIMER	120	S

The anti-recycle timer message shows the amount of time remaining before a compressor can be called to restart. These 300 - 600 sec. timers begin timing when a compressor starts, although a minimum of two minutes must always elapse after a compressor shuts down, before it may again restart. If a power failure occurs, the anti-recycle timers will reset to 120 seconds after power is restored. The purpose of the timer is to allow for motor cooling to dissipate the heat generated by inrush current at start-up.

Anti-Coincidence Timers:

SYS	#	COMP	RUNNING
SYS	#	AC	TIMER 22 S

The anti-coincident timer guards against two or more compressors starting simultaneously. This avoids excessive instantaneous starting currents. A minimum of 60 seconds between compressor starts is maintained even if demand is present and the anti-recycle timers are timed out. The display shows the time before the respective compressor can start. This display will only appear after the anti-recycle timers have timed out.

Run Permissive Contacts OPEN:

SYS	#	NO	RUN	PERM
SYS	#	NO	RUN	PERM

This display indicates that an external cycling contact and/or the flow switch connected to terminals 13 & 14 in the Logic Section(s) of the control panel(s) is/are open. Whenever the contact(s) is /are open, the No Run Permissive message will be displayed and the indicated system will not run.

System Loading Requirement:

SYS	#	NO	COOL	LOAD
SYS	#	NO	COOL	LOAD

This message indicates that chilled liquid temperature is below the point where the microprocessor will bring the lead system on and/or that the loading sequence has not loaded the chiller far enough to bring the lag system on. The lag system will display this message until the loading sequence is ready for the lag system to start.


2.3 UNIT WARNINGS

Unit Warnings are often caused by conditions which require operator intervention to start the unit or extreme operating conditions. All setpoints and programmable values should be checked, if a chiller shutdown occurred, before restarting the chiller. Unit Warnings are not logged into the HISTORY BUFFER.

Low Battery Warning

!!	LOW	BATTERY	!!
CHECK	PROG	SETP	TIME

On power-up the microprocessor will check the RTC (Real Time Clock) memory back-up battery to make sure it is still operational. Provided the battery checks out, operation will continue normally. If a check is made and the battery has failed, the microprocessor will not allow the chiller to run and the above Status message will appear.



If a low battery condition exists, the micro will restore programmed cut-outs, setpoints, and schedules to their default values.

Once a low battery condition is detected, the only way to run the chiller is to use the Manual Override key - see Section 7.4 page 159. This allows reprogramming of setpoints, cutouts, and schedule.

The U13 RTC chip should be replaced as soon as possible with Part # 031-00955-000. Otherwise, the chiller will shutdown and lose all programmed points, and require a MANUAL OVERRIDE restart, if a power failure occurs.

Pump Down:

```
SYS 1 PUMPING DOWN
SYS 2 PUMPING DOWN
```

This message indicates that both refrigerant systems are in a pumpdown cycle. Pumpdown display messages occur on shutdowns where the cooling load has been met, or when a system switch is turned OFF. Note that only one compressor could be pumping down, as shown in the following display:

```
SYS 1 PUMPING DOWN
SYS 2 COMP RUNNING
```

See Section 1.18 (page 130) for details of pumpdown control.


Incorrect Refrigerant Warning:

```
REPROGRAM TYPE OF
REFRIGERANT TO RUN
```

The incorrect Refrigerant Warning will occur if the DIP Switch setting for refrigerant type and the type programmed into the micro “at the factory” are not the same. This message will be displayed until the non-programmable “factory” programmed refrigerant type and DIP Switch setting agree.

Power Failure Warning:

The Power Failure Warning will only be displayed on “power restoration” after a “power loss,” if manual restart on power failure is selected under the PROGRAM key (page 160). If manual restart on power failure has been selected, the following warning message is displayed indefinitely on power restoration and the chiller will not run until the UNIT Switch is cycled OFF-and-on to restart the unit. This safety is available for users who desire a chiller lock-out on power failure.



This is typically not a desirable feature.

```
!! POWER FAILURE !!
CYCLE UNIT SWITCH
```

When this message appears, the chiller will not run and the Unit Switch must be cycled OFF and ON to start the unit.

2.4 ANTICIPATION CONTROL STATUS MESSAGES

Anticipation controls are built into the software to prevent safety shutdowns by automatically overriding the temperature controls, if system conditions approach safety thresholds. This avoids total loss of cooling resulting from a lockout by a safety control.

Anticipation controls monitor discharge pressure, motor current and suction temperature for each compressor and if maximum limits are approached, the slide valve loading of the respective compressor will be reduced to avoid exceeding the limit.

Displays of anticipation safety control messages and their meanings are as follows:

Discharge Pressure Limiting:

```
SYS # DSCH LIMITING
SYS # DSCH LIMITING
```

Discharge Pressure Limiting takes effect when compressor discharge pressure nears the point at which the high pressure cutout would shut the system down. When the above message appears, discharge pressure has exceeded the programmable threshold and the compressor is being unloaded in an effort to prevent shutdown on the high pressure cutout. The operation of this safety is important if condenser coils become dirty, if there is a problem with the condenser fan operation, or if extreme ambient or load conditions occur (see Section 8.2 / High Discharge Pressure Unload Point [page 166] for more details).

Compressor Motor Current Limiting:

```
SYS # CURR LIMITING
SYS # CURR LIMITING
```

The Motor Current Limiting message indicates that a compressor motor current has reached a programmable, Bas, or remote limit and the system is being unloaded to assure that motor current does not become excessively high causing a fault (see also Section 8.2 / High Motor Current Unload Point, page 161; Section 3.5, Motor Current Key, page 142; Section 1.10, page 128).

Suction Temperature Limiting:

```
SYS # SUCT LIMITING
SYS # SUCT LIMITING
```

The Suction Temperature Limiting message applies only when the chiller is set for Water Cooling Mode (see page 142). The message indicates that saturated suction

temperature on a system has dropped to 29°F (-2°C) and that any further temperature reduction could cause some icing of the evaporator tubes. Saturated suction temperature is computed by the micro by converting suction pressure to temperature.

For the first 3 minutes that the saturated suction temperature is at or below 29°F (-2°C) any further compressor loading is inhibited to allow time for the temperature to rise. If the condition persists for more than 3 minutes, a 5 minute timer is started. As this timer counts down to zero, a 1 second unload pulse will be sent to the slide valve of the affected compressor every 5 seconds as long as the temperature is below 31°F (-1°C). If the temperature rises above 31°F (-1°C), the micro will inhibit loading for the remainder of the 5 minute period.

If after the 5 minute period the saturated suction temperature is above 29°F (-2°C), the compressor is allowed to reload, if required, to maintain leaving chilled water. Otherwise, the micro will reset the 5 minute timer and start the process over again. To assure that leaving chilled water requirements are satisfied while one compressor is under Suction Temperature Limiting control, the micro will start or load other compressor(s) as necessary.

2.5 UNIT FAULT STATUS MESSAGES

A Unit Fault will shut the entire chiller down when a preset safety threshold is exceeded. The chiller will automatically restart after the condition causing the shutdown clears. Restart will occur only after anti-recycle timers are satisfied and cooling demand requires additional cooling. A reset hysteresis is built into each safety so repetitive faulting and clearing will not occur in a short time period.

Continuous monitoring by the microprocessor assures that instantaneous reactions result. When the chiller is shut down on one of these safeties, a message will appear on the Status display informing the operator of the problem as shown in the text that follows.

Any time that a Unit Fault occurs, the shutdown will be logged into the HISTORY BUFFER.

Low Ambient Temperature Cutout:

UNIT FAULT
LOW AMBIENT TEMP

The Low Ambient Temperature Safety protects the chiller from running in very low temperatures which

could cause damage due to low system pressures. This feature is programmable and can also be used to shut down the chiller at a temperature where continued running of the chiller is not economical compared to the use of “free” cooling techniques (see also Section 8.2 / Low Ambient Temperature Cutout [page 162]). The fault will clear when ambient temperature rises 2°F (1°C) above the cut-out.

High Ambient Temperature Cutout:

UNIT FAULT
HIGH AMBIENT TEMP

The High Ambient Temperature Safety protects the chiller from running in ambients above 130°F (54°C) where potential malfunction of system mechanical and electrical components may result. The High Ambient Cutout is programmable and can be set for lower limit values if required (see also Section 8.2 / High Ambient Temperature Cutout [page 162]). The fault will clear when ambient temperature drops 2°F (1°C) below the cut-out.

Low Leaving Chilled Liquid Temperature Cutout:

UNIT FAULT
LOW LIQUID TEMP

The Low Water Temperature Safety assures that the evaporator is not damaged from freezing due to improperly set control points. It also attempts to protect the chiller from freezing, if the flow switch should fail. Whenever the chilled liquid temperature drops below the programmable cutout, the chiller will shut down (see also Section 8.2 / Leaving Water Temperature Cutout, page 162). The chiller fault will clear when temperature rises 4°F (2°C) above the cut-out and cooling demand exists.

115VAC Under Voltage Cut-Out:

UNIT FAULT
115VAC UNDER VOLTAGE

The Under Voltage Safety assures that the system is not operated at voltages where malfunction of the microprocessor could result in system damage. Whenever the microprocessor senses an on-board control power supply failure while a compressor is running, the chiller is shut down. The microprocessor circuitry is capable of operating at voltages 10% below the nominal 115VAC supply to the panel. Auto-restart of the chiller occurs after a 2 minute start-up timer has elapsed from the time when power is reapplied, if the AUTO RE-START ON POWER FAILURE is enabled. Otherwise

the chiller must be manually reset. See Section 8.2 (page 162).

Flow Switch Open:

SYS	#	NO	RUN	PERM
SYS	#	NO	RUN	PERM


Closure of the flow switch(es) is monitored to check that flow is present in the evaporator when a compressor is running. Any external cycling devices fitted by the customer are connected in series with the flow switch(es). YCAS 2 System chillers have a single flow switch wired to the control panel. If the flow switch opens, all systems will shut down and a NO RUN PERM (Permissive) message will be displayed. Closing of the flow switch, when flow is present, will cause the message to disappear and auto-restart to occur.



Never bypass a flow switch. This will cause damage to the chiller and void any warranties.


2.6 SYSTEM FAULT (SAFETY) STATUS MESSAGES

A System Fault will shut the affected system down whenever a preset safety threshold is exceeded for 3 seconds. Automatic restart will occur after the first 2 shutdowns when the anti-recycle timer times out and temperature demand exists. After any combination of 3 Manual Reset Safeties in a 90 minute time period, the affected system will shut down and lock out on the last fault. When one or more systems are shut down on one of these safeties, a message will appear on the Status display informing the operator of the problem.



The High Motor Current Safety is a unique safety which will lock out a system after only a single fault.

To reset a locked out system, turn the System Switch for the affected system to the OFF position, then back to the ON position (see Section 1.11, Page 128, Fig. 46 for switch locations).



Before returning a locked out system to service, a thorough investigation of the cause of the fault should be made. Failure to repair the cause of the fault while manually allowing repetitive restarts may cause further expensive damage to the system.

High Discharge Pressure Cutout:

SYS	#	HIGH	DSCH	PRES
SYS	#	HIGH	DSCH	PRES

The Discharge Pressure Safety prevents system pressure from exceeding safe working limits. This safety is a backup for the mechanical High Pressure Cutout in each system. The Discharge Pressure Safety is programmable for a range of values below the system upper limit (see Section 8.2 / Page 160, High Discharge Pressure Cutout for more details).

High Discharge Temperature Cutout:

SYS	#	HIGH	DSCH	TEMP
SYS	#	HIGH	DSCH	TEMP

This safety protects the compressor rotors from damage due to overheating, expansion, and breakdown of the oil film seal between the rotors. It also protects against excessive oil temperature in the discharge oil separator.

For the first 4 seconds of operation discharge temperature is ignored. After 4 seconds of operation the compressor will shut down if the discharge temperature exceeds 260°F (127°C).

High Oil Differential Pressure Cutout:

SYS	#	HIGH	OIL	DIFF
SYS	#	HIGH	OIL	DIFF

The High Oil Pressure Differential Safety protects the compressors against loss of proper lubrication due to oil return line blockage. The “differential oil pressure” for this safety is computed by measuring discharge (oil separator) pressure and subtracting oil pressure returning to the compressor (Discharge - Oil = Oil PSID). Under normal operation, the oil pressure differential display will be less than 25 PSID (1.7 bar), typical 2 - 10 PSID

(0.1 to 0.7 bar). If oil pressure at the compressor drops due to filter blockage, the differential pressure on the display will increase and when the maximum limit is reached the compressor will be shut down.

This safety is activated after 3 minutes of operation. Oil pressure must be less than 65 PSID (4.4 bar) for R22 models as long as the compressor continues to run.

Low Oil Differential Pressure Cutout:

SYS # LOW OIL DIFF
SYS # LOW OIL DIFF

The Low Oil Pressure Differential Safety assures the compressor receives proper lubrication by monitoring the differential between oil pressure returning to the compressor and suction pressure. Lack of a differential indicates that the compressor is not pumping and no oil is being pumped through the compressor to lubricate the bearings and rotors.

This type of oil failure will not be picked up by the High Oil Differential Safety since no flow will cause the differential through the oil piping to drop to zero.

EXAMPLE:

For ambients above 50°F (10°C), the Low Oil Differential Safety is activated after 1 minute of compressor operation when the oil pressure differential must be greater than 10 PSID (.7 bar). After 2 minutes it must be greater than 20 PSID (1.4 bar); after 3 minutes, 30 PSID (2 bar); after 4 minutes, 40 PSID (2.7 bar); and from 5 minutes of operation and onwards, oil pressure must remain higher than 50 PSID (3.4 bar) or the system will be shut down. For lower ambients, the linear ramp times are as follows:

AMBIENT TEMP	RAMP TIME
>50°F (10°C)	5 Minutes
>45°F (7°C)	6 Minutes
>40°F (4°C)	7 Minutes
>35°F (2°C)	8 Minutes
>30°F (-1°C)	9 Minutes
<=30°F (-1°C)	10 Minutes

High Oil Temperature Cutout:

SYS # HIGH OIL TEMP
SYS # HIGH OIL TEMP

This safety assures oil temperature does not exceed a safe operating temperature which affects compressor

lubrication. Typical oil temperature during normal operation will be approximately 130 - 150°F (54 - 66°C).

The High Oil Temperature Safety is activated after 2 minutes of compressor operation, after which if oil temperature is above 225°F (107°C) for more than 3 seconds, the compressor will shut down.

Low Suction Pressure Cutout:

SYS # LOW SUCTION PRESS
SYS # LOW SUCTION PRESS


The Low Suction Pressure Cutout aids in protecting the evaporator from damage due to ice build up caused by operation at low refrigerant charge or restricted refrigerant flow. A number of transient timer features prevent nuisance trips during start-up, compressor loading, etc. The Low Suction Pressure Safety is programmable (see Section 8.2 / Page 161, Low Suction Pressure Cutout for more details).

The suction pressure cut-out is ignored for the first 45 seconds of operation. During the next 180 seconds of running, suction pressure may be lower than the cutout, but must be greater than:

$$\text{SP Cutout} = \frac{\text{Programmed Cutout} \times (\text{run Time} - 25)}{25}$$

This cutout value increases with time until after 225 seconds it equals the programmed cutout value. If suction pressure falls below the calculated cutout value before 225 seconds of run time, the system will be shut down.

The following graph shows a typical programmed suction pressure cutout of 44 PSIG (3 bar) and its change from time = 0 sec of compressor run time to 225 seconds of compressor run time.



Suction Pressure Cutout With
44 PSIG Programmed Cutout

LD07013A


FIG. 48 – SUCTION PRESSURE CUTOUT

After 225 seconds of operation with suction pressure operating above the cut-out, a 30 second transient timer prevents short term fluctuations in suction pressure due to loading or fan cycling from causing shutdown. If suction pressure drops below the cutout point after 225 seconds of operation, the transient timer is activated. While the transient timer is active, suction pressure must not drop below 10% of the cut-out initially programmed and must be greater than:

$$\text{C.O.} = \frac{\text{Programmed C.O.} \times (\text{Time} + .1)}{33.3}$$

This transient cutout value increases with time until after 30 seconds it equals the programmed cutout value. If the suction pressure falls below the value as calculated by the formula relative to time, the system will shut down on a low suction pressure fault. If the suction pressure rises above the programmed cutout value, the 30 second timer will be reset.

If the Dip Switch on the microprocessor board is set for "Water Cooling" (see page 142), the cutout is programmable between 44 - 70 PSIG (3-5 bar) for both R-22 and R407C models. In this mode, settings of 44 PSIG (3 bar) for R-22 and R407C are recommended. If the Switch is set for "Brine Cooling" (glycol) the cutout is programmable between 5 - 70 PSIG (0.3 - 5 bar) for R-22 and R407C models. In this mode, the cutout should typically be set to the saturated refrigerant pressure equivalent to 18°F (10°C) below the temperature of the chilled liquid.




The sludge point of the glycol MUST be at least 20°F (11°C) below the equivalent cutout temperature. This programmable value is password protected.

High Compressor Motor Current Cutout:

SYS # HIGH MTR CURR
SYS # HIGH MTR CURR

The High Motor Current Safety protects against excessively high motor current and shuts a system down and locks it out after only a single occurrence of a rise in average motor current above the cutout point. Motor current is monitored using 3 Current Transformers (CTs) per motor, one on each phase.

Average motor current is monitored after 7 seconds of compressor operation. The system will be shut down if average motor current exceeds 115% FLA.



FLA (full load amps) is approximately 1.2 x RLA (rated load amps). RLA is specified on the motor / chiller nameplate and is typical current demand under rated operating conditions in a fully loaded system. When a system is fully loaded, typical motor currents may be at 60 - 85% FLA depending on operating conditions.

Low Motor Current Cutout / Motor Protector (Hi Motor Winding Temp Cutout) / Mechanical High Pressure Cutout / External Motor Overload:

SYS # LOW CURR / MP / HP
SYS # LOW CURR / MP / HP

The **Low Motor Current Safety** prevents a compressor motor running with less current than would normally be expected. This may result from loss of refrigerant, contactor, or power problems as well as from a compressor that is not pumping due to a mechanical malfunction. Motor current is monitored using 3 Current Transformers (CTs) per motor, one on each phase.

Average motor current is monitored after 3 seconds of compressor operation. From this time the system will be shut down if average motor current is less than 10% of FLA.

Compressor Motor Protection Modules, External Motor Overloads and Mechanical High Pressure Cutouts are fitted to each system. All these devices stop the compressor by removing power from its motor contactor coils. This causes the CTs to obviously sense a zero current draw by the compressor motor and causes a Low Motor Current Fault to be displayed. These devices operate as follows:

The **Motor Protection Module** protects against excessive motor winding temperature by monitoring 3 or 6 sensors built into the motor windings. If the temperature becomes excessive, the module will cause power to be

removed from the compressor contactors shutting down the compressor. Auto restart will not occur since manual reset is required. A fault lockout will automatically occur after the micro attempts 2 more starts with the MP contacts open. Manual reset is accomplished by removing 115VAC control power from the micro panel after the motor sensors have sufficient time to cool. Details relating to operation of the Motor Protection Module can be found on page 18.

The **Mechanical High Pressure Cutout** protects against excessive refrigerant discharge pressure and is set to 405 PSIG (28 bar). Auto-restart will be permitted after shutdown on discharge pressure, when the pressure drops below 330 PSIG (23 bar) and the cutout contacts close. A fault lockout will result if safety thresholds are exceeded three times in a 90 minute period.

Low Evaporator Temperature Cutout (R407C Only):

S	Y	S	1	L	O	W	E	V	A	P	T	E	M	P
S	Y	S	2	L	O	W	E	V	A	P	T	E	M	P

The Low Evaporator Temperature Cutout is to protect the evaporator from freeze-up with R-407C. This safety uses the Cooler Inlet Refrigerant Temp Sensors to monitor evaporator inlet refrigerant temperature on each system. These sensors are only installed on R-407C units. If the refrigerant temperature falls below 21°F


(-6°C) in water cooling mode, the system will be shut down. If the refrigerant temp falls 19°F (11°C) below the leaving chilled liquid temp in glycol cooling mode, the system will shut down. Also, if the cooler inlet refrigerant temp sensor reads out of range low, the system will also shut down.

2.7 PRINTOUT ON FAULT SHUTDOWN


If an optional printer is installed, the contents of History Buffer 1 will be sent to the printer any time a fault shutdown occurs. This will allow record keeping of individual faults, even if they do not cause a lockout of the system. This information may be useful to identify developing problems and troubleshooting.

The No Run Permissive fault messages will not be stored in the History Buffer and will not cause an auto printout.

Due to extreme operating conditions or systems where control deficiencies are present, occasional faults may occur with the corresponding automatic printout. This is not a cause for concern.



3. DISPLAY KEYS & OPTION SWITCHES



29023A

3.1 GENERAL

The Display keys provide direct access to retrieve commonly required data about the operation of the chiller. This is particularly useful during commissioning, monitoring the operation of the chiller, diagnosing potential future problems and service troubleshooting.

When a Display key is pressed, the corresponding message will be displayed and will remain on the display until another key is pressed.

Displayed data is in “real-time” and is updated approximately every 2 seconds. If updating of one of the messages is required faster than every 2 seconds, the appropriate key for the desired display can be pushed and held to provide updating every 0.4 seconds.

Display Messages may show characters indicating “greater than” (>) or “less than” (<). These characters indicate the actual values are greater than or less than the values which are being displayed, but are outside the ability of the micro to give an actual reading. This

is unlikely to occur unless a problem exists in the measuring sensors or during extreme conditions.

The Display keys and the data available from each is as follows:

3.2 CHILLED LIQUID TEMPS KEY

When the Chilled Liquid Temperatures key is pressed a display of chilled liquid temperatures leaving the chiller (LCHLT) and returning to the chiller (RCHLT) is provided as follows:

```
LCHLT = 44.2 ° F
RCHLT = 54.0 ° F
```

If the key is pressed again, the following message will appear if an optional mixed chilled leaving temp sensor is installed for multi unit sequencing. If a sensor is not installed, pressing the key will have no effect.

```
MCHLT = 43.8 ° F
```

3.3 SYSTEM # DATA KEYS

Pressing one of the System # Data keys a number of times scrolls through displays of differential oil pressure (OIL), suction pressure (SP) and discharge pressure (DP), oil temperature, suction temperature (ST), discharge temperature (DT), saturated suction temperature, suction superheat, saturated discharge temperature, discharge superheat and compressor slide valve position.

Examples of these displays are as follows where # is the appropriate system number:

```
SYS # OIL = 176 PSIG
SP = 64 DP = 195 PSIG
```


```
SYS # OIL = 157.4 °F
ST = 31.0 DT = 123.2 °F
```

```
S# SAT SUCT = 32.9 °F
SUCT SHEAT = 15.0 °F
```

```
S# SAT DSCH = 130.0 °F
DSCH SHEAT = 54.3 °F
```

```
SYS # S V STEP = 3
```

```
SYS # COOLER INLET
REFRIG TEMP = 28.2 °F
```




The Cooler Inlet Temp. display will only appear if the chiller is selected for R407C.

Temperatures and pressures are either measured directly by transducers and temperature sensors, or computed from these measurements as follows:

Saturated discharge and suction temperatures are computed by converting measured pressure to temperature.


Slide Valve Position is computed based on the number of loading steps that the micro has sent to the slide valve solenoid in the form of a current signal. To the microprocessor, STEP 0 = fully unloaded and STEP 75 = fully loaded.




Slide valve position is APPROXIMATE and should be used for reference only. Under actual conditions the compressor may be fully loaded between step 60 - 75 and fully unloaded between step 0 - 40.

Superheats are the difference between the respective saturated temperature (converted from pressure) and the actual. Display Limits for the System Pressures and Temperatures displays are as follows:

	MIN. LIMIT	MAX. LIMIT
Oil Pressure	208 PSID (14 Bar)	0 PSID (0 Bar)
Suction Pressure	0 PSIG (0 Bar)	199 PSIG (14 Bar)
Discharge Pressure	0 PSIG (0 Bar)	399 PSIG (28 Bar)
Suction Temp.	*9.0 °F (-13°C)	84.2 °F (29°C)
Discharge Temp.	40.3 °F (5°C)	302.6 °F (150°C)
Oil Temp.	40.3 °F (5°C)	240.0 °F (116°C)
Sat. Discharge Temp.	-41.0 °F (-41°C)	140.5 °F (60°C)
Sat. Suction Temp.	-41.0 °F (-41°C)	101.3 °F (39°C)
Slide Valve Position	0% (0%)	100% (100%)
Suction Superheat	*-81.5 °F (-63.1°C)	60.9 °F (16°C)
Discharge Superheat	22.5 °F (-5.3°C)	216.0 °F (102.2°C)



Minimum and maximum values may change as software (EPROM) revisions are made.



**Below 9.0°F (13°C), the Suction Temp. display will disappear. This will in turn cause the Superheat display to disappear.*

3.4 AMBIENT TEMP KEY

When the Ambient Temperature key is pressed, ambient air temperature, as measured surrounding the chiller, is displayed.

```
AMBIENT AIR TEMP
= 71.9 °F
```

Display Limits: Minimum -4.6°F (-20.3°C)
Maximum 137.9°F (58.8°C)

3.5 MOTOR CURRENT KEY

Pressing the Motor Current key displays compressor current for each system:

```
COMP 1 = 63 AMP 85% FLA
COMP 2 = 30 AMP 41% FLA
```

This display shows the average motor current in amps and average compressor motor current as a percentage of FLA. All values are approximate. Keep in mind that current in “amps” is an “approximate” value.

```
ISN CRNT LIMIT: NONE
EMS CRNT LIMIT: NONE
```

On the second press of the of the Motor Current Key, the current limit values as set by the ISN (Remote BAS System) and EMS-PWM current limiting input are displayed, if they are active. See Sections 1.10, and 2.4 for more details.

3.6 OPERATING HRS / START COUNTER KEY


When the Operating Hours / Starts Counter key is pressed, the accumulated running hours and starts for System 1 and 2 compressors are displayed. Where applicable, pressing the key again displays the values for Systems 3 and 4 on larger models:

```
HRS 1 = 1143.2 = 1382
STR 1 = 285.2 = 322
```

```
HRS 3 = 1255.4 = 1095
STR 3 = 365.4 = 455
```

Display Limits : Maximum run hours 99,999
Maximum starts 99,999

Values roll over to zero, if the maximum limit is exceeded.



These counters are zeroed at the factory, but may indicate run time and number of starts logged during factory testing prior to shipment.

3.7 OPTIONS KEY & DIP SWITCH SETTINGS

The Options key provides a display of options which are programmed by the positions of the S1 Dip Switches on the Microprocessor Board. Proper programming of the switches is important during the commissioning of

the chiller. The Options key can be used to verify the Dip Switch positions without looking at or handling the Microprocessor Board.

Each press of the key will scroll to the next option/dip switch setting.

Three Option Switch Messages (S1-1 to S1-3) will then be displayed in sequence. At the end of the sequence, the display will automatically revert to the first Option Switch message.

The following is a detailed guide to programming the Dip Switches together with the associated display message provided for each selection when the Options key is pressed:

SWITCH 1: Water / Brine Cooling

Open:

```
S1 - 1 CHILLED LIQUID
      WATER
```

Water Cooling Mode is for water cooling applications and allows the chilled liquid leaving temperature setpoint to be programmed from 40 to 70 °F (4 to 21°C). Selecting this mode also auto-programs the Low Chilled Liquid Cut-Out at 36°F (2°C) and the Suction Pressure Cut-Out at 44 PSIG (3 bar).

Closed:

```
S1 - 1 CHILLED LIQUID
      GLYCOL
```

Brine Cooling Mode is for brine/glycol applications with setpoints below 40°F (4°C) and allows the chilled liquid leaving temperature setpoint to be programmed from 10 to 70°F (-12 - 21°C). In this mode, the Low Chilled Liquid Cut-Out can be programmed from 8 to 36° F (-13 to 2°C) and the Suction Pressure Cut-Out programmed from 20 to 70 PSIG (1 to 5 bar) for R-22 models and 5 to 70 PSIG (0.3 to 5 bar) for R407C models.

SWITCH 2: Ambient Temp. Low Limit

Open:

```
S1 - 2 AMBIENT CONTROL
      STANDARD
```

Standard Ambient Mode auto-programs the Low Ambient Cutout setting at 25°F (-4°C) and is not adjustable.

Closed:

**S 1 - 2 A M B I E N T C O N T R O L
L O W A M B I E N T**

Low Ambient Mode allows the Low Ambient Cut-Out to be programmed from 0 to 50 °F (-18 to 10°C). Values above 25°F (-4°C) can be used to automatically shut down the chiller when direct cooling methods become operational.

SWITCH 3: Refrigerant**Open:**

**S 1 - 3 R E F R I G E R A N T
R - 4 0 7 C**

The R-407C Mode MUST be selected for models using refrigerant R-407C. Incorrect selection of this switch may cause serious damage to the chiller.

Closed:

**S 1 - 3 R E F R I G E R A N T
R - 2 2**

The R-22 Mode MUST be selected for models using refrigerant type R-22. Incorrect selection of this switch may cause serious damage to the chiller.

SWITCH 4: Unit Type**Open:**

**S 1 - 4 U N I T T Y P E
Y C W S**

Set this switch to Open if the chiller type is YCWS.

Closed:

**S 1 - 4 U N I T T Y P E
Y C A S**

Set this switch to Closed if the chiller type is YCAS.

SWITCH 5: Motor Current Averaging**Open:**

**S 1 - 5 M O T O R C U R R E N T A V E R A G I N G
D O N O T U S E**

If do not use “motor current averaging”, set this switch to Open.

Closed:

**S 1 - 5 M O T O R C U R R E N T A V E R A G I N G
A V G. D I S A B L E**

If need to disable “motor current averaging”, set this switch to Closed.

SWITCH 6: Heat Recovery**Open:**

**S 1 - 6 H E A T R E C O V E R Y
D I S A B L E D**

Set this switch to Open if no “heat recovery” or do not need to use it.

Closed:

**S 1 - 6 H E A T R E C O V E R Y
E N A B L E D**

Set this switch to Closed if chiller with “heat recovery” and need to use it.

SWITCH 7: Exp. Valve Type**Open:**

**S 1 - 7 E X P. V A L V E T Y P E
T H E R M O S T A T I C**

If TXV is used, set this switch to Open position.

Closed:

**S 1 - 7 E X P. V A L V E T Y P E
E L E C T R O N I C**

If EEV is used, set this switch to Closed position.

SWITCH 8: Spare

Dip Switch Physical Location and Setting





FIG. 49 – ENLARGED PHOTOGRAPH OF DIP SWITCHES ON MICROPROCESSOR BOARD

Summary of Settings

The following table gives a summary of Modes (displayed messages) which can be selected using the Open and Closed positions for each of the eight SW1 Dip Switches.


SWITCH	SWITCH “OPEN” SETTING	SWITCH “CLOSED” SETTING
1	Water Cooling	Brine Cooling
2	Standard Ambient Control	Low Ambient Control
3	Refrigerant R-407C	Refrigerant R-22
4	Unit Type YCWS	Unit Type YCAS
5	Motor Current Averaging Do Not Use	Motor Current Averaging AVG. Disabled
6	Heat Recovery Disabled	Heat Recovery Enabled
7	EXP. Valve Type TXV	EXP. Valve Type EEV
8	SPARE	SPARE

3.8 FUNCTION KEY

Pressing the Function key only displays the same message as pressing the Status key. Pressing the Function key followed by another display key will scroll through all the data available under that key once. E.g., pressing the Function key followed by the System 1 Data key will result in scrolling through the 5 displays shown in Section 3.3 without the need to press the System 1 Data key to scroll to the next display. After scrolling through the data, the display returns to the status message.

The following keys can be scrolled using the Function Key: Chilled Liquid Temps, System # Data, Motor Current and Options.

4. PRINT KEYS



29023A

4.1 GENERAL

The Print keys provide access to two sets of information either locally on the panel display or, if an optional printer is connected, remotely as hard copy printouts.

The Operating Data (Oper Data) key provides a real-time list of system operating data and programmed settings. The History key provides a comprehensive list of operating data and programmed settings “at the instant of fault” on each of the last six faults (local display) or three faults (remote printout) which occurred on the chiller.

4.2 OPER DATA KEY

If a remote printer is not connected, pressing the Operating Data key allows the user to scroll through information, on the 40 character display, which is not directly available from the Display keys on the panel.

If a remote printer is connected, pressing the Operating Data key causes a snapshot to be taken of system operating conditions and of the user programming selections. The data is stored in temporary memory, then transmitted from the microprocessor to the remote printer. As the data is transmitted it is erased from the memory.

Information available using the Operating Data key is described in the following sections. In example displays “#” is used to indicate system number where appropriate.

4.3 OPERATING DATA – LOCAL DISPLAY MESSAGES

YCAS 2 SYSTEM MODELS :

When the Operating Data key is pressed, the following message appears:

**OPERATING DATA
DISPLAYS**

Repetitively pressing the ↑↓ keys will scroll through the following Common (whole chiller) Data and individual System Data information displays.

Common Data:

LOAD	TIMER	10	SEC
UNLOAD	TIMER	0	SEC

This message shows the time remaining on the Load Timer and the Unload Timer. These Timers constantly recycle and are used in conjunction with “rate control” and “temperature deviation from setpoint” to determine when loading should occur.

Micro Panel Contents

```
TEMP ERROR    00.5 °F
TEMP RATE    - 0.9 °F / M
```

The upper message gives the difference (error) between actual leaving chilled liquid temperature and the programmed Target temperature. The lower message gives the rate of change of the chilled liquid leaving temperature in degrees per minute. A minus sign (-) indicates falling temperature. No sign indicates rising temperature.

```
LEAD SYSTEM IS
SYSTEM NUMBER      #
```

This message advises which system is programmed as the lead.

```
EVAP PUMP IS      OFF
EVAP HEATER IS    ON
```

This message indicates the position of the optional auxiliary contacts for the evaporator water pump and the status of the evaporator heater.

For the evaporator pump contacts, ON = contacts closed, OFF = contacts open.

The Evaporator Heater status is controlled on ambient temperature as follows: If measured ambient falls below 40°F (4°C) the Evaporator Heater is switched ON. If measured ambient then rises above 45°F (7°C) the heater is switched OFF. The evaporator heater prevents water standing in the evaporator from freezing.

```
ACTIVE REMOTE CTRL
NONE
```

This message indicates that a remote device such as a Remote Control Center, an ISN controller, or another device sending a PWM signal for temperature or current reset is overriding control points programmed through the keypad or default microprocessor setpoints. The following displays may be encountered:

NONE – No remote control active. Remote monitoring may be active.

ISN – YorkTalk via ISN or Remote Control Center (remote mode).

PWM CURR – EMS PWM Current Limiting Enabled

PWM TEMP – EMS PWM Temp. Reset Enabled

CUR/TEMP – EMS PWM Current Limiting & Temperature Reset Enabled

System Data:

The following sequence of three displays are provided first for System 1, then for System 2, and then for Systems 3 and 4 as applicable.

```
SYS # RUN TIME
1 - 3 - 48 - 17 D - H - M - S
```

This message displays the accumulated Run Time since the last start in Days (D), Hours (H), Minutes (M), and Seconds (S).


```
SYS # LLSV IS      ON
ECON TXV SOL IS    ON
```

This message indicates the Liquid Line Solenoid Valve and the economizer TXV solenoid valve position: ON = Energized/Open, OFF = De-energized/Closed.

```
SYS # FAN STAGE    3
COMP HEATER IS     ON
```

This message advises the stage of condenser fan operation on this system and the status of the compressor heater. See Section 8.4 for details of fan staging.

Once the System Data sequence has been repeated for the second system, pressing the ↑ or ↓ key again will loop back to the beginning to the Load/Unload Timer display. To leave the sequence at any point press a key from another section of the keypad.



Pressing the “*” at any time while in the OPER DATA mode displays the EPROM software version being used, as shown below:

```
SOFTWARE VERSION
C . A 1 4 . 1 0 . 0 1
```

4.4 OPERATING DATA – REMOTE PRINTOUT

The follow text shows a typical example printout obtained by pressing the Operating Data key with an optional printer attached. In this case an example is shown for a YCAS 2 System Chiller.

YORK INTERNATIONAL CORPORATION
MILLENNIUM SCREW CHILLER

UNIT STATUS
2:04PM 10 OCT 98

SYS 1 NO COOLING LOAD
SYS 2 COMPRESSOR RUNNING

OPTIONS

CHILLED LIQUID WATER
AMBIENT CONTROL STANDARD
REFRIGERANT TYPE R407C

PROGRAM VALUES

DSCH PRESS CUTOUT 399 PSIG
DSCH PRESS UNLOAD 375 PSIG
SUCTION PRESS CUTOUT 44 PSIG
HIGH AMBIENT CUTOUT 130.0 DEGF
LOW AMBIENT CUTOUT 25.0 DEGF
LEAVING LIQUID CUTOUT 36.0 DEGF
MOTOR CURRENT UNLOAD 100 %FLA
ANTI RECYCLE TIME 600 SECS
LOCAL/REMOTE MODE REMOTE
LEAD/LAG CONTROL AUTOMATIC

UNIT DATA

LEAVING LIQUID TEMP 49.0 DEGF
RETURN LIQUID TEMP 58.2 DEGF
MIXED LIQUID TEMP 51.3 DEGF
COOLING RANGE 42.0 +/- 2.0 DEGF
AMBIENT AIR TEMP 74.8 DEGF
LEAD SYSTEM SYS 2
EVAPORATOR PUMP ON
EVAPORATOR HEATER OFF
ACTIVE REMOTE CONTROL NONE
SOFTWARE VERSION C.ACS.09.00

SYSTEM 1 DATA


COMPRESSORS STATUS OFF
RUN TIME 0- 0- 0- 0 D-H-M-S
MOTOR CURRENT 0 AMPS 0 %FLA
SUCTION PRESSURE 125 PSIG
DISCHARGE PRESSURE 131 PSIG
OIL PRESSURE 130 PSIG
SUCTION TEMPERATURE 68.4 DEGF
DISCHARGE TEMPERATURE 68.8 DEGF
OIL TEMPERATURE 68.8 DEGF
SAT SUCTION TEMP 71.8 DEGF
SUCTION SUPERHEAT 3.4 DEGF
SAT DISCHARGE TEMP 74.5 DEGF
DISCHARGE SUPERHEAT 6.3 DEGF
SLIDE VALVE STEP 0
COOLER INLET REFRIG 44.6 DEGF
LIQUID LINE SOLENOID OFF
ECONOMIZER TXV SOLENOID OFF
CONDENSER FAN STAGE OFF
COMPRESSOR HEATER ON
WYE-DELTA RELAY OFF

SYSTEM 2 DATA

COMPRESSORS STATUS ON
RUN TIME 0- 0-15-26 D-H-M-S
MOTOR CURRENT 104 AMPS 87 %FLA
SUCTION PRESSURE 57 PSIG
DISCHARGE PRESSURE 233 PSIG
OIL PRESSURE 218 PSIG
SUCTION TEMPERATURE 42.9 DEGF
DISCHARGE TEMPERATURE 145.5 DEGF
OIL TEMPERATURE 102.8 DEGF
SAT SUCTION TEMP 31.7 DEGF
SUCTION SUPERHEAT 11.2 DEGF
SAT DISCHARGE TEMP 112.1 DEGF
DISCHARGE SUPERHEAT 33.4 DEGF
SLIDE VALVE STEP 70
COOLER INLET REFRIG 23.6 DEGF
LIQUID LINE SOLENOID ON
ECONOMIZER TXV SOLENOID ON
CONDENSER FAN STAGE 3
COMPRESSOR HEATER OFF
WYE-DELTA RELAY ON

DAILY SCHEDULE

S M T W T F S *=HOLIDAY
MON START=00:00AM STOP=00:00AM
TUE START=00:00AM STOP=00:00AM
WED START=00:00AM STOP=00:00AM
THU START=00:00AM STOP=00:00AM
FRI START=00:00AM STOP=00:00AM
SAT START=00:00AM STOP=00:00AM
HOL START=00:00AM STOP=00:00AM



The System Cooler Inlet Refrigerant Temperature will be printed if the unit is in R407C mode.

4.5 HISTORY KEY

If a safety shutdown occurs on the chiller, a comprehensive list of operating and programmed settings data is stored by the microprocessor. The information is stored at the instant of the fault, regardless of whether the fault caused a lockout to occur. This information is not affected by power failures or manual resetting of a fault lockout.

The microprocessor stores data for up to 6 safety shutdowns. Once this limit is reached, a further shutdown will cause the oldest set of data to be discarded in favor of storing the new shutdown data. The Safety Shutdowns are numbered from 1 to 6 with number 1 always being the most recent.

If a remote printer is not connected, pressing the History key allows the operator to locally scroll through information relating to the stored safety shutdowns on the control panel display.

If a remote printer is connected, pressing the History key will cause data from the last 6 shutdowns to be transmitted from the microprocessor to the remote printer. The printout will begin with the most recent fault which occurred. This does not affect the stored data and as many prints as desired may be taken. See Section 4.7 for a HISTORY printout sample.

4.6 FAULT HISTORY DATA – LOCAL DISPLAY MESSAGES

When the History key is pressed, the following message will appear:

DISPLAY SAFETY SHUT -
DOWN NO. 1 (1 TO 6)

To select a Safety Shutdown, press the appropriate key on the numeric key pad, then press Enter. Remember that the most recent fault information is stored as shutdown No. 1. After the ENTER Key is pressed, a message indicating the time and date of the Fault Shutdown will appear:

SHUTDOWN OCCURRED
5 : 59 AM 29 NOV 98

Repetitively pressing the ↑↓ Keys allows scrolling through the information available in the Safety Shutdown buffer. This is divided into Common (Whole Chiller) Data and Individual System Data displays as follows:

Common Data:

SYS 1 NO FAULTS
SYS 2 HIGH MTR CURR

This message indicates the fault that caused the shutdown; in this case, a high motor current in System 2 was the cause of the shutdown.

S1 - 1 CHILLED LIQUID
WATER

This message displays the type of chilled liquid selected (water or glycol) at the time of the fault.

S1 - 2 AMBIENT CONTROL
LOW AMBIENT

This display indicates whether standard or low ambient operation was selected at the time of the fault.

S1 - 3 REFRIGERANT
R - 22

This message indicates the type of refrigerant that was programmed at the time of the fault (R-22 or R407C).

DISCHARGE PRESSURE
CUTOUT = 395.0 PSIG

This message indicates the discharge pressure cut-out programmed at the time of the fault.

DISCHARGE PRESSURE
UNLOAD = 375.0 PSIG

This display provides the discharge pressure unload point, programmed at the time of the fault.

SUCTION PRESSURE
CUTOUT = 44.0 PSIG

This message displays the suction pressure cut-out programmed at the time of the fault.

H I G H A M B I E N T T E M P
C U T O U T = 1 3 0 . 0 ° F

This message indicates the High Ambient Temperature Cutout at the time of the fault.

L O W A M B I E N T T E M P
C U T O U T = 2 5 . 0 ° F

This display shows the Low Ambient Cutout programmed at the time of the fault.

L E A V I N G L I Q U I D T E M P
C U T O U T = 3 6 . 0 ° F

This display shows the Low Leaving Chilled Liquid Cutout programmed at the time of the fault.

H I G H M O T O R C U R R E N T
U N L O A D - 1 0 0 % F L A

This message shows the programmed %FLA Motor Current Unload at the time of the fault.

L O C A L / R E M O T E M O D E
L O C A L

This message shows whether remote or local communications was selected at the time of the fault.

L E A D / L A G C O N T R O L
A U T O M A T I C

This message displays the lead/lag selection programmed at the time of the fault.

L C H L T = 4 4 . 1 ° F
R C H L T = 5 2 . 9 ° F

This message indicates the leaving and return chilled liquid temperature at the time of the fault.

M C H L T = 4 3 . 8 ° F

This message indicates the mixed water temperature at the time of the fault. A mixed water sensor may be present when multi-unit sequencing is utilized. If no mixed water temperature sensor is installed, the display will not appear.

S E T P O I N T = 4 4 . 0 ° F
R A N G E = + / - 2 . 0 ° F

This message displays the programmed chilled liquid setpoint and deviation (control range) programmed at the time of the fault.

A M B I E N T A I R T E M P
7 7 . 6 ° F

This message indicates the outdoor Ambient Air Temperature at the time of the fault.

L E A D S Y S T E M I S
S Y S T E M N U M B E R 1

This message indicates which system was in the lead at the time of the fault.

E V A P P U M P I S O N
E V A P H E A T E R I S O F F

This message indicates the status of both the evaporator pump signal from the microprocessor and the evaporator heater.

A C T I V E R E M O T E C T R L
N O N E

This message indicates that a remote device such as a Remote Control Center, an ISN controller, or another device sending a PWM signal for temperature or current temperature or current reset is overriding control points programmed through the keypad or default microprocessor setpoints.

System Data:

Following the Common Data is a sequence of twenty information displays which are given twice, first for System 1, then for System 2. In each example, “#” is used to indicate System number:

S Y S # C O M P R E S S O R
I S O N

This message indicates whether the compressor on this system was ON or OFF at the time of the fault.

Micro Panel Contents

```
SYS # RUN TIME
1 - 3 - 4 8 - 1 7 D - H - M - S
```

This message shows the Run Time logged on the system since the last compressor start, in Days (D), Hours (H), Minutes (M), and Seconds (S).

```
SYS # MOTOR CURRENT
7 8 % FLA
```

This message indicates the compressor motor current in as a percentage of Full Load Amps.

```
SYS # OIL = 1 5 4 . 8 ° F
ST = 9 . 0 DT = 1 2 3 . 7 ° F
```

This message shows the system differential oil pressure at the time of the fault.

```
SYS # OIL = 6 5 PSIG
SP = 6 2 DP = 2 7 1 PSIG
```

This message indicates the system oil line temperature at the time of the fault.

```
S # SAT SUCT = 3 4 . 7 ° F
SUCT SHEAT = - 6 . 5 ° F
```

These messages indicate compressor suction gas saturation temperature and superheat at the time of the fault.

```
S # SAT DSCH = 1 2 9 ° F
DSCH SHEAT < - 8 . 4 ° F
```

This message indicate compressor discharge gas saturation temperature and superheat at the time of the fault.

```
SYS # SV STEP = 4 0
```

This message indicates the compressor slide valve position at the time of the fault. 0 steps equals minimum capacity and 75 steps equals fully loaded.

```
SYS # COOLER INLET
REFRIG TEMP = 2 8 . 2 ° F
```

This message, which is only displayed if the unit is in R-407c mode, indicates the refrigerant temperature at the inlet of the cooler.

```
SYS # LLSV IS ON
ECON TXV SOL IS OFF
```

This message indicates the Liquid Line Solenoid Valve and the economizer Thermal Expansion Valve Solenoid Valve position: ON = Energized / OFF = De-Energized (OFF) at the time of the fault.

```
SYS # FAN STAGE 3
COMP HEATER IS OFF
```

This message indicates the stage of condenser fan operation on the system and the status of the compressor heater at the time of the fault. See Section 8.4 for details of fan staging.

4.7 FAULT HISTORY DATA – REMOTE PRINTOUT

A printout history of unit and system operating conditions, at the time of the fault, can be obtained by pressing the HISTORY Key with an optional printer installed. 2 compressor chillers will provide a history printout on the last 6 faults.

An example of the HISTORY Printout is shown below:

```

YORK INTERNATIONAL CORPORATION
MILLENNIUM SCREW CHILLER

SAFETY SHUTDOWN NUMBER 1
SHUTDOWN @ 3:56 PM 29 SEPT 98

SYS 1 HIGH DSCH PRESS SHUTDOWN
SYS 2 NO FAULTS

OPTIONS

CHILLED LIQUID WATER
AMBIENT CONTROL STANDARD
REFRIGERANT TYPE R407C

PROGRAM VALUES

DSCH PRESS CUTOUT 399 PSIG
DSCH PRESS UNLOAD 375 PSIG
SUCT PRESS CUTOUT 44 PSIG
HIGH AMBIENT CUTOUT 130.0 DEGF
LOW AMBIENT CUTOUT 25.0 DEGF
LEAVING LIQUID CUTOUT 36.0 DEGF
MOTOR CURRENT UNLOAD 100 %FLA
ANTI RECYCLE TIME 600 SECS
LOCAL/REMOTE LEAD DATA REMOTE
LEAD /LAG CONTROL AUTOMATIC

UNIT DATA

LEAVING LIQUID TEMP 49.0 DEGF
RETURN LIQUID TEMP 58.2 DEGF
MIXED LIQUID TEMP 51.3 DEGF
COOLING RANGE 42.0 +/- 2.0 DEGF
AMBIENT AIR TEMP 74.8 DEGF
LEAD SYSTEM SYS 2
EVAPORATOR PUMP ON
EVAPORATOR HEATER OFF
ACTIVE REMOTE CONTROL NONE
SOFTWARE VERSION C.ACS.09.00

SYSTEM 1 DATA

COMPRESSORS STATUS OFF
RUN TIME 0- 0- 0- 0 D-H-M-S
MOTOR CURRENT 0 AMPS 0 %FLA
SUCTION PRESSURE 125 PSIG
DISCHARGE PRESSURE 131 PSIG
OIL PRESSURE 130 PSIG
SUCTION TEMPERATURE 68.4 DEGF
DISCHARGE TEMPERATURE 68.8 DEGF
OIL TEMPERATURE 68.8 DEGF
SAT SUCTION TEMP 71.8 DEGF

```

```

SUCTION SUPERHEAT 3.4 DEGF
SAT DISCHARGE TEMP 74.5 DEGF
DISCHARGE SUPERHEAT 6.3 DEGF
SLIDE VALVE STEP 0
COOLER INLET REFRIG 44.6 DEGF
LIQUID LINE SOLENOID OFF
ECONOMIZER TXV SOLENOID OFF
CONDENSER FAN STAGE OFF
COMPRESSOR HEATER ON
WYE-DELTA RELAY OFF

```

SYSTEM 2 DATA

```

COMPRESSORS STATUS ON
RUN TIME 0- 0-15-26 D-H-M-S
MOTOR CURRENT 104 AMPS 87 %FLA
SUCTION PRESSURE 57 PSIG
DISCHARGE PRESSURE 233 PSIG
OIL PRESSURE 218 PSIG
SUCTION TEMPERATURE 42.9 DEGF
DISCHARGE TEMPERATURE 145.5 DEGF
OIL TEMPERATURE 102.8 DEGF
SAT SUCTION TEMP 31.7 DEGF
SUCTION SUPERHEAT 11.2 DEGF
SAT DISCHARGE TEMP 112.1 DEGF
DISCHARGE SUPERHEAT 33.4 DEGF
SLIDE VALVE STEP 70
COOLER INLET REFRIG 23.6 DEGF
LIQUID LINE SOLENOID ON
ECONOMIZER TXV SOLENOID ON
CONDENSER FAN STAGE 3
COMPRESSOR HEATER OFF
WYE-DELTA RELAY ON

```

DAILY SCHEDULE

S M T W T F S *=HOLIDAY

5. ENTRY KEYS



29023A

5.1 GENERAL

The Entry keys allow the user to change numerical values programmed in as chiller setpoints, cutouts, clock, etc.

5.2 NUMERICAL KEYPAD

The Numerical keypad provides all keys necessary to program numerical values into the Micro Panel.

The “*” key is used to designate holidays when programming special start/stop times for designated holidays in the SET SCHEDULE/HOLIDAY program mode.

The “+/-” key allows programming -C setpoints and cut-outs in the metric display mode.

5.3 ENTER KEY

The Enter key must be pushed after any change is made to setpoints, cutouts, or system clock. Pressing this key tells the micro to accept new values into memory. If this is not done, the new values entered will be lost and the original values will be returned.

The Enter key is also used to scroll through available data when using the Program or Set Schedule/Holiday keys.


5.4 CANCEL KEY

When the Cancel key is pressed, the cursor will always return to the first character to be programmed in the display message. This allows the operator to begin re-programming, if an error is made. When the Cancel key is pressed, the values already keyed in will be erased and the original or internally programmed default values will appear. In other instances the display will remain the same and the only reaction will be the cursor returning to the first character.

5.5 ↑↓ KEYS

The ↑↓ keys allow the user to scroll through data under the OPER DATA and HISTORY Key and to select the correct day of the week and the correct month when programming the micro with the correct time and date. The ↓ key also operates as a toggle AM/PM key if the cursor is over “AM” or “PM” on the display. For example, pressing the ↓ key when the cursor is on “PM” changes it to “AM.”

6. SETPOINTS KEYS & CHILLED LIQUID CONTROL



29023A

6.1 GENERAL


The microprocessor monitors leaving chilled liquid temperature and adjusts the chiller cooling capacity to maintain this temperature within a programmed range. The capacity is controlled by switching compressors on or off, and by varying a load/unload current to each compressor slide valve to adjust the capacity of the compressors. The microprocessor controls chilled liquid temperature through a combination of Fuzzy Logic control and internal timers. Fuzzy logic enables the micro to analyze the deviation from setpoint and the rate of change and determine the amount of loading and unloading necessary to control to the desired chilled liquid setpoint temperature. The micro also attempts to maximize efficiency by spreading the cooling load between compressors, minimize compressor cycling, and optimally utilize evaporator tube surface (maximize efficiency). This method of control is suitable for both water and brine cooling. Control setpoints can be programmed into the chiller to establish the desired range of leaving chilled liquid operating temperatures. A description of the operation and programming follows.

6.2 CHILLED LIQUID TEMPERATURE CONTROL

The Setpoints keys are used to program the required chilled water liquid temperature for the application. This is accomplished by programming the “Setpoint” and the acceptable deviation (+ or - Range) This deviation is simply called the “Control Range” and is best

described as the maximum acceptable + and - deviation from Setpoint.

The minimum acceptable temperature is the Lower Range and is calculated by subtracting the “-” Range from the Setpoint. The Lower Range is the lowest acceptable leaving temperature. The highest acceptable temperature is referred to as the Upper Range and is calculated by adding the “+” Range to the Setpoint. The Upper Range is the highest acceptable leaving temperature. For example, if the desired Setpoint temperature is 44.0°F (7°C) and the allowable deviation (+/- Range) from this temperature is +/- 2.0°F (1°C), then the micro will attempt to control leaving chilled liquid temperatures to 42.0°F (6°C) to 46.0°F (8°C). This can be viewed pictorially as follows:



To assure that the chilled liquid leaving temperature stays within the Control Range, the micro will attempt to control the leaving temperature to the actual Setpoint temperature. This is accomplished by analyzing the temperature error and the rate of change to determine the amount of loading necessary to cool the chilled liquid

to the Setpoint Temperature. The amount of loading is varied by changing the amount of signal to the slide valve solenoid of each compressor.

Slide Valve Control

The slide valve of each compressor can be moved 75 steps, where “0” equals minimum capacity and fully loaded equals 75 steps. The amount of movement that occurs when the micro initiates changes may vary according to the error or deviation from setpoint and the rate of change of chilled liquid temperature. Each time a change is made, the incremental change may vary from 1 to 10 steps as determined from the micro. In cases where internal limiting is not in effect due to possible fault conditions, the micro will load the compressor with the lowest number of steps, alternating loading back and forth between compressors until both are fully loaded or unloaded.

In some cases the micro will be required to make decisions regarding loading under conditions where the “error” and “rate” conflict. For example, the micro may elect to unload a compressor if the error is “0” (temperature is at setpoint), while the rate of change of chilled liquid temperature is negative (falling). The micro may also elect to hold capacity when error is “+” (temperature is above setpoint) because the rate of change of chilled liquid is “-”. Below is a chart which illustrates these conditions.

RATE \ ERROR	ERROR		
	Negative	Zero	Positive
Negative	Unload	Unload	Hold
Zero	Unload	Hold	Load
Positive	Hold	Load	Load

Load Timers

Fixed timers are set to minimize undershoot and overshoot as a result of slide valve control.

- Load Timers are always set at 10 seconds between changes.
- Unload timers are set at 5 seconds between changes.

Slide Valve Position

A slide valve position (S V STEP), under the keypad system keys, of 75 indicates that the compressor is fully loaded. However due to the non-exact movement of the mechanism, a position less than 75, possibly 60, could also mean that the compressor is fully loaded. Keep this potential indicator error in mind when attempting to determine slide valve position versus actual compressor capacity.

Compressor Starting & Loading Sequence

If no compressors are running, the Daily Schedule permits, all safeties and run permissives are satisfied, the anti-recycle timers have timed out, and the leaving liquid temperature rises above the upper limit of the Control Range, the lead compressor will be started. A full current signal is sent to the compressor slide valve control solenoid to allow the internal spring to push the slide valve to a minimum loading position to assure it is fully unloaded at start. For the first 15 seconds of operation, or until pumpdown to cutout occurs, the liquid line solenoid valve will remain closed. After an initial period of 15 seconds, the micro will begin to load up the lead compressor to bring the chilled liquid temperature to setpoint.

After 5 minutes of run time, if Setpoint Temperature is not met, the micro will start the lag compressor. This is not dependent on slide valve position which after 5 minutes will be fully loaded at a S V Step of “75”. The lead compressor will be reduced in capacity to a slide valve step of 40. The lag compressor will then be loaded until it also reaches a slide valve step of 40 while the lead compressor is maintained at a constant load. At this point the compressors will be alternately loaded with loading always occurring on the compressor with the lowest slide valve step until the leaving chilled liquid is satisfied.

Compressor Loading

The micro loads and unloads individual compressors by varying current to the Slide Valve solenoid which controls oil flow to the slide valve. The slide valve load solenoid applies oil pressure to the slide valve to overcome spring pressure from an internal spring, increasing capacity. The internal spring moves the slide valve in the opposite direction against oil pressure to decrease capacity.

Whenever chilled liquid leaving temperature is above the Setpoint, loading current will increase to allow oil pressure to move the slide valve to increase capacity. Every 10 seconds, the micro will increment the slide valve step from 1 to 10 steps according to error (deviation from setpoint) and rate of change of chilled liquid.

The micro will always choose the compressor with the lowest slide valve position to load on increasing demand, provided the compressor is not pumping down, has run at least 15 seconds, and is not in a “Limiting” condition.

Loading Limiting


Load limiting will occur if a system safety threshold is neared. The anticipatory capability of the micro limits loading or unloads a system if the micro anticipates a safety threshold will be exceeded. Under circumstance where loading is required and one of the systems is nearing a threshold, the micro may elect to split the number of steps that it would normally load a compressor between more than one compressor. For instance, if system 1 were nearing its motor current unload point and it was scheduled to load, the micro could split a load signal of 10 steps between system 1 and 2. It could only load SYS 1 “2” steps while loading SYS 2 “8” Steps. Under these circumstances, the two systems will not appear to equalize loading.

Compressor Unloading and Shutdown Sequence


Whenever temperature is below the Setpoint, unloading pulses will be sent to open the unloading port on the control solenoid to relieve oil pressure on the slide valve on the compressor with the highest slide valve

step. Opening of the unloading port on the control solenoid allows spring pressure to move the slide valve to decrease capacity. Every 5 seconds, the micro will decrement the compressor with the highest slide valve position by 1 - 10 steps according to the error (deviation from Setpoint) and the rate of change of chilled liquid temperature.

As load drops, the micro will continue to unload the compressor with the highest slide valve step until all compressor slide valves are at “0.” At this point, the last lag compressor will pump down and cycle off, if chilled liquid temperature drops below “Setpoint - Control Range/2”. As load continues to decrease and the lag compressor cycles off, the lead compressor will continue to unload to a slide valve position of “0” and will pump down and cycle off if the chilled liquid temperature drops below “Setpoint – Control Range.”



The lag compressor may be shut down before it is fully unloaded to avoid a Chiller fault on a Low Water Temperature cut-out under the following conditions: a) if chilled liquid temperature falls below the low end of the Control Range (CR) for more than 37 seconds, b) if chilled liquid temperature drops more than CR/4 below the low limit of the Control Range.



The lead compressor may be shut down before it is fully unloaded to avoid a Chiller Fault on Low Water Temperature under the following conditions: a) if chilled liquid temperature drops 2°F below the low limit of the Control Range (CR), b) if chilled liquid temperature drops more than CR/2 below the low limit of the Control Range.

6.3 LOCAL COOLING SETPOINTS KEY

The Local Cooling Setpoints key is used to program the required Leaving Chilled Liquid control temperatures for the application. When the key is pressed, the following message will be displayed:

```
SETPOINT = 44.0 °F
RANGE = + / - 2.0 °F
```

Key in the desired Chilled Liquid Setpoint and the allowable deviation (Range). The micro will accept values from 10.0 - 70.0°F (-12 to 21°C). For values below 40°F (4°C), Dip Switch S1, Switch #1 on the Microprocessor Board must be properly programmed for Brine Cooling (see Section 3.7). If unacceptable values are entered, or the switch is incorrectly selected when setpoints below 40°F (4°C) are entered, the following message will be displayed before returning to the Control Range message:


```
OUT OF RANGE -
TRY AGAIN!
```

After the Setpoint is keyed in, the cursor will automatically advance to the first digit of the Range as shown:

```
SETPOINT = 44.0 °F
RANGE = + / - 2.0 °F
```

This value should be programmed for the maximum allowable positive and negative chilled liquid temperature deviation that is acceptable from setpoint in the system application. A typical value would be +/- 2.0°F (1°C). The micro will accept a range from 1.5 - 2.5°F (- °C).

After the Setpoint and Range is keyed in, press the ENTER Key to store the data in memory.



Failure to press the Enter key will cause the newly programmed values to be ignored and not entered into memory.

After pressing the Enter key, the display will continue to show the message until another key is pressed.

6.4 REMOTE COOLING SETPOINTS KEY

Remote Cooling Setpoints key allows resetting the setpoint upward from the programmed value in memory from a remote device. This feature is typically used for demand limiting or ice storage applications. Reset is accomplished by timed closure of external contacts for a defined period of time and allows reset of the setpoint upward by up to 40°F (22°C) above the setpoint programmed in memory – see Section 1.7.

The maximum allowable reset must be programmed into memory and can be a value of 2 to 40°F (1 to 22°C) depending on user requirements. To program the reset, press the Remote Reset Temperature Range key. The following message will appear:

```
REM SETP = 44.0 °F
RANGE = + / - 2.0 °F
```

The display indicates the Remote Setpoint which is always equal to the chilled liquid setpoint programmed by the Chilled Liquid Temperature/Range key plus the offset from the remote reset signal. The display will also show the Range which is the programmed maximum deviation allowed for the application. This display is not programmable, and will change the setpoint only through a signal from a remote device.

```
MAX EMS - PWM REMOTE
TEMP RESET = + 40 °F
```

Pressing the REM RESET TEMP RANGE Key again scrolls the display to the MAX EMS-PWM REMOTE TEMP RESET which is programmable. This should be programmed to the maximum offset which is required for the application. The maximum programmable value is 40° F (22°C), while the minimum programmable value is 2°F (1°C).

The cursor will stop beneath the first digit of the maximum reset. Key in the maximum reset allowed for the application, remembering to use a leading “0” for values less than 10°F (or 10°C). Press the ENTER Key to store the new value in memory.

7. CLOCK KEYS



29023A

7.1 GENERAL

The microprocessor features a continuously running internal Clock and calendar and can display actual time as well as the day of the week and the date. An automatic schedule feature is provided for starting and stopping the chiller on individual days of the week, eliminating the need for an external time clock. Also provided are a Holiday feature, allowing special start/stop times to be set for designated holidays, and a Manual Override feature to aid servicing. If the automatic schedule feature is not required, the micro can be programmed to run the chiller on demand as long as the Chiller ON/OFF and System switches are in the ON position.

Programming of the internal clock/calendar and operating schedule are described below.

7.2 SET TIME KEY

When the Set Time key is pressed, a message showing the day, time and date will be displayed with the cursor below the first digit of the time as shown:

```
T O D A Y   I S   M O N   1 1 . 1 2 A M
1 9   F E B   1 9 9 9
```


First press the ↑ or ↓ key until the proper day appears. Press ENTER to move on to the hour part of the display. Next, key in the time (hours/minutes) using a leading

“0” for times before 10 o’clock. e.g. 08:31. The cursor will then advance to the AM/PM designation. If necessary press the ↑ or ↓ key to change to the opposite time period.

Next, key in the day of the month (the cursor will automatically skip from AM/PM to the first digit of the date when a “number key” is pressed). The cursor will then skip to the first digit of the year. Key in the year. Always use two digits for the day and the year, using a leading “0” for days 1-9 e.g. 02 FEB 99. Finally, change the month as needed by repetitively pressing the ↑ or ↓ key until the proper month appears. Once the desired information is keyed in, it must be stored into memory by pressing the Enter key.

Any valid time or date will be accepted. If an out of range value is entered, the following message will be displayed for 3 seconds then revert back to the Set Time display message for reprogramming:

```
O U T   O F   R A N G E   -
T R Y   A G A I N   !
```




Pressing the Set Time key once enters the “programming” mode in which the displayed time does not update. Pressing the Set Time key a second time enters “display” mode in which the cursor will disappear and the “live” clock will be displayed.

7.3 SET SCHEDULE / HOLIDAY KEY

Messages showing each week day and the holiday start/stop schedule, as shown below, can be displayed using the Set Schedule / Holiday key:

```
MON  START  =  06 : 00  AM
      STOP   =  05 : 30  PM
```


The displays for each day are scrolled through by repetitively pressing the ↑ or ↓ key. To reprogram any of the daily schedules, key in the new Start time then, if necessary, change the associated AM/PM by pressing the ↑ or ↓ key.




The ↑ or ↓ key can only be pressed once to change AM/PM. If an error is made, press Cancel and begin again.

Next key in the Stop Time (the cursor will automatically skip from AM/PM to the first digit of the date when a “number key” is pressed) and the AM/PM if necessary. Now press the ENTER key to store the new schedule. The display will scroll to the next day. If an unacceptable time is entered, the following message will be displayed for 3 seconds then return to the schedule display:

```
OUT OF RANGE
TRY AGAIN !
```




New start/stop times programmed for Monday are automatically used for all of the following days of the week.



Always use the Set Schedule/Holiday key, not the Enter key to scroll through the schedule displays. Pressing the ENTER key after viewing Monday will change times programmed for the remainder of the week to the Monday schedule.

If the chiller is not cycled by the Daily Schedule, but is required to run whenever remote cycling devices, system switches, and main Chiller ON/OFF switch are in the ON position, all 00.00s should be programmed into the daily schedule. This can be done manually for individual days or for all days by pressing Cancel and Enter for the Monday Start/Stop schedule.




Programming the DAILY SCHEDULE will not affect on the holiday schedule.

If the chiller is not required to run on a given day, the Start time should be programmed for 00:00 AM and the Stop time programmed for 12:00 AM.

Continue to program each day as needed. After SUN has been entered, the Holiday message will be displayed:

```
HOL  START  =  08 : 30  AM
      STOP   =  12 : 00  PM
```

The Holiday (HOL) Start / Stop allows a specific day(s) to be assigned for special requirements. This is provided so that a day(s) needing special start / stop requirements can be programmed without disturbing the normal working schedule. The start / stop times for the Holiday schedule are programmed just as any other day.




Only one start/stop time can be programmed which will apply to each of the Holiday days selected.

After the Enter key is pressed, a display to designate which days of the week are holidays will appear:

```
S  *  M  T  W  T  F  S
HOLIDAY NOTED BY *
```

When the display appears, the cursor will first stop after Sunday as shown. To designate a day as a holiday, press the “*” key. If a day marked as a holiday is not to be a holiday, press the “*” key. When the “*” key is pressed, the cursor will advance to the next day. Use the ↑ or ↓ keys to move back and forth among days. After all the holiday days are programmed, press Enter to store the new data. The display will then return to the beginning of the Daily Schedule (MON).



The Holiday Schedule is only performed once, then erased from memory. This avoids the need for reprogramming after the holiday, as most special Holiday Schedule requirements are occur only occasionally.


If an error is made while programming or a change is required, press Cancel. This will clear the programmed (*) "Holiday" days (the "0" key will not cancel out a "*" and cannot be used for correcting a programming error).

7.4 MANUAL OVERRIDE KEY

When the Manual Override key is pressed, the Daily Schedule programmed into the chiller is ignored and the chiller will start up when water temperature is above the high limit of the Control Range, the Chiller ON/OFF switch is ON, remote cycling devices are CLOSED, and system switches permit.


Normally this key is only used for servicing when the chiller is required to run but the Daily Schedule is in an OFF period. This key avoids the need to reprogram the Daily Schedule. Once activated, Manual Override is only active for a period of 30 minutes and the following status message will be observed:

M A N U A L
O V E R R I D E



If a Warning – Low Battery fault message appears on the display the internal clock, calendar and program settings cannot be relied on for accuracy. Default values are loaded into the microprocessor memory and the Manual Override key can be used to zero out the daily schedule and allow unlimited operation regardless of the time on the internal clock. Reprogramming of the setpoints and cutout values may also be necessary. When the MANUAL OVERRIDE key is pressed the low battery message will disappear. If a power failure should again occur, the above process will again need to be repeated to bring the chiller back on line. See also Section 2.5.

8. PROGRAM KEY



29023A

8.1 GENERAL

The Program key is used to program 12 system operating parameters including cutout points for safeties, anticipatory unload points to avoid faults, and anti-recycle timer duration.

When the Program key is pressed, the following message will be displayed to indicate the display is in the Program Mode:

PROGRAM MODE

Pressing the ENTER Key causes the display to show the operator in what language the control panel message are displayed.

**DISPLAY LANGUAGE
ENGLISH**

The operator may select 5 display message languages. The options are English, Spanish, French, German and Italian. The $\uparrow$ or $\downarrow$ keys can be used to select the desired language.


Pressing the Enter key repeatedly allows scrolling through the programmable displays.

As each value is displayed, it may be reprogrammed using the 12 Entry keys and $\uparrow\downarrow$ Keys. New values will be programmed into memory when the Enter key is pressed and the display will scroll on to the next programmable value.

If an unacceptable value is entered at any stage, the following message is displayed for a few seconds and the entered value is ignored:

**OUT OF RANGE
TRY AGAIN!**

The following section shows examples of each programmable value display in the order in which they appear after pressing the Program key, together with guidance on programming each parameter.



The programmable values under the Program Key must be checked and properly programmed when commissioning the chiller. Failure to properly program these values may cause damage to the Chiller or operating problems.

8.2 PROGRAM KEY – USER PROGRAMMABLE VALUES

High Discharge Pressure Cut-Out

**DISCHARGE PRESSURE
CUTOUT = 395.0 PSIG**

The Discharge Pressure Cutout is a microprocessor backup for the mechanical high pressure cutout located in each refrigerant circuit. This safety is bypassed for the first 5 seconds of operation after which if the cutout point is exceeded for 3 seconds, the system will shut down.

Normally, air-cooled chillers such as YCAS chillers should have the cutout set at 395 PSIG (27 bar) for R22 and R407C models. The micro will, however, accept values between 200 - 399 PSIG (14 - 28 bar). For this cutout to be functional, the Discharge Pressure Read-out Option must be installed (fitted as standard on 50 Hz models). This programmable value is password protected.

To program the Discharge Pressure Cutout, key in the desired value and press the Enter key to store the value into memory and scroll to the next display.

High Discharge Pressure Unload Point

**D I S C H A R G E P R E S S U R E
U N L O A D = 3 6 0 . 0 P S I G**

The Discharge Pressure Unload point is used to avoid a high pressure cutout shutdown by unloading a compressor, if its discharge pressure approaches the cutout value. The chiller can then continue to run automatically at reduced capacity until the cause of the excessive pressure is attended to (e.g. dirty condenser coils) or ceases naturally (e.g. high ambient temperature).

For the first 60 seconds of operation, discharge pressure limiting is disabled. After this time, if discharge pressure exceeds the programmed limit, a 1 second unload pulse will be sent to the slide valve of the affected compressor every 5 seconds until the discharge pressure drops below the programmed limit. The message will be removed and reloading take place when discharge pressure has dropped 60 PSIG (4 bar) below the threshold.

Typically the unload point should be set 20 - 25 PSIG (1.4 - 1.7 bar) below the below the discharge pressure cutout setting. The micro will accept a range of programmable values between 200 - 399 PSIG (14 - 28 bar). This programmable value is password protected.

To program the Discharge Pressure Unload, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.

Low Suction Pressure Cutout

**S U C T I O N P R E S S U R E
C U T O U T = 4 4 . 0 P S I G**

The Low Suction Pressure Cutout protects the evaporator from damage due to ice build up caused by operation at low refrigerant suction pressure.

After the compressor starts, and the pump down cycle is completed (pump down to cutout or 30 seconds, whichever comes first.), suction pressure is monitored as long as the compressor runs. For the first 270 seconds of running, suction pressure can be lower than the programmed cutout, but must be greater than:

$$\frac{\text{Programmed Cutout}}{\text{Cutout}} \times \frac{\text{Run Time}/3 + 10}{100}$$

Example: If programmed Cutout = 44 PSIG (3 bar) and Run Time = 60 seconds

$$\text{New Cutout} = 44 \times \frac{60/3 + 10}{100} = 13.2 \text{ PSIG (0.9 bar)}$$

This cutout value increases with time, until after 270 seconds, it equals the programmed cutout value. If suction pressure falls below the calculated cutout value before 270 seconds, the system will be shut down.

After 270 seconds, a transient timer system prevents short term fluctuations in suction pressure from causing shutdown as follows: If suction pressure drops below the cutout point, a 90 second transient timer starts. During the 90 second time period, the suction pressure must be greater than:

$$\frac{\text{Programmed Cutout}}{\text{Cutout}} \times \frac{100 - \text{transient time remaining}}{100}$$

Example: If programmed Cutout = 44 PSIG (3 bar) and the timer has run 30 seconds:

$$\text{New Cutout} = 44 \text{ PSIG} \times \frac{100 - 60}{100} = 17.6 \text{ PSIG (1.2 bar)}$$

This cutout value increases with time, until after 90 seconds, it equals the programmed cutout value. If the suction pressure rises to more than 5 PSI (0.3 bar) above the programmed cutout value during the 90 second time period, the timer will be reset. If the suction pressure does not rise to more than 5 PSI (0.3 bar) above the cutout, the timer will remain at zero and if the pressure then falls below the cutout again, the system will shut down on a low pressure fault.

If the Dip Switch on the microprocessor board is set for "Water Cooling" (see Section 3.7), the cutout is programmable between 44 - 70 PSIG (3-5 bar) for both R22 and R-407c models. In this mode, settings of 44 PSIG (3 bar) for R22 and R-407C are recommended. If the Switch is set for "Brine Cooling" (glycol) the cutout is programmable between 5 - 70 PSIG (0.3 bar) for R22 and R-407c models. In this mode, the cutout should be

set to the saturated refrigerant pressure equivalent to 18°F (10°C) below the lowest temperature of the programmed chilled liquid Control Range (Section 6). This programmable value is password protected.

To program the Suction Pressure Cutout, key in the required setting and press the Enter key to store the value into memory and scroll the next display.

High Ambient Temperature Cutout

H I G H A M B I E N T T E M P
C U T O U T = 1 3 0 . 0 ° F

The High Ambient Cutout is used to select the ambient temperature above which the chiller may not operate. If the ambient temperature rises 1°F (1°C) above this point, the chiller will shut down. Restart will occur automatically, when temperature falls more than 1°F (1°C) below the cutout and cooling demand is present.

This cutout is normally set at 130°F (54°C) to allow operation to the absolute maximum temperature capability of the electromechanical components; however, values between 100.0 - 130.0°F (38 - 54°C) are accepted. This programmable value is password protected.

To program the High Ambient Cutout, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.

Low Ambient Temperature Cutout


L O W A M B I E N T T E M P
C U T O U T = 2 5 . 0 ° F

The Low Ambient Cutout is used to select the ambient temperature below which the chiller may not operate. If the ambient temperature falls 1°F (1°C) below this point, the chiller will shut down. Restart will occur automatically, when temperature rises more than 1°F (1°C) above the cutout and cooling demand is present (see also Section 2.5 page 135). This programmable value is password protected.

If the SW1 Dip Switch on the Microprocessor Board is set for “Standard Ambient Control” (see Section 3.7) the low ambient cutout is set at 25°F (-4°C) and is NOT programmable. If the Dip Switch is set for “Low Ambient Control”, programming of the cutout between 00.0 - 50.0°F (8 - 10°C) is allowed. This allows higher values than 25° F (-4°C) to be programmed to shut down the chiller when other cooling methods become operational. Values below 25°F (-4°C) can be used for applications requiring chiller operation at lower

temperatures. If operation is occasionally needed below 1°F (-17°C), the cutout should be set at 00.0°F. This will allow operation at any temperature, as the micro will only recognize temperatures above 1°F (-17°C). Temperatures below 1°F (-17°C) will not be displayed.

To program the Low Ambient Cutout, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.



Operation below 1°F (-17°C) may occasionally cause nuisance low pressure safety shutdowns. This will generally not cause a problem provided ambient temperature is not expected to be below 1°F (-17°C) for more than a short time.

Low Leaving Liquid Temperature CutOut

L E A V I N G L I Q U I D T E M P
C U T O U T = 3 6 . 0 ° F

The Low Leaving Liquid Temperature Cutout protects the evaporator from damage due to ice build up caused by operation below the chilled liquid freezing point.

If the leaving chilled liquid temperature (water or glycol) drops below the cutout point, the chiller will shut down. The chiller will restart automatically when temperature rises more than 4°F (2°C) above the cutout point and cooling demand exists.

If the Dip Switch on the microprocessor board is set for “Water Cooling” (see Section 3.7, page 142) the cutout is automatically set at 36°F (2°C) and cannot be reprogrammed. If the Switch is set for “Brine Cooling” (glycol) the cutout can be programmed between 08.0 - 36.0°F (-13 through -2°C). The cutout should normally be set to 4°F (2°C) below the setpoint minus the range, i.e. 34°F (setpoint) – 2°F (range) - 4°F = 28°F (see Section 6, page 153).

To program the Leaving Liquid Temperature Cutout, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.

High Motor Current Unload Point

H I G H M O T O R C U R R E N T
U N L O A D = 1 0 5 % F L A

The Motor Current Unload point is used to avoid a high motor current safety shutdown by unloading a compressor, if current draw approaches the maximum

limit cutout value. The chiller can then continue to run automatically at reduced capacity until the cause of the excessive current is attended to.

The micro will accept between 30 - 105% for the unload point. The motor current safety will shut the compressor down whenever current exceeds 115%.

If the programmable limit is set between 100% and 105% of full load current, this safety will protect against excessive current causing compressor shutdown due to extremely high ambient, high chilled liquid temperature, and condenser malfunction caused by dirt or fan problems.

If the programmable limit is set below 100% of full load current, this feature can be used for “demand limiting”. This is important when demand limiting is critical due to power requirements or limitations in the building (See also Section 1.10).

For the first 60 seconds of operation, the unloading safety is disabled. After this time, if motor current exceeds the programmed limit, the SYS x CRNT LIMITING message will appear on the display and a 1 second unload pulse will be sent to the slide valve of the affected compressor every 5 seconds, until the motor current drops below the programmed limit. The message will be removed and additional loading will take place when motor current drops below 90% of the programmed threshold.

Typically, this setpoint should be set at 100% for maximum motor protection. Programming for 100% is recommended. When programming values below 100% use of a leading “0” is required, e.g. 085%.

To program the High Motor Current Unload, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.

Anti-Recycle Time

ANTI RECYCLE TIMER
= 600 SECS

The Anti-Recycle Timer controls the minimum time between starts for each compressor. This is the time available for the heat build up caused by inrush current at start to be dissipated before the next start. Insufficient cooling time between starts can cause heat build up and motor damage. A fast compressor start response is needed in some applications and not in others. Although the minimum setting allowed on this timer will avoid excessive heat build up, adjusting the timer for

the longest period acceptable in each application will reduce cycling and maximize motor life. **600 seconds is recommended.**

The micro will accept a range of programmable values between 300 - 600 seconds.

To program the Anti-Recycle Time, key in the required setting and press the Enter key to store the value into memory and scroll to the next display.

Local/Remote Communications

LOCAL / REMOTE MODE
LOCAL

The panel can be programmed for “Local” or “Remote” communications. “Local” mode allows monitoring through the RS-485 port only. “Remote,” allows an external device such as an ISN or Remote Control Center to change setpoints and programming points.

The $\uparrow\downarrow$ keys are used to change from Local to Remote. The ENTER Key must be pressed to save the selection in memory.

Imperial/SI Units Display

DISPLAY UNITS
IMPERIAL

This allows the operator to select the display messages to display Imperial Units (PSIG, F, etc.) or SI (Scientific International, Bars, C, etc.).

The $\uparrow\downarrow$ keys are used to change from Imperial to SI units. The ENTER Key must be pressed to save the selection in memory.

Automatic/Manual “Lead/Lag”

LEAD / LAG CONTROL
AUTOMATIC

The chiller may be selected for manual lead/lag or automatic lead/lag. In some cases the operator may want to manually select the system that is desired to be the lead system. In most cases, automatic lead/lag is selected to allow the micro to attempt to balance run time between the system. Details of manual and automatic lead / lag operation are outlined in Section 1.21.

The $\uparrow\downarrow$ keys are used to change from Automatic to Manual lead/lag. The ENTER key must be pressed to save the selection in memory.

If manual control is desired, press the ↑ or ↓ key. One of the following messages will be displayed:

LEAD / LAG CONTROL
MANUAL SYS 1 LEAD


LEAD / LAG CONTROL
MANUAL SYS 2 LEAD

System 1, 2, 3 or 4 can be selected as the lead by pressing the ↑ or ↓ key. The ENTER key must be pressed to save the selection in memory.

Automatic/Manual Power Failure Restart

POWER FAIL RESTART
AUTOMATIC

The chiller may be selected for “Automatic” or “Manual” restart after a power failure. In most instances, “Automatic Restart” is preferred to allow the chiller to automatically restart when power is reapplied after a power failure. When “Manual” is selected, the chiller will not operate after re-application of power until the ON / OFF Rocker Switch on the keypad is cycled OFF and then ON.



In most applications, it is undesirable to use Manual Reset on power failure since chillers normally are required to auto-restart after a power failure.

8.3 PROGRAMMING “DEFAULT” VALUES

Programmable values may be individually programmed at start-up or any time thereafter. For ease of programming, once the type of refrigerant is programmed in under the Program key, a “defaults password” may be programmed to automatically program default values into memory. This will preset all programmable values under the Program key to values that will allow operation of the chiller under most operating conditions. This allows quick start-up programming for typical chilled water applications.

To program the default values into memory, first press the PROGRAM key followed by the ENTER key, to program the “refrigerant type.” Press the Program key again, key in the numbers “6140”, then press Enter. As

the code is being keyed in, the digits are not displayed but are shown as “*” as shown:

PROGRAM MODE


When the Enter key is pressed, the following message will appear:

DEFAULT SETPOINTS ?
1 = YES , 0 = NO, 1

Key in a “1” for if default setpoints are required, or a “0” for individually programmed values, then press Enter to store the selection into memory.

If individual programming is selected, the display will now return to the Status display. If a default setpoints have been selected, the display will momentarily display the message shown below before returning to the Status display:

PROGRAM OPTIONS SET
TO DEFAULT VALUES



It is often easier to select Default Setpoints and then reprogram a few that require changing rather than programming each individual value from scratch.


A list of the default values entered into memory, if this program option is selected, is shown below:

Programmable Value		6140 Default Setting
Discharge Pressure Cutout	R22	399 PSIG(28 Bar)
Low Ambient Cutout	Std. Amb.	25°F (-4°F)
	Low Amb.	25°F (-4°F)
High Ambient Temperature Cutout		130°F (38°C)
Discharge Pressure Unload	R22	375 PSIG(26 Bar)
High Motor Current Unload		100%
Anti-Recycle Timer		600 sec.
Leaving Chilled Liquid Temp Cutout		36°F (2°C)
Suction Pressure Cutout	R22	44 PSIG (3 Bar)

8.4 CONDENSER FAN CONTROL

The chiller is equipped with 6 condenser fans, with 3 fans per system as shown in Fig. 50 below. Fan control is via Outside Ambient Temperature (OAT) and Discharge Pressure (DP). There are 3 or 6 stages of fan control, depending upon the version of EPROM, utilizing 3 outputs per system from the Relay Output Board. The fan stages will operate according to Tables 3, 4, 5 and 6, according to the EPROM version installed. Operation of the fans, regardless of the EPROM version, will be satisfactory in all ambient conditions,

Tables are provided which show fan on/off points and also include fan contactors, wire numbers, and Relay Output Board output numbers related to specific fans operation. System 1 fan contactors are controlled by Relay Output Board #1 and System 2 fan contactors are controlled by Relay Output Board #2.



LD06907

FIG. 50 – CONDENSER FAN CONTROL LAYOUT FOR DXST COMPRESSORS UNITS

EPROM Versions C.ACS.09.01 (F350) and C.ACS.09.02 (3902)

Fan operation on these versions is outlined in Table 3. Condenser fan ON conditions are governed solely by the Discharge Pressure (DP). When the DP rises above 220 PSIG, fan stage 1 is activated. From there, subsequent fan stages are activated as the discharge pressure rises in increments of 15 PSIG, except stage 6, which is activated when the DP rises over 290 PSIG. The system will remain at the highest fan stage reached unless the OFF conditions outlined in the next paragraph are satisfied.

Condenser fan OFF conditions are governed by both the DP and OAT. Fan staging will be decreased from the highest fan stage reached if both the DP and OAT requirements

are met. For example, if a system is at fan stage 4, and the DP falls below 195 PSIG and the OAT drops below 75 °F, the fan stage will be reduced to stage 3.

EPROM Version C.A17.09.02 (5320)

Fan operation on these versions is outlined in Table 4. These EPROM versions operate very similar to versions 0 and 1. The only difference is that the ON/OFF pressures are 15 PSIG lower. Condenser fan ON conditions are governed solely by the Discharge Pressure (DP). When the DP rises above 205 PSIG, fan stage 1 is activated. From there, subsequent fan stages are activated as the discharge pressure rises in increments of 15 PSIG, except stage 6, which is activated when the DP rises over 275 PSIG. The system will remain at the highest fan stage reached unless the OFF conditions outlined in the next paragraph are satisfied.

Condenser fan OFF conditions are governed by both the DP and OAT. Fan staging will be decreased from the highest fan stage reached if both the DP and OAT requirements are met. For example, if a system is at fan stage 4, and the DP falls below 180 PSIG and the OAT drops below 75°+ F, the fan stage will be reduced to stage 3.

EPROM Versions C.A32.09.02 (0483), C.ACS.09.02 (D87E), and C.A06.09.03 (E10C)

These EPROM's operate according to the Flowchart in Fig. 51. This control scheme is designed to minimize fan cycling. Whenever discharge pressure stabilizes between 150 PSIG and 250 PSIG, the micro will neither start or stop stages of fans.

If discharge pressure rises between 250 PSIG and 285 PSIG, the micro will add another fan stage and start a 15 minute timer. If the discharge pressure remains in this range for 15 minutes, another step of fan cycling will be added and the micro will restart the 15 minute timer.

If discharge pressure falls between 150 PSIG and 120 PSIG, a step of fan cycling will be dropped and the micro will start a 15 minute timer. If the discharge pressure remains in this range for 15 minutes, another step of fan cycling will be dropped and the micro will restart the 15 minute.

If discharge pressure rises above 285 PSIG, the micro will add a step of fan cycling every 5 seconds, until the discharge pressure drops below 285 PSIG in an effort to quickly control the discharge pressure to an acceptable range.

If discharge pressure drops below 120 PSIG or oil to suction pressure differential falls below 75 PSID, the micro will turn off a step of fan cycling every 5 seconds: until the discharge pressure rises above 120 PSIG and oil to suction pressure differential rises above 75 PSID in an effort to quickly control the discharge pressure to an acceptable range.

Table 5 provides a simplified operating graph of the fan staging for this version.

Fan stages increment identical to the stages shown in Table 3.

**TABLE 3 – CONDENSER FAN CONTROL AND FAN CONTACTOR DATA FOR DXST UNITS
WITH 4 FANS/SYSTEM (EPROM VERSIONS C.ACS.09.01 (F350) AND C.ACS.09.02 (3902))**

	Fan Stage	Fans	ON * Conditions DP	OFF * Conditions DP & OAT	Fan Contactor	Wire Number	Relay Board Output*
S Y S 1	1	1	>220 PSIG	<150 PSIG & <60°F	9M	130	15
	2	3	>235 PSIG	<165 PSIG & <65°F	10M	131	14
	3	5	>250 PSIG	<180 PSIG & <70°F	11M	132	10
	4	1, 5	>265 PSIG	<195 PSIG & <75°F	9M, 11M	130, 132	10, 15
	5	3, 5	>280 PSIG	<210 PSIG & <80°F	10M, 11M	131, 132	10, 14
	6	1, 3, 5	>290 PSIG	<220 PSIG & <85°F	9M, 10M, 11M	130, 131, 132	10, 14, 15
S Y S 2	1	2	>220 PSIG	<150 PSIG & <60°F	15M	230	15
	2	4	>235 PSIG	<165 PSIG & <65°F	16M	231	14
	3	6	>250 PSIG	<180 PSIG & <70°F	17M	232	10
	4	2, 6	>265 PSIG	<195 PSIG & <75°F	15M, 17M	230, 232	10, 15
	5	4, 6	>280 PSIG	<210 PSIG & <80°F	16M, 17M	231, 232	10, 14
	6	2, 4, 6	>290 PSIG	<220 PSIG & <85°F	15M, 16M, 17M	230, 231, 232	10, 14, 15

* Sys 1 Outputs are on Relay Output Board #1


Sys 2 Outputs are on Relay Output Board #2

**TABLE 4 – CONDENSER FAN CONTROL AND FAN CONTACTOR DATA FOR DXST UNITS
WITH 5 FANS/SYSTEM (EPROM VERSION C.A17.09.02 (5320))**

	Fan Stage	Fans	ON * Conditions DP	OFF * Conditions DP & OAT	Fan Contactor	Wire Number	Relay Board Output*
S Y S 1	1	1	>205 PSIG	<135 PSIG & <60°F	9M	130	15
	2	3	>220 PSIG	<150 PSIG & <65°F	10M	131	14
	3	5	>235 PSIG	<165 PSIG & <70°F	11M	132	10
	4	1, 5	>250 PSIG	<180 PSIG & <75°F	9M, 11M	130, 132	10, 15
	5	3, 5	>265 PSIG	<195 PSIG & <80°F	10M, 11M	131, 132	10, 14
	6	1, 3, 5	>275 PSIG	<205 PSIG & <85°F	9M, 10M, 11M	130, 131, 132	10, 14, 15
S Y S 2	1	2	>205 PSIG	<135 PSIG & <60°F	15M	230	15
	2	4	>220 PSIG	<150 PSIG & <65°F	16M	231	14
	3	6	>235 PSIG	<165 PSIG & <70°F	17M	232	10
	4	2, 6	>250 PSIG	<180 PSIG & <75°F	15M, 17M	230, 232	10, 15
	5	4, 6	>265 PSIG	<190 PSIG & <80°F	16M, 17M	231, 232	10, 14
	6	2, 4, 6	>275 PSIG	<205 PSIG & <85°F	15M, 16M, 17M	230, 231, 232	10, 14, 15

* Sys 1 Outputs are on Relay Board #1


Sys 2 Outputs are on Relay Output Board #2



LD06011A

FIG. 51 – CONDENSER FAN CONTROL
(EPROM VERSIONS C.A32.09.02 (0483), C.ACS.09.02 (087E), AND C.A06.09.03 (EI0C))

TABLE 5 – CONDENSER FAN CONTROL
(EPROM VERSIONS C.A32.09.02 (0483),
C.ACS.09.02 (D87E), AND C.A06.09.03
(EIOC)



Note: A low Oil - Suction differential Pressure less than 75 PSID will cause the micro to turn a fan stage Off every 5 sec. This will override pressure control of the fans.

**EPROM Version C.A14.09.03 (A85F),
other .03 versions and higher**

Fan operation is outlined in Table 6. Condenser fan ON conditions are governed solely by the Discharge Pressure (DP). When the DP rises above 205 PSIG, fan stage 1 is activated. From there, subsequent fan stages are activated as the discharge pressure rises. The system will remain at the highest fan stage reached unless the OFF conditions outlined in the next paragraph are satisfied.

Condenser fan OFF conditions are governed by both the DP and OAT. Fan staging will be decreased from the highest fan stage reached if both the DP and OAT requirements are met. For example, if a system is at fan stage 3, and the DP falls below 180 PSIG and the OAT drops below 75° F, the fan stage will be reduced to stage 3.

**TABLE 6 – CONDENSER FAN CONTROL AND FAN CONTACTOR DATA FOR DXST UNITS
WITH 3 FANS/SYSTEM (EPROM VERSIONS C.A14.09.03 (A85F), OTHER .03 VERSIONS, AND
HIGHER**

	Fan Stage	Fans	ON * Conditions DP	OFF * Conditions DP & OAT	Fan Contactor	Wire Number	Relay Board Output*
SYS1	1	1	>205 PSIG	<135 PSIG & <60°F	9M	130	15
	2	3	>265 PSIG	<160 PSIG & <65°F	10M	131	14
	3	5	>285 PSIG	<180 PSIG & <70°F	11M	132	10
SYS2	4	1, 5	>205 PSIG	<135 PSIG & <75°F	9M, 11M	130, 132	10, 15
	5	3, 5	>265 PSIG	<160 PSIG & <80°F	10M, 11M	131, 132	10, 14
	6	1, 3, 5	>285 PSIG	<180 PSIG & <85°F	9M, 10M, 11M	130, 131, 132	10, 14, 15

* Sys 1 Outputs are on Relay Board #1


Sys 2 Outputs are on Relay Output Board #2

MAINTENANCE

GENERAL REQUIREMENTS

The units have been designed to operate continuously provided they are regularly maintained and operated within the limitations given in this manual. Each unit should be included in a routine schedule of daily maintenance checks by the operator/customer, backed up by regular service inspection and maintenance visits by a suitably qualified Service Engineer.

It is entirely the responsibility of the owner to provide for these regular maintenance requirements and/or enter into a maintenance agreement with a York International service organization to protect the operation of the unit. If damage or a system failure occurs due to improper maintenance during the warranty period, YORK shall not be liable for costs incurred to return the unit to satisfactory condition.



This maintenance section applies to the basic unit only and may, on individual contracts, be supplemented by additional requirements to cover any modifications or ancillary equipment as applicable.



The Safety Section of this manual should be read carefully before attempting any maintenance operations on the unit. This section should be read in conjunction with the MBCS Manual.

Daily Maintenance

The following maintenance checks should be carried out on a daily basis by the operator/customer. Please note that the units are not generally user serviceable and no attempt should be made to rectify faults or problems found during daily checks unless competent and equipped to do so. If in any doubt, contact your local YORK Service Agent.

Unit Status: Press the 'STATUS' key on the keypad and ensure no fault messages are displayed (refer to the MBCS Manual for explanation of messages and the Trouble Shooting section for courses of action).

Refrigerant Leaks: Visually check the heat exchangers, compressors and pipework for damage and gas leaks.

Airflow obstructions: Check the air cooled condenser coil intakes and adjacent areas are clear of foreign materials or obstructions e.g. paper, leaves, etc.

Operating conditions: Read the operating pressures and temperatures at the control panel using the display keys and check that these are within the operating limitations given in the MBCS Manual.

Compressor oil level: Check the compressor oil level after the compressor has been operating on 'FULL LOAD' for approximately half an hour. The oil level should be about half way up the upper of the two sight glasses. When the compressor is operating at 'PART LOAD', the level may fall as far as half way down the lower sight glass but should not fall below this level. When the compressor returns to full load the level will return to the upper sight glass.

Refrigerant charge: When a system starts up, or sometimes after a change of capacity, a flow of bubbles will be seen in the liquid line sight glass. After a few minutes of stable operation, the bubbles should clear leaving just liquid refrigerant showing in the sight glass.

Scheduled Maintenance

The maintenance operations detailed in the following table should be carried out on a regular basis by a suitably qualified Service Engineer. It should be noted that the interval necessary between each 'minor' and 'major' service can vary depending on, for instance, application, site conditions and expected operating schedule. Normally a 'minor' service should be carried out every three to six months and a 'major' service once a year. It is recommended that your local YORK Service Center is contacted for recommendations for individual sites.

Chiller / Compressor Operating Log

A Chiller/Compressor Operating Log is supplied on the following page for logging compressor and chiller operating data.

CHILLER/COMPRESSOR Operating Log

YORK Order No. _____
 Compr. Ser. No. _____
 Unit Ser. No. _____
 Refrigerant _____

[illegible]

Remarks:

Note: Temperature and Pressure Units in °F and PSIG respectively unless otherwise noted.

MAINTENANCE REQUIREMENTS FOR YORK YCAS SCREW CHILLERS

PROCEDURE	WEEKLY	QUARTERLY	SEMI-ANNUALLY	YEARLY	EVERY * <u> </u> HOURS
Check oil level in oil separator sight glass	X				
Check liquid line sight glass / moisture indicator	X				
Record system operating pressures and temperatures	X				
Check programmable operating setpoints and safety cutouts and assure they are correct for particular application.		X			
Check condenser coils for dirt/debris and clean if necessary	X				
Check compressor superheat on evaporator and economizer TXV's; Check condenser and economizer subcooling ¹			X		
Check compressor and cooler heaters for operation		X			
Sample compressor oil and replace oil if necessary ¹				X	
Leak check the chiller ¹			X		
Disconnect power source and lock out; Check tightness of power wiring connections ¹				X	

* Reserved for customer use for any special site determined requirements.

¹ This procedure must be performed at the specified time interval by an Industry Certified Technician who has been trained and qualified to work on this type of YORK equipment. A record of this procedure being successfully carried out must be maintained on file by the equipment owner should proof of adequate maintenance be required at a later date for warranty validation purposes.

GENERAL PERIODIC MAINTENANCE CHECKS STANDARD UNITS

SERVICE SCHEDULE	MINOR SERVICE	MAJOR SERVICE All items under Minor Service plus:
Unit general:	Check thermal insulation. Check vibration isolators.	Check main structure. Check paint-work.
Refrigerant systems general:	Check relief valves. Check fusible plugs. Check for pipework damage. Check for leaks. Check moisture indicator. Check suction superheat. Check economizer superheat. Check liquid subcooling.	Check solenoid valves.
Compressors / Oil separator:	Check liquid subcooling. Check oil level. Check oil pressure. Check unloader operation. Check crankcase heater. Check condition of oil.	None
Cooler	Check water flow. Check water pressure drop. Check heater mats.	Check water pH / glycol strength.
Air cooled condensers:	Check for airflow obstructions. pH cleaner. Check fins. Check fans and fan guards.	Brush fins. Clean with mild, low Check fan motor bearings.
Power & Control system general:	Check panel condition. Check mains and control wiring. Check sensor location. Check mechanical HP cutouts. Check emergency stop. Check residual current devices.	Check all connections. Check compressor contactors. Check fan contactors / overloads. Check sensor / transducer calibration. Check motor protectors. Check contactor contacts.
Microprocessor controls:	Check fault history. Check program settings. Check HP / LP cutout functions Check pump-down function. Check load / unload function.	Check fan control function. Check ambient cut-out function. Check low oil pressure function.

SPARE PARTS

Recommended Spares

It is recommended that the following common spare parts are held for preventative of corrective maintenance operations.

Description	Item	Part Number
Pressure Transducer 200PSI (14 Bar)	BSP	025-29583-000
Pressure Transducer 400PSI (28 Bar)	BDP, BOP	025-29139-001
Sensor, High Temperature	BOT, BDT	025-30440-000
Sensor, Ambient Temperature	BAMB	025-28663-001
Sensor, Water Temperature	BLCT	025-29964-000
Sensor, Water Temperature	BMLT	025-29964-000

Other spare parts vary depending on the unit model. Contact your local YORK Sales and Service Center for information and please quote the unit model number and serial number.

When ordering spare parts, we will require the following information to ensure the correct parts are supplied:

Full unit model number, serial number, application and details of the parts required.

All requests for parts should be made to your local YORK Sales and Service Center.

Recommended Compressor Oils

The correct type of oil must be used in the unit as shown on the unit data plate and labels. Standard units use the following oils:

REFRIGERANT	COMPRESSOR OIL
R407C	YORK Grade L

Associated Drawings

Models		R-407C
General Arrangement		
Wiring Diagrams	Schematic Connection Customer wiring Legend	201.18-W7

COMPETENT PERSONS TROUBLESHOOTING GUIDE

PROBLEM	POSSIBLE CAUSE	ACTION
No display on panel - unit will not start	Mains supply to control system OFF.	Switch on main supply if safe to do so.
	Emergency stop device off.	Check if control panel emergency stop switch and any remote emergency stop devices are in the OFF position. Turn to ON position (1) if safe to do so.
	Under voltage relay tripped.	Check mains supply.
	No supply to - T2.	Check emergency stop switch fuses.
	No 24VAC supply to power board.	Check wiring from - T2 to powerboard and fuse.
	No +12V output from powerboard.	Replace powerboard or isolate excessive load on the board.
NO RUN PERM displayed (No run permissive)	No liquid flow through the cooler.	Ensure that liquid pumps are running. Valves are correctly set and flow is established.
	Flow switch contacts are not made.	Check that the flow switch is functional and is installed according to the manufacturer's instructions. Note: On some systems the pump starter may be wired to the unit and controlled to start by the unit.
SYS # HIGH OIL TEMP coils.	Poor airflow through the condenser	Check for airflow restrictions caused by blockages on intake faces of air coils.
	Measured temperature incorrect.	Check sensor calibration, location and wiring.
Chiller FAULT: LOW AMBIENT TEMP displayed	Ambient air temperature is lower than the programmed operating limit.	Use the 'ambient temp.' key to display the temperature and confirm that the displayed value is approximately correct. The warning message should clear when the ambient air temperature rises above the programmed operating limit.
		Check the programmed settings are correct for the options fitted to the unit.
	Measured temperature is incorrect.	Check sensor calibration, location and wiring.
Chiller FAULT: HIGH AMBIENT TEMP displayed	Ambient air temperature is higher than the programmed operating limit.	Use the 'ambient temp.' key to display the temperature and confirm that the displayed value is approximately correct. The warning message should clear when the ambient air temperature falls below the programmed operating limit.
		Check that the programmed settings are correct for the options fitted to the unit.
	Resid. heat is not being dissipated.	Check fan is operating correctly and the rotation is correct. Check for airflow recirculation.
	Measured temperature is incorrect.	Check sensor calibration, location and wiring.
Chiller FAULT: LOW WATER TEMP displayed	Leaving liquid drops below the programmed low limit faster than the unit can unload.	Check for restrictions in the liquid flow line. Check that the liquid flow is stable.
	Unit is not unloading.	Check the supply to the unloader valve solenoid. Check that the compressor unloads correctly.
	Measured temperature is incorrect.	Check sensor calibration, location and wiring.
Chiller FAULT: VAC UNDERVOLTAGE displayed.	Poor mains supply voltage.	Check mains supply is stable and within allowable limits. Check for voltage dip on compressor start.

COMPETENT PERSONS TROUBLESHOOTING GUIDE - CONT'D

PROBLEM	POSSIBLE CAUSE	ACTION
SYS # HIGH DSCH displayed (High discharge pressure trip)	Poor airflow through condenser coils.	Check for airflow restrictions caused by blockages on intake faces of air coils. Check for damaged fins/return bends. Check for correct fan operation and direction of rotation. Check for non-condensables (air) in system.
	Excessive refrigerant charge.	Check that the sub-cooling is correct.
	Measured pressure is incorrect.	Check discharge transducer calibration and wiring.
SYS # HIGH DSCH TEMP displayed (High discharge temperature)	Suction superheat too high.	Check suction superheat is within range.
	Poor airflow through the condenser coils.	Check for airflow restrictions caused by blockages on intake faces of air coils.
	Measured temperature incorrect.	Check sensor calibration, location and wiring.
SYS # DSCH LIMITING displayed (Discharge pressure unloading)	Discharge pressure unloading due to unit operating above load limit. See also SYS # HIGH DSCH.	Check chilled liquid temperature is within range. Check if ambient air temperature is above design conditions.
SYS # HIGH OIL PRESS DIFF is displayed. (High oil differential pressure.)	Ball valve in oil circuit closed.	Check ball valves are in open position.
SYS # LOW SUCTION displayed	Dirty / blocked oil filter.	Check and change oil filter cartridge.
	Badly adjusted or faulty expansion valve.	Check superheat.
	Reduced evaporator performance.	Check for restricted chilled liquid flow. Check for fouled tube surfaces. Check superheat.
	Low refrigerant charge.	Check subcooling is correct. Check for leaks.
	Restricted refrigerant flow.	Check for blocked filter / drier. Check YLLSV is operating correctly.
SYS # LOW CURR/MP/HP displayed	Measured pressure incorrect.	Check suction pressure transducer calibration and wiring.
	Compressor current too low.	Check compressor mains supply, fuses, contactors and wiring. Check mains supply voltage is within tolerance.
	Measured current is incorrect.	Check for defective current transformer (resistance should be between 42 and 44 Ohms.) Check calibration resistor is correctly fitted.
	Compressor motor protector signal failure.	Check motor protector and wiring. Check compressor motor.
	Mechanical high pressure cut-out trip.	Check compressor discharge valve is open. Check cut-out setting and wiring.
SYS # CURR LIMITING displayed (Compressor current unloading.)	No motor cooling.	Check motor cooling service valve is open. Check operation of economizer and motor cooling TEVs and liquid solenoid valve.
	High compressor motor current has activated unloading.	Check if liquid temperature is within operating limits. Check if ambient air temperature is above operating limits.

SENSOR CALIBRATION CHARTS

Chilled Leaving Water Temperature (CLT) and Chilled Return Water Temperature (CRT) Sensors

Temperature °F (°C)	Resistance ohms	Voltage VDC
14° (-10°)	16598	1,45
18° (-7.8°)	14896	1,57
21° (-6.1°)	13388	1,69
25° (-3.9°)	12047	1,80
28° (-2.2°)	10856	1,93
32° (0.0°)	9795	2,05
36° (2.2°)	8849	2,17
39° (3.9°)	8005	2,30
43° (6.1°)	7251	2,42
46° (7.8°)	6575	2,54
50° (10°)	5970	2,66
68° (20°)	3748	3,22
86° (30°)	2417	3,69
104° (40°)	1598	4,05

TEST POINTS:

Leaving Water Microboard J11-7/1
Return Water Microboard J11-8/2

Ambient Temperature Sensor

Temperature °F (°C)	Resistance ohms	Voltage VDC
14° (-10°)	55330	0,97
23° (-5°)	42227	1,20
32° (0.0°)	32650	1,45
41° (5°)	25390	1,72
50° (10°)	19900	2,00
59° (15°)	15710	2,29
68° (20°)	12490	2,58
77° (25°)	10000	2,85
86° (30°)	8057	3,11
95° (35°)	6530	3,35
104° (40°)	5327	3,57

TEST POINT:

Test Point..... Microboard J11-9/3

Oil & Discharge Temperature Sensors

Temperature °F (°C)	Resistance ohms	Voltage VDC
32° (0°)	163250	0,282
50° (10°)	99500	0,447
68° (20°)	62450	0,676
86° (30°)	40285	0,976
104° (40°)	26635	1,34
122° (50°)	18015	1,76
140° (60°)	12440	2,20
158° (70°)	8760	2,63
176° (80°)	6290	3,04
194° (90°)	4588	3,40
212° (100°)	3400	3,71
230° (110°)	2556	3,96
248° (120°)	1946	4,17
266° (130°)	1504	4,33
284° (140°)	1174	4,46
302° (150°)	926	4,57

TEST POINTS:

Oil Temperature:

System 1:..... Extension-board J10-7/3
System 2:..... Extension-board J10-6/2

Discharge Temperature:

System 1:..... Extension-board J8-4/1
System 2:..... Extension-board J8-6/3

Pressure Transducers

0 - 200 PSIG Transducer		0 - 400 bar Transducer	
Pressure PSIG	Voltage VDC	Pressure PSIG	Voltage VDC
0	0,5	0	0,5
25	1,0	50	1,0
50	1,5	100	1,5
75	2,0	150	2,0
100	2,5	200	2,5
125	3,0	250	3,0
150	3,5	300	3,5
175	4,0	350	4,0
200	4,5	400	4,5

Red Wire = 5V, Black wire = 0V, White/Green Wire = signal

TEST POINTS:

Suction Pressure:

System 1:..... Microboard J13-7/1
System 2:..... Microboard J14-7/1

Oil Pressure:

System 1:..... Microboard J13-8/3
System 2:..... Microboard J14-8/3

Discharge Pressure:

System 1:..... Microboard J15-8/3
System 2:..... Microboard J15-7/1

LIMITED WARRANTY APPLIED SYSTEMS

WARRANTY ON NEW EQUIPMENT

York International Corporation ("YORK") warrants all equipment and materials of its manufacture, or installation or start-up services in connection therewith, against defects in workmanship and material for a period of one year from date of initial start-up or eighteen (18) months from date of shipment, whichever occurs first. Subject to the exclusions listed below, YORK, at its option, will repair or replace, FOB point of shipment, such YORK products or components as it finds defective. On materials or components furnished by YORK, but manufactured by others, YORK will extend the same warranty it receives from the manufacturer.

Exclusions: Unless specifically agreed to in the contract documents, this warranty does not include the following costs and expenses:

1. Labor to remove or reinstall any equipment, materials, or components.
2. Shipping, handling, or transportation charges.
3. Cost of refrigerants.

No warranty repairs or replacements will be made until payment for all equipment, materials, or components has been received by YORK.

WARRANTY ON RECONDITIONED OR REPLACEMENT MATERIALS

Except for reciprocating replacement compressors, which YORK warrants for a period of one year from date of shipment, YORK warrants reconditioned or replacement materials, or installation or start-up services in connection therewith, against defects in workmanship or material for a period of ninety (90) days from date of shipment. Subject to the exclusions listed below, YORK will replace, FOB point of shipment, such materials or parts as YORK finds defective. However, where reconditioned or replacement materials or parts are placed on equipment still under the original new equipment warranty, then such reconditioned or replacement parts are warranted only until the expiration of such original new equipment warranty.

Exclusions: Unless specifically agreed to in the contract documents, this warranty does not include the following costs and expenses:

1. Labor to remove or reinstall any equipment, materials, or components.
2. Shipping, handling, or transportation charges.
3. Cost of refrigerant.

No warranty repairs or replacements will be made until payment for all equipment, materials, or components has been received by YORK.

ALL WARRANTIES AND GUARANTEES ARE VOID IF:

1. Equipment is used with refrigerants, oil, or antifreeze agents other than those authorized by YORK.
2. Equipment is used with any material or any equipment such as evaporators, tubing, other low side equipment, or refrigerant controls not approved by YORK.
3. Equipment has been damaged by freezing because it is not properly protected during cold weather, or damaged by fire or any other conditions not ordinarily encountered.
4. Equipment is not installed, operated, maintained and serviced in accordance with instructions issued by YORK.
5. Equipment is damaged due to dirt, air, moisture, or other foreign matter entering the refrigerant system.
6. Equipment is not properly stored, protected or inspected by the customer during the period from date of shipment to date of initial start-up.

THIS WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES AND LIABILITIES, EXPRESS OR IMPLIED IN LAW OR IN FACT, INCLUDING THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. THE WARRANTIES CONTAINED HEREIN SET FORTH BUYER'S SOLE AND EXCLUSIVE REMEDY IN THE EVENT OF A DEFECT IN WORKMANSHIP OR MATERIALS. IN NO EVENT SHALL YORK'S LIABILITY FOR DIRECT OR COMPENSATORY DAMAGES EXCEED THE PAYMENTS RECEIVED BY YORK FROM BUYER FOR THE MATERIALS OR EQUIPMENT INVOLVED. NOR SHALL YORK BE LIABLE FOR ANY SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES. THESE LIMITATIONS ON LIABILITY AND DAMAGES SHALL APPLY UNDER ALL THEORIES OF LIABILITY OR CAUSES OF ACTION, INCLUDING, BUT NOT LIMITED TO, CONTRACT, WARRANTY, TORT (INCLUDING NEGLIGENCE) OR STRICT LIABILITY. THE ABOVE LIMITATIONS SHALL INURE TO THE BENEFIT OF YORK'S SUPPLIERS AND SUBCONTRACTORS.

TEMPERATURE CONVERSION CHART

Temperature Conversion Chart -
Actual Temperatures

°F	=	°C	°C	=	°F
0	=	-17.8	-18	=	-0.4
4	=	-15.6	-16	=	3.2
8	=	-13.3	-14	=	6.8
12	=	-11.1	-12	=	10.4
16	=	-8.9	-10	=	14
20	=	-6.7	-8	=	17.6
24	=	-4.4	-6	=	21.2
28	=	-2.2	-4	=	24.8
32	=	0.0	-2	=	28.4
36	=	2.2	0	=	32
40	=	4.4	2	=	35.6
44	=	6.7	4	=	39.2
48	=	8.9	6	=	42.8
52	=	11.1	8	=	46.4
56	=	13.3	10	=	50
60	=	15.6	12	=	53.6
64	=	17.8	14	=	57.2
68	=	20.0	16	=	60.8
72	=	22.2	18	=	64.4
76	=	24.4	20	=	68
80	=	26.7	22	=	71.6
84	=	28.9	24	=	75.2
88	=	31.1	26	=	78.8
92	=	33.3	28	=	82.4
96	=	35.6	30	=	86
100	=	37.8	32	=	89.6
104	=	40.0	34	=	93.2
108	=	42.2	36	=	96.8
112	=	44.4	38	=	100.4
116	=	46.7	40	=	104
120	=	48.9	42	=	107.6
124	=	51.1	44	=	111.2
128	=	53.3	46	=	114.8
132	=	55.6	48	=	118.4
136	=	57.8	50	=	122
140	=	60.0	52	=	125.6
144	=	62.2	54	=	129.2
148	=	64.4	56	=	132.8
152	=	66.7	58	=	136.4
156	=	68.9	60	=	140
160	=	71.1	62	=	143.6
164	=	73.3	64	=	147.2
168	=	75.6	66	=	150.8
172	=	77.8	68	=	154.4
176	=	80.0	70	=	158
180	=	82.2	72	=	161.6
184	=	84.4	74	=	165.2
188	=	86.7	76	=	168.8
192	=	88.9	78	=	172.4
196	=	91.1	80	=	176
200	=	93.3	82	=	179.6
204	=	95.6	84	=	183.2
208	=	97.8	86	=	186.8
212	=	100.0	88	=	190.4
216	=	102.2	90	=	194
220	=	104.4	92	=	197.6
224	=	106.7	94	=	201.2
228	=	108.9	96	=	204.8
232	=	111.1	98	=	208.4
236	=	113.3	100	=	212
240	=	115.6	102	=	215.6
244	=	117.8	104	=	219.2

Temperature Conversion Chart -
Differential Temperatures

°F	=	°C	°C	=	°F
0	=	0	0	=	0
4	=	2.2	2	=	3.6
8	=	4.4	4	=	7.2
12	=	6.7	6	=	10.8
16	=	8.9	8	=	14.4
20	=	11.1	10	=	18
24	=	13.3	12	=	21.6
28	=	15.6	14	=	25.2
32	=	17.8	16	=	28.8
36	=	20	18	=	32.4
40	=	22.2	20	=	36
44	=	24.4	22	=	39.6
48	=	26.7	24	=	43.2
52	=	28.9	26	=	46.8
56	=	31.1	28	=	50.4
60	=	33.3	30	=	54

Pressure Conversion Chart -
Gauge or Differential

PSI	=	BAR	BAR	=	PSI
20	=	1.38	1.5	=	21.8
30	=	2.07	2	=	29
40	=	2.76	2.5	=	36.3
50	=	3.45	3	=	43.5
60	=	4.14	3.5	=	50.8
70	=	4.83	4	=	58
80	=	5.52	4.5	=	65.3
90	=	6.21	5	=	72.5
100	=	6.9	5.5	=	79.8
110	=	7.59	6	=	87
120	=	8.28	6.5	=	94.3
130	=	8.97	7	=	101.5
140	=	9.66	7.5	=	108.8
150	=	10.34	8	=	116
160	=	11.03	8.5	=	123.3
170	=	11.72	9	=	130.5
180	=	12.41	9.5	=	137.8
190	=	13.1	10	=	145
200	=	13.79	10.5	=	152.3
210	=	14.48	11	=	159.5
220	=	15.17	11.5	=	166.8
230	=	15.86	12	=	174
240	=	16.55	12.5	=	181.3
250	=	17.24	13	=	188.5
260	=	17.93	13.5	=	195.8
270	=	18.62	14	=	203
280	=	19.31	14.5	=	210.3
290	=	20	15	=	217.5
300	=	20.69	15.5	=	224.8
310	=	21.38	16	=	232
320	=	22.07	16.5	=	239.3
330	=	22.76	17	=	246.5
340	=	23.45	17.5	=	253.8
350	=	24.14	18	=	261
360	=	24.83	18.5	=	268.3
370	=	25.52	19	=	275.5
380	=	26.21	19.5	=	282.8
390	=	26.9	20	=	290
400	=	27.59	20.5	=	297.3

This page intentionally left blank.



P.O. Box 1592, York, Pennsylvania USA 17405-1592
Copyright © by Johnson Controls 2016
Form 201.18-NM7 (916)
Issue Date: September 30, 2016
Supersedes: 201.18-NM7 (701)

800-861-1001
www.johnsoncontrols.com

Subject to change without notice. Printed in USA
ALL RIGHTS RESERVED