

	Form No.: 160.49-RP4 (LS1)	101
	Supersedes: None	
<b>LITERATURE SUPPLEMENT</b>	File with: 160.49-RP4 (799)	
Subject: YK Style D & E Compressor Gasket Update		

YK Style D & E Chillers manufactured after June 1999 utilize 1/16" thick discharge and suction gaskets. The Unit Components Table on page 11 of 160.49-RP4 (799) call out 1/8" thick gaskets that were used on YK Style D & E Chillers manufactured up to June 1999. These gaskets should continue to be used on chillers built prior to June 1999.

When replacing suction and discharge gaskets on chillers built after June 1999 reference the alternate Unit Components table below for items 42 and 43:

### UNIT COMPONENTS

#### STYLE D & E UNITS (Manufactured after June 1999)

ITEM NO.	DESCRIPTION	PART NUMBER	QUAN/UNIT	REF. FIG.
42	GASKET, COMPR. SUCTION TO SHELL (G & H COMPR.)	028-13995-000	1	8
	(J1 & J2 COMPR.)	028-13996-000		
	(J3 & J4 COMPR.)	028-13991-000		
43	GASKET, COMPR. DISCH. TO SHELL (G & H COMPR.)	028-13990-000	2	12
	(J1 & J2 COMPR.)	028-13993-000		
	(J3 & J4 COMPR.)	028-13992-000		