



File in SJ4B Manual(s).

SERVICE BULLETIN

Supersedes: NOTHING 896 Form 160.49-M2 (SB11)

File with Form: 160.49-M2

SUBJECT: MICROCOMPUTER CONTROL CENTER (YK CENTRIFUGAL CHILLER) -
EPROM VERSION C.02F.14 & C.02T.14

On/about August 1996, the subject units will be equipped with eeprom version C.02F.14 (P/N 031-01431-002). Also, version C.02T.14 (P/N 031-01431-003) will be available for Remote Chiller Communications applications. These versions differ from the previous versions only in that certain portions of the program have been moved to other areas of available memory. This achieves standardization of memory location usage. These new versions provide chiller operation that is exactly the same as the previous version.

S.L. BAER
ELECTRONICS PRODUCT
SERVICE ENGINEER