

YCAV Simulator Set Up Data						
SET POINT		VALUE		NOTES		Password
System 1 Number of Condenser Fans		4		Setup Mode		4245
System 2 Number of Condenser Fans		4		Setup Mode		4245
Compressor 1 Operating Hours		No Change		Setup Mode		4245
Compressor 2 Operating Hours		No Change		Setup Mode		4245
Compressor 1 Starts		No Change		Setup Mode		4245
Compressor 2 Starts		No Change		Setup Mode		4245
Clear History Buffer		Yes		Setup Mode		4245
Remote Temperature Reset Option		Disabled		Setup Mode		4245
Remote Current Limit Option		Disabled		Setup Mode		4245
Remote Sound Limit Option		Disabled		Setup Mode		4245
Remote Inputs Service Time		5 Minutes		Setup Mode		4245
System 1 Motor Sensor to Ignore		1		Setup Mode		4245
System 2 Motor Sensor to Ignore		2		Setup Mode		4245
Suction Pressure Cut-Out		28 PSIG		Program Key		
Low Ambient Air Temp Cut-Out		10° F		Program Key		
Leaving Liquid Temp Cut-Out		36° F		Program Key		
Motor Current Limit		100%		Program Key		
Pulldown Current Limit		80%		Program Key		
Pulldown Current Limit Time		20 mins		Program Key		
Suction Superheat Setpoint		12° F		Program Key		
Unit ID		1		Program Key		
Sound Limit Setpoint		80%		Program Key		
Leaving Chilled Liquid Setpoint		45° F		Set Points Key		
Leaving Chilled Liquid Control Range		1.8° F		Set Points Key		
Max Remote Temperature Reset		10° F		Set Points Key		
Language		English		Options Key		
Chilled Liquid Cooling Mode		Water		Options Key		
Local/Remote Mode		Local		Options Key		
Display Units		Imperial		Options Key		
Lead/Lag Control Mode		Automatic		Options Key		
Remote Temperature Reset		0-10VDC		Options Key		
Remote Current Limit Input		0-10VDC		Options Key		
Remote Sound Limit Selection		0-10VDC		Options Key		
Low Ambient Cutout		Enabled		Options Key		
Compressor Overload ( VERIFY )		35 Amps		VSD Key/Logic Board		