

Opti-Logic Control LON / BACnet List

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet net OID ⁷ | BACnet Address/ Attribute |
|---|------------------|------------------|---------------------|--------------------------|---------------------|-----------------------------------|---------------------------------|
| nvoSpaceTemp | R | SNVT_temp_p | | | | | |
| nviSpaceTemp | W | SNVT_temp_p | | | | | |
| nvoUnitStatus_in_Alarm | R | SNVT_hvac_status | | | | | |
| cpSndHrtBt | W | SNVT_time_sec | | | | | |
| cpHvacType | R | SNVT_hvac_type | | | | | |
| cpMinOutTm | R | SNVT_time_sec | | | | | |
| cpRcvHrtBt | R | SNVT_time_sec | | | | | |
| | | | Device / Local Date | yymmddmmdd | R/W | | |
| | | | Device / Local Time | hh: mm : sshh | R/W | | |
| nvoUnitStatus_Mode; HVAC_COOL | R | SNVT_hvac_status | Unit Mode | 0 = Occupied Cooling | R | | AV1109 |
| nvoUnitStatus_Mode; HVAC_HEAT | R | SNVT_hvac_status | | 1 = Occupied Heating | | | |
| nvoUnitStatus_Mode; HVAC_COOL | R | SNVT_hvac_status | | 2 = Unoccupied Standby | | | |
| nvoUnitStatus_Mode; HVAC_HEAT | R | SNVT_hvac_status | | 3 = Unoccupied Cooling | | | |
| nvoUnitStatus_Mode; HVAC_HEAT | R | SNVT_hvac_status | | 4 = Unoccupied Heating | | | |
| nvoUnitStatus_Mode; HVAC_NIGHT_PURGE | | SNVT_hvac_status | | 5 = Manual Override | | | |
| nvoUnitStatus_Mode: HVAC_FAN_ONLY | R | SNVT_hvac_status | | 6 = Warm-up | | | |
| | | | | 7 = Sys. Start Delay | | | |
| | | | | 8 = Preoccupancy Purge | | | |
| | | | | 9 = Smoke Purge | | | |
| nvoUnitStatus_in_Alarm | R | SNVT_hvac_status | | 10 = Emergency Shut Down | | | |
| nvoUnitStatus_in_Alarm | R | SNVT_hvac_status | | 11 = Fault Shutdown | | | |
| | | | | 12 = Occupied Standby | | | |
| | | | Control Method | 0 = Thermostat | R | | AV1110 |
| | | | | 1 = Space Sensor | | | |
| | | | | 2 = Stand Alone Control | | | |
| nvoSplyFanState | R | SNVT_switch | Supply Fan Binary | 0, 1 (0=Off, 1=On) | R | | BV1207 |
| nvoFanSpeed | R | SNVT_lev_percent | Supply Fan VFD AV | XXX % | R | | AV1107 |

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet OID ⁷ | BACnet Address/Attribute |
|----------------------------|---------------|------------------|-------------------------------|----------------------------|------------------|-------------------------|--------------------------|
| nvoExhFanState | R | SNVT_switch | Exhaust Fan Binary | 0, 1 (0=Off, 1=On) | R | | BV1208 |
| nvoExhFanValue | R | SNVT_lev_percent | Exhaust Damper AV | XXX % | R | | AV1108 |
| nvoDrtyFiltrState | R | SNVT_switch | Dirty Filter Input | 0, 1 (0=Normal, 1=Replace) | R | | BV1209 |
| nvoOutdoorTemp | R | SNVT_temp_p | OA Temperature AV | XXX °F | R | | AV1111 |
| nviOutdoorTemp | W | SNVT_temp_p | | | | | |
| nvoOutdoorRH | R | SNVT_lev_percent | OA Rel Humid AV | | | | AV1112 |
| nviOutdoorRH | W | SNVT_lev_percent | | | R | | |
| nvoRATemp | R | SNVT_temp_p | RA Temperature AV | XXX °F | R | | AV1113 |
| nviRATemp | W | SNVT_temp_p | | | | | |
| nvoReturnAirRH | R | SNVT_lev_percent | RA Rel Humid AV | XXX % | R | | AV1114 |
| nvoDischAirTemp | R | SNVT_temp_p | SAT AV | XXX °F | R | | AV1115 |
| nvoSplyAirSP | R | SNVT_temp_p | Supply Air Temp Stpt | XXX °F | R | | AV1121 |
| nvoDuctPress | R | SNVT_press_p | Duct Static Pres AV | X.XX inwg | R | | AV1116 |
| nvoDuctPressSP | R | SNVT_press_p | Duct Static Setpt AV | X.XX inwg | R/W | | AV1118 |
| nviDuctPressSP | W | SNVT_press_p | | | | | |
| nvoBldgPress | R | SNVT_press_p | Building Static Pres AV | +/-X.XX inwg | R | | AV1117 |
| cpBldgPressSP ^o | R/W | SNVT_press_p | Building Static Setpt AV | +/-X.XX inwg | R/W | | AV1119 |
| nvoEffectSetpt | R | SNVT_temp_p | UnOccupied Heating Setpoint | XX °F | R/W | | AV1100 |
| cpSetpoints | W | SNVT_temp_setpt | | | | | |
| nvoEffectSetpt | R | SNVT_temp_p | UnOccupied Cooling Setpoint | XX °F | R/W | | AV1101 |
| cpSetpoints | W | SNVT_temp_setpt | | | | | |
| nvoEffectSetpt | R | SNVT_temp_p | Occupied Heating Setpoint | XX °F | R/W | | AV1102 |
| cpSetpoints | W | SNVT_temp_setpt | | | | | |
| nvoEffectSetpt | R | SNVT_temp_p | Occupied Cooling Setpoint | XX °F | R/W | | AV1103 |
| cpSetpoints | W | SNVT_temp_setpt | | | | | |
| nvoVAVCoolHiSP | R | SNVT_temp_p | VAV Cool High Temp Setpoint | XX °F | R/W | | AV1104 |
| nviVAVCoolHiSP | W | SNVT_temp_p | | | | | |
| nvoVAVCoolLoSP | R | SNVT_temp_p | VAV Cool Low Temp Setpoint | XX °F | R/W | | AV1105 |
| nviVAVCoolLoSP | W | SNVT_temp_p | | | | | |
| cpVAVSATResetSP | R/W | SNVT_temp_p | VAV SP for SAT Reset Setpoint | XX °F | R/W | | AV1106 |
| nvoEffectOccup | R | SNVT_occupancy | Occupied | 0, 1 (0=Unocc, 1=Occ) | R/W | | BV1203 |
| nviOccSensor | W | SNVT_occupancy | | | | | |

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet OID ⁷ | BACnet Address/Attribute |
|-----------------------------------|---------------|------------------|--|--|------------------|-------------------------|--------------------------|
| nviEmergOverride, 0,4 | W | SNVT_hvac_emerg | Shutdown | 0, 1 (0=Normal, 1=Shutdown) | R/W | | BV1205 |
| nviEmergOverride, 0,3 | W | SNVT_hvac_emerg | Smoke Purge | 0, 1 (0=Normal, 1=Purge) | R/W | | BV1204 |
| nvoVAVHeatRly | R | SNVT_switch | VAV Heat Relay BV | 0, 1 (0=No Heat, 1=Heat) | R/W | | BV1206 |
| | | | Smoke Purge Mode | 0=No Action | R/W | | AV1120 |
| | | | | 1=Shutdown | | | |
| | | | | 2= Pressurization | | | |
| | | | | 3=Exhaust | | | |
| | | | | 4=Purge | | | |
| | | | | 5=Purge w/Duct Pres. | | | |
| cpPreOccPurge | W | SNVT_switch | Pre-occupancy Purge | 0, 1 (0=Disabled, 1=Enabled) | R/W | | BV1212 |
| cpSchdPreocPurge | W | SNVT_switch | Sched Preocc Purge | 0, 1 (0=Disabled, 1=Enabled) | R/W | | BV1202 |
| cpWarmupReq | W | SNVT_switch | Warmup Request | 0, 1 (0=Disabled, 1=Enabled) | R/W | | BV1210 |
| nvoLastActFault ⁹ | R | SNVT_count | Alarm Notification Object | Ydcu_XXXXXXXXX Programing Alarm Notification | | | |
| nvoUnitStatus_heat_output_primary | R | SNVT_hvac_status | Property 1 (Heating Valve) ² | 0-100% | R | | AO304 |
| | | | Property 2 (Cooling/Heating Stage #1) | On, Off | R | | BO400 |
| | | | Property 3 (Cooling/Heating Stage #2) | On, Off | R | | BO401 |
| | | | Property 4 (Cooling/Heating Stage #3) | On, Off | R | | BO402 |
| | | | Property 5 (Cooling/Heating Stage #4) | On, Off | R | | BO403 |
| | | | Property 6 (Cooling/Heating Stage #5) | On, Off | R | | BO404 |
| | | | Property 7 (Cooling/Heating Stage #6) | On, Off | R | | BO405 |
| | | | Property 8 (Cool/Heat Changeover) | On, Off | R | | BO406 |
| | | | Property 9 (Supply Fan) | On, Off | R | | BO408 |
| | | | Property 10 (Exhaust Fan) | On, Off | R | | BO407 |

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet OID ⁷ | BACnet Address/Attribute |
|-------------------|---------------|-------------|--|--------------------------------|------------------|-------------------------|--------------------------|
| | | | Property 11 (VAV Heat Relay) | On, Off | R | | BO409 |
| | | | Property 12 (System 1, Suction Pressure) | XXX psig | R | | AI113 |
| | | | Property 13 (System 1, Discharge Pressure) | XXX psig | R | | AI114 |
| | | | Property 14 (System 2, Suction Pressure) | XXX psig | R | | AI115 |
| | | | Property 15 (System 2, Discharge Pressure) | XXX psig | R | | AI116 |
| | | | Property 16 (System 3, Suction Pressure) | XXX psig | R | | AI117 |
| | | | Property 17 (System 3, Discharge Pressure) | XXX psig | R | | AI118 |
| | | | Property 18 (Cond. Fan, System 1) | 0-100% | R/W | | AO308 |
| | | | Property 19 (Cond. Fan, System 2) | 0-100% | R/W | | AO309 |
| | | | Property 20 (Cond. Fan, System 3) | 0-100% | R/W | | AO310 |
| cpRfigSys1Status | R | SNVT_switch | Refrig System 1; Status = | 0, 1 (0=Normal, 1=Safety Trip) | R | 16 | 63210 |
| nvoRfigSys1State | R | SNVT_count | Refrig System 1; Comps ON = | 0=A, 1=B, 2=Both, 3=None | R | 13 | 63362 |
| cpRfigSys2Status | R | SNVT_switch | Refrig System 2; Status = | 0, 1 (0=Normal, 1=Safety Trip) | R | 17 | 63210 |
| nvoRfigSys2State | R | SNVT_count | Refrig System 2; Comps ON = | 0=A, 1=B, 2=Both, 3=None | R | 13 | 63363 |
| cpRfigSys3Status | R | SNVT_switch | Refrig System 3; Status = | 0, 1 (0=Normal, 1=Safety Trip) | R | 18 | 63210 |
| nvoRfigSys3State | R | SNVT_count | Refrig System 3; Comps ON = | 0=A, 1=B, 2=Both, 3=None | R | 13 | 63364 |
| (see Property #1) | | | Hydronic Heat System; Cntrl Output = | XXX % | R | 304 | 85 |
| nvoHydroFrzState | R | SNVT_switch | Hydronic Heat System; Freezestat = | 0, 1 (0=inactive, 1=active) | R | 211 | 85 |
| nvoHeatStepsOn | R | SNVT_count | Staged Heat System; Stages ON = | X, N/A | R | 28 | 63277 |

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet OID ⁷ | BACnet Address/Attribute |
|-----------------------------|---------------|------------------|---|---|------------------|-------------------------|--------------------------|
| | | | Staged Heat System; Stages Avail = | X, N/A | R | 28 | 63250 |
| | | | Economizer System; Type = | 0=OA Dry Bulb, 1=Single Enthalpy, 2=Dual Enthalpy, 3=N/A | R | 28 | 63406 |
| nvoEconSysStatus | R | SNVT_switch | Economizer System; Status = | 0=Inactive, 1=Active, 2=N/A, 3=Fault | R | 28 | 63409 |
| CpEconEnStatus ⁴ | W | SNVT_switch | Economizer Enable; Setting = ⁴ | 0=Yes, 1=No, | | | |
| | | | Ventilation System; Type = | 0=None, 1=Min Dampr Pos, 2=Min Airflow, 3=25/75 Airflow, 4=Full Airflow | R | 28 | 63388 |
| cpVentSysState | R | SNVT_switch | Ventilation System; Status = | 0, 1 (0=Off, 1=On) | R | 28 | 63387 |
| nvoOADp#1Pos | R | SNVT_lev_percent | Outside Air Damper #1; MIN Position = | XXX % | R/W | 28 | 63270 |
| cpOADp#1MinPos | R/W | SNVT_lev_percent | | | | | |
| cpOADp#2MinPos | R/W | SNVT_lev_percent | Outside Air Damper #2; Min Pos = | XXX % | R/W | 28 | 63271 |
| nvoMinOAFFlowSP | R | SNVT_flow | Minimum Outside Airflow; Setpoint= | XXXXX cfm | R/W | 28 | 63661 |
| nviMinOAFFlowSP | W | SNVT_flow | | | | | |
| nvoOAFFlow | R | SNVT_flow | Outside Air Damper; Total Flow = | XXXXX cfm | R | 14 | 63278 |
| nvoSpaceCO2 | R* | SNVT_ppm | | | | | |
| nviSpaceCO2 | W | SNVT_ppm | | | | | |
| cpSpaceCO2SP | R/W | SNVT_ppm | Demand Ventilation; Setpoint = | XXXX ppm | R/W | 28 | 63045 |
| cpEcon1stStgSP | R/W | SNVT_temp_p | Economizer 1st Stage; Setpoint = | XX °F | R/W | 28 | 63048 |
| cpEcon2ndStgSP | R/W | SNVT_temp_p | Economizer 2nd Stage; Setpoint = | XX °F | R/W | 28 | 63049 |
| cpEconLoadHeatSP | R/W | SNVT_temp_p | SAT Econo Load Heat; Setpoint = | XXX °F | R/W | 28 | 63043 |
| | | | Outside Air Enthalpy; Setpoint = | XX btu/lb | R/W | 28 | 63758 |
| cpCmfrtVtHiSATSP | R/W | SNVT_temp_p | Cmfrt Vent High SAT; Setpoint = | XX °F | R/W | 28 | 63027 |

| LON Variable Name | LON Rev. 1.63 | SNVT | BACnet Object Name | Parameter Displayed | BACnet Rev. 1.63 | BACnet OID ⁷ | BACnet Address/Attribute |
|-------------------|---------------|------------------|----------------------------------|--|------------------|-------------------------|--------------------------|
| cpCmfrtVtLoSATSP | R/W | SNVT_temp_p | Cmfrt Vent Low SAT; Setpoint = | XX °F | R/W | 28 | 63028 |
| nvoRATWarmupSP | R | SNVT_temp_p | Warm-Up RAT; Setpoint = | XX °F | R/W | 28 | 63273 |
| nviRATWarmupSP | W | SNVT_temp_p | | | | | |
| cpHydroHeat1StgSP | R/W | SNVT_temp_p | Hydro Heat 1st Stage; Setpoint = | XXX °F | R/W | 28 | 63255 |
| cpHydroHeat2StgSP | R/W | SNVT_temp_p | Hydro Heat 2nd Stage; Setpoint = | XXX °F | R/W | 28 | 63256 |
| nvoFlexMxAirTemp | R | SNVT_temp_p | Mixed Supply Air Tmp | XX.X °F | R | | AI119 |
| nviFlexMxAirTemp | W | SNVT_temp_p | | | | | |
| nvoFlexMxAirSP | R | SNVT_temp_p | | | | | |
| nviFlexMxAirSP | W | SNVT_temp_p | | | | | |
| nvoFlexSlabTemp | R | SNVT_temp_p | Under Floor Slab Tmp | XX.X °F | R | | AI120 |
| nviFlexSlabTemp | W | SNVT_temp_p | | | | | |
| nvoFlexFlrRH | R | SNVT_lev_percent | Under Floor Rel Humd | 0 - 100 % | R | | AI121 |
| nviFlexFlrRH | W | SNVT_lev_percent | | | | | |
| nvoFlexBypSPct | R | SNVT_lev_percent | Bypass Damper | 0 - 100 % | R | | AO311 |
| nvoFlexBypSPDpPos | R | SNVT_lev_percent | | | | | |
| nviFlexDewptReset | W | SNVT_switch | | | | | |
| nviDemandLimit | W | SNVT_count | Demand Limit | 0=No Demand Limit, 1=50% Demand Limit, 2=100% Demand Limit | | | |

- 1 – The occurrence of a fault is available from UnitStatus_in_Alarm (LON Cnt (nvi + nvo) = 3)
- 2 – BACnet Standard Objects “Property #1 to Property #20” are Standard Objects which are exposed as readable and writable but, they must be Read Only as writing to these points will cause improper operation of the unit.
- 3 – The nvoLastActFault uses the SNVT_flow to provide the number of the last active alarm fault and the last active trouble fault. These are given numerically as XX0YY where XX is the number of the last active alarm and YY is the last active trouble. This number will have flow units.
- 4 – The Economizer Enable; Setting= is not included in the BACnet Standard Objects. In Rev. 1.53, the Economizer Enable was an nvo.
- 5 – CP’s may not be accessible on some LON front ends
- 6 – CO2 Space DISPLAY rounds to whole numbers and is therefore unusable.
- 7 – BACnet Proprietary Object Identifier