

**SERVICE BULLETIN**Supersedes: Nothing 195 Form 155.17-RP2 (SB2)File with Form: 155.17-RP2

SUBJECT: PARAFLOW ABSORPTION UNITS - MICROCOMPUTER CONTROL CENTER PARTS LIST

THE FOLLOWING NEW PART SHOULD BE ADDED TO THE REPLACEMENT PARTS LIST:

<u>P/N</u>	<u>DESCRIPTION</u>	<u>QTY.</u>
031-01586-000	VOLTAGE TRANSIENT PROTECTION MODULE FOR MICRO BOARD RS-485 SERIAL PORT (ONLY USED ON UNITS EQUIPPED WITH ISN FAX-4500 BAS CONNECTED TO RS-485 SERIAL PORT TB7)	1

NOTE: IF THIS MODULE IS BEING INSTALLED FOR THE FIRST TIME, ORDER KIT 371-01477-000. KIT INCLUDES MODULE AND INSTALLATION INSTRUCTIONS.


S.L. BAER
ELECTRONICS PRODUCT
SERVICE ENGINEER