

|                                                                                   |                                             |                         |
|-----------------------------------------------------------------------------------|---------------------------------------------|-------------------------|
|  | <b>AIR-COOLED SCREW<br/>LIQUID CHILLERS</b> |                         |
| <b>INSTALLATION, OPERATION, MAINTENANCE</b>                                       | Supersedes: 201.28-NM1.1 (1117)             | Form 201.28-NM1.1 (118) |

035-23219-100

**MODEL YVAA STYLE A  
AIR-COOLED SCREW LIQUID CHILLERS WITH  
VARIABLE SPEED DRIVE  
FRAME SIZES 015 - 052**

**150 - 500 TONS  
525 - 1750 KW  
2 COMPRESSOR  
50 AND 60 HZ**



LD15045

**HFC-134A OR R-513A**

Issue Date:  
January 31, 2018



# IMPORTANT!

## READ BEFORE PROCEEDING!

### GENERAL SAFETY GUIDELINES

This equipment is a relatively complicated apparatus. During rigging, installation, operation, maintenance, or service, individuals may be exposed to certain components or conditions including, but not limited to: heavy objects, refrigerants, materials under pressure, rotating components, and both high and low voltage. Each of these items has the potential, if misused or handled improperly, to cause bodily injury or death. It is the obligation and responsibility of rigging, installation, and operating/service personnel to identify and recognize these inherent hazards, protect themselves, and proceed safely in completing their tasks. Failure to comply with any of these requirements could result in serious damage to the equipment and the property in

which it is situated, as well as severe personal injury or death to themselves and people at the site.

This document is intended for use by owner-authorized rigging, installation, and operating/service personnel. It is expected that these individuals possess independent training that will enable them to perform their assigned tasks properly and safely. It is essential that, prior to performing any task on this equipment, this individual shall have read and understood the on-product labels, this document and any referenced materials. This individual shall also be familiar with and comply with all applicable industry and governmental standards and regulations pertaining to the task in question.

---

### SAFETY SYMBOLS

The following symbols are used in this document to alert the reader to specific situations:




***Indicates a possible hazardous situation which will result in death or serious injury if proper care is not taken.***



***Identifies a hazard which could lead to damage to the machine, damage to other equipment and/or environmental pollution if proper care is not taken or instructions are not followed.***



***Indicates a potentially hazardous situation which will result in possible injuries or damage to equipment if proper care is not taken.***



***Highlights additional information useful to the technician in completing the work being performed properly.***



***External wiring, unless specified as an optional connection in the manufacturer's product line, is not to be connected inside the control cabinet. Devices such as relays, switches, transducers and controls and any external wiring must not be installed inside the micro panel. All wiring must be in accordance with Johnson Controls' published specifications and must be performed only by a qualified electrician. Johnson Controls will NOT be responsible for damage/problems resulting from improper connections to the controls or application of improper control signals. Failure to follow this warning will void the manufacturer's warranty and cause serious damage to property or personal injury.***

## CHANGEABILITY OF THIS DOCUMENT

In complying with Johnson Controls' policy for continuous product improvement, the information contained in this document is subject to change without notice. Johnson Controls makes no commitment to update or provide current information automatically to the manual or product owner. Updated manuals, if applicable, can be obtained by contacting the nearest Johnson Controls Service office or accessing the Johnson Controls QuickLIT website at <http://cgproducts.johnsoncontrols.com>.



***The Control/VSD Cabinet contains lethal high AC and DC voltages. Before performing service inside the cabinet, remove the AC supply feeding the chiller and verify using a non-contact voltage sensor.***



***The DC voltage on the VSD DC Bus will take 5 minutes to bleed off, after AC power is removed. Always check the DC Bus Voltage with a Voltmeter to assure the capacitor charge has bled off before working on the system.***



***NEVER short out the DC Bus to discharge the filter capacitors.***



***NEVER place loose tools, debris, or any objects inside the Control Panel/VSD Cabinet.***

It is the responsibility of rigging, lifting, and operating/ service personnel to verify the applicability of these documents to the equipment. If there is any question regarding the applicability of these documents, rigging, lifting, and operating/service personnel should verify whether the equipment has been modified and if current literature is available from the owner of the equipment prior to performing any work on the chiller.

### CHANGE BARS

Revisions made to this document are indicated with a line along the left or right hand column in the area the revision was made. These revisions are to technical information and any other changes in spelling, grammar or formatting are not included.



***NEVER allow the Control Panel VSD Cabinet doors to remain open if there is a potential for rain to enter the panel. Keep doors closed and assure all latches are engaged on each door unless the unit is being serviced.***



***ALWAYS lockout the disconnect supplying AC to the chiller.***



***The 1L Line Inductor will reach operating temperatures of over 150°C (300°F.) DO NOT open panel doors during operation. Assure the inductor is cool whenever working near the inductor with power OFF.***

## ASSOCIATED LITERATURE

| MANUAL DESCRIPTION                                                                                                                                                        | FORM NUMBER |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|
| Equipment Pre-Startup and Startup Checklist                                                                                                                               | 201.28-CL2  |
| YVAA Style A Frame Size 015 - 027, 2 Compressor 60 Hz (150-350 Tons)<br>YVAA Style A Frame Size 054 - 098, 2 Compressor 50 Hz (525-950 KW) Manufactured before April 2012 | 201.28-RP1  |
| YVAA Style A Frame Size 015 - 052, 2 Compressor 50 & 60 Hz (150-500 Tons)<br>(Manufactured after April 2012 to before September 2014)                                     | 201.28-RP2  |
| YVAA Style B Frame Size 015 - 052, 2 Compressor 50 & 60 Hz (150-500 Tons)<br>(Manufactured after September 2014)                                                          | 201.28-RP3  |

THIS PAGE INTENTIONALLY LEFT BLANK

## TABLE OF CONTENTS

|                                                                 |           |
|-----------------------------------------------------------------|-----------|
| <b>SECTION 1 - GENERAL CHILLER INFORMATION AND SAFETY .....</b> | <b>13</b> |
| Introduction.....                                               | 13        |
| Warranty .....                                                  | 13        |
| Quality Assurance and Safety .....                              | 14        |
| Fluorinated Greenhouse Gases .....                              | 14        |
| Responsibility for Safety .....                                 | 14        |
| About This Manual.....                                          | 14        |
| Misuse of Equipment.....                                        | 14        |
| Suitability for Application .....                               | 14        |
| Structural Support .....                                        | 15        |
| Mechanical Strength .....                                       | 15        |
| General Access .....                                            | 15        |
| Pressure Systems .....                                          | 15        |
| Electrical.....                                                 | 15        |
| Rotating Parts.....                                             | 15        |
| Sharp Edges.....                                                | 15        |
| Refrigerants and Oils.....                                      | 16        |
| High Temperature and Pressure Cleaning .....                    | 16        |
| Emergency Shutdown .....                                        | 16        |
| Safety Labels.....                                              | 16        |
| <b>SECTION 2 - PRODUCT DESCRIPTION .....</b>                    | <b>17</b> |
| General System Description.....                                 | 17        |
| Semi-Hermetic YORK Twin-Screw Compressors.....                  | 19        |
| Evaporator .....                                                | 19        |
| Condenser.....                                                  | 19        |
| Refrigerant Circuit .....                                       | 19        |
| Electrical.....                                                 | 19        |
| Building Automation System Capabilities .....                   | 20        |
| Microcomputer Control Center .....                              | 20        |
| Display Data .....                                              | 20        |
| Programmable Setpoints .....                                    | 20        |
| Accessories and Options.....                                    | 21        |
| Sound Attenuation .....                                         | 21        |
| Fan Options.....                                                | 21        |
| Condenser Coils.....                                            | 21        |
| Condenser Coil Protection .....                                 | 21        |
| Protective Chiller Panels .....                                 | 21        |
| Evaporator Options .....                                        | 22        |
| Controls Options.....                                           | 22        |
| General Options .....                                           | 22        |
| Vibration Isolation.....                                        | 23        |
| <b>SECTION 3 - RIGGING, HANDLING AND STORAGE .....</b>          | <b>25</b> |
| Lifting Weights .....                                           | 25        |
| Delivery and Storage.....                                       | 25        |
| Inspection .....                                                | 26        |
| Moving the Chiller.....                                         | 26        |
| Unit Removal From Shipping Container.....                       | 26        |
| Lifting Using Lugs.....                                         | 26        |
| Lifting Using Shackles .....                                    | 26        |

## TABLE OF CONTENTS (CONT'D)

|                                                          |               |
|----------------------------------------------------------|---------------|
| <b>SECTION 4 - INSTALLATION .....</b>                    | <b>37</b>     |
| Location Requirements .....                              | 37            |
| Outdoor Installations .....                              | 37            |
| Location Clearances.....                                 | 37            |
| Recommended Minimum Clearances .....                     | 38            |
| Vibration Isolators.....                                 | 39            |
| Installation .....                                       | 39            |
| Shipping Braces .....                                    | 39            |
| Chilled Liquid Piping.....                               | 39            |
| General Requirements .....                               | 39            |
| Evaporator Pressure Drop.....                            | 40            |
| Water Treatment.....                                     | 41            |
| Pipework Arrangement .....                               | 41            |
| Minimum Water Volume .....                               | 42            |
| Leaving Water Temperature Out of Range .....             | 42            |
| Thermal Storage.....                                     | 43            |
| Variable Primary Flow .....                              | 43            |
| Connection Types and Sizes.....                          | 43            |
| Evaporator Connections.....                              | 43            |
| Option Flanges .....                                     | 45            |
| Refrigerant Relief Valve Piping.....                     | 45            |
| Electrical Connection.....                               | 45            |
| Power Wiring .....                                       | 46            |
| Power Supply Wiring .....                                | 46            |
| 115VAC Control Supply Transformer.....                   | 46            |
| Control Wiring.....                                      | 46            |
| Volts Free Contacts .....                                | 47            |
| Chilled Liquid Pump Starter.....                         | 47            |
| Run Contact .....                                        | 47            |
| Alarm Contacts.....                                      | 47            |
| System Inputs.....                                       | 47            |
| Flow Switch .....                                        | 47            |
| Remote Run / Stop.....                                   | 47            |
| Remote Print .....                                       | 47            |
| Optional Remote Setpoint Offset – Temperature.....       | 47            |
| Optional Remote Setpoint Offset – Current.....           | 47            |
| Optional Remote Setpoint Offset – Sound Limiting .....   | 47            |
| Power Supply Wiring .....                                | 48            |
| Single Point Wiring.....                                 | 48            |
| Voltage Utilization Range .....                          | 48            |
| Dual Point Wiring.....                                   | 49            |
| Customer Control Wiring .....                            | 50            |
| <br><b>SECTION 5 - TECHNICAL DATA .....</b>              | <br><b>63</b> |
| Nomenclature .....                                       | 63            |
| Elastomeric Isolator Installation.....                   | 90            |
| Elastomeric Isolator Specifications.....                 | 91            |
| One Inch Deflection Isolator Installation .....          | 92            |
| One Inch Deflection Spring Isolator Specifications ..... | 93            |
| CPX-xx-xxx.....                                          | 93            |

## TABLE OF CONTENTS (CONT'D)

|                                                                      |            |
|----------------------------------------------------------------------|------------|
| Two Inch Deflection Isolator Installation And Adjustment .....       | 94         |
| Two Inch Deflection, Restrained Spring Isolator Specifications ..... | 95         |
| Y2RSI-xx-xxx.....                                                    | 95         |
| <b>SECTION 6 - COMMISSIONING .....</b>                               | <b>97</b>  |
| Preparation .....                                                    | 97         |
| Inspection .....                                                     | 97         |
| Refrigerant Charge.....                                              | 97         |
| Correct System Refrigerant Charge.....                               | 97         |
| Service and Oil Line Valves.....                                     | 97         |
| Compressor Oil .....                                                 | 97         |
| Fans .....                                                           | 98         |
| Isolation / Protection.....                                          | 98         |
| Control Panel.....                                                   | 98         |
| Power Connections .....                                              | 98         |
| Grounding.....                                                       | 98         |
| Water System .....                                                   | 98         |
| Flow Switch .....                                                    | 98         |
| Temperature Sensor(s).....                                           | 98         |
| Programmed Options .....                                             | 98         |
| Programmed Settings .....                                            | 98         |
| Date and Time .....                                                  | 98         |
| Start/Stop Schedule .....                                            | 98         |
| Setpoint and Remote Offset .....                                     | 99         |
| First Time Start Up .....                                            | 99         |
| Interlocks .....                                                     | 99         |
| Unit Switch .....                                                    | 99         |
| Startup.....                                                         | 99         |
| Oil Pressure.....                                                    | 99         |
| Loading.....                                                         | 99         |
| Condenser and Fan Rotation .....                                     | 99         |
| System Charge.....                                                   | 99         |
| General Operation .....                                              | 100        |
| Operation in Sub-freezing Conditions .....                           | 100        |
| Unit Maintenance and Shutdown in Sub-freezing Conditions .....       | 100        |
| <b>SECTION 7 - OPERATION .....</b>                                   | <b>101</b> |
| Operating Controls .....                                             | 101        |
| Unit Switch .....                                                    | 101        |
| Keypad .....                                                         | 101        |
| Keypad Data Entry Mode .....                                         | 102        |
| Display.....                                                         | 102        |
| Anti-recycle Timer.....                                              | 102        |
| Evaporator Pump Control.....                                         | 102        |
| Evaporator Heater Control .....                                      | 103        |
| Alarms .....                                                         | 103        |
| Chiller Run Contact .....                                            | 103        |
| Flow Switch Control.....                                             | 103        |
| Remote Run / Stop.....                                               | 103        |

## TABLE OF CONTENTS (CONT'D)

|                                                             |     |
|-------------------------------------------------------------|-----|
| Basic Operating Sequence.....                               | 103 |
| Start Sequence and Loading.....                             | 103 |
| Unit Warning.....                                           | 103 |
| Unit Warning Operation.....                                 | 103 |
| Low Battery Warning.....                                    | 103 |
| Microboard (331-03478-xxx).....                             | 104 |
| Power Supplies and LEDs.....                                | 104 |
| Power Supply Test Points.....                               | 104 |
| Configuration Jumpers.....                                  | 104 |
| Building Automation System (BAS) Communications.....        | 106 |
| Using Communications Protocol.....                          | 106 |
| E-Link or SC-EQ Interface.....                              | 107 |
| SC-EQ or E-Link BAS Communications Card.....                | 110 |
| VSD.....                                                    | 118 |
| Program Update.....                                         | 118 |
| Data Logging.....                                           | 118 |
| Invalid Number of Compressors Warning.....                  | 119 |
| Invalid Serial Number Warning.....                          | 119 |
| Unit Safeties.....                                          | 120 |
| Unit Safety Operation.....                                  | 120 |
| High Ambient Temp Fault.....                                | 120 |
| Low Ambient Temp Fault.....                                 | 120 |
| Low Leaving Chilled Liquid Temp Fault.....                  | 120 |
| VSD Communications Failure Fault.....                       | 120 |
| System Safeties (Faults).....                               | 121 |
| System Safety (Fault) Operation.....                        | 121 |
| High Discharge Pressure Cutout (Software) Fault.....        | 121 |
| High Discharge Pressure Cutout (HPCO) (Hardware) Fault..... | 121 |
| Low Suction Pressure Cutout (Software) Fault.....           | 122 |
| Low Motor Current Cutout Fault.....                         | 122 |
| High Differential Oil Pressure Cutout Fault.....            | 122 |
| Low Differential Oil Pressure Cutout Fault.....             | 122 |
| High Discharge Temperature Cutout Fault.....                | 123 |
| Low Discharge Superheat Cutout Fault.....                   | 123 |
| Discharge Pressure Load Limiting/Unloading.....             | 123 |
| Suction Pressure Load Limiting/Unloading.....               | 124 |
| Sensor Failure Cutout Fault.....                            | 124 |
| High Motor Temperature Cutout Fault.....                    | 125 |
| System Control Voltage Cutout Fault.....                    | 125 |
| Eductor Clog Fault.....                                     | 125 |

## TABLE OF CONTENTS (CONT'D)

|                                                                     |            |
|---------------------------------------------------------------------|------------|
| <b>SECTION 8 - MICROPANEL .....</b>                                 | <b>127</b> |
| <b>SECTION 9 - MAINTENANCE.....</b>                                 | <b>161</b> |
| General Requirements .....                                          | 161        |
| Weekly Maintenance .....                                            | 161        |
| Unit Status.....                                                    | 161        |
| Refrigerant Leaks .....                                             | 161        |
| Operating Conditions.....                                           | 161        |
| Compressor Oil Level.....                                           | 161        |
| Refrigerant Charge.....                                             | 161        |
| Adding Charge to a System .....                                     | 161        |
| Refrigerant Removal, Evacuation and Charging a YVAA Chiller .....   | 162        |
| Refrigerant Removal .....                                           | 162        |
| Evacuating a System.....                                            | 162        |
| Charging Refrigerant into a System .....                            | 163        |
| Microchannel Coil Cleaning.....                                     | 163        |
| Scheduled Maintenance.....                                          | 163        |
| Maintenance Requirements for YVAA Chillers .....                    | 164        |
| R-513A Conversion Table .....                                       | 168        |
| R-513A Conversion Table .....                                       | 169        |
| <b>SECTION 10 - DECOMMISSIONING, DISMANTLING AND DISPOSAL .....</b> | <b>175</b> |

## LIST OF FIGURES

|                                                                                                                                        |     |
|----------------------------------------------------------------------------------------------------------------------------------------|-----|
| <b>FIGURE 1</b> - YVAA Air-Cooled Screw Liquid Chiller with Variable Speed Drive .....                                                 | 17  |
| <b>FIGURE 2</b> - Chiller Control System .....                                                                                         | 18  |
| <b>FIGURE 3</b> - View of York Control Center User Interface .....                                                                     | 20  |
| <b>FIGURE 4</b> - Acceptable Minimum Clearances Around/Between Unit(s) .....                                                           | 38  |
| <b>FIGURE 5</b> - Three Pass Water Pressure Drop, english units.....                                                                   | 40  |
| <b>FIGURE 6</b> - Two Pass Water Pressure Drop, SI Units .....                                                                         | 41  |
| <b>FIGURE 7</b> - Pipework Arrangement .....                                                                                           | 41  |
| <b>FIGURE 8</b> - Leaving Water Temperature Out of Range Suggested Layout .....                                                        | 42  |
| <b>FIGURE 9</b> - Suggested Layout For Applications With A Flow Rate Less Than The Evaporator<br>Minimum Allowable Flow Rate.....      | 42  |
| <b>FIGURE 10</b> - Suggested Layout For Applications With A Flow Rate Greater Than The Evaporator<br>Maximum Allowable Flow Rate ..... | 42  |
| <b>FIGURE 11</b> - Victaulic Groove.....                                                                                               | 43  |
| <b>FIGURE 12</b> - Flange For GB Vessels.....                                                                                          | 45  |
| <b>FIGURE 13</b> - Flange Attachment.....                                                                                              | 45  |
| <b>FIGURE 14</b> - Single Point Power Wiring .....                                                                                     | 48  |
| <b>FIGURE 15</b> - Dual Point Power Wiring.....                                                                                        | 49  |
| <b>FIGURE 16</b> - Customer Control Connections .....                                                                                  | 50  |
| <b>FIGURE 17</b> - YVAA Dimensions .....                                                                                               | 82  |
| <b>FIGURE 18</b> - Keyboard and Display.....                                                                                           | 101 |
| <b>FIGURE 19</b> - New 331-03478-xxx Microboard .....                                                                                  | 105 |
| <b>FIGURE 20</b> - LON E-Link Gateway Option .....                                                                                     | 110 |

## LIST OF TABLES

|                                                                                                                |     |
|----------------------------------------------------------------------------------------------------------------|-----|
| <b>TABLE 1</b> - Unit Rigging .....                                                                            | 28  |
| <b>TABLE 2</b> - Minimum Evaporator Tube Removal Clearance .....                                               | 38  |
| <b>TABLE 3</b> - Evaporator Connections Dimensions .....                                                       | 44  |
| <b>TABLE 4</b> - Electrical Lug Data .....                                                                     | 52  |
| <b>TABLE 5</b> - Physical Data - Microchannel Coil .....                                                       | 64  |
| <b>TABLE 6</b> - Physical Data - Round Tube Coil .....                                                         | 68  |
| <b>TABLE 7</b> - Optional One-Pass Evaporator .....                                                            | 70  |
| <b>TABLE 8</b> - Standard Two-Pass, Rear Inlet/Outlet Evaporator .....                                         | 74  |
| <b>TABLE 9</b> - Optional Three-Pass Rear Inlet/Front Outlet Evaporator .....                                  | 78  |
| <b>TABLE 10</b> - Isolator Selection and Mounting Locations .....                                              | 84  |
| <b>TABLE 11</b> - Values Required for BAS Communication .....                                                  | 108 |
| <b>TABLE 12</b> - Real Time Error Numbers For BAS, SC-EQ or E-Link Communications Card .....                   | 109 |
| <b>TABLE 13</b> - YVAA Native Communications Data Map .....                                                    | 111 |
| <b>TABLE 14</b> - YVAA Operational and Fault / Inhibit Codes .....                                             | 114 |
| <b>TABLE 15</b> - YVAA E-Link Communications Data Map .....                                                    | 115 |
| <b>TABLE 16</b> - Flash Card Update Error XXXXX .....                                                          | 118 |
| <b>TABLE 17</b> - Data Logging .....                                                                           | 119 |
| <b>TABLE 18</b> - Low Differential Oil Pressure Cutout .....                                                   | 123 |
| <b>TABLE 19</b> - Discharge Pressure Load Limiting/Unloading .....                                             | 124 |
| <b>TABLE 20</b> - Suction Pressure Load Limiting/Unloading .....                                               | 124 |
| <b>TABLE 21</b> - Start Inhibit Sensor Thresholds .....                                                        | 125 |
| <b>TABLE 22</b> - Sensor Min/Max Outputs .....                                                                 | 134 |
| <b>TABLE 23</b> - Compressor Motor Overload Settings .....                                                     | 136 |
| <b>TABLE 24</b> - Setpoint Limits .....                                                                        | 146 |
| <b>TABLE 25</b> - Programmable Operating Parameters .....                                                      | 149 |
| <b>TABLE 26</b> - Printout Types .....                                                                         | 157 |
| <b>TABLE 27</b> - Troubleshooting Guide .....                                                                  | 165 |
| <b>TABLE 28</b> - R-513A Refrigerant Pressure to Saturated Temperature .....                                   | 168 |
| <b>TABLE 29</b> - R-513A Refrigerant Temperature to Pressure .....                                             | 169 |
| <b>TABLE 30</b> - Temperature Input Voltage Sensor (Measured Signal To Shield At The Sensor) .....             | 170 |
| <b>TABLE 31</b> - Outside Air Temperature Sensor Input Voltage (Measured Signal To Shield At The Sensor) ..... | 171 |
| <b>TABLE 32</b> - Pressure Transducer Output Voltage (Measured Signal To Return At The Transducer) .....       | 172 |
| <b>TABLE 33</b> - Motor Temperature Sensor Resistance (Check At The Motor) .....                               | 173 |
| <b>TABLE 34</b> - SI Metric Conversion .....                                                                   | 176 |

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 1 - GENERAL CHILLER INFORMATION AND SAFETY


1

### INTRODUCTION

YORK YVAA chillers are manufactured to the highest design and construction standards to ensure high performance, reliability and adaptability to all types of air conditioning installations.

The unit is intended for cooling water or glycol solutions and is not suitable for purposes other than those specified in this manual.

Rigging and lifting should only be done by a professional rigger in accordance with a written rigging and lifting plan. The most appropriate rigging and lifting method will depend on job specific factors, such as the rigging equipment available and site needs. Therefore, a professional rigger must determine the rigging and lifting method to be used, and it is beyond the scope of this manual to specify rigging and lifting details.



***The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configurations. Contact your nearest Johnson Controls sales office for weight data. See SECTION 3 - RIGGING, HANDLING AND STORAGE for more details.***

This manual contains all the information required for correct installation and commissioning of the unit, together with operating and maintenance instructions. The manual should be read thoroughly before attempting to operate or service the unit.

All procedures detailed in the manual, including installation, commissioning and maintenance tasks must only be performed by suitably trained and qualified personnel.

The manufacturer will not be liable for any injury or damage caused by incorrect installation, commissioning, operation or maintenance resulting from a failure to follow the procedures and instructions detailed in the manual.

### WARRANTY

Johnson Controls warrants YVAA chillers in accordance with the "Limited Warranty Engineered Systems Equipment" procedure. Refer to *Form 50.05-NM2*.

Johnson Controls warrants all equipment and materials against defects in workmanship and materials for a period of eighteen months from date of shipment or 12 months from date of startup, whichever comes first, unless labor or extended warranty has been purchased as part of the contract. The warranty is limited to parts only replacement and shipping of any faulty part, or sub-assembly, which has failed due to poor quality or manufacturing errors. All claims must be supported by evidence that the failure has occurred within the warranty period, and that the unit has been operated within the designed parameters specified.

All warranty claims must specify the unit model, serial number, order number and run hours/starts. Model and serial number information is printed on the unit identification plate.

The unit warranty will be void if any modification to the unit is carried out without prior written approval from Johnson Controls. For warranty purposes, the following conditions must be satisfied:

- The initial start of the unit must be carried out by trained personnel from an authorized Johnson Controls Service Center. See "*SECTION 6 - COMMISSIONING*" on page 97 for more information.
- Only genuine YORK approved spare parts, oils, coolants, and refrigerants must be used.
- All the scheduled maintenance operations detailed in this manual must be performed at the specified times by suitably trained and qualified personnel. See "*SECTION 9 - MAINTENANCE*" for more information.
- Failure to satisfy any of these conditions will automatically void the warranty. Refer to *Form 50.05-NM2* for complete details.

## QUALITY ASSURANCE AND SAFETY

YVAA chillers are designed within EN ISO 9001 and built within an EN ISO 9002 accredited manufacturing organization.

Units conform with the following European Directives:

- Machinery Directive (2006/42/EC)
- EMC Directive (2004/108/EC)
- Pressure Equipment Directive (97/23/EC)
- Low Voltage Directive (2006/95/EC)
- Safety Code for Mechanical Refrigeration (EN378-2(2008))

CE/PED marked units conform to the following standards:

- Machinery Directive (2006/42/EC).
- EMC Directive (2004/108/EC).
- Pressure Equipment Directive (97/23/EC).
- Low Voltage Directive (2006/95/EC).
- Safety Code for Mechanical Refrigeration (EN378-2(2008)).

ETL/ASME marked units conform to the following standards:

- ANSI/ASHRAE 15 – Safety Code for Mechanical Refrigeration.
- ANSI/ASHRAE 34 – Number Designation and Safety Classification of Refrigerants.
- ANSI/NFPA 70 – National Electrical Code (N.E.C.).
- ASME Boiler and Pressure Vessel Code, Section VIII, Division 1.

GB marked units conform to the following standards:

- GB5226.1 Safety of machinery- Electrical equipment of machines – Part 1: General requirements.
- GB25131 Safety requirements for water chiller (heat pump) using the vapor compression cycle.

## FLUORINATED GREENHOUSE GASES

- This equipment contains fluorinated greenhouse gases covered by the Kyoto Protocol.
- The global warming potential of the refrigerant used in this unit is 1300 for R-134a, and 630 for R-513A.
- The refrigerant quantity is as stated in *Table 5 on Page 64* of this document.
- The fluorinated greenhouse gases in this equipment may not be vented to the atmosphere.
- This equipment should only be serviced by qualified technicians.

## RESPONSIBILITY FOR SAFETY

Every care has been taken in the design and manufacture of the unit to ensure compliance with the safety requirements listed above. However, the individual rigging, lifting, maintaining, operating or working on any machinery is primarily responsible for:

- Personal safety, safety of other personnel, and the machinery.
- Correct utilization of the machinery in accordance with the procedures detailed in the manual.

## ABOUT THIS MANUAL

The contents of this manual include suggested best working practices and procedures. These are issued for guidance only, and they do not take precedence over the above stated individual responsibility and/or local safety regulations.

This manual and any other document supplied with the unit are the property of Johnson Controls which reserves all rights. They may not be reproduced, in whole or in part, without prior written authorization from an authorized Johnson Controls representative.

## MISUSE OF EQUIPMENT

### Suitability for Application

The unit is intended for cooling water or glycol solutions and is not suitable for purposes other than those specified in these instructions. Any use of the equipment other than its intended use, or operation of the equipment contrary to the relevant procedures may result in injury to the operator, or damage to the equipment.

The unit must not be operated outside the design parameters specified in this manual.

## Structural Support

Structural support of the unit must be provided as indicated in these instructions. Failure to provide proper support may result in injury to the operator, or damage to the equipment and/or building.

## Mechanical Strength

The unit is not designed to withstand loads or stresses from adjacent equipment, pipework or structures. Additional components must not be mounted on the unit. Any such extraneous loads may cause structural failure and may result in injury to the operator, or damage to the equipment.

## General Access

There are a number of areas and features, which may be a hazard and potentially cause injury when working on the unit unless suitable safety precautions are taken. It is important to ensure access to the unit is restricted to suitably qualified persons who are familiar with the potential hazards and precautions necessary for safe operation and maintenance of equipment containing high temperatures, pressures and voltages.

## Pressure Systems

The unit contains refrigerant vapor and liquid under pressure, release of which can be a danger and cause injury. The user should ensure that care is taken during installation, operation and maintenance to avoid damage to the pressure system. No attempt should be made to gain access to the component parts of the pressure system other than by suitably trained and qualified personnel.

## Electrical

The unit must be grounded. No installation or maintenance work should be attempted on the electrical equipment without first switching power OFF, isolating and locking-off the power supply. Servicing and maintenance on live equipment must not be attempted. No attempt should be made to gain access to the control panel or electrical enclosures during normal operation of the unit.

### Caution:

This equipment (Class A, Group 1) is designed and manufactured for use in an industrial environment, in accordance with EN 61000-6-2:2005 and EN 61000-6-4:2007 (with EN 55011:2007 limits). It is not intended to be used on a low-voltage public network which supplies domestic premises. Radio frequency interference may occur if it is used on a low voltage public network.

This equipment equipped with VSD, may generate conducted and radiated disturbances, which may interfere with or damage susceptible connected apparatus.

Generally accepted engineering standards and practices should be followed to ensure trouble-free and EMC compliant electrical installation. Installations must be supervised or completed by a competent person in accordance with EN 13313.

Special considerations depending on the application:

- Industry standard grounding or “earthing” practices for the equipment and installation.
- Use of shielded or special cables (power and/or control).
- Use of metallic conduit and/or cable trays for power and control cables connected to equipment.
- Cable segregation (in order to avoid the risk of crosstalk or cross interference to signal cables, the power cables shall be segregated from signal cables).
- Dedicated isolation transformer.
- Use of additional EMC filters.

It is the responsibility of a designated System Integrator to take proper steps assuring the Electromagnetic Compatibility of both equipment and installation as a system.

## Rotating Parts

Fan guards must be fitted at all times and not removed unless the power supply has been isolated. If ductwork is to be fitted, requiring the wire fan guards to be removed, alternative safety measures must be taken to protect against the risk of injury from rotating fans.

## Sharp Edges

The fins on the air-cooled condenser coils have sharp metal edges. Reasonable care should be taken when working in contact with the coils to avoid the risk of minor abrasions and lacerations. The use of gloves is recommended.

Frame rails, brakes, and other components may also have sharp edges. Reasonable care should be taken when working in contact with any components to avoid risk of minor abrasions and lacerations.

## Refrigerants and Oils

Refrigerants and oils used in the unit are generally non-toxic, non-flammable and non-corrosive, and pose no special safety hazards. Use of gloves and safety glasses is, however, recommended when working on the unit. The buildup of refrigerant vapor, from a leak for example, does pose a risk of asphyxiation in confined or enclosed spaces and attention should be given to good ventilation.

Use only the refrigerant specifically designated for the unit. Any other type of refrigerant may cause damage to the equipment and will void the warranty.

## High Temperature and Pressure Cleaning

High temperature and pressure cleaning methods (e.g. steam cleaning) should not be used on any part of the pressure system as this may cause operation of the pressure relief device(s). Detergents and solvents, which may cause corrosion, should also be avoided.

## Emergency Shutdown

In case of emergency, the control panel is fitted with an incoming supply circuit breaker with a red and yellow handle which can be used as the emergency stop device. When operated it removes the electrical supply to the inverter, fans, and control circuit thus shutting down the unit.

## Safety Labels



White symbol on blue background.  
For safe operation, read the Instructions first.



Black symbol on yellow background.  
Warning: This machine may start automatically without prior warning.



Black symbol on yellow background.  
Warning: Hot surface.




Black symbol on yellow background.  
Warning: Safety relief valve may discharge gas or liquid without prior warning.



Black symbol on yellow background.  
Warning: Isolate all electrical sources of supply before opening or removing the cover, as lethal voltages may exist.



Black symbol on yellow background.  
General attention symbol.



Black symbol on yellow background.  
Warning: On isolating the supply it may take up to 300 seconds for the capacitor voltage to fall below 50 volts.

## SECTION 2 - PRODUCT DESCRIPTION

YORK YVAA chillers are designed for water or glycol cooling. All units are designed to be located outside on the roof of a building or at ground level.

The units are completely assembled with all interconnecting refrigerant piping and internal wiring, ready for field installation.

Prior to delivery, the unit is pressure tested, evacuated, and fully charged with refrigerant and oil in each of the two independent refrigerant circuits. After assembly, an operational test is performed with water flowing through the evaporator to ensure that each refrigerant circuit operates correctly.

The unit structure is manufactured from heavy gauge, galvanized steel. Many external structural parts are coated with baked-on enamel powder “Champagne” paint color ((RAL 7006), (Munsel No. 9.8YR4.36/1.2)).

All exposed power wiring is routed through liquid-tight, non-metallic conduit.

### GENERAL SYSTEM DESCRIPTION

The YVAA Chiller combines the best of modern screw compressor design with the latest technology in variable speed drives. The result is superior control and efficiency in real world conditions. The VSD enables slowing the speed of the compressor to match the load on the system resulting in precise chilled liquid control, minimized sound, maximum energy efficiency, and reduced cost of ownership. The VSD also provides soft starts with no electrical inrush. The lack of heat build-up on start also enables required off time between starts to be reduced to a period of two minutes.


The YVAA Air-Cooled Screw Chiller utilizes many components, which are the same or nearly the same as a standard screw chiller of a similar size. This includes modular frame rails, condenser, fans, compressors and evaporator.

The chiller consists of two screw compressors in a corresponding number of separate refrigerant circuits, a hybrid falling film evaporator, an air-cooled condenser, receiver/flash tanks, feed valves, oil separators, and compressor mufflers.



LD15045

**FIGURE 1 - YVAA AIR-COOLED SCREW LIQUID CHILLER WITH VARIABLE SPEED DRIVE**

**FIGURE 2 - CHILLER CONTROL SYSTEM**

Oil separators utilize no moving parts. Oil cooling is accomplished by refrigerant leaving the eductor flashing in the suction line which cools the oil, motor and compressor.

An integral liquid cooled, transistorized, PWM, Variable Speed Drive (VSD) is controlled by the chiller microprocessor control panel to start/stop, select compressors to run, and select compressor speed. Displacement Power Factor is 0.95 at part or full load.

The chiller microprocessor communicates with the VSD Logic Board via a 3-wire RS-485 opto coupled data link. The VSD Logic Board runs the number of compressors required to meet the load and the compressors to the speed requested by the chiller microprocessor.

The basic system control and VSD system architecture is shown in *Figure 2 on Page 18*.

## SEMI-HERMETIC YORK TWIN-SCREW COMPRESSORS

Compressors are direct drive, semi-hermetic and rotary twin-screw type, including: muffler, temperature actuated 'off-cycle' heater, IP55 terminal board and precision machined cast iron housing.

Reliable suction gas cooled, high efficiency, accessible hermetic compressor motor, full suction gas flow through mesh screen filter, with inherent internal thermal overload protection and external current overload on all three phases.

Continuous function, microprocessor controlled, Variable Speed Drive (VSD) shall provide valve-less, smooth capacity control from 100% down to 10% of chiller capacity.

In addition, elimination of the slide valve and associated unloading components has resulted in a 50% reduction in compressor moving parts.

## EVAPORATOR

The evaporator is a shell and tube, hybrid falling film type heat exchanger. It contains a balance of flooded and falling film technology to optimize efficiency, minimize refrigerant charge, and maintain reliable control. A specifically designed distribution system provides uniform refrigerant flow for optimum performance.

## CONDENSER

The YVAA introduces micro-channel coil to the York screw compressor chiller line. The micro-channel maximizes condenser heat transfer, resulting in a smaller footprint, and reduces refrigerant charge by as much as 50%.

Each condenser coil is a single piece all aluminum construction including headers, tubes and fins to avoid galvanic corrosion due to dissimilar metals. Coils and headers are brazed as one piece. Integral sub-cooling is included. The design working pressure is 375 PSIG (25.9 barg).

Multiple, standard low sound, high efficiency, TEAO motor driven fans move air through the coils. They are dynamically and statically balanced, direct drive with corrosion-resistant glass fiber reinforced composite blades molded into low-noise, full airfoil cross sections, providing vertical air discharge from extended orifices for efficiency and low sound.

Fan motors are Totally Enclosed Air-Over (TEAO), squirrel-cage type and current protected. The direct drive motors feature double-sealed and permanently lubricated ball bearings, cutting down on maintenance cost over the life of the unit.

## REFRIGERANT CIRCUIT

An independent refrigerant circuit is provided per compressor. Each circuit uses copper refrigerant pipe formed on computer controlled bending machines to reduce the number of brazed joints resulting in a reliable and leak resistant system.

- Discharge lines are provided with a manual compressor shutoff service valve See *"Accessories and Options"* on page 21 for suction line service valve).
- The external oil separators, with no moving parts and designed for minimum oil carry-over, are mounted in the discharge line of the compressor.
- Liquid line components include: high absorption removable core filter-drier, sight glasses with moisture indicators, manual shut-off valve with charging port, orifice and electronic expansion valve.
- An economizer (flash) tank is located in each refrigerant circuit to increase the system efficiency.

## ELECTRICAL

Johnson Controls has over 25 years of experience designing variable -speed drives specifically for chiller applications. The result is an extremely reliable air-cooled chiller system that offers industry leading efficiency at real world operating conditions, valve-less compressor loading/unloading, excellent capacity control, high power factor and soft start..

Incoming single point power is standard utilizing a lockable circuit breaker, 115VAC control transformer, VSD, fan contactors, ON/OFF unit switch, microcomputer keypad and display, Chiller Control and VSD Logic boards, and relay boards.

Standard design includes IP55 rating, powder painted steel cabinet with hinged, latched, and gasket sealed outer doors equipped with wind struts for safer servicing. The panel includes a control display access door so that display and control features can be accessed without opening main cabinet doors. All exposed power wiring is routed through liquid-tight, UV-stabilized, non-metallic conduit.

## BUILDING AUTOMATION SYSTEM CAPABILITIES

The E-Link Gateway provides an economical and versatile connection between York equipment and open/standard protocols. It efficiently manages the communication protocols currently used by York equipment, exposing the data in a consistent, organized, and defined fashion. The E-Link Gateway is available as a field-installed option on YVAA. A simple switch selection allows configuration of the required equipment profile and output protocol, which reduces equipment connectivity startup time.

## MICROCOMPUTER CONTROL CENTER

The microcomputer control center (see *Figure 3 on Page 20*) provides automatic control of chiller operation including compressor start/ stop and load/unload anti-recycle timers, condenser fans, evaporator pump, evaporator heater, unit alarm contacts and run signal contacts. The microcomputer control center comes online as soon as the main power switch on the unit is switched on; immediately, the microcomputer control center will begin to check all variables with a frequency ranging from 30 seconds to almost continuous monitoring.

The microprocessor controls the unit's capacity by matching the actual leaving chilled water temperature (LCWT) to the user-defined setpoint. Factors that may cause the system's actual LCWT to fluctuate are changes in ambient temperature, loop flow rate, load, and loop volume. The control system reacts to such changes by adjusting the number of compressors that are on and the loading of each compressor in order to keep the LCWT at the setpoint.

The control system logic monitors the rate at which the LCWT is approaching the setpoint to ramp up or down compressor capacity as required. Variable frequency drive allows the compressor capacity to match the load.

### Display Data

- Leaving Chilled Liquid Temperature
- Returning Liquid Temperature
- Ambient Temperature
- Lead System
- Compressor Capacity (% of Full Load Amps)
- VSD Output Frequency / Compressor Speed
- Compressor Run Hours

- Compressor Number of Starts
- Oil Pressure and Temperature (per Compressor)
- Evaporator Pump Status
- Evaporator Heater Status
- History Data for Last Twenty Normal Shutdowns
- History Data for Last Ten Shutdown Faults

### Programmable Setpoints

- Chiller On/Off
- Chilled Liquid (Water or Glycol)
- Local or Remote Control
- Units of Measure (Imperial or SI)
- System Lead / Lag
- Remote Temperature Reset
- Remote Current Limit
- Leaving Chilled Liquid Temperature Setpoint and Range

Johnson Controls' systems or another vendor's systems can incorporate these setpoints and data outputs to give the customer a complete understanding of how the system is running through a Building Automation System.




**FIGURE 3 - VIEW OF YORK CONTROL CENTER USER INTERFACE**

**Extreme Conditions** – During extreme or unusual conditions (that is, blocked condenser coils, ambient above scheduled maximum, and so on) the chiller control system will avoid shutdown by varying capacity. By monitoring motor current and suction and discharge pressures, the chiller can maintain maximum available cooling output without shutting down.

Unit Safeties are provided for the chiller to perform auto-reset shut down for the following conditions:

- Ambient temperature above or below allowable range
- Out of range leaving chilled liquid temperature
- Under voltage
- Flow switch operation

## ACCESSORIES AND OPTIONS

All options factory mounted unless otherwise noted.

### Sound Attenuation

**Low Noise Kits** – The standard chiller configuration is equipped with low sound fans and acoustic treatments on the refrigerant lines and compressors. There are several sound attenuation options available to further reduce sound at its source thereby meeting local sound level regulations.

**SilentNight™** – Due to time of day based sound regulations in some locations it may be desirable to force the chiller to a lower sound level on demand. The SilentNight control option provides a control input to limit sound output of the chiller based on time of day. This feature is programmable at the chiller panel or can be controlled remotely via a signal (4-20mA or 0-10VDC) from a BAS system.

## FAN OPTIONS

**Ultra Quiet Fans** – The chiller is equipped with specially designed fans and motors to provide lower sound levels yet retain appropriate airflow. The result is reduced fan generated sound with minimal effect on the chiller capacity or efficiency.

**High Static Fans** – The chiller is equipped with condenser fans with higher power motors suitable for high external static pressure, up to 100 Pa (0.4 water), across condenser coils. This option should be selected if additional airflow resistance may be present due to flow restrictions such as field installed ducts, filters, sound enclosures and so on. Please contact your local JCI representative for more information.

**High Airflow Fans** – The chiller is equipped with condenser fans with airfoil type blades and high power motors providing extra airflow across coils. In some chiller configurations, this option can provide an increase in chiller capacity at high ambient. The high airflow fans are also available with variable speed control. Please contact your local JCI representative for more information.

## CONDENSER COILS

Fin and tub condenser coils of seamless, internally-enhanced, high-condensing-coefficient, corrosion resistant copper tubes are arranged in staggered rows. The tubes are mechanically expanded into aluminum fins. Integral subcooling is included. The design working pressure of the coils is 350 PSIG (24 barg).

### Condenser Coil Protection

The aluminum alloys used in the YVAA micro-channel condenser have been carefully selected and tested for high corrosion resistance. However, all metals can corrode in harsh conditions. Consider protecting coils from corrosive environments such as coastal, marine, urban and industrial.

**Post-Coated Epoxy Dipped Condenser** – Micro-channel condenser coils applied with electro-deposited and baked flexible epoxy coating that is finished with a polyurethane UV resistant top-coat suitable for highly corrosive applications.

### Protective Chiller Panels

**Wire Panels** – UV stabilized black polyvinyl chloride coated, heavy gauge, welded wire mesh guards mounted on the exterior of the full unit. Protects condenser coil faces and prevents unauthorized access to refrigerant components (compressors, pipes, evaporator, and so on), yet provides free air flow. This can cut installation cost by eliminating the need for separate, expensive fencing.

**Louvered Panels** – Louvered panels, painted the same color as the unit, enclose the unit to visually screen and protect the coils as well as preventing unauthorized access to internal components. Also available as a condenser-only option.

**Louvered/Wire Panels Combination** – Louvered panels, painted the same color as the unit, are mounted on external condenser coil faces. Heavy gauge, welded wire-mesh panels, coated to resist corrosion, are mounted around base of machine to restrict unauthorized access.

**End Hail Guard** – Louvered panels, painted with the same color as the unit, are installed on the rear of the unit (opposite end of the control panel) to protect the exposed condenser from flying debris or hail.

**V-Guard Panels** – Solid panels, painted the same color as the unit, are installed along the sides of the units to cover exposed piping within the condenser section without impacting airflow. These guard panels can be combined with End Hail Guard option for additional protection from debris.

### Evaporator Options

**38 mm insulation** – Double thickness insulation provided.

**Flange Kit** – Provides contractor with the couplings best suited to tie into the chilled water piping. All flanges are PN10.

**Connection Location** – The standard unit configuration is available with fluid inlet connections at rear (opposite control panel end) of unit. Option available for front fluid inlet on select configurations.

**Water Box Heater** – The standard unit comes with evaporator shell heaters and water pump control software. Optional water box heaters are required for storage below 0°F (-17°C). See the *Refrigerant Valve - Off option on page 100* for more information on freeze protection.

### Controls Options

**High Ambient Operation** – This provides special control logic coupled with high airflow fans to permit high ambient up to 52°C (125°F) operation. Fans are airfoil type blades with high power motors. This option may also allow for increased machine capacity, allowing the selection of a smaller chassis to meet specific capacity requirements.

**Building Automation System Interface (Temperature)** – Factory installed option to accept a 4 to 20mA or a 0 to 10VDC input to allow remote reset of the Leaving Chilled Liquid Temperature Setpoint. The setpoint can be positively offset upwards up to 22.2°C (40°F). This option is useful for ice storage or process applications or for periods where higher chilled liquid temperatures are adequate for low loads. Available alone or in combination with BAS Load Limit.

**Building Automation System Interface (Load Limit)** – Factory installed option to accept a 4 to 20mA or a 0 to 10VDC input to allow remote reset of the Load Limit Setpoint. The setpoint can limit system demand from 30-100%. Available alone or in combination with BAS Temperature Reset.

**E-Link** – The optional E-Link gateway provides communication between the equipment and Building Automation Systems, including BACnet (MS/TP), Modbus, LON and N2.

**Thermal Storage** – Provides special control logic and modifications to produce leaving chilled brine temperatures below 4.4°C (40°F) primarily at times of low ambient temperatures (night time). Option can be used to produce ice to supplement cooling and significantly decrease energy costs. The capability of the chiller is enhanced by using both ice and chilled water simultaneously during times of peak cooling needs.

### General Options

**Flow Switch Accessory** – Vapor proof SPDT, NEMA 3R switch, 10.3 barg (150 psig) DWP, -29°C to 121°C (-20°F to 250°F) with 1" NPT (IPS) connection for upright mounting in horizontal pipe. This flow switch or equivalent must be furnished with each unit. **Field mounted.**

**Differential Pressure Switch** – This 0.2-3 barg (3-45 psig) range switch, with 1/4" NPTE pressure connections, is an alternative to the paddle-type flow switch. **Field mounted.**

**Service Isolation Valve** – Service suction isolation valve added to unit for each refrigerant circuit.

**Dual Pressure Relief Valve** – Two safety relief valves are mounted in parallel; one is always operational to assist in valve replacement during maintenance.

**Terminal Block [not available for CE marked units]** Terminal Block connections shall be provided at the point of incoming single point connection for field connection and interconnecting wiring to the compressors. Separate external protection must be supplied, by others, in the incoming power wiring, which must comply with local codes.

**Circuit Breaker** – A unit-mounted circuit breaker with external lockable handle will be supplied to isolate the single point power voltage for servicing. The circuit breaker is sized to provide motor branch circuit protection, short circuit protection and ground fault protection for the motor branch-circuit conductors, the motor control apparatus and the motors.

**Non-Fused Disconnect Switch** – Unit-mounted disconnect switch with external lockable handle can be supplied to isolate the unit power voltage for servicing. Separate external fusing must be supplied by the power wiring, which must comply with local codes.

## Vibration Isolation

**Elastomeric Isolation** – This option is recommended for normal installations. It provides very good performance in most applications for the least cost. **Field mounted.**

**25 mm (1") Spring Isolators** – Spring and cage type isolators for mounting under the unit base rails are available to support unit. They are level adjustable. 25 mm (1") nominal deflection may vary slightly by application. **Field mounted.**

**50 mm (2") Restrained Spring Isolators** – Restrained Spring-Flex Mounting isolators incorporate a rugged welded steel housing with vertical and horizontal limit stops. Housings designed to withstand a minimum 1.0g accelerated force in all directions up to 51 mm (2"). The deflection may vary slightly by application. They are level adjustable. **Field mounted.**

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 3 - RIGGING, HANDLING AND STORAGE



# WARNING

**Failure to follow these instructions could result in death, serious injury or equipment damage.**

**Follow all warnings and instructions in the unit's Manual(s).**

|                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                                                                        |                                                                                                                                                                                    |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>EN</b> Installation Instructions for the technician / fitter<br><b>PL</b> Instrukcja instalacji dla technika / monter<br><b>SV</b> Installationsguide for installer / montör<br><b>CS</b> Pokyny k instalaci pro techniky a montéry | <b>IT</b> Istruzioni d'installazione per il personale specializzato<br><b>NL</b> Installatiehandleiding voor de vakman / monteur<br><b>DE</b> Installationsanleitung für die Fachkraft / Monteur<br><b>ES</b> Instrucciones de instalación para el técnico / contratista especializado | <b>JA</b> 一般仕様・取扱説明書<br><b>FR</b> Manuel d'installation pour le spécialiste / monteur<br><b>RU</b> Инструкция по установке для техника/монтажника<br><b>ZH</b> 适用于技术人员与安装人员的 安装说明书 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|



1. Follow all applicable regulations and safety practices during rigging and lifting.
2. Prepare and follow written rigging and lifting plan.
3. Rigging must be directed by trained professional rigger.
4. Spreader bars must be used and be long enough to prevent rigging from contacting unit.
5. Use all and only designated lift points according to units manual(s).
6. Locate center of gravity through trial lifts to account for possible variations in unit configuration.
7. Use rigging and lifting techniques that keep unit stable and level.
8. Keep clear of unit when lifted.

035-23962-000 REV A

LD19197



***Rigging and lifting should only be done by a professional rigger in accordance with a written rigging and lifting plan. The most appropriate rigging and lifting method will depend on job specific factors, such as the rigging equipment available and site needs. Therefore, a professional rigger must determine the rigging and lifting method to be used, and it is beyond the scope of this manual to specify rigging and lifting details.***

### LIFTING WEIGHTS

Refer to the unit nameplate for unit shipping weight. Note that weight may vary depending on unit configuration at the time of lifting. See *Table 5 on page 64* or *Table 6 on page 68* for further information regarding shipping and operating weights.

### DELIVERY AND STORAGE

To ensure consistent quality and maximum reliability, all units are tested and inspected before leaving the factory. Units are shipped completely assembled and containing refrigerant under pressure. Units are shipped without export crating unless crating has been specified on the Sales Order.

If the unit is to be put into storage, prior to installation, the following precautions should be observed:

- The chiller must be “blocked” so that the base is not permitted to sag or bow.
- Ensure that all openings, such as water connections, are securely capped.
- Do not store where exposed to high ambient air temperatures that may exceed relief valve settings. Refer to *Long-Term Storage Requirement - Field Preparation (Form 50.20-NM7)*.
- The condensers should be covered to protect the coils and fins from potential damage and corrosion, particularly where building work is in progress.
- The unit should be stored in a location where there is minimal activity in order to limit the risk of accidental physical damage.
- To prevent inadvertent operation of the pressure relief devices the unit must not be steam cleaned.
- It is recommended that the unit is periodically inspected during storage.

## INSPECTION

Remove any transit packing and inspect the unit to ensure that all components have been delivered and that no damage has occurred during transit. If any damage is evident, it should be noted on the carrier's freight bill and a claim entered in accordance with the instructions given on the advice note.

Major damage must be reported immediately to your local Johnson Controls representative.

## MOVING THE CHILLER

Prior to moving the unit, ensure that the installation site is suitable for installing the unit and is easily capable of supporting the weight of the unit and all associated services.



***The unit must only be lifted by the base frame at the points provided. Never move the unit on rollers, or lift the unit using a forklift truck.***

Care should be taken to avoid damaging the condenser cooling fins when moving the unit.

## UNIT REMOVAL FROM SHIPPING CONTAINER


1. Place a clevis pin into the holes provided at the end of each base rail on the unit. Attach chains or nylon straps through the clevis pins and hook onto a suitable lift truck for pulling the unit out of the container.
2. Slowly place tension on the chains or straps until the unit begins to move and then slowly pull the unit from the container. Be sure to pull straight so the sides do not scrape the container.
3. Place a lifting fixture on the forks of the lift truck and reattach the chain or strap. Slightly lift the front of the unit to remove some weight from the floor of the container. Continue pulling the unit with an operator on each side to guide the lift truck operator.
4. Pull the unit until the lifting locations are outside of the container. Place 4 X 4 blocks of wood under the base rails of the unit. Gently rest the unit on the blocks and remove the chains and lift truck.
5. Attach lifting rigging from the crane and slowly complete the removal from the container then lift up and away.



LD19197a

## LIFTING USING LUGS

Units are provided with lifting holes in the base frame which accept the accessory lifting lug set as shown in the figure below. The lugs (RH and LH) should be inserted into the respective holes in the base frame and turned so that the spring loaded pin engages into the hole and the flanges on the lug lock behind the hole. The lugs should be attached to the cables/chains using shackles or safety hooks.




LD19197b

## LIFTING USING SHACKLES

The shackles should be inserted into the respective holes in the base frame and secured from the inside.

- Use spreader bars to avoid lifting chains hitting the chiller. Various methods of spreader bar arrangements may be used, keeping in mind the intent is to keep the unit stable and to keep the chains from hitting the chiller and causing damage.
- Never lift the chiller using a forklift or by hooking to the top rails. Use only the lifting holes provided.
- Lifting Instructions are placed on a label on the chiller and on the shipping bag.

THIS PAGE INTENTIONALLY LEFT BLANK

**TABLE 1 - UNIT RIGGING**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |   |   |   |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|---|---|---|
| FRAME      | COND | EVAP |                       |        | A             | B    | C    | D    | E    | F | G | H |
| 015        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 116  | 192  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1512 | 2937 | 4866 |      |   |   |   |
| 016        | 5    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 214  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3482 | 5435 |      |   |   |   |
| 017        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 144  | 197  | 260  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3654 | 5012 | 6593 |   |   |   |
| 018        | 3    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 220  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3636 | 5598 |      |   |   |   |
| 019        | 5    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 227  | 272  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3636 | 5761 | 6920 |   |   |   |
| 019        | 8    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 302  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3484 | 5455 | 7670 |   |   |   |
| 020        | 0    | C    | Rigging Hole Location | inches | 18            | 60   | 131  | 214  |      |   |   |   |
|            |      |      |                       | mm.    | 464           | 1518 | 3332 | 5430 |      |   |   |   |
| 021        | 3    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 227  | 272  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3637 | 5761 | 6920 |   |   |   |
| 021        | 5    | C    | Rigging Hole Location | inches | 12            | 73   | 144  | 197  | 260  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3654 | 5012 | 6593 |   |   |   |
| 021        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 324  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 8218 |   |   |   |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.





**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |   |   |   |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|---|---|---|
| FRAME      | COND | EVAP |                       |        | I             | J    | K    | L    | M    | N | O | P |
| 015        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 116  | 192  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1511 | 2937 | 4866 |      |   |   |   |
| 016        | 5    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 214  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3485 | 5435 |      |   |   |   |
| 017        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 144  | 197  | 260  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3654 | 5012 | 6593 |   |   |   |
| 018        | 3    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 220  |      |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3636 | 5598 |      |   |   |   |
| 019        | 5    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 227  | 272  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3636 | 5761 | 6920 |   |   |   |
| 019        | 8    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 302  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3484 | 5455 | 7670 |   |   |   |
| 020        | 0    | C    | Rigging Hole Location | inches | 60            | 131  | 214  |      |      |   |   |   |
|            |      |      |                       | mm     | 1518          | 3332 | 5430 |      |      |   |   |   |
| 021        | 3    | A    | Rigging Hole Location | inches | 18            | 60   | 143  | 227  | 272  |   |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3637 | 5761 | 6920 |   |   |   |
| 021        | 5    | C    | Rigging Hole Location | inches | 12            | 73   | 144  | 197  | 260  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3654 | 5012 | 6593 |   |   |   |
| 021        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 324  |   |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 8218 |   |   |   |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.

**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |      |   |   |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|------|---|---|
| FRAME      | COND | EVAP |                       |        | A             | B    | C    | D    | E    | F    | G | H |
| 023        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 272  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3485 | 5456 | 6919 |      |   |   |
| 024        | 5    | C    | Rigging Hole Location | inches | 18            | 60   | 149  | 240  | 324  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3789 | 6088 | 8218 |      |   |   |
| 024        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 8825 |      |   |   |
| 026        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 302  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3484 | 5455 | 7670 |      |   |   |
| 027        | 3    | D    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 264  | 324  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6717 | 8217 |   |   |
| 027        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 264  | 324  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6717 | 8218 |   |   |
| 027        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 347  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6169 | 8825 |   |   |
| 029        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 179  | 290  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4551 | 7358 | 8825 |      |   |   |
| 030        | 3    | C    | Rigging Hole Location | inches | 12            | 73   | 161  | 254  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4092 | 6443 | 8825 |      |   |   |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.





**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |      |   |   |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|------|---|---|
| FRAME      | COND | EVAP |                       |        | I             | J    | K    | L    | M    | N    | O | P |
| 023        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 272  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3485 | 5456 | 6919 |      |   |   |
| 024        | 5    | C    | Rigging Hole Location | inches | 18            | 60   | 149  | 240  | 324  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3789 | 6088 | 8218 |      |   |   |
| 024        | 8    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 8825 |      |   |   |
| 026        | 3    | B    | Rigging Hole Location | inches | 18            | 60   | 137  | 215  | 302  |      |   |   |
|            |      |      |                       | mm     | 464           | 1533 | 3484 | 5455 | 7670 |      |   |   |
| 027        | 3    | D    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 264  | 324  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6717 | 8218 |   |   |
| 027        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 264  | 324  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6717 | 8218 |   |   |
| 027        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 347  |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6169 | 8825 |   |   |
| 029        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 179  | 290  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4551 | 7358 | 8825 |      |   |   |
| 030        | 3    | C    | Rigging Hole Location | inches | 12            | 73   | 161  | 254  | 347  |      |   |   |
|            |      |      |                       | mm     | 314           | 1845 | 4092 | 6443 | 8825 |      |   |   |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.

**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |       |       |       |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|-------|-------|-------|
| FRAME      | COND | EVAP |                       |        | A             | B    | C    | D    | E    | F     | G     | H     |
| 030        | 5    | C    | Rigging Hole Location | inches | 12            | 73   | 161  | 254  | 306  | 391   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4092 | 6443 | 7763 | 9941  |       |       |
| 030        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 179  | 243  | 296   | 391   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3072 | 4549 | 6169 | 7508  | 9942  |       |
| 031        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 179  | 243  | 353   | 435   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3072 | 4549 | 6169 | 8962  | 11059 |       |
| 032        | 3    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 347   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6169 | 8825  |       |       |
| 033        | 3    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 306  | 391   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 7765 | 9942  |       |       |
| 034        | 3    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 296   | 391   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4602 | 6170 | 7511  | 9942  |       |
| 034        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 353   | 435   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4602 | 6170 | 8961  | 11059 |       |
| 036        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 392   | 434   | 501   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 9957  | 11024 | 12725 |
| 037        | 3    | F    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 11059 |       |       |
| 037        | 5    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 11059 |       |       |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.





**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |       |       |       |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|-------|-------|-------|
| FRAME      | COND | EVAP |                       |        | I             | J    | K    | L    | M    | N     | O     | P     |
| 030        | 5    | C    | Rigging Hole Location | inches | 12            | 73   | 161  | 254  | 306  | 391   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4092 | 6443 | 7763 | 9941  |       |       |
| 030        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 179  | 243  | 296   | 391   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3072 | 4549 | 6169 | 7508  | 9942  |       |
| 031        | 8    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 179  | 243  | 353   | 435   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3072 | 4549 | 6169 | 8962  | 11059 |       |
| 032        | 3    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 347   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4601 | 6169 | 347   |       |       |
| 033        | 3    | C    | Rigging Hole Location | inches | 12            | 73   | 163  | 254  | 306  | 391   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4144 | 6443 | 7765 | 9942  |       |       |
| 034        | 3    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 296   | 391   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4602 | 6170 | 7511  | 9942  |       |
| 034        | 5    | E    | Rigging Hole Location | inches | 12            | 73   | 121  | 181  | 243  | 353   | 435   |       |
|            |      |      |                       | mm     | 314           | 1845 | 3073 | 4602 | 6170 | 8961  | 11059 |       |
| 036        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 392   | 434   | 501   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 9957  | 11024 | 12725 |
| 037        | 3    | F    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 11059 |       |       |
| 037        | 5    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 11059 |       |       |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.

**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |       |       |       |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|-------|-------|-------|
| FRAME      | COND | EVAP |                       |        | A             | B    | C    | D    | E    | F     | G     | H     |
| 039        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12135 | 13835 |
| 041        | 3    | H    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4601 | 6039 | 7662 | 11059 |       |       |
| 042        | 5    | H    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12135 | 13835 |
| 042        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12546 | 14541 |
| 044        | 3    | G    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7662 | 11059 | 12135 | 13835 |
| 047        | 5    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12546 | 14541 |
| 048        | 3    | G    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12546 | 14529 |
| 049        | 0    | K    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   |       |       |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 |       |       |
| 050        | 0    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   |       | 572   |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 |       | 14529 |
| 052        | 3    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 | 12548 | 14529 |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.




**TABLE 1 - UNIT RIGGING (CONT'D)**

| YVAA MODEL |      |      | DESCRIPTION           | UNITS  | RIGGING HOLES |      |      |      |      |       |       |       |
|------------|------|------|-----------------------|--------|---------------|------|------|------|------|-------|-------|-------|
| FRAME      | COND | EVAP |                       |        | I             | J    | K    | L    | M    | N     | O     | P     |
| 039        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12135 | 13835 |
| 041        | 3    | H    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   |       |       |
|            |      |      |                       | mm     | 314           | 1845 | 4601 | 6039 | 7662 | 11059 |       |       |
| 042        | 5    | H    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12135 | 13835 |
| 042        | 8    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 302  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12546 | 14541 |
| 044        | 3    | G    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 478   | 545   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12135 | 13835 |
| 047        | 5    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 314           | 1845 | 4602 | 6039 | 7358 | 11059 | 12546 | 14541 |
| 048        | 3    | G    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   |       |       |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 |       |       |
| 049        | 0    | K    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   |       |       |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 |       |       |
| 050        | 0    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   |       |       |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 |       |       |
| 052        | 3    | J    | Rigging Hole Location | inches | 12            | 73   | 181  | 238  | 290  | 435   | 494   | 572   |
|            |      |      |                       | mm     | 305           | 1854 | 4597 | 6045 | 7366 | 11049 | 12548 | 14529 |

**NOTE:** Rigging and lifting the unit must be done safely by a professional rigger as discussed in this section. The rigger should locate the center of gravity through trial lifts to account for possible variations in unit configuration. Contact your nearest Johnson Controls Sales Office for weight data.

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 4 - INSTALLATION

### LOCATION REQUIREMENTS

For optimum performance and trouble-free service, it is essential that the installation site meet the location and space requirements for the model being installed.

It is important to ensure that the minimum service access space is maintained for cleaning and maintenance purposes.

### OUTDOOR INSTALLATIONS

The units are designed for outdoor installation and can be installed at ground level on a suitable flat level foundation easily capable of supporting the weight of the unit, or on a suitable rooftop location. In both cases an adequate supply of air is required. Avoid locations where the sound output and air discharge from the unit may be objectionable.

The location should be selected for minimum sun exposure and away from boiler flues and other sources of airborne chemicals that could attack the condenser coils and steel parts of the unit.

If located in an area accessible to unauthorized persons, steps must be taken to prevent access to the unit by means of a protective fence. This will help to prevent the possibility of vandalism, accidental damage, or possible harm caused by unauthorized removal of protective guards or opening panels to expose rotating or high voltage components.

For ground level locations, the unit must be installed on a suitable flat and level concrete base that extends to fully support the two side channels of the unit base frame. A one-piece concrete slab, with footings extending below the frost line is recommended. To avoid noise and vibration transmission, the unit should not be secured to the building foundation.

On rooftop locations, choose a place with adequate structural strength to safely support the entire operating weight of the unit and service personnel. The unit can be mounted on a concrete slab, similar to ground floor locations, or on steel channels of suitable strength. The channels should be spaced with the same centers as the unit side and front base rails. This will allow vibration isolators to be fitted if required. Isolators are recommended for rooftop locations.

Mounting holes (5/8") are provided in the base rails for bolting the unit to its foundation. See *Table 10 on Page 84* for location of the mounting holes.

Any ductwork or attenuators fitted to the unit must not have a total static pressure resistance, at full unit airflow, exceeding the capability of the fans installed in the unit.

The condenser fans are propeller-type and are not recommended for use with ductwork, filters or other impediments to airflow in the condenser air stream.

When it is desirable to surround the unit(s) in addition to the optional louver package selected, it is recommended that the screening passes the required chiller CFM without exceeding 0.1 w.g. (24.9084 pa) external static pressure.

Protection against corrosive environments is available by ordering the units with cured epoxy-coating on the microchannel condenser coil. Epoxy-coated coils should be used with any units being installed at the seashore where salt spray/mist may hit the units, or where acid rain is prevalent.

On installations where winter operation is intended and snow accumulations are expected, additional elevation must be provided to insure normal condenser air flow.

Avoid locations near windows or structures where normal operating sounds may be objectionable.

### LOCATION CLEARANCES

Adequate clearances around the unit(s) are required for the unrestricted airflow for the air-cooled condenser coils and to prevent re-circulation of warm discharge air back onto the coils. If clearances given are not maintained, airflow restriction or re-circulation will cause a loss of unit performance, an increase in power consumption, and may cause the unit to malfunction. Consideration should also be given to the possibility of down drafts, caused by adjacent buildings, which may cause re-circulation or uneven unit airflow.

For locations where significant cross winds are expected, such as exposed roof tops, an enclosure of solid or louver type is recommended to prevent wind turbulence interfering with the unit airflow.

When units are installed in an enclosure, the enclosure height should not exceed the height of the unit on more than one side. If the enclosure is of louvered construction, the same requirement of static pressure loss applies as for ducts and attenuators stated above.

**Recommended Minimum Clearances**

Recommended clearances for the YVAA units are:

- Side to wall – 6' (1.8 m)
- Rear to wall – 6' (1.8 m)
- Control panel end to wall – 4' (1.2 m)
- Top – no obstructions whatsoever
- Distance between adjacent units – 10' (3 m)




**FIGURE 4 - ACCEPTABLE MINIMUM CLEARANCES AROUND/BETWEEN UNIT(S)**



*Clearance dimensions provided in Figure 4 on page 38 and Table 2 on Page 38 are necessary to maintain good airflow and ensure correct unit operation. It is also necessary to consider access requirements for safe operation and maintenance of the unit and power and control panels. Local health and safety regulations, or practical considerations for service replacement of large components, may require larger clearances than those recommended.*

**TABLE 2 - MINIMUM EVAPORATOR TUBE REMOVAL CLEARANCE**

| MODEL YVAA |      |      | TUBE REMOVAL CLEARANCE DIMENSIONS |     |     |     |     |      |
|------------|------|------|-----------------------------------|-----|-----|-----|-----|------|
|            |      |      | A                                 |     | B   |     | C   |      |
| FRAME      | COND | EVAP | IN.                               | MM  | IN. | MM  | IN. | MM   |
| 015        | 3    | B    | 26                                | 663 | 36  | 914 | 132 | 3353 |
| 016        | 5    | B    | 26                                | 663 | 36  | 914 | 132 | 3353 |
| 017        | 8    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 018        | 3    | A    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 019        | 5    | A    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 019        | 8    | B    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 020        | 0    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 021        | 3    | A    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 021        | 5    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 021        | 8    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 023        | 3    | B    | 26                                | 663 | 36  | 914 | 132 | 3353 |
| 024        | 5    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 024        | 8    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 026        | 3    | B    | 26                                | 663 | 36  | 914 | 132 | 3353 |
| 027        | 0    | D    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 027        | 3    | D    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 027        | 5    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 027        | 8    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 029        | 5    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 030        | 3    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 030        | 5    | E    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 030        | 8    | E    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 031        | 8    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 032        | 3    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 033        | 3    | C    | 26                                | 663 | 36  | 914 | 156 | 3962 |
| 034        | 3    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 034        | 5    | E    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 036        | 8    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 037        | 3    | F    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 037        | 5    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 039        | 8    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 041        | 3    | H    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 042        | 5    | H    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 042        | 8    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 044        | 3    | G    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 047        | 5    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 048        | 3    | G    | 26                                | 663 | 36  | 914 | 144 | 3658 |
| 049        | 0    | K    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 050        | 0    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |
| 052        | 3    | J    | 26                                | 663 | 36  | 914 | 192 | 4877 |

## VIBRATION ISOLATORS

Optional sets of vibration isolators can be supplied loose with each unit.

Using the Isolator tables shipped with the unit in the information pack. Identify each mount and its correct location on the unit.

### Installation

Place each mount in its correct position and lower the unit carefully onto the mounts ensuring the mount engages in the mounting holes in the unit base frame.

On adjustable mounts, transfer the unit weight evenly to the springs by turning the mount adjusting nuts (located just below the top plate of the mount) counter-clockwise to raise and clockwise to lower. This should be done two turns at a time until the top plates of all mounts are between 1/4" (6 mm) and 1/2" (12 mm) clear of top of their housing and the unit base is level.

## SHIPPING BRACES

The chiller's modular design does not require shipping braces.


## CHILLED LIQUID PIPING

### General Requirements


The following piping recommendations are intended to ensure satisfactory operation of the unit(s). Failure to follow these recommendations could cause damage to the unit, or loss of performance, and may invalidate the warranty.



***The maximum flow rate and pressure drop for the evaporator must not be exceeded at any time. See "SECTION 5 - TECHNICAL DATA" on page 63 for details.***



***The Maximum acceptable Chilled Liquid pressure in the inlet of Evaporator is same as the statement in "Maximum Tube Side Pressure" of Pressure Vessel Name Plate for YVAA and YVFA with Falling Film Evaporator.***



***The liquid must enter the evaporator at the inlet connection. The standard inlet connection for the evaporator is opposite the control panel end of the evaporator. A flow switch must be installed in the customer piping at the outlet of the evaporator and wired back to the control panel using shielded cable.***


There should be a straight run of piping of at least 5 pipe diameters on either side. The flow switch should be wired to Terminals 2 and 13 on the 1TB terminal block. A flow switch is required to prevent damage to the evaporator caused by the unit operating without adequate liquid flow.

The flow switch used must have gold plated contacts for low voltage/current operation. Paddle type flow switches suitable for 10 bar (150 PSIG) working pressure and having a 1" N.P.T. connection can be obtained from Johnson Controls as an accessory for the unit. Alternatively, a differential pressure switch fitted across an orifice plate may be used, preferably of the high/low limit type.

The chilled liquid pump(s) installed in the piping system(s) should discharge directly into the unit evaporator section of the system. The pump(s) may be controlled by the chiller controls or external to the unit.

Pipework and fittings must be separately supported to prevent any loading on the evaporator. Flexible connections are recommended which will also minimize transmission of vibrations to the building. Flexible connections must be used if the unit is mounted on anti-vibration mounts, as some movement of the unit can be expected in normal operation.

Piping and fittings immediately next to the evaporator should be readily de-mountable to enable cleaning before operation, and to facilitate visual inspection of the exchanger nozzles.



***The evaporator must be protected by a strainer, preferably of 16 mesh, fitted as close as possible to the liquid inlet connection, and provided with a means of local isolation.***

The evaporator must not be exposed to flushing velocities or debris released during flushing. It is recommended that a suitably sized bypass and valve arrangement is installed to allow flushing of the piping system. The bypass can be used during maintenance to isolate the heat exchanger without disrupting flow to other units.


Thermometer and pressure gauge connections should be provided on the inlet and outlet connections of each evaporator. Gauges and thermometers are not provided with the unit and are to be furnished by others.

Drain and air vent connections should be provided at all low and high points in the piping to permit drainage of the system and to vent any air in the pipes. Liquid system lines at risk of freezing, due to low ambient temperatures should be protected using insulation and heater tape and/or a suitable glycol solution.

The liquid pump(s) may also be used to ensure liquid is circulated when the ambient temperature approaches freezing point.

Insulation should also be installed around the evaporator nozzles. Heater tape of 21 Watts per meter under the insulation is recommended, supplied independently and controlled by an ambient temperature thermostat set to switch ON at approximately 2.2°C (4°F), above the freezing temperature of the chilled liquid.

Evaporator heater mats are installed under the insulation, and are powered from the chiller's control panel. In sub-freezing conditions, unless the evaporator has been drained or an appropriate water-to-glycol concentration is maintained, high voltage power to the chiller must be kept on to ensure the heater mats assist in evaporator freeze protection. If there is a potential for power loss, Johnson Controls recommends that the evaporator is drained or that water in the chilled water circuit be replaced with an appropriate water-to-glycol concentration.




**Any debris left in the water piping between the strainer and evaporator could cause serious damage to the tubes in the evaporator and must be avoided. Be sure the piping is clean before connecting it to the evaporator. Keep evaporator nozzles and chilled liquid piping capped prior to installation to assure construction debris is not allowed to enter.**




**The installer/user must also ensure that the quality of the water in circulation is adequate, without any dissolved gases, which can cause oxidation of steel or copper parts within the evaporator.**

## EVAPORATOR PRESSURE DROP

The evaporator is designed in accordance with ARI-590-92 which allows for an increase in pressure drop of up to 15% above the design value shown in the Pressure Drop tables shown in Figure 5 on Page 40 and Figure 6 on Page 41. Debris in the water may also cause additional pressure drop.



**Excessive flow above the maximum GPM will damage the evaporator.**



**To determine evaporator/frame size See Table 12 on page 109 to find the applicable evaporator line.**




**FIGURE 5 - THREE PASS WATER PRESSURE DROP, ENGLISH UNITS**




**FIGURE 6 - TWO PASS WATER PRESSURE DROP, SI UNITS**

## WATER TREATMENT

The unit performance provided in the Design Guide is based on a fouling factor of 0.018m<sup>2</sup>/hr °C/kW (0.0001 ft<sup>2</sup>hr°F/Btu). Dirt, scale, grease and certain types of water treatment will adversely affect the heat exchanger surfaces and therefore the unit performance. Foreign matter in the water system(s) can increase the heat exchanger pressure drop, reducing the flow rate and causing potential damage to the heat exchanger tubes.

Aerated, brackish or salt water is not recommended for use in the water system(s). Johnson Controls recommends that a water treatment specialist should be consulted to determine whether the proposed water composition will adversely affect the evaporator materials of carbon steel and copper. The pH value of the water flowing through the evaporator must be kept in a range between 7 and 8.5.

## PIPEWORK ARRANGEMENT

The following is a suggested piping arrangement for single unit installations.




**FIGURE 7 - PIPEWORK ARRANGEMENT**

## MINIMUM WATER VOLUME

It is good practice to include as much water volume as possible in a chilled water loop. This increases the thermal mass and “Flywheel” effect within the system (that is, the more; the better) which in turn promotes stable water temperature control and increases reliability by reducing compressor cycling.

For air conditioning applications, a minimum of 3 gallons/ton is required, with a preferred gallon/ton ratio to be within the 5 to 8 range. For process applications, a minimum of 6 gallons/ton ratio is required with preference towards a range of 7 to 11. Install a tank or increase pipe sizes to provide sufficient water volume.

## LEAVING WATER TEMPERATURE OUT OF RANGE

The YVAA chiller line has a maximum leaving water temperature of 15.6°C (60°F). Where process applications require a chilled water temperature higher than what the chiller provides, a simple piping change can remove the problem. By using a mixture of chiller-cooled water and returning process water, the chilled water entering the process can be held at the desired temperature. A tank can also be used to meet high leaving water temperature requirements.

Each YVAA evaporator has a minimum and maximum flow rate. Some process applications require a flow rate that is out of range for the evaporator. In those applications, a piping change can remove the problem.




**FIGURE 8 - LEAVING WATER TEMPERATURE OUT OF RANGE SUGGESTED LAYOUT**

In applications where the required flow rate is less than the evaporator’s minimum allowable, the chilled water can be recirculated to the chiller.




**FIGURE 9 - SUGGESTED LAYOUT FOR APPLICATIONS WITH A FLOW RATE LESS THAN THE EVAPORATOR MINIMUM ALLOWABLE FLOW RATE**

In applications where the required flow rate is greater than the evaporator’s maximum allowable, the chilled water can be recirculated to the load.




**FIGURE 10 - SUGGESTED LAYOUT FOR APPLICATIONS WITH A FLOW RATE GREATER THAN THE EVAPORATOR MAXIMUM ALLOWABLE FLOW RATE**

## THERMAL STORAGE

Thermal storage is the practice of storing cooling energy during a period of little or no load and/or low energy costs for use during periods of high load and/or energy costs. Conventional cooling systems produce cooling when it is needed which is commonly during times of peak demand. Thermal storage allows generation of cooling capacity to occur during off-peak periods and store that capacity to meet future cooling requirements. Using thermal storage can result in smaller equipment sizes, thereby reducing capital cost, and also can result in significant energy cost savings.

The YVAA has special control logic to be able to produce chilled leaving brine temperatures below 4.4°C (40°F) so as to supply a storage tank with chilled liquid during times of low demand. YVAA chillers selected for thermal storage operation can also be selected to efficiently provide chilled fluid at nominal cooling loads.

## VARIABLE PRIMARY FLOW


Johnson Controls recommends a maximum 10% per minute flow rate of change, based on design flow, for variable primary flow applications. Provide 8 to 10 gallons per chiller ton (8.6 to 10.8 liter per cooling KW) system water volume. Insufficient system volume and rapid flow changes can cause control problems or can even cause chiller shutdowns. There are many other design issues to evaluate with variable primary flow systems. Consult your Johnson Controls Sales Office for more information about successfully applying YVAA chillers.

## CONNECTION TYPES AND SIZES

For connection sizes relevant to individual models see *SECTION 5 - TECHNICAL DATA*.

## EVAPORATOR CONNECTIONS

Standard chilled liquid connections on evaporators are of the Victaulic Groove type for ASME and PED marked units and Flange type for GB marked units (see *Figure 12 on page 45* for flange dimensions on GB marked vessels).



LD10494

**FIGURE 11 - VICTAULIC GROOVE**

**TABLE 3 - EVAPORATOR CONNECTIONS DIMENSIONS**

| FRAME | COND. | EVAP. | VICTAULIC<br>CONNECTIONS<br>SIZE | NOMINAL<br>DIAMETER | FLANGE DIMENSIONS (GB ONLY) IN MM* |    |     |       |    |     |   | QTY |
|-------|-------|-------|----------------------------------|---------------------|------------------------------------|----|-----|-------|----|-----|---|-----|
|       |       |       |                                  |                     | B                                  | C  | D   | K     | L  | D   | N |     |
| 015   | 3     | B     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 016   | 5     | B     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 017   | 8     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 018   | 3     | A     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 019   | 5     | A     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 019   | 8     | B     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 020   | 0     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 021   | 3     | A     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 021   | 5     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 021   | 8     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 023   | 3     | B     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 024   | 5     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 024   | 8     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 026   | 3     | B     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 027   | 0     | D     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 027   | 3     | D     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 027   | 5     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 027   | 8     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 029   | 5     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 030   | 3     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 030   | 5     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 030   | 8     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 031   | 8     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 032   | 3     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 033   | 3     | C     | 6"                               | DN150               | 170.5                              | 27 | 280 | 241.5 | 22 | 216 | 8 | 2   |
| 034   | 3     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 034   | 5     | E     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 036   | 8     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 037   | 3     | F     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 037   | 5     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 039   | 8     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 041   | 3     | H     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 042   | 5     | H     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 042   | 8     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 044   | 3     | G     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 047   | 5     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 048   | 3     | G     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 049   | 0     | K     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 050   | 0     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |
| 052   | 3     | J     | 8"                               | DN200               | 221.5                              | 27 | 345 | 298.5 | 22 | 270 | 8 | 2   |

\* Reference Figure 12 on Page 45 for flange dimensions.




**FIGURE 12 - FLANGE FOR GB VESSELS**

### Option Flanges

One of two types of flanges may be fitted depending on the customer or local pressure vessel code requirements. These are Victaulic-Adapter flanges, normally supplied loose, or weld flanges, which may be supplied loose or ready-fitted. Victaulic-Adapter and weld flange dimensions are to ISO 7005 - NP10.




**FIGURE 13 - FLANGE ATTACHMENT**

### REFRIGERANT RELIEF VALVE PIPING

The evaporator is protected against internal refrigerant overpressure by refrigerant relief valves. A pressure relief valve is mounted on each of the main refrigerant lines connecting the evaporator to the compressors.

A piece of pipe is fitted to each valve and directed so that when the valve is activated the release of high pressure gas and liquid cannot be a danger or cause injury. For indoor installations (not recommended), pressure relief valves should be piped to the exterior of the building.

The size of any piping attached to a relief valve must be of sufficient diameter so as not to cause resistance to the operation of the valve. Unless otherwise specified by local regulations. Internal diameter depends on the length of pipe required and is given by the following formula:

$$D^5 = 1.447 \times L$$

Where:

- D = minimum pipe internal diameter in cm
- L = length of pipe in meters

If relief piping is common to more than one valve, its cross-sectional area must be at least the total required by each valve. Valve types should not be mixed on a common pipe. Precautions should be taken to ensure the outlets of relief valves or relief valve vent pipes remain clear of obstructions at all times.

### ELECTRICAL CONNECTION

The following connection recommendations are intended to ensure safe and satisfactory operation of the unit. Failure to follow these recommendations could cause harm to persons or damage the unit, and may invalidate the warranty.



**No additional controls (relays, and so on) should be mounted in the control panel. Power and control wiring not connected to the control panel should not be run through the control panel. If these precautions are not followed it could lead to a risk of electrocution. In addition, electrical noise could cause malfunctions or damage the unit and its controls.**



***After power wiring connection, do not switch on mains power to the unit. Some internal components are live when the mains are switched on and this must only be done by “Authorized” persons familiar with starting, operating, and troubleshooting this type of equipment.***

## POWER WIRING

All electrical wiring should be carried out in accordance with local regulations. Route properly sized cables to cable entries on the unit.

In accordance with local codes, NEC codes, U.L. and C.E. standards, it is the responsibility of the user to install over current protection devices between the supply conductors and the power supply terminals on the unit.

To ensure that no eddy currents are set up in the power panel, the cables forming the 3-phase power supply must enter via the same cable entry.



***All sources of supply to the unit must be taken via a common point of isolation (not supplied by Johnson Controls).***

Copper power wiring only should be used for supplying power to the chiller. This is recommended to avoid safety and reliability issues resulting from connection failure at the power connections to the chiller. Aluminum wiring is not recommended due to thermal characteristics that may cause loose terminations resulting from the contraction and expansion of the wiring. Aluminum oxide may also build up at the termination causing hot spots and eventual failure. If aluminum wiring is used to supply power to the chiller, AL-CU compression fittings should be used to transition from aluminum to copper. This transition should be done in an external box separate to the power panel. Copper conductors can then be run from the box to the chiller.



***Caulk power and control wiring conduit entering the power panel to assure moist air from the building cannot enter the panel.***

## POWER SUPPLY WIRING

- Units require only one 3-phase supply, plus earth.
- Connect the 3-phase supplies to the circuit breaker located in the panel See *Table 4 on page 52*.
- Connect a suitably sized earth wire to the PE terminal in the panel.

## 115VAC CONTROL SUPPLY TRANSFORMER

A 3-wire high voltage to 115VAC supply transformer is standard in the chiller. This transformer is mounted in the cabinet and steps down the high voltage supply to 115VAC to be used by the controls, VSD, Feed and Drain Valve Controller, valves, solenoids, heaters, and so on.

The high voltage for the transformer primary is taken from the chiller input. Fusing is provided for the transformer.



***Removing high voltage power to the chiller will remove the 115VAC supply voltage to the control panel circuitry and the evaporator heater mat. In sub-freezing weather, this could cause serious damage to the chiller due to evaporator freeze-up. Do not remove power unless alternate means are taken to ensure operation of the control panel, evaporator heater mat, and waterbox heaters.***

## CONTROL WIRING

All control wiring utilizing contact closures to the control panel terminal block is nominal 115VAC and must be run in shielded cable, with the shield grounded at the panel end only, and run in water tight conduit. Run shielded cable separately from mains cable to avoid electrical noise pick-up. Use the control panel cable entry to avoid the power cables.

Voltage free contacts connected to the panel must be suitable for 115VAC 10 ma (gold contacts recommended). If the voltage free contacts form part of a relay or contactor, the coil of the device must be suppressed using a standard R/C suppressor. The above precautions must be taken to avoid electrical noise, which could cause a malfunction or damage to the unit and its controls.

## VOLTS FREE CONTACTS

### Chilled Liquid Pump Starter

Terminals 23 and 24 on 1TB close to start the chilled liquid pump. This contact can be used as a master start/stop for the pump in conjunction with the daily start/stop schedule. Cycle the pumps from the unit panel if the unit will be operational or shut-down during sub-freezing conditions. See *"Evaporator Pump Control"* on page 102 for more information on testing the pumps.

### Run Contact

Terminals 21 and 22 on 1TB close to indicate that a system is running.

### Alarm Contacts

Each system has a single voltage-free contact, which will operate to signal an alarm condition whenever any system locks out, or there is a power failure. To obtain system alarm signal, connect the alarm circuit to volt free Terminals 25 & 26 (Sys 1), Terminals 27 and 28 (Sys 2) of 1TB.

## SYSTEM INPUTS

### Flow Switch

A chilled liquid flow switch of suitable type MUST be connected between Terminals 2 and 13 of 1TB to provide protection against loss of liquid flow, which will cause evaporator freeze-up if the chiller is permitted to run. The flow switch circuitry is a 115VAC circuit. Contacts must be rated for low current (5mA). Gold contacts should be used.

### Remote Run / Stop

A Remote Run/Stop input is available for each systems. These inputs require a dry contact to start and stop the system. System 1 remote dry contacts are connected between Terminals 2 and 15 of 1TB and System 2 dry contacts are connected between Terminals 2 and 16 of 1TB. If remote start/stop is not utilized, a jumper must be placed across the terminals to allow the system to run. The remote run/stop circuitry is a 115VAC circuit. Contacts must be rated for low current (5mA). Gold contacts should be used.

### Remote Print

Closure of suitable contacts connected to Terminals 2 and 14 of 1TB will cause a hard copy printout of Operating Data/Fault History to be made if an optional printer is connected to the RS-232 port. The remote print circuitry is a 115VAC circuit. Contacts must be rated for low current (5mA). Gold contacts should be used.

### Optional Remote Setpoint Offset – Temperature

A voltage signal connected to Terminals 17 and 18 of 1TB will provide a remote offset function of the chilled liquid setpoint, if required.


### Optional Remote Setpoint Offset – Current

A voltage signal connected to Terminals 19 and 20 of 1TB will provide a remote setting of current limit setpoint, if required.


### Optional Remote Setpoint Offset – Sound Limiting

A voltage signal connected to Terminals 40 and 41 of 1TB will provide remote setting of sound limit setpoint, if required.

POWER SUPPLY WIRING



LD18588




*Minimum Circuit Ampacity (MCA), Minimum/Maximum Fuse Size and Minimum/Maximum Circuit Breaker size varies on chillers based upon model and options ordered. Consult YorkWorks or the chiller data plate for electrical data on a specific chiller.*

**Voltage Utilization Range**

| RATED VOLTAGE | UTILIZATION RANGE |
|---------------|-------------------|
| 200/60/3      | 180-220           |
| 230/60/3      | 208-254           |
| 380/60/3      | 342-402           |
| 400/60/3      | 360-440           |
| 460/60/3      | 414-508           |
| 575/60/3      | 520-635           |
| 400/50/3      | 360-440           |

FIGURE 14 - SINGLE POINT POWER WIRING

## Dual Point Wiring



LD18589

**FIGURE 15 - DUAL POINT POWER WIRING**

CUSTOMER CONTROL WIRING




FIGURE 16 - CUSTOMER CONTROL CONNECTIONS

THIS PAGE INTENTIONALLY LEFT BLANK

**TABLE 4 - ELECTRICAL LUG DATA**

| FIELD WIRING LUGS   |      |      |             |            | STANDARD & ULTRA QUIET CONDENSER FANS |                |                 |                  |                             |                |
|---------------------|------|------|-------------|------------|---------------------------------------|----------------|-----------------|------------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                        |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRES PER PHASE                       | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                       |                |                 |                  |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                       |                |                 |                  |                             |                |
| 015                 | 3    | B    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 016                 | 5    | B    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 017                 | 8    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #2/0 ~ 500 kcmil | 2                           | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 018                 | 3    | A    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 019                 | 5    | A    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 019                 | 8    | B    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 020                 | 0    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 021                 | 3    | A    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |
| 021                 | 5    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                  |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil  |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #2 ~ 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS   |      |      |             |            | HIGH AIRFLOW/HIGH STATIC CONDENSER FANS |                  |                 |                 |                             |                |
|---------------------|------|------|-------------|------------|-----------------------------------------|------------------|-----------------|-----------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                          |                  | CIRCUIT BREAKER |                 | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRE PER PHASE                          | LUG WIRE RANGE   | WIRES PER PHASE | LUG WIRE RANGE  | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                         |                  |                 |                 |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                         |                  |                 |                 |                             |                |
| 015                 | 3    | B    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 016                 | 5    | B    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 017                 | 8    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 018                 | 3    | A    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 019                 | 5    | A    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 019                 | 8    | B    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 020                 | 0    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 021                 | 3    | A    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 021                 | 5    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS   |      |      |             |            | STANDARD & ULTRA QUIET CONDENSER FANS |                |                 |                 |                             |                |
|---------------------|------|------|-------------|------------|---------------------------------------|----------------|-----------------|-----------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                        |                | CIRCUIT BREAKER |                 | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRES PER PHASE                       | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE  | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                       |                |                 |                 |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                       |                |                 |                 |                             |                |
| 021                 | 8    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 023                 | 3    | B    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 024                 | 5    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 024                 | 8    | C    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 026                 | 3    | B    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 0    | D    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 3    | D    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 5    | E    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 8    | E    | 200         | 60         | 4                                     | #2 - 600 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                     | #2 - 600 kcmil | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS   |      |      |             |            | HIGH AIRFLOW/HIGH STATIC CONDENSER FANS |                  |                 |                 |                             |                |
|---------------------|------|------|-------------|------------|-----------------------------------------|------------------|-----------------|-----------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                          |                  | CIRCUIT BREAKER |                 | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRE PER PHASE                          | LUG WIRE RANGE   | WIRES PER PHASE | LUG WIRE RANGE  | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                         |                  |                 |                 |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                         |                  |                 |                 |                             |                |
| 021                 | 8    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 023                 | 3    | B    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 024                 | 5    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 024                 | 8    | C    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 026                 | 3    | B    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 0    | D    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 3    | D    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 ~ 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 5    | E    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |
| 027                 | 8    | E    | 200         | 60         | 4                                       | #1/0 ~ 700 kcmil |                 |                 |                             |                |
|                     |      |      | 230         | 60         | 4                                       | #2 - 600 kcmil   | 4               | 4/0 ~ 500 kcmil |                             |                |
|                     |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil   | 3               | 3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil   | 2               | #1 - 500 kcmil  | 2                           | #2 ~ 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS   |      |      |             |            | STANDARD & ULTRA QUIET CONDENSER FANS |                |                 |                  |                             |                |
|---------------------|------|------|-------------|------------|---------------------------------------|----------------|-----------------|------------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                        |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRES PER PHASE                       | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                       |                |                 |                  |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                       |                |                 |                  |                             |                |
| 029                 | 5    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 030                 | 3    | C    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 030                 | 5    | C    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 030                 | 8    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 031                 | 8    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 032                 | 3    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 033                 | 3    | C    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 034                 | 3    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
| 034                 | 5    | E    | 200         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                       |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 460         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |
|                     |      |      | 575         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 ~ 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS   |      |      |             |            | HIGH AIRFLOW/HIGH STATIC CONDENSER FANS |                |                 |                  |                             |                |
|---------------------|------|------|-------------|------------|-----------------------------------------|----------------|-----------------|------------------|-----------------------------|----------------|
|                     |      |      |             |            | TERMINAL BLOCK                          |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                |
| YVAA MODEL          |      |      | INPUT VOLTS | INPUT FREQ | WIRE PER PHASE                          | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE |
| FRAME               | COND | EVAP |             |            |                                         |                |                 |                  |                             |                |
| SINGLE POINT WIRING |      |      |             |            |                                         |                |                 |                  |                             |                |
| 029                 | 5    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 030                 | 3    | C    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 030                 | 5    | C    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 030                 | 8    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 031                 | 8    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 032                 | 3    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 033                 | 3    | C    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 034                 | 3    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |
| 034                 | 5    | E    | 200         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 230         | 60         |                                         |                |                 |                  |                             |                |
|                     |      |      | 380         | 60         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 400         | 50         | 4                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 4*                          | #2 - 600 kcmil |
|                     |      |      | 460         | 60         | 3                                       | #2 - 600 kcmil | 4               | #4/0 ~ 500 kcmil | 3                           | #2 - 600 kcmil |
|                     |      |      | 575         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #2 - 600 kcmil |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS |      |      |             |            | STANDARD & ULTRA QUIET CONDENSER FANS |                |                 |                  |                             |                  |
|-------------------|------|------|-------------|------------|---------------------------------------|----------------|-----------------|------------------|-----------------------------|------------------|
|                   |      |      |             |            | TERMINAL BLOCK                        |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                  |
| YVAA MODEL        |      |      | INPUT VOLTS | INPUT FREQ | WIRES PER PHASE                       | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE   |
| FRAME             | COND | EVAP |             |            |                                       |                |                 |                  |                             |                  |
| DUAL POINT WIRING |      |      |             |            |                                       |                |                 |                  |                             |                  |
| 036               | 8    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 037               | 3    | F    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 037               | 5    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 039               | 8    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 041               | 3    | H    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 042               | 5    | H    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 042               | 8    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 044               | 3    | G    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 047               | 5    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS |      |      |             |            | HIGH AIRFLOW/HIGH STATIC CONDENSER FANS |                |                 |                  |                             |                  |
|-------------------|------|------|-------------|------------|-----------------------------------------|----------------|-----------------|------------------|-----------------------------|------------------|
|                   |      |      |             |            | TERMINAL BLOCK                          |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                  |
|                   |      |      |             |            | WIRE PER PHASE                          | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE   |
| DUAL POINT WIRING |      |      |             |            |                                         |                |                 |                  |                             |                  |
| YVAA MODEL        |      |      | INPUT VOLTS | INPUT FREQ |                                         |                |                 |                  |                             |                  |
| FRAME             | COND | EVAP |             |            |                                         |                |                 |                  |                             |                  |
| 036               | 8    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 037               | 3    | F    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 037               | 5    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 039               | 8    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 041               | 3    | H    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 042               | 5    | H    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 042               | 8    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 044               | 3    | G    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 047               | 5    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS |      |      |             |            | STANDARD & ULTRA QUIET CONDENSER FANS |                |                 |                  |                             |                  |
|-------------------|------|------|-------------|------------|---------------------------------------|----------------|-----------------|------------------|-----------------------------|------------------|
|                   |      |      |             |            | TERMINAL BLOCK                        |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                  |
| YVAA MODEL        |      |      | INPUT VOLTS | INPUT FREQ | WIRE PER PHASE                        | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE   |
| FRAME             | COND | EVAP |             |            |                                       |                |                 |                  |                             |                  |
| DUAL POINT WIRING |      |      |             |            |                                       |                |                 |                  |                             |                  |
| 048               | 3    | G    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 49                | 0    | K    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 050               | 0    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 052               | 3    | J    | 200         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                       |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                     | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
|                   |      |      | 575         | 60         | 2                                     | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |

**TABLE 4 - ELECTRICAL LUG DATA (CONT'D)**

| FIELD WIRING LUGS |      |      |             |            | HIGH AIRFLOW/HIGH STATIC CONDENSER FANS |                |                 |                  |                             |                  |
|-------------------|------|------|-------------|------------|-----------------------------------------|----------------|-----------------|------------------|-----------------------------|------------------|
|                   |      |      |             |            | TERMINAL BLOCK                          |                | CIRCUIT BREAKER |                  | NON-FUSED DISCONNECT SWITCH |                  |
| YVAA MODEL        |      |      | INPUT VOLTS | INPUT FREQ | WIRE PER PHASE                          | LUG WIRE RANGE | WIRES PER PHASE | LUG WIRE RANGE   | WIRES PER PHASE             | LUG WIRE RANGE   |
| FRAME             | COND | EVAP |             |            |                                         |                |                 |                  |                             |                  |
| DUAL POINT WIRING |      |      |             |            |                                         |                |                 |                  |                             |                  |
| 048               | 3    | G    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 49                | 0    | K    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 050               | 0    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |
| 052               | 3    | J    | 200         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 230         | 60         |                                         |                |                 |                  |                             |                  |
|                   |      |      | 380         | 60         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 400         | 50         | 3                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 460         | 60         | 2                                       | #2 - 600 kcmil | 3               | #3/0 ~ 400 kcmil | 3                           | #3/0 ~ 400 kcmil |
|                   |      |      | 575         | 60         | 2                                       | #2 - 600 kcmil | 2               | #1 ~ 500 kcmil   | 2                           | #1 ~ 500 kcmil   |

| FIELD WIRING LUGS      |      |      |             | TERMINAL BLOCK |                 | TERMINAL BLOCK WITH INDEPENDENT SYSTEM CIRCUIT BREAKERS |                 | TERMINAL BLOCK WITH INDEPENDENT SYSTEM NON-FUSED DISCONNECT SWITCHES |                 |                |
|------------------------|------|------|-------------|----------------|-----------------|---------------------------------------------------------|-----------------|----------------------------------------------------------------------|-----------------|----------------|
| SINGLE POINT WIRING    |      |      |             |                |                 |                                                         |                 |                                                                      |                 |                |
| YVAA MODEL             |      |      | INPUT VOLTS | INPUT FREQ     | WIRES PER PHASE | LUG WIRE RANGE                                          | WIRES PER PHASE | LUG WIRE RANGE                                                       | WIRES PER PHASE | LUG WIRE RANGE |
| FRAME                  | COND | EVAP |             |                |                 |                                                         |                 |                                                                      |                 |                |
| Models<br>0368 to 0523 |      |      | 200         | 60             |                 |                                                         |                 |                                                                      |                 |                |
|                        |      |      | 230         | 60             |                 |                                                         |                 |                                                                      |                 |                |
|                        |      |      | 380         | 60             | 4               | #1 - 750 kcmil                                          | 4               | #1 - 750 kcmil                                                       | 4               | #1 - 750 kcmil |
|                        |      |      | 400         | 50             | 4               | #1 - 750 kcmil                                          | 4               | #1 - 750 kcmil                                                       | 4               | #1 - 750 kcmil |
|                        |      |      | 460         | 60             | 4               | #1 - 750 kcmil                                          | 4               | #1 - 750 kcmil                                                       | 4               | #1 - 750 kcmil |
|                        |      |      | 575         | 60             | 4               | #1 - 750 kcmil                                          | 4               | #1 - 750 kcmil                                                       | 4               | #1 - 750 kcmil |

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 5 - TECHNICAL DATA

### NOMENCLATURE

|                                     |   |  |   |                            |   |   |                                   |   |   |   |                         |   |                                     |   |
|-------------------------------------|---|--|---|----------------------------|---|---|-----------------------------------|---|---|---|-------------------------|---|-------------------------------------|---|
| <b>YVAA 021 3AXX 46 AA</b>          |   |  |   |                            |   |   |                                   |   |   |   |                         |   |                                     |   |
| <b>1 2 3 4</b><br>BASE PRODUCT TYPE |   |  |   | <b>5 6 7</b><br>FRAME SIZE |   |   | <b>8 9 10 11</b><br>CONFIGURATION |   |   |   | <b>12 13</b><br>VOLTAGE |   | <b>14 15</b><br>LEVEL / REFRIGERANT |   |
| Y                                   | V |  | A | #                          | # | # | #                                 | # | # | # | 1                       | 7 | #                                   | A |
| : York                              |   |  |   |                            |   |   | : Condenser code                  |   |   |   | : 200 / 3 / 60          |   | : Development Level                 |   |
| : Variable Speed Screw              |   |  |   |                            |   |   | : Evaporator code                 |   |   |   | : 230 / 3 / 60          |   | : Refrigerant R134a                 |   |
| : Air cooled                        |   |  |   |                            |   |   | : Compressor code                 |   |   |   | : 380 / 3 / 60          |   | : Refrigerant R531A                 |   |
| : Design Series                     |   |  |   |                            |   |   | : Condenser fan & sound kit code  |   |   |   | : 400 / 3 / 60          |   |                                     |   |
|                                     |   |  |   |                            |   |   |                                   |   |   |   | : 460 / 3 / 60          |   |                                     |   |
|                                     |   |  |   |                            |   |   |                                   |   |   |   | : 380-415 / 3 / 50      |   |                                     |   |
|                                     |   |  |   |                            |   |   |                                   |   |   |   | : 575 / 3 / 60          |   |                                     |   |



Products are produced at a facility whose quality-management systems are ISO9001 certified.



ASHRAE 90.1 Compliant



The data shown in this table is applicable to selected typical configurations. Other configurations are available through our configuration/selection software.

Please contact your nearest Johnson Controls Sales Office for the chiller configuration that best matches your specific needs.

**TABLE 5 - PHYSICAL DATA - MICROCHANNEL COIL**

| UNIT FRAME                                                   | 15                 | 16                 | 17                 | 18                 | 19                 | 19                  | 20                   | 21                 | 21                   | 21                   |
|--------------------------------------------------------------|--------------------|--------------------|--------------------|--------------------|--------------------|---------------------|----------------------|--------------------|----------------------|----------------------|
| CONDENSER CODE                                               | 3                  | 5                  | 8                  | 3                  | 5                  | 8                   | 0                    | 3                  | 5                    | 8                    |
| EVAPORATOR CODE                                              | B                  | B                  | C                  | A                  | A                  | B                   | C                    | A                  | C                    | C                    |
| GENERAL UNIT DATA                                            |                    |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Number of Independent Refrigerant Circuits                   | 2                  |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Refrigerant Charge, R-134a, R-513A, Ckt.-1/ Ckt.-2, lbs (kg) | 175/175 (79/79)    | 190/190 (86/86)    | 225/225 (102/102)  | 175/155 (79/70)    | 190/170 (86/77)    | 220/195 (100/88)    | 205/205 (93/93)      | 175/175 (79/79)    | 225/225 (102/102)    | 240/240 (109/109)    |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                      | 2.1/2.0 (8.0/ 7.7) | 2.2/2.2 (8.5/ 8.5) | 2.5/2.5 (9.3/ 9.3) | 2.4/2.0 (9.2/ 7.7) | 2.6/2.1 (9.7/ 8.0) | 2.7/2.2 (10.4/ 8.5) | 2.6/2.6 (10.0/ 10.0) | 2.5/2.5 (9.3/ 9.3) | 2.8/2.8 (10.5/ 10.5) | 2.9/2.9 (10.8/ 10.8) |
| Minimum Load (%)                                             | 10%                |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Chassis Dimensions - Length, inches (mm)                     | 203.3 (5163)       | 247.2 (6280)       | 291.2 (7397)       | 247 (6274)         | 291.2 (7397)       | 335.2 (8514)        | 226 (5741)           | 291.2 (7397)       | 291.2 (7397)         | 335.2 (8514)         |
| Chassis Dimensions - Width, inches (mm)                      | 88.3 (2242)        | 88.3 (2242)        | 88.3 (2242)        | 88.3 (2242)        | 88.3 (2242)        | 88.3 (2242)         | 88.3 (2242)          | 88.3 (2242)        | 88.3 (2242)          | 88.3 (2242)          |
| Chassis Dimensions - Height, inches (mm)                     | 94.6 (2403)        | 94.6 (2403)        | 94.6 (2403)        | 94.6 (2403)        | 94.6 (2403)        | 94.6 (2403)         | 94.6 (2403)          | 94.6 (2403)        | 94.6 (2403)          | 94.6 (2403)          |
| COMPRESSORS, SEMI-HERMETIC SCREW                             |                    |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Qty per Chiller                                              | 2                  |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| CONDENSER FANS                                               |                    |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Number Ckt-1/Ckt-2                                           | 4/4                | 5/5                | 6/6                | 6/4                | 7/5                | 8/6                 | 4/4                  | 6/6                | 6/6                  | 7/7                  |
| Air on Condenser (Min/Max), °F (°C)                          | 0/131 (-17.8/55)   |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM <sup>2</sup>  |                    |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Water Volume, gal (liters)                                   | 58 (220)           | 58 (220)           | 71 (269)           | 48 (182)           | 48 (182)           | 58 (220)            | 71 (269)             | 48 (182)           | 71 (269)             | 71(269)              |
| Leaving Water Temperature (Min/Max), °F (°C) 3               | 40/60 (4.4/15.6)   |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Maximum Water Side Pressure, psig (barg)                     | 150 (10.3)         |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Maximum Refrigerant Side Pressure, psig (barg)               | 235 (16.2)         |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Evap Drain Connection, inches (mm)                           | 3/4                |                    |                    |                    |                    |                     |                      |                    |                      |                      |
| Minimum Chilled Water Flow Rate, gpm (l/sec)                 | 250 (15.8)         | 250 (15.8)         | 300 (18.9)         | 200 (12.6)         | 200 (12.6)         | 250 (15.8)          | 300 (18.9)           | 200 (12.6)         | 300 (18.9)           | 300 (18.9)           |
| Maximum Chilled Water Flow Rate, gpm (l/sec)                 | 950 (59.9)         | 950 (59.9)         | 1150 (72.6)        | 750 (47.3)         | 750 (47.3)         | 950 (59.9)          | 1150 (72.6)          | 750 (47.3)         | 1150 (72.6)          | 1150 (72.6)          |
| Inlet and Outlet Water Connections, in                       | 6                  | 6                  | 6                  | 6                  | 6                  | 6                   | 6                    | 6                  | 6                    | 6                    |

**NOTES:**

- Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.
- For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 5 - PHYSICAL DATA - MICROCHANNEL COIL (CONT'D)**

| UNIT FRAME                                                   | 23                  | 24                   | 24                   | 26                   | 27                   | 27                   | 27                   | 27                   | 29                   | 30                   |
|--------------------------------------------------------------|---------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| CONDENSER CODE                                               | 3                   | 5                    | 8                    | 3                    | 0                    | 3                    | 5                    | 8                    | 5                    | 3                    |
| EVAPORATOR CODE                                              | B                   | C                    | C                    | B                    | D                    | D                    | E                    | E                    | E                    | C                    |
| GENERAL UNIT DATA                                            |                     |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Number of Independent Refrigerant Circuits                   | 2                   |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Refrigerant Charge, R-134a, R-513A, Ckt.-1/ Ckt.-2, lbs (kg) | 210/190 (95/86)     | 250/225 (113/102)    | 250/250 (113/113)    | 210/210 (95/95)      | 250/250 (114/114)    | 265/265 (120/120)    | 265/265 (120/120)    | 270/270 (122/122)    | 310/265 (141/120)    | 290/245 (132/111)    |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                      | 2.7/2.6 (10.1/ 9.7) | 2.9/2.8 (11.1/ 10.5) | 2.9/2.9 (11.1/ 11.1) | 2.7/2.7 (10.1/ 10.1) | 3.0/3.0 (11.4/ 11.4) | 3.0/3.0 (11.4/ 11.4) | 3.0/3.0 (11.4/ 11.4) | 3.1/3.1 (11.6/ 11.6) | 3.8/3.1 (14.4/ 11.7) | 3.7/3.0 (14.0/ 11.4) |
| Minimum Load (%)                                             | 10%                 |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Chassis Dimensions - Length, inches (mm)                     | 291.2 (7397)        | 335.2 (8514)         | 379.1 (9631)         | 335.2 (8514)         | 291.2 (7397)         | 335.2 (8514)         | 335.2 (8514)         | 379.2 (9631)         | 379.2 (9631)         | 379.2 (9631)         |
| Chassis Dimensions - Width, inches (mm)                      | 88.3 (2242)         | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          | 88.3 (2242)          |
| Chassis Dimensions - Height, inches (mm)                     | 94.6 (2403)         | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          | 94.6 (2403)          |
| COMPRESSORS, SEMI-HERMETIC SCREW                             |                     |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Qty per Chiller                                              | 2                   |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| CONDENSER FANS                                               |                     |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Number Ckt-1/Ckt-2                                           | 7/5                 | 8/6                  | 8/8                  | 7/7                  | 6/6                  | 7/7                  | 7/7                  | 8/8                  | 9/7                  | 9/7                  |
| Air on Condenser (Min/Max), °F (°C)                          | 0/131 (-17.8/55)    |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM <sup>2</sup>  |                     |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Water Volume, gal (liters)                                   | 58(220)             | 71(269)              | 71(269)              | 58(220)              | 82(310)              | 82(310)              | 113(428)             | 113(428)             | 113(428)             | 71(269)              |
| Leaving Water Temperature (Min/Max), °F (°C) 3               | 40/60 (4.4/15.6)    |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Maximum Water Side Pressure, psig (barg)                     | 150 (10.3)          |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Maximum Refrigerant Side Pressure, psig (barg)               | 235 (16.2)          |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Evap Drain Connection, inches (mm)                           | 3/4                 |                      |                      |                      |                      |                      |                      |                      |                      |                      |
| Minimum Chilled Water Flow Rate, gpm (l/sec)                 | 250 (15.8)          | 300 (18.9)           | 300 (18.9)           | 250 (15.8)           | 300 (18.9)           | 300 (18.9)           | 400 (25.2)           | 400 (25.2)           | 400 (25.2)           | 300 (18.9)           |
| Maximum Chilled Water Flow Rate, gpm (l/sec)                 | 950 (59.9)          | 1150 (72.6)          | 1150 (72.6)          | 950 (59.9)           | 1150 (72.6)          | 1150 (72.6)          | 1500 (94.7)          | 1500 (94.7)          | 1500 (94.7)          | 1150 (72.6)          |
| Inlet and Outlet Water Connections, in                       | 6                   | 6                    | 6                    | 6                    | 6                    | 6                    | 8                    | 8                    | 8                    | 6                    |

**NOTES:**

- Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.
- For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 5 - PHYSICAL DATA - MICROCHANNEL COIL (CONT'D)**

| UNIT FRAME                                                     | 30                      | 30                      | 31                      | 32                      | 33                      | 34                      | 34                      | 36                      | 37                      |
|----------------------------------------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| CONDENSER CODE                                                 | 5                       | 8                       | 8                       | 3                       | 3                       | 3                       | 5                       | 8                       | 3                       |
| EVAPORATOR CODE                                                | C                       | E                       | E                       | E                       | C                       | E                       | E                       | J                       | F                       |
| GENERAL UNIT DATA                                              |                         |                         |                         |                         |                         |                         |                         |                         |                         |
| Number of Independent Refrigerant Circuits                     | 2                       |                         |                         |                         |                         |                         |                         |                         |                         |
| Refrigerant Charge, R-134a, or R-513A, Ckt.-1/Ckt.-2, lbs (kg) | 295/250<br>(134/114)    | 315/275<br>(143/125)    | 315/295<br>(143/134)    | 295/295<br>(134/134)    | 290/290<br>(132/132)    | 310/310<br>(141/141)    | 315/315<br>(143/143)    | 475/320<br>(216/145)    | 420/245<br>(191/111)    |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                        | 3.7/3.0<br>(14.0/ 11.4) | 3.9/3.2<br>(14.8/ 12.1) | 3.9/3.3<br>(14.8/ 12.5) | 3.7/3.7<br>(14.0/ 14.0) | 3.7/3.7<br>(14.0/ 14.0) | 3.8/3.8<br>(14.4/ 14.4) | 3.9/3.9<br>(14.8/ 14.8) | 4.1/4.0<br>(15.5/ 15.1) | 4.0/2.9<br>(15.1/ 11.0) |
| Minimum Load (%)                                               | 10%                     |                         |                         |                         |                         |                         |                         |                         |                         |
| Chassis Dimensions - Length, inches (mm)                       | 423.1<br>(10748)        | 423.1<br>(10748)        | 467.1<br>(11865)        | 379.2<br>(9631)         | 423.1<br>(10748)        | 423.1<br>(10748)        | 467.1<br>(11865)        | 511<br>(12979)          | 467.1<br>(11864)        |
| Chassis Dimensions - Width, inches (mm)                        | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2242)             | 88.3 (2243)             | 88.3 (2243)             |
| Chassis Dimensions - Height, inches (mm)                       | 94.6 (2403)             | 94.6 (2403)             | 94.6 (2403)             | 94.6 (2403)             | 94.6 (2403)             | 94.6 (2403)             | 94.6 (2403)             | 94.7 (2405)             | 94.7 (2405)             |
| COMPRESSORS, SEMI-HERMETIC SCREW                               |                         |                         |                         |                         |                         |                         |                         |                         |                         |
| Qty per Chiller                                                | 2                       |                         |                         |                         |                         |                         |                         |                         |                         |
| CONDENSER FANS                                                 |                         |                         |                         |                         |                         |                         |                         |                         |                         |
| Number Ckt-1/Ckt-2                                             | 10/8                    | 10/8                    | 8/8                     | 8/8                     | 9/9                     | 9/9                     | 10/10                   | 14/8                    | 13/7                    |
| Air on Condenser (Min/Max), °F (°C)                            | 0/125<br>(-17.8/51.7)   |                         |                         |                         |                         |                         |                         |                         |                         |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM <sup>2</sup>    |                         |                         |                         |                         |                         |                         |                         |                         |                         |
| Water Volume, gal (liters)                                     | 71 (269)                | 113 (428)               | 113 (428)               | 113 (428)               | 71 (269)                | 113 (428)               | 113 (428)               | 147 (556)               | 96 (363)                |
| Leaving Water Temperature (Min/Max), °F (°C) <sup>2</sup>      | 40/60<br>(4.4/15.6)     |                         |                         |                         |                         |                         |                         |                         |                         |
| Maximum Water Side Pressure, psig (barg)                       | 150<br>(10.3)           |                         |                         |                         |                         |                         |                         |                         |                         |
| Maximum Refrigerant Side Pressure, psig (barg)                 | 235<br>(16.2)           |                         |                         |                         |                         |                         |                         |                         |                         |
| Evap Drain Connection, inches (mm)                             | 3/4                     |                         |                         |                         |                         |                         |                         |                         |                         |
| Minimum Chilled Water Flow Rate, gpm (l/sec)                   | 300<br>(18.9)           | 400<br>(25.2)           | 400<br>(25.2)           | 400<br>(25.2)           | 300<br>(18.9)           | 400<br>(25.2)           | 400<br>(25.2)           | 550<br>(34.1)           | 460<br>(29.0)           |
| Maximum Chilled Water Flow Rate, gpm (l/sec)                   | 1150<br>(72.6)          | 1500<br>(94.7)          | 1500<br>(94.7)          | 1500<br>(94.7)          | 1150<br>(72.6)          | 1500<br>(94.7)          | 1500<br>(94.7)          | 1880<br>(118.1)         | 1540<br>(97.0)          |
| Inlet and Outlet Water Connections, in                         | 6                       | 8                       | 8                       | 8                       | 6                       | 8                       | 8                       | 8                       | 8                       |

**NOTES:**

- Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.
- For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 5 - PHYSICAL DATA - MICROCHANNEL COIL (CONT'D)**

| UNIT FRAME                                                     | 37                         | 39                         | 41                         | 42                         | 42                         | 44                         | 47                         | 48                         | 49                         | 50                         | 52                         |
|----------------------------------------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| CONDENSER CODE                                                 | 5                          | 8                          | 3                          | 5                          | 8                          | 3                          | 5                          | 3                          | 0                          | 0                          | 3                          |
| EVAPORATOR CODE                                                | J                          | J                          | H                          | H                          | J                          | G                          | J                          | G                          | K                          | J                          | J                          |
| GENERAL UNIT DATA                                              |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Number of Independent Refrigerant Circuits                     | 2                          |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Refrigerant Charge, R-134a, or R-513A, Ckt.-1/Ckt.-2, lbs (kg) | 470/310<br>(213/141)       | 475/360<br>(216/163)       | 460/345<br>(209/156)       | 480/365<br>(218/166)       | 475/385<br>(215/175)       | 370/370<br>(168/168)       | 445/445<br>(202/202)       | 385/385<br>(175/175)       | 390/390<br>(179/179)       | 405/405<br>(184/184)       | 445/445<br>(202/202)       |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                        | 4.1/3.8<br>(15.5/<br>14.4) | 4.1/4.1<br>(15.5/<br>15.5) | 4.0/4.0<br>(15.1/<br>15.1) | 4.1/4.1<br>(15.5/<br>15.5) | 4.1/4.1<br>(15.5/<br>15.5) | 4.0/4.0<br>(15.1/<br>15.1) | 4.2/4.2<br>(15.9/<br>15.9) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.2/4.2<br>(15.9/<br>15.9) |
| Minimum Load (%)                                               | 10%                        |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Chassis Dimensions - Length, inches (mm)                       | 467.1<br>(11864)           | 555.3<br>(14104)           | 467.1<br>(11864)           | 555.3<br>(14104)           | 599.3<br>(15222)           | 555.3<br>(14104)           | 599.3<br>(15222)           | 599.3<br>(15222)           | 467.1<br>(11864)           | 467.1<br>(11865)           | 599.3<br>(15222)           |
| Chassis Dimensions - Width, inches (mm)                        | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.4<br>(2244)             | 88.3<br>(2242)             | 88.3<br>(2243)             | 88.3<br>(2243)             |
| Chassis Dimensions - Height, inches (mm)                       | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.6<br>(2403)             | 94.7<br>(2405)             | 94.7<br>(2405)             |
| COMPRESSORS, SEMI-HERMETIC SCREW                               |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Qty per Chiller                                                | 2                          |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| CONDENSER FANS                                                 |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Number Ckt-1/Ckt-2                                             | 13/7                       | 14/10                      | 12/8                       | 14/10                      | 14/12                      | 12/12                      | 13/13                      | 13/13                      | 10/10                      | 10/10                      | 13/13                      |
| Air on Condenser (Min/Max), °F (°C)                            | 0/125                      |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM <sup>2</sup>    |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Water Volume, gal (liters)                                     | 147(556)                   | 147(556)                   | 130(492)                   | 130(492)                   | 147(556)                   | 96(363)                    | 147(556)                   | 96(363)                    | 130 (492)                  | 147(556)                   | 147(556)                   |
| Leaving Water Temperature (Min/Max), °F (°C) <sup>2</sup>      | 40/60<br>(4.4/15.6)        |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Maximum Water Side Pressure, psig (barg)                       | 150<br>(10.3)              |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Maximum Refrigerant Side Pressure, psig (barg)                 | 235<br>(16.2)              |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Evap Drain Connection, inches (mm)                             | 3/4                        |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Minimum Chilled Water Flow Rate, gpm (l/sec)                   | 550<br>(34.1)              | 550<br>(34.1)              | 520<br>(33.0)              | 520<br>(33.0)              | 550<br>(34.1)              | 460<br>(29.0)              | 550<br>(34.1)              | 460<br>(29.0)              | 470<br>(30)                | 550<br>(34.1)              | 550<br>(34.1)              |
| Maximum Chilled Water Flow Rate, gpm (l/sec)                   | 1880<br>(118.1)            | 1880<br>(118.1)            | 1700<br>(107.0)            | 1700<br>(107.0)            | 1880<br>(118.1)            | 1540<br>(97.0)             | 1880<br>(118.1)            | 1540<br>(97.0)             | 1870<br>(118)              | 1880<br>(118.1)            | 1880<br>(118.1)            |
| Inlet and Outlet Water Connections, in                         | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          |

**NOTES:**

- Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.
- For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 6 - PHYSICAL DATA - ROUND TUBE COIL**

| UNIT FRAME                                                | 15                 | 18                | 20                | 21                | 23                 | 26                  | 27                  | 27                  | 30                  |
|-----------------------------------------------------------|--------------------|-------------------|-------------------|-------------------|--------------------|---------------------|---------------------|---------------------|---------------------|
| CONDENSER CODE                                            | 3                  | 3                 | 0                 | 3                 | 3                  | 3                   | 0                   | 3                   | 3                   |
| EVAPORATOR CODE                                           | B                  | A                 | C                 | A                 | B                  | B                   | D                   | D                   | C                   |
| GENERAL UNIT DATA                                         |                    |                   |                   |                   |                    |                     |                     |                     |                     |
| Number of Independent Refrigerant Circuits                | 2                  |                   |                   |                   |                    |                     |                     |                     |                     |
| Refrigerant Charge, R-134a, Ckt.-1/Ckt.-2, lbs (kg)       | 211/211 (96/96)    | 229/191 (104/87)  | 241/241 (109/109) | 229/229 (104/104) | 273/235 (124/107)  | 273/273 (124/124)   | 304/304 (138/138)   | 328/328 (149/149)   | 371/308 (168/140)   |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                   | 2.1/2.0 (8.0/7.7)  | 2.4/2.0 (9.2/7.7) | 2.6/2.6 (9.9/9.9) | 2.5/2.5 (9.5/9.5) | 2.7/2.6 (10.3/9.9) | 2.7/2.7 (10.3/10.3) | 3.0/3.0 (11.4/11.4) | 3.0/3.0 (11.4/11.4) | 3.7/3.0 (14.0/11.4) |
| Minimum Load (%)                                          | 10%                |                   |                   |                   |                    |                     |                     |                     |                     |
| Chassis Dimensions - Length, inches (mm)                  | 203.3 (5163)       | 247 (6274)        | 226 (5740)        | 291.2 (7397)      | 291.2 (7397)       | 335.2 (8514)        | 291.2 (7397)        | 335.2 (8514)        | 379.2 (9631)        |
| Chassis Dimensions - Width, inches (mm)                   | 88.3 (2242)        | 88.3 (2242)       | 88.3 (2242)       | 88.3 (2242)       | 88.3 (2242)        | 88.3 (2242)         | 88.3 (2242)         | 88.3 (2242)         | 88.3 (2242)         |
| Chassis Dimensions - Height, inches (mm)                  | 94.6 (2403)        | 94.6 (2403)       | 94.6 (2403)       | 94.6 (2403)       | 94.6 (2403)        | 94.6 (2403)         | 94.6 (2403)         | 94.6 (2403)         | 94.6 (2403)         |
| COMPRESSORS, SEMI-HERMETIC SCREW                          |                    |                   |                   |                   |                    |                     |                     |                     |                     |
| Qty per Chiller                                           | 2                  |                   |                   |                   |                    |                     |                     |                     |                     |
| CONDENSER FANS                                            |                    |                   |                   |                   |                    |                     |                     |                     |                     |
| Number Ckt-1/Ckt-2                                        | 4/4                | 6/4               | 4/4               | 6/6               | 7/5                | 7/7                 | 6/6                 | 7/7                 | 9/7                 |
| Air on Condenser (Min/Max), °F (°C)                       | 0/125 (-17.8/51.7) |                   |                   |                   |                    |                     |                     |                     |                     |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM            |                    |                   |                   |                   |                    |                     |                     |                     |                     |
| Water Volume, gal (liters)                                | 58 (220)           | 48 (182)          | 71 (269)          | 48 (182)          | 58 (220)           | 58 (220)            | 82 (310)            | 82 (310)            | 71 (269)            |
| Leaving Water Temperature (Min/Max), °F (°C) <sup>2</sup> | 40/60 (4.4/15.6)   |                   |                   |                   |                    |                     |                     |                     |                     |
| Maximum Water Side Pressure, psig (barg)                  | 150 (10.3)         |                   |                   |                   |                    |                     |                     |                     |                     |
| Maximum Refrigerant Side Pressure, psig (barg)            | 235 (16.2)         |                   |                   |                   |                    |                     |                     |                     |                     |
| Evap Drain Connection, inches (mm)                        | 3/4                |                   |                   |                   |                    |                     |                     |                     |                     |
| Minimum Chilled Water Flow Rate, gpm (l/sec)              | 250 (15.8)         | 200 (12.6)        | 300 (18.9)        | 200 (12.6)        | 250 (15.8)         | 250 (15.8)          | 300 (18.9)          | 300 (18.9)          | 300 (18.9)          |
| Maximum Chilled Water Flow Rate, gpm (l/sec)              | 950 (59.9)         | 750 (47.3)        | 1150 (72.6)       | 750 (47.3)        | 950 (59.9)         | 950 (59.9)          | 1150 (72.6)         | 1150 (72.6)         | 1150 (72.6)         |
| Inlet and Outlet Water Connections, in                    | 6                  | 6                 | 6                 | 6                 | 6                  | 6                   | 6                   | 6                   | 6                   |

**NOTES:**

Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.

1. R-513A is not an option.
2. For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 6 - PHYSICAL DATA - ROUND TUBE COIL (CONT'D)**


| UNIT FRAME                                                | 32                         | 33                         | 34                         | 37                         | 41                         | 44                         | 48                         | 49                         | 50                         | 52                         |
|-----------------------------------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| CONDENSER CODE                                            | 3                          | 3                          | 3                          | 3                          | 3                          | 3                          | 3                          | 0                          | 0                          | 3                          |
| EVAPORATOR CODE                                           | E                          | C                          | E                          | F                          | H                          | G                          | G                          | K                          | J                          | J                          |
| GENERAL UNIT DATA                                         |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Number of Independent Refrigerant Circuits                | 2                          |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Refrigerant Charge, R-134a, Ckt.-1/Ckt.-2, lbs (kg)       | 367/367<br>(166/166)       | 371/371<br>(168/168)       | 391/391<br>(177/177)       | 537/308<br>(244/140)       | 568/417<br>(258/189)       | 478/478<br>(217/217)       | 502/502<br>(228/228)       | 480/480<br>(218/218)       | 495/495<br>(224/224)       | 562/562<br>(255/255)       |
| Oil Charge, Ckt.-1/Ckt.-2, gal (liters)                   | 3.7/3.7<br>(14.0/<br>14.0) | 3.7/3.7<br>(14.0/<br>14.0) | 3.8/3.8<br>(14.4/<br>14.4) | 4.0/2.9<br>(15.1/<br>11.0) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.0/4.0<br>(15.1/<br>15.1) | 4.2/4.2<br>(15.9/<br>15.9) |
| Minimum Load (%)                                          | 10%                        |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Chassis Dimensions - Length, inches (mm)                  | 379.2<br>(9631)            | 423.1<br>(10748)           | 423.1<br>(10748)           | 467.1<br>(11864)           | 467.1<br>(11864)           | 555.3<br>(14104)           | 599.3<br>(15222)           | 467.1<br>(11864)           | 467.1<br>(11864)           | 599.3<br>(15222)           |
| Chassis Dimensions - Width, inches (mm)                   | 88.3<br>(2242)             | 88.3<br>(2242)             | 88.3<br>(2242)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.3<br>(2243)             | 88.4<br>(2244)             | 88.3<br>(2242)             | 88.4<br>(2244)             | 88.3<br>(2243)             |
| Chassis Dimensions - Height, inches (mm)                  | 94.6<br>(2403)             | 94.6<br>(2403)             | 94.6<br>(2403)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.7<br>(2405)             | 94.6<br>(2403)             | 94.7<br>(2405)             | 94.7<br>(2405)             |
| COMPRESSORS, SEMI-HERMETIC SCREW                          |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Qty per Chiller                                           | 2                          |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| CONDENSER FANS                                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Number Ckt-1/Ckt-2                                        | 8/8                        | 9/9                        | 9/9                        | 13/7                       | 12/8                       | 12/12                      | 13/13                      | 10/10                      | 10/10                      | 13/13                      |
| Air on Condenser (Min/Max), °F (°C)                       | 0/125<br>(-17.8/51.7)      |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| EVAPORATOR, SHELL AND TUBE HYBRID FALLING FILM            |                            |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Water Volume, gal (liters)                                | 113 (428)                  | 71 (269)                   | 113 (428)                  | 96 (363)                   | 130 (492)                  | 96 (363)                   | 96 (363)                   | 130 (492)                  | 147 (556)                  | 147 (556)                  |
| Leaving Water Temperature (Min/Max), °F (°C) <sup>2</sup> | 40/60<br>(4.4/15.6)        |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Maximum Water Side Pressure, psig (barg)                  | 150<br>(10.3)              |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Maximum Refrigerant Side Pressure, psig (barg)            | 235<br>(16.2)              |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Evap Drain Connection, inches (mm)                        | 3/4                        |                            |                            |                            |                            |                            |                            |                            |                            |                            |
| Minimum Chilled Water Flow Rate, gpm (l/sec)              | 400<br>(25.2)              | 300<br>(18.9)              | 400<br>(25.2)              | 460<br>(29.0)              | 520<br>(33.0)              | 460<br>(29.0)              | 460<br>(29.0)              | 470<br>(30)                | 550<br>(34.1)              | 550<br>(34.1)              |
| Maximum Chilled Water Flow Rate, gpm (l/sec)              | 1500<br>(94.7)             | 1150<br>(72.6)             | 1500<br>(94.7)             | 1540<br>(97.0)             | 1700<br>(107.0)            | 1540<br>(97.0)             | 1540<br>(97.0)             | 1870<br>(118)              | 1880<br>(118.1)            | 1880<br>(118.1)            |
| Inlet and Outlet Water Connections, in                    | 8                          | 6                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          | 8                          |

**NOTES:**

Shipping and operating weights shown are for base unit; selected options may add weight to unit. Contact your nearest Johnson Controls Sales office for weight data.

1. R-513A is not an option.

2. For leaving liquid temperature below 40°F(4.4°C) or above 60°F (15.6°C), contact your nearest Johnson Controls Sales Office for application requirements.

**TABLE 7 - OPTIONAL ONE-PASS EVAPORATOR**

| ALL DIMENSIONS - INCHES (MM) |       |            |              |             |               |                                |                                           |                                           |
|------------------------------|-------|------------|--------------|-------------|---------------|--------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A,B        | C            | D           | E-NOZZLE SIZE | WATER VOLUME. GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |              |             |               |                                |                                           |                                           |
| 15                           | 3     | 20.8 (528) | 6.8 (173)    | 34.5 (876)  | 8             | 58 (220)                       | 500 (32)                                  | 1970 (124)                                |
| 16                           | 5     | 20.8 (528) | 29.2 (742)   | 56.1 (1425) | 8             | 58 (220)                       | 500 (32)                                  | 1970 (124)                                |
| 17                           | 8     | 20.8 (528) | 34.9 (886)   | 70 (1778)   | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 18                           | 3     | 19.8 (503) | 17.7 (450)   | 56.8 (1443) | 6             | 48 (182)                       | 400 (25)                                  | 1230 (77)                                 |
| 19                           | 5     | 19.8 (503) | 61.5 (1562)  | 56.7 (1440) | 6             | 48 (182)                       | 400 (25)                                  | 1230 (77)                                 |
| 19                           | 8     | 21 (533)   | 117.3 (2979) | 56.1 (1425) | 8             | 58 (220)                       | 500 (32)                                  | 1970 (124)                                |
| 20                           | 0     | 20.8 (528) | 1.7 (43)     | 38.1 (968)  | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 21                           | 3     | 19.8 (503) | 61.7 (1567)  | 56.8 (1443) | 6             | 48 (182)                       | 400 (25)                                  | 1230 (77)                                 |
| 21                           | 5     | 20.8 (528) | 34.9 (886)   | 70 (1778)   | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 21                           | 8     | 21 (533)   | 78.9 (2004)  | 70 (1778)   | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.





**TABLE 7 - OPTIONAL ONE-PASS EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |              |             |               |                                |                                           |                                           |
|------------------------------|-------|------------|--------------|-------------|---------------|--------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A,B        | C            | D           | E-NOZZLE SIZE | WATER VOLUME. GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |              |             |               |                                |                                           |                                           |
| 23                           | 3     | 20.8 (528) | 73.2 (1859)  | 56.1 (1425) | 8             | 58 (220)                       | 500 (32)                                  | 1970 (124)                                |
| 24                           | 5     | 21 (533)   | 92.9 (2360)  | 56.1 (1425) | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 24                           | 8     | 21 (533)   | 122.9 (3122) | 70 (1778)   | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 26                           | 3     | 21 (533)   | 117.1 (2974) | 56.1 (1425) | 8             | 58 (220)                       | 500 (32)                                  | 1970 (124)                                |
| 27                           | 0     | 21 (533)   | 16.8 (427)   | 51.9 (1318) | 8             | 82 (310)                       | 590 (37)                                  | 2190 (138)                                |
| 27                           | 3     | 21 (533)   | 42.9 (1090)  | 70 (1778)   | 8             | 82 (310)                       | 590 (37)                                  | 2190 (138)                                |
| 27                           | 5     | 22.5 (572) | 44.7 (1135)  | 71.8 (1824) | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 27                           | 8     | 22.5 (572) | 88.3 (2243)  | 71.8 (1824) | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 29                           | 5     | 22.5 (572) | 88.6 (2250)  | 71.8 (1824) | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 30                           | 3     | 21 (533)   | 122.9 (3122) | 70 (1778)   | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.

**TABLE 7 - OPTIONAL ONE-PASS EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |               |              |               |                                |                                           |                                           |
|------------------------------|-------|------------|---------------|--------------|---------------|--------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A,B        | C             | D            | E-NOZZLE SIZE | WATER VOLUME. GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |               |              |               |                                |                                           |                                           |
| 30                           | 5     | 21 (533)   | 166.9 (4239)  | 70 (1778)    | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 30                           | 8     | 22.5 (572) | 132.2 (3358)  | 71.8 (1824)  | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 31                           | 8     | 22.5 (572) | 176.6 (4486)  | 71.8 (1824)  | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 32                           | 3     | 22.5 (572) | 88.6 (2250)   | 71.8 (1824)  | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 33                           | 3     | 21 (533)   | 166.9 (4239)  | 70 (1778)    | 8             | 71 (269)                       | 590 (37)                                  | 2190 (138)                                |
| 34                           | 3     | 22.5 (572) | 132.6 (3368)  | 71.8 (1824)  | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 34                           | 5     | 22.5 (572) | 176.21 (4476) | 71.8 (1824)  | 10            | 113 (428)                      | 810 (51)                                  | 3200 (202)                                |
| 36                           | 8     | 23.3 (592) | 208.6 (5298)  | 83.5 (2121)  | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |
| 37                           | 3     | 22.3 (566) | 180.9 (4595)  | 112.2 (2850) | 10            | 96 (363)                       | 840 (53)                                  | 3320 (209)                                |
| 37                           | 5     | 23.3 (592) | 164.3 (4173)  | 83.4 (2118)  | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.





**TABLE 7 - OPTIONAL ONE-PASS EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |              |             |               |                                |                                           |                                           |
|------------------------------|-------|------------|--------------|-------------|---------------|--------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A,B        | C            | D           | E-NOZZLE SIZE | WATER VOLUME. GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |              |             |               |                                |                                           |                                           |
| 39                           | 8     | 23.3 (592) | 252.5 (6414) | 83.5 (2121) | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |
| 41                           | 3     | 22.5 (572) | 164.6 (4181) | 83.8 (2129) | 10            | 130 (492)                      | 940 (59)                                  | 3420 (215)                                |
| 42                           | 5     | 22.5 (572) | 252.6 (6416) | 83.8 (2129) | 10            | 130 (492)                      | 940 (59)                                  | 3420 (215)                                |
| 42                           | 8     | 23.3 (592) | 296.5 (7531) | 83.5 (2121) | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |
| 44                           | 3     | 22.3 (566) | 287.1 (7292) | 94.2 (2393) | 10            | 96 (363)                       | 840 (53)                                  | 3320 (209)                                |
| 47                           | 5     | 23.3 (592) | 308.4 (7833) | 71.5 (1816) | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |
| 48                           | 3     | 22.3 (566) | 331.2 (8412) | 94.2 (2393) | 10            | 96 (363)                       | 840 (53)                                  | 3320 (209)                                |
| 49                           | 0     | 22.5 (571) | 176.5 (4482) | 71.7 (1820) | 10            | 130 (492)                      | 940 (59)                                  | 3420 (215)                                |
| 50                           | 0     | 23.3 (592) | 176.2 (4475) | 71.5 (1816) | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |
| 52                           | 3     | 23.3 (592) | 308.4 (7833) | 71.5 (1816) | 10            | 147 (556)                      | 1090 (69)                                 | 3420 (215)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.

SIDE VIEW



LD19639

FRONT VIEW




TABLE 8 - STANDARD TWO-PASS, REAR INLET/OUTLET EVAPORATOR

| ALL DIMENSIONS - INCHES (MM) |       |            |            |              |   |               |             |   |                               |                                           |                                           |
|------------------------------|-------|------------|------------|--------------|---|---------------|-------------|---|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B          | C            | D | E-NOZZLE SIZE | F           | G | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |            |              |   |               |             |   |                               |                                           |                                           |
| 15                           | 3     | 15.1 (384) | 11.4 (290) | 6.8 (173)    | — | 6             | 34.5 (876)  | — | 58 (220)                      | 250 (16)                                  | 980 (62)                                  |
| 16                           | 5     | 15.1 (384) | 11.4 (290) | 29.4 (747)   | — | 6             | 56.1 (1425) | — | 58 (220)                      | 250 (16)                                  | 980 (62)                                  |
| 17                           | 8     | 15.1 (384) | 11.4 (290) | 34.9 (886)   | — | 6             | 70 (1778)   | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |
| 18                           | 3     | 14.1 (358) | 11.4 (290) | 17.7 (450)   | — | 6             | 56.8 (1443) | — | 48 (182)                      | 200 (13)                                  | 790 (50)                                  |
| 19                           | 5     | 14.1 (358) | 11.4 (290) | 61.5 (1562)  | — | 6             | 56.7 (1440) | — | 48 (182)                      | 200 (13)                                  | 790 (50)                                  |
| 19                           | 8     | 15.3 (389) | 11.4 (290) | 117.3 (2979) | — | 6             | 56.1 (1425) | — | 58 (220)                      | 250 (16)                                  | 980 (62)                                  |
| 20                           | 0     | 15.1 (384) | 11.4 (290) | 1.7 (43)     | — | 6             | 38.1 (968)  | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |
| 21                           | 3     | 14.1 (358) | 11.4 (290) | 61.7 (1567)  | — | 6             | 58.8 (1494) | — | 48 (182)                      | 200 (13)                                  | 790 (50)                                  |
| 21                           | 5     | 15.1 (384) | 11.4 (290) | 29.9 (759)   | — | 6             | 70 (1778)   | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |
| 21                           | 8     | 15.3 (389) | 11.4 (290) | 78.9 (2004)  | — | 6             | 70.3 (1786) | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.





**TABLE 8 - STANDARD TWO-PASS, REAR INLET/OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |            |              |   |               |             |   |                               |                                           |                                           |
|------------------------------|-------|------------|------------|--------------|---|---------------|-------------|---|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B          | C            | D | E-NOZZLE SIZE | F           | G | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |            |              |   |               |             |   |                               |                                           |                                           |
| 23                           | 3     | 15.1 (384) | 11.4 (290) | 73.3 (1862)  | — | 6             | 56.1 (1425) | — | 58 (220)                      | 250 (16)                                  | 980 (62)                                  |
| 24                           | 5     | 15.3 (389) | 11.4 (290) | 29.9 (759)   | — | 6             | 56.1 (1425) | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |
| 24                           | 8     | 15.3 (389) | 11.4 (290) | 122.9 (3122) | — | 6             | 70 (1778)   | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |
| 26                           | 3     | 15.3 (389) | 11.4 (290) | 117.3 (2979) | — | 6             | 56.1 (1425) | — | 58 (220)                      | 250 (16)                                  | 980 (62)                                  |
| 27                           | 0     | 15.3 (388) | 11.4 (290) | 16.8 (427)   | — | 6             | 51.9 (1318) | — | 82 (310)                      | 300 (19)                                  | 1170 (74)                                 |
| 27                           | 3     | 15.3 (389) | 11.4 (290) | 42.9 (1090)  | — | 6             | 70 (1778)   | — | 82 (310)                      | 300 (19)                                  | 1170 (74)                                 |
| 27                           | 5     | 15.5 (394) | 14 (356)   | 44.3 (1125)  | — | 8             | 71.8 (1824) | — | 113 (428)                     | 410 (26)                                  | 1600 (101)                                |
| 27                           | 8     | 15 (381)   | 14 (356)   | 88.3 (2243)  | — | 8             | 71.8 (1824) | — | 113 (428)                     | 410 (26)                                  | 1600 (101)                                |
| 29                           | 5     | 15.5 (394) | 14 (356)   | 88.3 (2243)  | — | 8             | 71.8 (1824) | — | 113 (428)                     | 410 (26)                                  | 1600 (101)                                |
| 30                           | 3     | 15.3 (389) | 11.4 (290) | 122.9 (3122) | — | 6             | 70 (1778)   | — | 71 (269)                      | 300 (19)                                  | 1170 (74)                                 |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.

**TABLE 8 - STANDARD TWO-PASS, REAR INLET/OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |               |               |                  |                 |                |                 |                 |                               |                                           |                                           |
|------------------------------|-------|---------------|---------------|------------------|-----------------|----------------|-----------------|-----------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A             | B             | C                | D               | E- NOZZLE SIZE | F               | G               | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |               |               |                  |                 |                |                 |                 |                               |                                           |                                           |
| 30                           | 5     | 15.3<br>(389) | 11.4<br>(290) | 166.8<br>(4237)  | —               | 6              | 70<br>(1778)    | —               | 71<br>(269)                   | 300 (19)                                  | 1170 (74)                                 |
| 30                           | 8     | 15.5<br>(394) | 14<br>(356)   | 132.2<br>(3358)  | —               | 8              | 83.4<br>(2118)  | —               | 113<br>(428)                  | 410 (26)                                  | 1600 (101)                                |
| 31                           | 8     | 15.5<br>(394) | 14<br>(356)   | 176.21<br>(4476) | —               | 8              | 83.4<br>(2118)  | —               | 113<br>(428)                  | 410 (26)                                  | 1600 (101)                                |
| 32                           | 3     | 15.5<br>(394) | 14<br>(356)   | 88.6<br>(2250)   | —               | 8              | 83.4<br>(2118)  | —               | 113<br>(428)                  | 410 (26)                                  | 1600 (101)                                |
| 33                           | 3     | 15.3<br>(389) | 11.4<br>(290) | 166.9<br>(4239)  | —               | 6              | 83.4<br>(2118)  | —               | 71<br>(269)                   | 300 (19)                                  | 1170 (74)                                 |
| 34                           | 3     | 15.5<br>(394) | 14<br>(356)   | 132.2<br>(3358)  | —               | 8              | 83.4<br>(2118)  | —               | 113<br>(428)                  | 410 (26)                                  | 1600 (101)                                |
| 34                           | 5     | 15.5<br>(394) | 14<br>(356)   | 176.2<br>(4475)  | —               | 8              | 83.4<br>(2118)  | —               | 113<br>(428)                  | 410 (26)                                  | 1600 (101)                                |
| 36                           | 8     | 16.3<br>(414) | 14<br>(356)   | 208.5<br>(5296)  | —               | 8              | 83.4<br>(2118)  | —               | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |
| 37                           | 3     | 15.8<br>(401) | 13<br>(330)   | 180.9<br>(4595)  | 176.4<br>(4480) | 8              | 112.2<br>(2850) | 107.7<br>(2735) | 96<br>(363)                   | 420 (26)                                  | 1660 (105)                                |
| 37                           | 5     | 16.3<br>(414) | 14<br>(356)   | 164.4<br>(4176)  | —               | 8              | 83.4<br>(2118)  | —               | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.





**TABLE 8 - STANDARD TWO-PASS, REAR INLET/OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |               |             |                 |                 |                |                |                |                               |                                           |                                           |
|------------------------------|-------|---------------|-------------|-----------------|-----------------|----------------|----------------|----------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A             | B           | C               | D               | E- NOZZLE SIZE | F              | G              | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |               |             |                 |                 |                |                |                |                               |                                           |                                           |
| 39                           | 8     | 16.3<br>(414) | 14<br>(356) | 252.5<br>(6414) | —               | 8              | 83.5<br>(2121) | —              | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |
| 41                           | 3     | 15.5<br>(394) | 14<br>(356) | 164.6<br>(4181) | —               | 8              | 83.8<br>(2129) | —              | 130<br>(492)                  | 470 (30)                                  | 1870 (118)                                |
| 42                           | 5     | 15.5<br>(394) | 14<br>(356) | 252.6<br>(6416) | —               | 8              | 83.8<br>(2129) | —              | 130<br>(492)                  | 470 (30)                                  | 1870 (118)                                |
| 42                           | 8     | 16.3<br>(414) | 14<br>(356) | 296.5<br>(7531) | —               | 8              | 83.5<br>(2121) | —              | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |
| 44                           | 3     | 15.8<br>(401) | 13<br>(330) | 287.1<br>(7292) | 282.5<br>(7177) | 8              | 94.2<br>(2393) | 89.7<br>(2278) | 96<br>(363)                   | 420 (26)                                  | 1660 (105)                                |
| 47                           | 5     | 16.3<br>(414) | 14<br>(356) | 308.4<br>(7833) | —               | 8              | 71.5<br>(1816) | —              | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |
| 48                           | 3     | 15.8<br>(401) | 13<br>(330) | 331.2<br>(8412) | 326.6<br>(8296) | 8              | 94.2<br>(2393) | 89.7<br>(2278) | 96<br>(363)                   | 420 (26)                                  | 1660 (105)                                |
| 49                           | 0     | 15.5<br>(394) | 14<br>(355) | 176.5<br>(4482) | —               | 8              | 71.7<br>(1820) | —              | 130<br>(492)                  | 470 (30)                                  | 1870 (118)                                |
| 50                           | 0     | 16.3<br>(414) | 14<br>(356) | 176.2<br>(4475) | —               | 8              | 71.5<br>(1816) | —              | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |
| 52                           | 3     | 16.3<br>(414) | 14<br>(356) | 308.4<br>(7833) | —               | 8              | 71.5<br>(1816) | —              | 147<br>(556)                  | 550 (35)                                  | 2160 (136)                                |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.



LD19641

**TABLE 9 - OPTIONAL THREE-PASS REAR INLET/FRONT OUTLET EVAPORATOR**

| ALL DIMENSIONS - INCHES (MM) |       |            |             |              |             |                |                               |                                           |                                           |
|------------------------------|-------|------------|-------------|--------------|-------------|----------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B           | C            | D           | E- NOZZLE SIZE | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |             |              |             |                |                               |                                           |                                           |
| 15                           | 3     | 15.1 (384) | 26.5 (673)  | 6.8 (173)    | 34.5 (876)  | 5              | 58 (220)                      | 170 (11)                                  | 650 (41)                                  |
| 16                           | 5     | 15.1 (384) | 26.5 (673)  | 29.2 (742)   | 56.1 (1425) | 5              | 58 (220)                      | 170 (11)                                  | 650 (41)                                  |
| 17                           | 8     | 15.1 (384) | 26.5 (673)  | 34.9 (886)   | 70 (1778)   | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 18                           | 3     | 25.5 (648) | 25.5 (648)  | 17.7 (450)   | 56.8 (1443) | 5              | 48 (182)                      | 130 (8)                                   | 520 (33)                                  |
| 19                           | 5     | 14.1 (358) | 25.5 (648)  | 61.5 (1562)  | 56.7 (1440) | 5              | 48 (182)                      | 130 (8)                                   | 520 (33)                                  |
| 19                           | 8     | 15.3 (389) | 26.7 (678)  | 117.3 (2979) | 56.1 (1425) | 5              | 58 (220)                      | 170 (11)                                  | 650 (41)                                  |
| 20                           | 0     | 15.1 (384) | 26.53 (674) | 1.7 (43)     | 38.1 (968)  | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 21                           | 3     | 14.1 (358) | 25.5 (648)  | 61.6 (1565)  | 58.8 (1494) | 5              | 48 (182)                      | 130 (8)                                   | 520 (33)                                  |
| 21                           | 5     | 15.1 (384) | 26.5 (673)  | 34.9 (886)   | 70 (1778)   | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 21                           | 8     | 15.3 (389) | 26.7 (678)  | 78.9 (2004)  | 70.3 (1786) | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.





**TABLE 9 - OPTIONAL THREE-PASS REAR INLET/FRONT OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |            |              |             |                |                               |                                           |                                           |
|------------------------------|-------|------------|------------|--------------|-------------|----------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B          | C            | D           | E- NOZZLE SIZE | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |            |              |             |                |                               |                                           |                                           |
| 23                           | 3     | 14.1 (358) | 25.5 (648) | 73.2 (1859)  | 56.1 (1425) | 5              | 58 (220)                      | 170 (11)                                  | 650 (41)                                  |
| 24                           | 5     | 15.3 (389) | 26.7 (678) | 29.9 (759)   | 56.1 (1425) | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 24                           | 8     | 15.3 (389) | 26.7 (678) | 122.9 (3122) | 70 (1778)   | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 26                           | 3     | 15.3 (389) | 26.7 (678) | 117.1 (2974) | 56.1 (1425) | 5              | 58 (220)                      | 170 (11)                                  | 650 (41)                                  |
| 27                           | 0     | 15.3 (388) | 26.7 (678) | 16.8 (427)   | 51.9 (1318) | 6              | 82 (310)                      | 200 (13)                                  | 780 (49)                                  |
| 27                           | 3     | 15.3 (389) | 26.7 (678) | 42.9 (1090)  | 70 (1778)   | 6              | 82 (310)                      | 200 (13)                                  | 780 (49)                                  |
| 27                           | 5     | 15.5 (394) | 29.5 (749) | 88.6 (2250)  | 71.8 (1824) | 6              | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 27                           | 8     | 15.5 (394) | 29.5 (749) | 88.3 (2243)  | 71.8 (1824) | 6              | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 29                           | 5     | 15.5 (394) | 29.5 (749) | 88.6 (2250)  | 71.8 (1824) | 6              | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 30                           | 3     | 15.3 (389) | 26.7 (678) | 122.9 (3122) | 70 (1778)   | 6              | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.

**TABLE 9 - OPTIONAL THREE-PASS REAR INLET/FRONT OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |            |              |              |               |                               |                                           |                                           |
|------------------------------|-------|------------|------------|--------------|--------------|---------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B          | C            | D            | E-NOZZLE SIZE | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |            |              |              |               |                               |                                           |                                           |
| 30                           | 5     | 15.3 (389) | 26.7 (678) | 166.9 (4239) | 70 (1778)    | 6             | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 30                           | 8     | 15 (381)   | 30.3 (770) | 132.2 (3358) | 71.8 (1824)  | 6             | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 31                           | 8     | 15 (381)   | 29.5 (749) | 176.6 (4486) | 71.8 (1824)  | 6             | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 32                           | 3     | 15.5 (394) | 29.5 (749) | 88.6 (2250)  | 71.8 (1824)  | 6             | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 33                           | 3     | 15.3 (389) | 26.7 (678) | 166.9 (4239) | 70 (1778)    | 6             | 71 (269)                      | 200 (13)                                  | 780 (49)                                  |
| 34                           | 3     | 15.5 (394) | 29.5 (749) | 132.6 (3368) | 71.8 (1824)  | 6             | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 34                           | 5     | 15.5 (394) | 29.5 (749) | 176.2 (4475) | 71.8 (1824)  | 6             | 113 (428)                     | 270 (17)                                  | 1060 (67)                                 |
| 36                           | 8     | 16.3 (414) | 30.3 (770) | 208.6 (5298) | 83.5 (2121)  | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |
| 37                           | 3     | 15.8 (401) | 28.8 (732) | 180.9 (4595) | 112.2 (2850) | 6             | 94 (356)                      | 280 (18)                                  | 1100 (69)                                 |
| 37                           | 5     | 16.3 (414) | 30.3 (770) | 164.3 (4173) | 83.4 (2118)  | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.




**TABLE 9 - OPTIONAL THREE-PASS REAR INLET/FRONT OUTLET EVAPORATOR (CONT'D)**

| ALL DIMENSIONS - INCHES (MM) |       |            |            |              |             |               |                               |                                           |                                           |
|------------------------------|-------|------------|------------|--------------|-------------|---------------|-------------------------------|-------------------------------------------|-------------------------------------------|
| YVAA                         |       | A          | B          | C            | D           | E-NOZZLE SIZE | WATER VOLUME GALLONS (LITERS) | MINIMUM CHILLED WATER FLOW RATE GPM (L/S) | MAXIMUM CHILLED WATER FLOW RATE GPM (L/S) |
| FRAME                        | COND. |            |            |              |             |               |                               |                                           |                                           |
| 39                           | 8     | 16.3 (414) | 30.3 (770) | 252.5 (6414) | 83.5 (2121) | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |
| 41                           | 3     | 15.5 (394) | 29.5 (749) | 164.6 (4181) | 83.8 (2129) | 6             | 128 (485)                     | 320 (20)                                  | 1230 (77)                                 |
| 42                           | 5     | 15.5 (394) | 29.5 (749) | 252.6 (6416) | 83.8 (2129) | 6             | 128 (485)                     | 320 (20)                                  | 1230 (77)                                 |
| 42                           | 8     | 16.3 (414) | 30.3 (770) | 296.5 (7531) | 83.5 (2121) | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |
| 44                           | 3     | 15.8 (401) | 28.8 (732) | 287.1 (7292) | 94.2 (2393) | 6             | 94 (356)                      | 280 (18)                                  | 1100 (69)                                 |
| 47                           | 5     | 16.3 (414) | 30.3 (770) | 308.4 (7833) | 71.5 (1816) | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |
| 48                           | 3     | 15.8 (401) | 28.8 (732) | 331.2 (8412) | 94.2 (2393) | 6             | 94 (356)                      | 280 (18)                                  | 1100 (69)                                 |
| 49                           | 0     | 15.5 (394) | 29.5 (749) | 176.2 (4476) | 71.5 (1817) | 6             | 130 (492)                     | 320 (20)                                  | 1230 (77)                                 |
| 50                           | 0     | 16.3 (414) | 30.3 (770) | 176.2 (4475) | 71.5 (1816) | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |
| 52                           | 3     | 16.3 (414) | 30.3 (770) | 308.4 (7833) | 71.5 (1816) | 8             | 147 (556)                     | 370 (23)                                  | 1440 (91)                                 |

**NOTE:** Minimum Chilled Water Flow Rate is for full load selections; Variable Primary Flow ratings as low as 50% of the minimum are permitted. Glycol limits are higher. Please contact your Johnson Controls Sales Office for ratings and further information.

The data below is applicable to select configurations. Other configurations are available through our configuration/selection software.

Please contact your nearest Johnson Controls Sales Office for the chiller configuration that best matches your specific needs.




**FIGURE 17 - YVAA DIMENSIONS**

THIS PAGE INTENTIONALLY LEFT BLANK




LD18587

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 1           | 2            | 3             | 4             | 5             | 6             | 7 | 8 |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|---------------|---|---|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |               |   |   |
| 015                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 73<br>(1852) | 144<br>(3662) | 193<br>(4900) |               |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 016                | 5    | B    | Isolator X-Dimension | 10<br>(263) | 77<br>(1943) | 118<br>(3000) | 157<br>(3985) | 220<br>(5589) |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 017                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 018                | 3    | A    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 124<br>(3152) | 163<br>(4137) | 210<br>(5323) |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 019                | 5    | A    | Isolator X-Dimension | 10<br>(259) | 76<br>(1939) | 118<br>(2997) | 157<br>(3982) | 208<br>(5295) | 281<br>(7132) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 019                | 8    | B    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(3000) | 157<br>(3985) | 209<br>(5299) | 308<br>(7823) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 020                | 0    | C    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(3000) | 157<br>(3985) | 209<br>(5299) | 281<br>(7136) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 021                | 3    | A    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 021                | 5    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 021                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 235<br>(5968) | 301<br>(7653) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 023                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(2999) | 157<br>(3984) | 209<br>(5298) | 281<br>(7135) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 024                | 5    | C    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 128<br>(3260) | 173<br>(4391) | 220<br>(5579) | 301<br>(7654) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |
| 024                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3638) | 187<br>(4748) | 245<br>(6232) | 339<br>(8609) |   |   |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |               |   |   |

**NOTES:**

1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).



LD18587

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS (CONT'D)**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 9           | 10           | 11            | 12            | 13            | 14            | 15 | 16 |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|---------------|----|----|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |               |    |    |
| 015                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 73<br>(1852) | 144<br>(3662) | 193<br>(4900) |               |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 016                | 5    | B    | Isolator X-Dimension | 10<br>(263) | 77<br>(1943) | 118<br>(3000) | 157<br>(3985) | 220<br>(5589) |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 017                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 018                | 3    | A    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 124<br>(3152) | 163<br>(4137) | 210<br>(5323) |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 019                | 5    | A    | Isolator X-Dimension | 10<br>(259) | 76<br>(1939) | 118<br>(2997) | 157<br>(3982) | 208<br>(5295) | 281<br>(7132) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 019                | 8    | B    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(3000) | 157<br>(3985) | 209<br>(5299) | 308<br>(7823) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 020                | 0    | C    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(3000) | 157<br>(3985) | 209<br>(5299) | 281<br>(7136) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 021                | 3    | A    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 021                | 5    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 251<br>(6368) |               |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 021                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 235<br>(5968) | 301<br>(7653) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 023                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 118<br>(2999) | 157<br>(3984) | 209<br>(5298) | 281<br>(7135) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 024                | 5    | C    | Isolator X-Dimension | 10<br>(263) | 76<br>(1943) | 128<br>(3260) | 173<br>(4391) | 220<br>(5579) | 301<br>(7654) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |
| 024                | 8    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3638) | 187<br>(4748) | 245<br>(6232) | 339<br>(8609) |    |    |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |               |    |    |

**NOTES:**

1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS (CONT'D)**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 1           | 2            | 3             | 4             | 5             | 6              | 7              | 8              |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|----------------|----------------|----------------|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |                |                |                |
| 026                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 77<br>(1943) | 118<br>(2999) | 157<br>(3984) | 209<br>(5298) | 308<br>(7823)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 027                | 0    | D    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 264<br>(6709) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 027                | 3    | D    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 301<br>(7654) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 027                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 301<br>(7654) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 027                | 8    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4095) | 201<br>(5105) | 298<br>(7582) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 029                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4095) | 201<br>(5105) | 296<br>(7512) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 030                | 3    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3638) | 187<br>(4748) | 245<br>(6232) | 339<br>(8608)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 030                | 5    | C    | Isolator X-Dimension | 10<br>(260) | 81<br>(2057) | 144<br>(3663) | 187<br>(4755) | 277<br>(7047) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 030                | 8    | E    | Isolator X-Dimension | 10<br>(260) | 81<br>(2054) | 161<br>(4081) | 201<br>(5102) | 298<br>(7579) | 383<br>(9723)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 031                | 8    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 032                | 3    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 033                | 3    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3636) | 188<br>(4781) | 245<br>(6232) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 034                | 3    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 034                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 036                | 8    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 205<br>(5219) | 284<br>(7218) | 383<br>(9725)  | 439<br>(11157) | 495<br>(12577) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |

**NOTES:**

1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS (CONT'D)**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 9           | 10           | 11            | 12            | 13            | 14             | 15             | 16             |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|----------------|----------------|----------------|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |                |                |                |
| 026                | 3    | B    | Isolator X-Dimension | 10<br>(263) | 77<br>(1943) | 118<br>(2999) | 157<br>(3984) | 209<br>(5298) | 308<br>(7823)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 027                | 0    | D    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 149<br>(3779) | 187<br>(4756) | 264<br>(6709) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 027                | 3    | D    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 301<br>(7654) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 027                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 301<br>(7654) |                |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 027                | 8    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4095) | 201<br>(5105) | 298<br>(7582) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 029                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4095) | 201<br>(5105) | 296<br>(7512) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 030                | 3    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3638) | 187<br>(4748) | 245<br>(6232) | 339<br>(8608)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 030                | 5    | C    | Isolator X-Dimension | 10<br>(260) | 81<br>(2057) | 144<br>(3663) | 187<br>(4755) | 277<br>(7047) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 030                | 8    | E    | Isolator X-Dimension | 10<br>(260) | 81<br>(2054) | 161<br>(4081) | 201<br>(5102) | 298<br>(7579) | 383<br>(9723)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 031                | 8    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 032                | 3    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 339<br>(8609)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 033                | 3    | C    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 143<br>(3636) | 188<br>(4781) | 245<br>(6232) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 034                | 3    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 383<br>(9726)  |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 034                | 5    | E    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 161<br>(4084) | 201<br>(5105) | 298<br>(7582) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 036                | 8    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 205<br>(5219) | 284<br>(7218) | 383<br>(9725)  | 439<br>(11157) | 495<br>(12577) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |

**NOTES:**

1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS (CONT'D)**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 1           | 2            | 3             | 4             | 5             | 6              | 7              | 8              |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|----------------|----------------|----------------|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |                |                |                |
| 037                | 3    | F    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 037                | 5    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 039                | 8    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 041                | 3    | H    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 205<br>(5219) | 284<br>(7218) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 042                | 5    | H    | Isolator X-Dimension | 10<br>(254) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 042                | 8    | J    | Isolator X-Dimension | 10<br>(260) | 81<br>(2054) | 145<br>(3677) | 205<br>(5216) | 284<br>(7215) | 427<br>(10839) | 505<br>(12817) | 562<br>(14262) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 044                | 3    | G    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 047                | 5    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 048                | 3    | G    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 049                | 0    | K    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 205<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 050                | 0    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(2908) | 205<br>(5219) | 284<br>(7218) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |
| 052                | 3    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 1 (34)      |              |               |               |               |                |                |                |

**NOTES:**



1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).

**TABLE 10 - ISOLATOR SELECTION AND MOUNTING LOCATIONS (CONT'D)**

| YVAA CONFIGURATION |      |      | DESCRIPTION          | 9           | 10           | 11            | 12            | 13            | 14             | 15             | 16             |
|--------------------|------|------|----------------------|-------------|--------------|---------------|---------------|---------------|----------------|----------------|----------------|
| FRAME              | COND | EVAP |                      |             |              |               |               |               |                |                |                |
| 037                | 3    | F    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 037                | 5    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 039                | 8    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 041                | 3    | H    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 145<br>(3680) | 205<br>(5219) | 284<br>(7218) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 042                | 5    | H    | Isolator X-Dimension | 10<br>(254) | 81<br>(2057) | 145<br>(3680) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 042                | 8    | J    | Isolator X-Dimension | 10<br>(260) | 81<br>(2054) | 145<br>(3677) | 205<br>(5216) | 284<br>(7215) | 427<br>(10839) | 505<br>(12817) | 562<br>(14262) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 044                | 3    | G    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 483<br>(12274) | 539<br>(13694) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 047                | 5    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 048                | 3    | G    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 049                | 0    | K    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 205<br>(5219) | 284<br>(7218) | 427<br>(10842) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 050                | 0    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(2908) | 205<br>(5219) | 284<br>(7218) | 427<br>(10843) |                |                |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |
| 052                | 3    | J    | Isolator X-Dimension | 10<br>(263) | 81<br>(2057) | 154<br>(3907) | 206<br>(5219) | 284<br>(7218) | 427<br>(10842) | 505<br>(12820) | 562<br>(14265) |
|                    |      |      | Isolator Y-Dimension | 87 (2206)   |              |               |               |               |                |                |                |

**NOTES:**

1. Contact your nearest Johnson Controls Sales Office for weight data.
2. All isolator mounting holes are 19mm.
3. Dimensions are in inches (mm).


**ELASTOMERIC ISOLATOR INSTALLATION**

LD13762C

Read the following instructions before beginning installation.

1. Isolators are shipped fully assembled and are to be positioned in accordance with the submittal drawings or as otherwise recommended.
2. Set isolators on floor, housekeeping pad or sub-base, ensuring that all isolator lines match the equipment mounting holes. The VMC group recommends that the isolator base (A) be installed on a level surface. Shim or grout as required, leveling all isolator bases to the same elevation (0.03125 of an inch maximum difference can be tolerated).
3. Bolt or anchor all isolators to supporting structure utilizing base thru holes (B).
4. Remove top bolt and top washer. Place equipment on top of isolators so that mounting holes in equipment or base line up with threaded hole (C).
5. Reinstall top bolt and washer and tighten down.


## ELASTOMERIC ISOLATOR SPECIFICATIONS



LD17304

| MOUNT TYPE | DIMENSION DATA (INCHES) |      |      |      |      |      |                   |      |
|------------|-------------------------|------|------|------|------|------|-------------------|------|
|            | L                       | W    | HF   | AL   | AD   | BT   | CD                | DW   |
| RD1-WR     | 3.13                    | 1.75 | 1.25 | 2.38 | 0.34 | 0.19 | 5/16-18 UNC X 3/4 | 1.25 |
| RD2-WR     | 3.88                    | 2.38 | 1.75 | 3.00 | 0.34 | 0.22 | 3/8-16 UNC X 1    | 1.75 |
| RD3-WR     | 5.50                    | 3.38 | 2.88 | 4.13 | 0.56 | 0.25 | 1/2-13 UNC X 1    | 2.50 |
| RD4-WR     | 6.25                    | 4.63 | 2.75 | 5.00 | 0.56 | 0.38 | 1/2-13 UNC X 1    | 3.00 |

| MODEL NUMBER      | ISOLATOR COLOR | WEIGHT RANGE (LBS) | WEIGHT RANGE (KGS) |
|-------------------|----------------|--------------------|--------------------|
| RD-3-CHARCOAL-WR  | CHARCOAL       | Up thru 825        | UP TO 374          |
| RD-4-BRICK RED-WR | BRICK RED      | 826 thru 1688      | 375 - 766          |
| RD-4-CHARCOAL-WR  | CHARCOAL       | 1689 thru 4000     | 767 - 1814         |


**ONE INCH DEFLECTION ISOLATOR INSTALLATION**

Read the following instructions before beginning installation.

1. Isolators are shipped fully assembled and are to be positioned in accordance with the submittal drawings or as otherwise recommended.
2. Set isolators on floor, housekeeping pad or sub-base, ensuring that all isolators centerlines match the equipment mounting holes. The VMC group recommends that the isolator base ("B") be installed on a level surface. Shim or grout as required, leveling all isolator bases to the same elevation (0.25-inch maximum difference can be tolerated).
3. Bolt or anchor all isolators to supporting structure utilizing base slotted holes ("C").
4. Place equipment on top of isolators making sure that mounting holes of the equipment line up with isolator positioning pin ("H").
5. Equipment or machine is at its full operating weight.
6. Adjust each isolator in sequence by turning spring adjusting bolt ("D") one full counterclockwise turn at a time. Repeat this procedure on all isolators, one at a time.
7. Continue adjusting each isolator until a minimum of 0.25" clearance is achieved between the lower housing and upper housing. See illustration above.
8. Fine adjust isolators to level equipment.

## ONE INCH DEFLECTION SPRING ISOLATOR SPECIFICATIONS

### CPX-xx-xxx




| MOUNT TYPE | DIMENSION DATA (INCHES) |     |        |       |       |      |       |
|------------|-------------------------|-----|--------|-------|-------|------|-------|
|            | W                       | D   | L      | B     | C     | T    | H     |
| CP         | 3                       | 5/8 | 7-3/4  | 6-1/2 | 4-3/4 | 1/2  | 5-5/8 |
| C2P        | 3                       | 5/8 | 10-1/2 | 9-1/4 | 7-3/4 | 9/16 | 6     |

| MODEL NUMBER | COLOR CODE | RATED CAPACITY (FOR UNITS WITH ALL LOAD POINTS LESS THAN 1785 LBS (810 KG)) |              |               |
|--------------|------------|-----------------------------------------------------------------------------|--------------|---------------|
|              |            | (LBS.)                                                                      | (KG)         | PART NUMBER   |
| CP-1D-510    | BLACK      | Up thru 434                                                                 | Up thru 197  | 029-25334-002 |
| CP-1D-900    | DARK GREEN | 435 thru 765                                                                | 198 thru 347 | 029-25334-003 |
| CP-1D-1200   | GRAY       | 766 thru 1020                                                               | 348 thru 463 | 029-25334-004 |
| CP-1D-1360   | WHITE      | 1021 thru 1156                                                              | 464 thru 524 | 029-25334-005 |
| CP-1D-1785N  | GRAY/RED   | 1157 thru 1785                                                              | 525 thru 810 | 029-25334-006 |

| MODEL NUMBER | COLOR CODE  | RATED CAPACITY (FOR UNITS WITH ANY LOAD POINT ABOVE 1518 LBS (689 KG)) |             |               |
|--------------|-------------|------------------------------------------------------------------------|-------------|---------------|
|              |             | (LBS.)                                                                 | (KG)        | PART NUMBER   |
| C2P-1D-1350  | DARK PURPLE | Up thru 1148                                                           | Up to 521   | 029-25334-008 |
| C2P-1D-1800  | DARK GREEN  | 1149 thru 1530                                                         | 522 - 694   | 029-25334-009 |
| C2P-1D-2400  | GRAY        | 1531 thru 2040                                                         | 695 - 925   | 029-25334-010 |
| C2P-1D-2720  | WHITE       | 2041 thru 2312                                                         | 926 - 1049  | 029-25334-012 |
| C2P-1D-3570N | GRAY/RED    | 2313 thru 3570                                                         | 1050 - 1619 | 029-25334-013 |

**NOTES:**

1. Use either all CP's or all CP2's at all locations on a unit.
2. Installation requires bolting or anchoring mount to support structure with a 2 x 0.625" diameter bolts or 2 x 0.5" diameter concrete anchors.
3. All springs are designed for 50% over-travel.


**TWO INCH DEFLECTION ISOLATOR INSTALLATION AND ADJUSTMENT**

Read the following instructions before beginning installation.

- Isolators are shipped fully assembled and are to be positioned in accordance with the submittal drawings or as otherwise recommended.
- Set isolators on floor, housekeeping pad, or sub-base, ensuring that all isolator centerlines match the equipment mounting holes. The VMC group recommends that the isolator base plates ("B") be installed on a level surface. Shim or grout as required, levelling all isolator base plates to the same elevation (0.25 of an inch maximum difference can be tolerated).
- Bolt or anchor all isolators to supporting structure utilizing base plate through holes ("C") or weld base plate to supporting structure with 0.375" fillet weld 2" long @ 4" on center around entire base plate or as engineered for specific load and or field conditions.
- Isolators are shipped to the job site with (2) removable spacer shims ("E") between the top plate and the housing. These shims must be in place when the equipment is positioned over the isolators.
- With all shims ("E") in place, position equipment on top of plate ("A") of isolator.
- Bolt equipment securely to top plate of isolator using a minimum of 2 x 0.625" UNC A325 GRADE 5 SAE bolts or weld equipment or bracket to the top plate ("A") of isolator with a minimum 0.375" fillet welds 2" long @ 3" O.C. for a minimum total weld of 10". (All sides of equipment or bracket resting on top plate ("A") must be welded).
- The adjustment process can only begin after the equipment or machine is at its full operating weight.
- Back off each of the 4 limit stop lock nuts ("F") on the isolators 0.5".
- Adjust each isolator in sequence by turning spring adjusting nuts ("G") one full clockwise turn at a time. Repeat this procedure on all isolators, one at a time. Check the limit stop lock nuts ("F") periodically to ensure that clearance between the washer and rubber grommet is maintained. Stop adjustment of isolator only when the top plate ("A") has risen just above the shim ("E").
- Remove all spacer shims ("E").
- Fine adjust isolators to level equipment.
- Adjust all limit stop lock nuts ("F") per isolator, maintaining 0.25-to 0.375-inch gap. The limit stop nuts must be kept at this gap to ensure uniform bolt loading during uplift (as the case when equipment is drained).

## TWO INCH DEFLECTION, RESTRAINED SPRING ISOLATOR SPECIFICATIONS

### Y2RSI-xx-xxx



| MODEL NUMBER   | WEIGHT RANGE (LBS) | WEIGHT RANGE (KGS) | YORK P/N      |
|----------------|--------------------|--------------------|---------------|
| Y2RSI-2D-460   | Up thru 391        | UP TO 177          | 029-25336-006 |
| Y2RSI-2D-710   | 392 thru 604       | 178 - 274          | 029-25336-008 |
| Y2RSI-2D-870   | 605 thru 740       | 275 - 336          | 029-25336-009 |
| Y2RSI-2D-1200N | 741 thru 1020      | 337 - 463          | 029-25336-010 |
| Y2RSI-2D-1690  | 1021 thru 1437     | 464 - 652          | 029-25336-011 |
| Y2RSI-2D-2640N | 1438 thru 2244     | 653 - 1018         | 029-25336-012 |
| Y2RSI-2D-2870N | 2245 thru 2618     | 1019 - 1188        | 029-25336-013 |
| Y2RSI-2D-3280N | 2619 thru 3740     | 1189 - 1696        | 029-25336-014 |


#### NOTES:

1. All dimensions are in inches, interpret as per ANSI Y14.
2. Equipment must be bolted or welded to the top plate to meet allowable seismic ratings.
3. All springs are designed for 50% overload capacity with exception of the 029-25336-013 and 029-25336-014.
4. Consult JCI for concrete installation.

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 6 - COMMISSIONING

### PREPARATION



***Commissioning of this unit should only be carried out by Johnson Controls Authorized personnel.***

Commissioning personnel should be thoroughly familiar with the information contained in this document before starting the unit.

The following basic checks should be made with the customer power to the unit switched OFF.



***Proper electrical lock out and tag out procedures must be followed.***

### Inspection

Inspect unit for installation damage. If found, take action and/or repair as appropriate.


### Refrigerant Charge

Packaged units are normally shipped as standard with a full refrigerant operating charge. Check that refrigerant pressure is present in both systems and that no leaks are apparent. If no pressure is present, a leak test must be undertaken, the leak(s) located and repaired.

Do not evacuate or liquid charge with static water in the evaporator. Turn the pump on. Take care to liquid charge slowly to avoid excessive thermal stress at the charging point and to assure the refrigerant temperature in the evaporator does not go below the freezing point with liquid refrigerant in the evaporator. Once the vacuum is broken, charge into the evaporator or flash tank with the Condenser Drain Valve (Flash Tank Feed) open and the chilled liquid pump ON to the full operating charge, as detailed in **SECTION 5 - TECHNICAL DATA**.

### Correct System Refrigerant Charge

The charge on a system should always be checked when operating for several minutes at full speed with the system stable. Stable conditions are defined as operation without fan cycling, economizer cycling, VI solenoid cycling, or any other system transient conditions. Ideal refrigerant charge will be reached when the refrigerant level in the evaporator is near the middle of the evaporator sight glass.



***Refrigerant should not be added or removed unless the level is at the bottom or the top of the glass. It is not necessary to weigh charge unless the entire charge has been lost. The ease of charging is possible since the microchannel coils hold only a small amount of refrigerant charge. A charging valve is located between the fixed orifice and the evaporator for adjusting charge. Charge should be added as liquid with the pump ON and liquid flowing through the evaporator.***

### Service and Oil Line Valves

Open each compressor oil, economizer, and discharge ball or service valves. If valves are of the back-seat type, open them fully (counterclockwise) then close one turn of the stem to ensure operating pressure is fed to pressure transducers.

### Compressor Oil

To add oil to a circuit - connect a YORK hand oil pump (Part No. 470-10654-000) to the 1/4" (6.35 mm) oil charging valve on the oil separator piping with a length of clean hose or copper line, but do not tighten the flare nut. Using clean oil of the correct type ("L" oil), pump oil until all air has been purged from the hose then tighten the nut. Stroke the oil pump to add oil to the oil system. While the compressor is running at full speed, the oil level should be visible in the sight glass of the oil separator. Approximately 2 to 3.1 gallons (7.5 to 11.6 liters) are present in each refrigerant system.

Avoid levels in either oil separator that are above the middle of the top sight glass. This may cause excessive oil carryover in the system.

High oil concentration in the system may cause nuisance trips resulting from incorrect readings on the level sensor and temperature sensors. Temperature sensor errors may result in poor liquid control which will result in liquid overfeed and subsequently damage the compressor. High oil carryover may also cause liquid to be returned to the compressor, which can damage the compressor.

### Fans

Check that all fans are free to rotate and are not damaged. Ensure blades are at the same height when rotated. Ensure fan guards are securely fixed.

### Isolation / Protection

Verify all sources of electrical supply to the unit are taken from a single point of isolation. Check that the maximum recommended fuse sizes given in *SECTION 5 - TECHNICAL DATA* has not been exceeded.

### Control Panel

Check the panel to see that it is free of foreign materials (wire, metal chips, and so on) and clean out if required.

### Power Connections

Check that the customer power cables are connected correctly to the terminal blocks or optional circuit breaker. Ensure that connections of power cables within the panels to the circuit breaker or terminal blocks are tight.

### Grounding

Verify that the unit's protective ground terminal(s) are properly connected to a suitable grounding point. Ensure that all unit internal ground connections are tight.

### Water System

Verify the chilled liquid system has been installed correctly, and has been commissioned with the correct direction of water flow through the evaporator. The inlet should be at the bottom connection on a two pass evaporator. Purge air from the top of the evaporator using the plugged air vent mounted on the top of the evaporator body.

Flow rates and pressure drops must be within the limits given in *SECTION 5 - TECHNICAL DATA*. Operation outside of these limits is undesirable and could cause damage. If main power must be switched OFF for maintenance or shutdown, precautions must be taken.

See *Unit Maintenance and Shutdown in Sub-freezing Conditions on Page 100*. Before placing the unit back in service, valves should be opened and power must be switched on (if power is removed for more than 8 hours) for at least 8 hours (24 hours if ambient temperature is below 86°F [30°C]) before the unit is restarted.

### Flow Switch

Verify a chilled water flow switch is correctly fitted in the customer's piping on the evaporator outlet, and wired into the control panel correctly using shielded cable.

There should be a straight run of at least five pipe diameters on either side of the flow switch. The flow switch should be connected to Terminals 2 and 13 in the panel.

### Temperature Sensor(s)

Ensure that the leaving liquid temperature sensor is coated with heat conductive compound (Part No. 013-00890-000) and is inserted to the bottom of the water outlet sensor well in the evaporator. This sensor is part of the pump control freeze protection operation. It provides some freeze protection and must always be fully inserted in the water outlet sensor well.

### Programmed Options

Verify that the options factory-programmed into the Micro Panel are in accordance with the customer's order requirements by pressing the OPTIONS key on the keypad and reading the settings from the display.

### Programmed Settings

Ensure the system cutout and operational settings are in accordance with the operating requirements by pressing the PROGRAM key.

### Date and Time

Program the date and time by first ensuring that the CLK jumper JP2 on the Chiller Control Board is in the ON position. Then press the DATE/TIME key and set the date and time (see *"Date/Time and Schedule Keys" on page 153*).

### Start/Stop Schedule


Program the daily and holiday start/stop by pressing the SCHEDULE key (see *"Date/Time and Schedule Keys" on page 153*).

## Setpoint and Remote Offset

Set the required leaving chilled liquid temperature setpoint and Control Range under the SETPOINTS key. The chilled liquid temperature control settings need to be set according to the required operating conditions.

If remote temperature reset (offset) is to be used, the maximum reset required must be programmed by pressing the SETPOINTS key (see "Setpoints Key" on page 145).

## FIRST TIME START UP



*During the commissioning period there should be sufficient heat load to run the unit under stable full load operation to enable the unit controls, and system operation to be set up correctly, and a commissioning log taken.*

## Interlocks

Verify that liquid is flowing through the evaporator and that heat load is present. Ensure that any remote run interlocks are in the run position and that the Daily Schedule requires the unit to run or is overridden.

## Unit Switch

Place the UNIT switch on the keypad to the ON position.

## Startup

Press the SYSTEM SWITCHES key and place the system switch for System 1 to the ON position. There may be a few seconds delay before the first compressor starts because of the anti-recycle timer). Be ready when each compressor starts, to switch the UNIT switch OFF immediately, if any unusual noises or other adverse conditions develop.

When a compressor is running, the controller monitors oil pressure, motor current, and various other system parameters such as discharge pressure, chilled liquid temperature, and so on. Should any problems occur; the control system will immediately take appropriate action and display the nature of the fault.

## Oil Pressure

When a compressor starts, press the relevant "System Pressures" key and verify that oil differential pressure (oil pressure-suction pressure) develops immediately. If oil pressure does not develop, the automatic controls will shut down the compressor. Under no circumstances should a restart attempt be made on a compressor, which does not develop oil pressure immediately. Switch the UNIT switch to the OFF position.

## Loading

Once the unit has been started, all operations are fully automatic. After an initial period at minimum capacity, the control system will adjust the unit load depending on the chilled liquid temperature and rate of temperature change. If a high heat load is present, the controller will increase the speed of the compressor(s).

## Condenser and Fan Rotation

Once a compressor is running, discharge pressure rises as refrigerant is pumped into the air-cooled condenser coils. This pressure is controlled by stages of fans to ensure maximum unit efficiency while maintaining sufficient pressure for correct operation of the condensers and the lubrication system.

As discharge pressure rises, the condenser fans operate in stages or ramp up in speed to control the pressure. Verify that the fans operate in the correct direction of rotation and operation is correct for the type of unit.

## System Charge

Check system charge at steady full compressor load only. It is important that all fans are running for the system. The refrigerant level in the evaporator should be about in the middle of the sight glass. Unless levels are at the bottom or the top of the sight glass, they should not cause concern or require adding or removing charge.

## GENERAL OPERATION

After completion of the above checks for System 1, switch OFF the SYS 1 switch on the keypad and repeat the process for each subsequent system. When all run correctly, stop the unit, switch all applicable switches to the 'ON' position and restart the unit.

Assure all checks are completed in the Equipment Pre - Startup and Startup Checklist. The chiller is then ready to be placed into operation.

### Operation in Sub-freezing Conditions

The YVAA may be operated in sub-freezing conditions if the following freeze protections are taken:

- A. A suction service valve electric actuator is installed. Chiller software will operate the actuator in order to protect against freezing due to evaporator refrigerant migration.

-or-

- B. No suction service valve is installed but the water circuit valves are kept open, there is continuous power to the chiller and pump for chilled water pump control, and the pump will operate and circulate water through the evaporator whenever commanded by the chiller.



*The above operation is only advised if uninterrupted power can be ensured. Unforeseen power interruptions can damage the evaporator in a very short time frame if the temperature falls below freezing.*

If there is potential for power loss, Johnson Controls recommends the water in the chilled water circuit be replaced with an appropriate water-to-glycol concentration.

## Unit Maintenance and Shutdown in Sub-freezing Conditions

If the YVAA is maintained or shut down and will be subjected to sub-freezing conditions, it is critical to protect against evaporator and waterbox freeze damage. Johnson Controls recommends the following options (in order of freeze protection level) be performed on each circuit.

- A. **Glycol:** Replace water with an appropriate water to glycol concentration of antifreeze.

-or-

- B. **Drain:** Remove power to the waterbox heaters. Close the water valves, drain the evaporator, and leave the evaporator drain valves open.

-or-


- C. **Refrigerant Valve - Off:** Close the water valves, close flash tank drain valves, close the suction service valves and leave power to the chiller for evaporator heater mat and waterbox heater operation. For units without a suction service valve, close the discharge and compressor oil valves.

-or-

- D. **Pump Control:** Keep power to the chiller in order to have control over chilled water pumps and heater operation and leave the water circuit valves open. This will enable water to circulate through the evaporator to avoid freezing.



*Options A and B are the recommended processes for unit maintenance and shutdown. Unforeseen power interruptions can damage the evaporator in a very short time frame if the temperature falls below freezing.*



*Failure to follow Johnson Controls freeze protection recommendations can void the warranty.*

## SECTION 7 - OPERATION

### OPERATING CONTROLS




**FIGURE 18 - KEYBOARD AND DISPLAY**

#### Unit Switch

A double pole single throw ON/OFF rocker switch on the front of the control panel is used to turn the entire chiller ON and OFF. When the switch is placed in the OFF position, the entire unit shuts down immediately and all systems will be disabled. One pole of the UNIT switch contacts is wired to the Run Signal input and the Chiller Control Board “UNIT switch X” digital input (X equals System 1 or 2). Separate System Fuses are also wired in series with each set of UNIT switch contacts. If either fuse is pulled or blown, only the system with the good fuse (Input is high) will run. When both inputs are high, the entire chiller will be enabled to run. When both inputs are low, the chiller will be disabled as a UNIT switch OFF Shutdown.

#### Keypad

An operator keypad allows complete control of the system from a central location. The keypad offers a multitude of command keys on the left and right side of the keypad to access displays, program setpoints, history data, and initiate system commands. Most keys have multiple displays that can be accessed by repetitively pressing the key or by pressing the ▲, ▼, ◀, and ▶ (ARROW) keys. The keypad utilizes an overlay to convert the keypad to various languages.

The keypad also contains keys in the center section for data entry in the various program modes. These keys are listed below:

- 0-9 Keys NUMERIC KEYPAD
- PERIOD/DECIMAL
- +/- PLUS/MINUS
- ✓ ENTER
- ✕ CANCEL
- ▲ UP ARROW
- ▼ DOWN ARROW
- ◀ LEFT ARROW
- ▶ RIGHT ARROW

The numeric keys allow keying numeric values into memory.

The • (PERIOD/DECIMAL) key allows keying a decimal point into numeric values.

The +/- (PLUS/MINUS) key allows making numeric values negative.

The ✓ (ENTER) key stores program changes into memory.

The X (CANCEL) key is used to cancel the data entry operation and returns the programmed value to the original value, before any programming changes were made, when an error is made.

The ▲ (UP ARROW) and ▼ (DOWN ARROW) keys allow scrolling backward (▲) and forward (▼) through items to be programmed under keys such as the PROGRAM or OPTIONS key.

The ▲ (UP ARROW) and ▼ (DOWN ARROW) keys also allow scrolling forward (▼) or backwards (▲) through data display keys that have multiple displays under keys such as UNIT DATA, SYSTEM DATA, HISTORY, PROGRAM, OPTIONS, and so on. The arrow keys can be used instead of repeatedly pressing the data key to see the multiple displays under a key. Once the ▲ ▼ (ARROW) keys are pressed and used for scrolling, pressing the original data key will return to the first display message displayed under the data (UNIT DATA, SYSTEM DATA, and so on) keys.

The ◀ ▶ (LEFT and RIGHT ARROW) keys allow scrolling between non-numeric program choices under the OPTION, DATE/TIME, and SCHEDULE keys.

The ◀ (LEFT ARROW) key allows programming the default value when programming numeric values. For changing numeric values, the ▶ (RIGHT ARROW) key has no function.

The ◀ ▶ (ARROW) keys also allow scrolling sideways between the same displays on different systems. For example, pressing the ▶ (RIGHT ARROW) key while viewing the system #1 suction pressure moves the display to system #2 suction pressure.

Pressing the ◀ (LEFT ARROW) key moves the opposite direction. The arrow keys also allow fast scrolling through data under keys such as HISTORY by enabling the operator to move between subgroups of data such as Unit, System, and VSD data.

### Keypad Data Entry Mode

For numeric programmable items, the data entry mode is entered by pressing any of the number keys, the decimal point key, or the +/- key. When the data entry mode is entered, the data from the key press will be entered and the cursor will appear under the position where the data is being entered.

For non-numeric programmable items, data entry mode is entered by pressing the ◀ or ▶ (ARROW) keys. When the data entry mode is entered, the cursor will appear under the first position of the non-numeric string. The programmable choice may be changed by pressing the ◀ or ▶ (ARROW) keys.

To exit the data entry mode and store the programmed value, the ✓ (ENTER) key must be pressed. When the ✓ (ENTER) key is pressed, the cursor will disappear.

The data entry mode may also be exited by pressing the X (CANCEL) key. The programmed data will be returned to its original value when the X (CANCEL) key is pressed.

When the data entry mode is exited, the cursor will disappear. If any other key is pressed while in the Data Entry Mode, the following display will appear for 2 seconds indicating the user must choose between accepting or canceling the change:

```
XXXXXXXXXXXX PRESS ✓ TO ACCEPT VALUE OR
                X TO CANCEL DATA ENTRY
```

If the ✓ (ENTER) key was pressed from the data entry mode and the numeric value entered was out of range, the following message will appear for 2 seconds followed by the original data display.

```
XXXXXXXXXXXX OUT OF RANGE TRY AGAIN!
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
```

### Display

The 80 character (2 lines of 40 characters per line) display is a Liquid Crystal Display (LCD) used for displaying unit parameters, system parameters, and operator messages. The display has an LED backlight background for night viewing and is viewable in direct sunlight.

### Anti-recycle Timer

On power-up of the control panel, the anti-recycle timer for each system will be set to 120 seconds and must time out before a compressor is allowed to start.

Whenever a system starts, the anti-recycle timer for all systems will be set to 120 seconds and will count down from the time the motor starts. The timer must time out before another compressor is allowed to start.

Whenever a system shuts down, the anti-recycle timer for that system will be set to 120 seconds. The timer must time out before the system is allowed to restart.

### Evaporator Pump Control

The evaporator pump dry contacts are energized when any of the following conditions are true:

- If a Low Leaving Chilled Liquid Fault occurs.
- Whenever a compressor is running.
- The Daily Schedule is ON and the UNIT switch is ON.

Even if one of above is true, the pump will not run if the panel has been powered up for less than 30 seconds or if the pump has run in the last 30 seconds to prevent pump motor overheating.

## Evaporator Heater Control

The evaporator heater is controlled by ambient air temperature. If no systems are running and the ambient temperature drops below 4.4 °C (40°F), the heater is turned ON. If no systems are running and the temperature rises above 7.2°C (45°F) the heater is turned OFF. Whenever a system is running, the evaporator heater is turned OFF. Both evaporator heater outputs will always be turned ON and OFF together. An under voltage condition will keep the heater OFF until full voltage is restored to the system.

## Compressor Heater Control

Each compressor has its own heater. The purpose of the heater is to assure refrigerant does not condense in the compressor. There is no oil sump, but refrigerant could possibly condense in the rotors or the motor housing. The heater will be OFF whenever the respective compressor is running. As soon as the compressor shuts OFF, the heater will turn ON as long as all motor temperature sensors in the compressor read less than 70°C (158°F). The heater will turn OFF, if any internal compressor motor temperature sensor reads more than 71.1°C (160°F).

## Alarms

Each system has its own alarm. The Alarm output is ON (dry contact closed) when no fault condition is present and OFF (dry contact open) to indicate an alarm situation. The Alarm will be activated (contacts open), if any of the following are true.

- A System is faulted or inhibited from starting for more than 5 seconds.
- The Unit is faulted or inhibited from starting for more than 5 seconds.
- A System is locked out.
- The Unit is locked out.
- Power is removed from the chiller.

## Chiller Run Contact

The Chiller Run dry contact is closed whenever any system is running. It is open when all systems are shut OFF.

## Flow Switch Control

A chilled liquid flow switch of suitable type MUST be connected between Terminals 2 and 13 of 1TB to provide protection against loss of liquid flow, which will cause evaporator freeze-up if the chiller is permitted to run.

## Remote Run / Stop

A Remote Run/Stop input is available for each system.

## BASIC OPERATING SEQUENCE

### Start Sequence and Loading

To initiate the start sequence of the chiller, the following conditions must be satisfied before the pre-charge of the DC Bus will take place:

- UNIT SWITCH must be ON.
- At least one System Switch is ON.
- Run permissive inputs (Remote Cycling Contacts) must be closed.
- No unit faults exist.
- No unit start inhibits exist.
- At least one system not faulted or inhibited.
- The Daily Schedule is calling for the chiller to run.
- The Flow Switch is closed.
- Leaving Chilled Liquid Setpoint is above the Setpoint plus CR (Setpoint High Limit).

Once the precharge takes place, if the anti-recycle timer is timed out the chiller control system on the Chiller Control Board will select the number of compressors to start and begin operation of the compressors. The compressor(s) speed will be ramped to the minimum start frequency and increase speed as needed in an effort to regulate the leaving chilled liquid temperature to meet the desired Setpoint. Unit Warnings

## UNIT WARNING

### Unit Warning Operation

Unit warnings are caused when a condition is present requiring operator intervention to restart the unit. All setpoints, program values, and options should be checked before operating the unit. Warnings are not logged to the history buffer. If a unit warning is in effect, the message will be displayed to the operator when the STATUS key is pressed.

### Low Battery Warning

The LOW BATTERY WARNING can only occur at unit power-up. On micropanel power-up, the RTC battery is checked to see if it is still operational. If it is, normal unit operation is allowed. If the battery voltage is determined to be low, the following warning message is displayed indefinitely.

**UNIT WARNING: !! LOW BATTERY !!**  
**CHECK SETPOINTS/PROGRAM/OPTIONS/TIME**

If a low battery condition exists, all programmed setpoints, program values, time, schedule, and history buffers will have been lost. These values will all be reset to their default values, which may not be the desired operating values. Once a bad battery is detected, the unit will be prevented from running until the MANUAL OVERRIDE key is pressed. Once the MANUAL OVERRIDE key is pressed, the anti recycle timers will be set to the programmed default anti recycle time to allow the operator sufficient time to check setpoints, program values, and so on.

If a low battery is detected, it should be replaced as soon as possible. The programmed values will all be lost and the unit will be prevented from running on the next power interruption.

### **MICROBOARD (331-03478-XXX)**

The 331-03478-xxx microboard was developed as a direct replacement for the 031-02478-xxx line of microboards. No adapter harness is required when replacing a 02478 with the new 03478. The 03478 uses the IPUII processor card and provides some new features for the chillers that the 02478 did not have. The 03478 program resides in flash memory instead of EPROM. Program updates are accomplished by loading the new program from an SD card inserted into the SD card reader/writer. This same SD card reader/writer also allows the user to datalog the operating parameters to an SD card every 5 seconds. This information is invaluable when troubleshooting unit and system problems since it allows the service technician to view operating parameters prior to a unit fault. Details on the new datalogging capability are explained in the OPTIONS Key area of this manual. A Real Time Clock/BRAM keeps time and setpoints during power outages.

Refer *Figure 19 on page 105*. to locate the following ports of the 03478 microboard.

### **Power Supplies and LEDs**

The 03478 has LEDs to indicate various states of operation of the microboard.

**STATUS** – Flashes every ½ second to indicate that the base board processor is running its program.

**POWER** – On solid indicates that the base board +12V and +5V power supplies are operational.

**TX1** – Red LED flashes when transmitting data out Port 1 TB3 (Future native communications BAS port).

**RX1** – Green LED flashes when receiving data in Port 1 TB3 (Future native communications BAS port).

**TX2** – Red LED that flashes when transmitting data out Port 2 (E-Link TB2 or printer TB1).

**RX2** – Green LED that flashes when receiving data in Port 2 (E-Link TB2 or printer TB1).

**VSD\_TX** – Red LED that flashes when transmitting data out Port 3 to the VSD Logic board.

**VSD\_RX** – Green LED that flashes when receiving data in Port 3 from the VSD Logic board.

24VAC power is applied to the 331-03478-xxx microboard connector J12 and is then used to create the various DC power sources required by the microboard circuitry. If the chiller control is malfunctioning, the power supply test points should be measured to determine the status of the microboard.

### **Power Supply Test Points**

**TP1** GND (Measure TP2, TP3, TP4 and TP5 in reference to this Test Point).

**TP2** +3.3V [3.2 to 3.4VDC] provides power to the processors.

**TP3** +5V [4.8 to 5.2VDC] power communication ports 2,3 and 4 and analog sensors.

**TP4** +12V [11.64 to 12.36VDC] powers the display and backlight and is regulated to become the +5V.

**TP5** +15V [11.3 to 16.6VDC] powers the analog outputs to the EEV valves.


### **Configuration Jumpers**

The same configuration jumpers that existed on the 02478 are provided on the 03478.

**JP4** Remote Temp Reset jumper position Pins 1 to 2 (left) = 4-20 mA, Pins 2 to 3 (right) = 0-10 VDC.

**JP5** Remote Current Limit jumper position Pins 1 to 2 (left) = 4-20 mA, Pins 2 to 3 (right) = 0-10 VDC.

**JP6** Remote Sound Limit jumper position (Pins 1 to 2 (left) = 4-20 mA, Pins 2 to 3 (right) = 0-10 VDC.



LD19331

| NUM | DESC                                  | NUM | DESC                                   | NUM | DESC                            | NUM | DESC              |
|-----|---------------------------------------|-----|----------------------------------------|-----|---------------------------------|-----|-------------------|
| 1   | TP3 +5V                               | 6   | Power LED                              | 11  | Port 2 RX2, TX2                 | 16  | Port 1 Native BAS |
| 2   | TP2 +3.3V                             | 7   | Status LED                             | 12  | PORT 2 RS-232 Printer or Modbus | 17  | TP1 GND           |
| 3   | SD Card                               | 8   | Power LED                              | 13  | VSD RX VSD-TX                   | 18  | TP4+12V           |
| 4   | JP4, JP5, JP6 Remote Setpoint Jumpers | 9   | Port 2 RS485 to E-Link/SC-EQ or Modbus | 14  | U18 VSD RS-485 Driver           | 19  | TP5 + 15V         |
| 5   | U5 RTC/BRAM                           | 10  | U23 Port 2 RS-485 Driver               | 15  | U26 PORT 1 RS-485 Driver        | 20  | TP10 + 24V        |

**FIGURE 19 - NEW 331-03478-XXX MICROBOARD**

## BUILDING AUTOMATION SYSTEM (BAS) COMMUNICATIONS

There are three different ways the chiller communicates to the BAS.

- Via board Native Communication protocol
- Using an E-Link Gateway
- Using an SC-EQ Communication Card

### Using Communications Protocol

**TB3** Port 1 Native BAS RS-485.

**SW1** RS-485 Biasing Switch for Port. Set to ON if chiller is in an End of Line position on the network.

**U26** is the Port 1 RS-485 Driver Chip. It is socketed to allow field replacement. RX1 and TX1 LEDs illuminate to indicate Port 1 communications activity.

### YVAA Native Communication Setup

Native communication is applicable to three types of protocols, they are BACnet, N2 and Modbus RTU. It requires IPU II Microboard (331-03478-101) and software version Y.ACS.20.02 or later.

### BACnet MS/TP Setup Port 1 (TB3)

To setup the BACNET MS/TP Port 1, follow the steps below:

1. Connect the BACnet MS/TP Network to Port 1 on the IPU II I/O Board.
2. Set up the YVAA Port 1 (P1) for BACnet Communications as shown in *Figure 19 on page 105*.

#### To access the Port communication parameters:


1. Press the PROGRAM key once.
2. Enter password 5255.
3. Press the ✓(ENTER) key to display the Port 1 (P1) settings.

#### Set the following parameters:

1. DE Modifier Address (number entered is multiplied by 100): set as required by network.
2. DE Modifier Offset (number entered is added to DE Modifier Address): as required by network (see 8).
3. P1 Protocol: set to BACNET (Default Setting).
4. P1 Manual MAC Address: set to 1 (Default Setting).

5. P1 Baud rate: set as required by network. If not known set to AUTO.
6. P1 Parity: set to NONE (Default Setting).
7. P1 Stop Bits: set to 1 (Default Setting).
8. The BACnet DE Instance (Device Instance) is determined by adding the :  
**[DE MODIFIER AD-DRESS x 100] with the DE MODIFIER OFFSET.**

For example, if the desired DE Instance address is 5023, set the DE Modifier Address to 50, and then set the DE Modifier Offset to 23 ( $50 \times 100 + 23 = 5023$ ). DE Instances must be limited to values between 1 and 4,194,303 and every device in the network must have a unique Device Instance.



**Reboot required (cycle power) after settings are changed.**

### N2 Metasys Setup Port 1 (TB3)

1. Connect the N2 Network to Port 1 on the IPU II I/O Board as shown in *Figure 19 on page 105*.
2. Set up the YVAA Port 1 (P1) for N2 Communications.

#### To access the Communication parameters:

1. Press the PROGRAM key once
2. Enter password 5255
3. Press ✓(ENTER) to display the Port 1 (P1) settings.

#### Set the following parameters:

1. DE Modifier Address: N/A
2. DE Modifier Offset; N/A
3. P1 Protocol : Set to N2
4. P1 Manual MAC Address: Set to 0-127 as required by the parameters set in the BAS network.
5. P1 Baud Rate : 9600
6. P1 Parity: None (Default Setting)
7. P1 Stop Bits1: (Default Setting)

## **MODBUS Setup Port 2**

The YVAA 03478 microboard supports Modbus RS232 or RS485 communications for Port 2 communications. Port 2 communications can be directed to either TB1 for RS232 or TB2 for RS485.

To connect to the network:

1. Connect your Modbus Network to Port 2 on the IPU II I/O Board as shown in *Figure 19 on page 105*.
2. Set up the YVAA Port 2 (P2) for Modbus Communications.

### **To access the communication parameters:**

1. Press the PROGRAM key once.
2. Enter the password 5255.
3. Press the ✓(ENTER) key to display the Port 1 (P1) settings.

### **Set the following parameters:**

1. DE Modifier Address: Set to 1
2. DE Modifier Offset: Set to 0
3. P1 Protocol: Set to API
4. P2 Protocol: Set to Modbus Server
5. P2 Manual MAC Address: Set to 0-127 (as required by Modbus network)
6. P2 Baud rate: Set to 19.2K (or as required by the Modbus network)
7. P2 Parity: Set to NONE (or as required by Modbus network)
8. P2 Stop Bits: Set to 1
9. P2 Hw Select Bit: Set to RS-485 or RS-232 (as required by Modbus network)

Cycle power to the Microboard following port setups.

**J13-5** Remote Stop Start must be closed for BAS remote commands to take effect. If this input is open the unit will shut down and the panel will display the message:

REMOTE STOP - NO RUN PERMISSIVE.

## **E-LINK OR SC-EQ INTERFACE**

Communications to a LON network requires a LON E-Link and Port 2 set for YorkTalk 2. Connected Services requires a SC-EQ and Port 2 set for YorkTalk 2. To connect to the network:


1. Connect the E-Link or SC-EQ to Port 2 on the IPU II I/O Board as shown in *Figure 19 on page 105*.
2. Set up the YVAA Port 2 (P2) for YorkTalk 2 Communications.

### **To access the communication parameters:**

1. Press the PROGRAM key once.
2. Enter the password 5255.
3. Press the ✓(ENTER) key to display the Port 1 (P1) settings.

### **Set the following parameters:**

1. DE Modifier Address: Set to -1
2. Chiller ID: 0



***Reboot required (cycle power) after settings are changed.***

The table below shows set-up requirements for each communication protocol.

**TABLE 11 - VALUES REQUIRED FOR BAS COMMUNICATION**

| SETTING DESCRIPTION   | Protocol                                        |                                 |                      | YorkTalk2 <sup>6</sup> |
|-----------------------|-------------------------------------------------|---------------------------------|----------------------|------------------------|
|                       | BACnet MS/TP                                    | Modbus RTU <sup>5</sup>         | N2                   |                        |
| DE MODIFIER ADDRESS   | 0 to 41943 <sup>(3)</sup>                       | 1                               | N/A                  | -1                     |
| DE MODIFIER OFFSET    | 0 to 99 <sup>(4)</sup>                          | 0                               | N/A                  | N/A                    |
| P1 PROTOCOL           | BACNET                                          | N/A                             | N2                   | N/A                    |
| P1 MANUAL MAC ADDRESS | 0-127 <sup>(1)</sup>                            | N/A                             | 0-127 <sup>(1)</sup> | N/A                    |
| P1 BAUD RATE          | 9600 To 76800 or Auto Selectable <sup>(1)</sup> | N/A                             | 9600 or 19200        | N/A                    |
| P1 PARITY             | NONE                                            | N/A                             | NONE                 | N/A                    |
| P1 STOP BITS          | 1                                               | N/A                             | 1                    | N/A                    |
| P2 PROTOCOL           | N/A                                             | MODBUS SVR                      | N/A                  | N/A                    |
| P2 MANUAL MAC ADDRESS | N/A                                             | 0-127 <sup>(1)</sup>            | N/A                  | N/A                    |
| P2 BAUD RATE          | N/A                                             | 19,200 <sup>(2)</sup>           | N/A                  | N/A                    |
| P2 PARITY             | N/A                                             | NONE <sup>(2)</sup>             | N/A                  | N/A                    |
| P2 STOP BITS          | N/A                                             | 1                               | N/A                  | N/A                    |
| P2 HW SELECT BIT      | N/A                                             | RS-485 or RS-232 <sup>(1)</sup> | N/A                  | N/A                    |
| RESET REAL TIME ERROR | N/A                                             | N/A                             | N/A                  | N/A                    |
| CHILLER ID            | N/A                                             | N/A                             | N/A                  | 0                      |

**NOTES:**

1. As Required By Network.
2. Or Other As Required By Network.
3. Number Is Multiplied By 100, Set As Required By Network.
4. Number Is Added To DE Modifier Address, Set As Required By Network.
5. Unit Operating Software Version C.Mmc.13.03 Or Later Required For Modbus Protocol.
6. E-Link or SC-EQ interface requires YorkTalk2 setup.

The following table shows the real time error numbers that may be encountered during communication setup and a description of each.

**TABLE 12 - REAL TIME ERROR NUMBERS FOR BAS, SC-EQ OR E-LINK COMMUNICATIONS CARD**


| ERROR NUMBER (##) | DESCRIPTION                |
|-------------------|----------------------------|
| 0                 | ALL OK                     |
| 1                 | DATUM TYPE OK TEST FAILED  |
| 2                 | ENGLISH TEXT TOO LONG      |
| 3                 | FLOATING POINT EXCEPTION   |
| 4                 | GET PACKET FAILED          |
| 5                 | GET TYPE FAILED            |
| 6                 | INVALID UNIT CONVERSION    |
| 7                 | INVALID HARDWARE SELECTION |
| 8                 | REAL TIME FAULT            |
| 9                 | SPANISH TEXT TOO LONG      |
| 10                | THREAD EXITED              |
| 11                | THREAD FAILED              |
| 12                | THREAD STALLED             |
| 13                | IO BOARD RESET             |
| 14                | RTC/BRAM INVALID           |
| 15                | BACNET SETUP FAILED        |

This data can be read and in some cases modified using a BACnet, Modbus, or N2 network connection. The BACnet Name is a 12 character or shorter name used to identify the data in BACnet. The AI, AV, BI, and BV columns are indexes used to select the data.


The AI, AV, BI, and BV number associated with a BACnet Name should not be changed. If a value is not wanted in this table, change the BACnet Name to SPARE\_XX\_##. SPARE rows can be used for new values.

When set to BACnet or N2, communications automatically sets Stop Bit (1) and Parity (None) for port.

When connected via BAS and port is set for BACnet, Modbus, or N2, the remote settings will continue to follow the remote setpoints until the port is changed to another protocol or DE modifier address is set to -1.



***The most current data map information is listed on the Johnson Controls/York Chiller Equipment Integration website. A copy of the data map can also be obtained by contacting a local Johnson Controls office.***



***Reboot required (cycle power) after settings are changed.***


## SC-EQ OR E-LINK BAS COMMUNICATIONS CARD

### Received Data (Control Data)

The chiller receives eight data values from the SC-EQ or E-Link. The first four are analog values and the last four are digital values. These eight data values are used as control parameters when in REMOTE mode. When the unit is in LOCAL mode, these eight values are ignored. If the unit receives no valid YorkTalk 2 transmission for 5 minutes it will revert back to all local control values. *Table 13 on page III* lists the control parameters.

### Transmitted Data

After receiving a valid transmission from the SC-EQ or E-Link, the chiller will transmit either operational data or history buffer data depending on the History Buffer Request, ENG PAGE 10, found in *Table 13 on page III*. Data must be transmitted for every page. If there is no value to be sent to a particular page, a zero will be sent. *Table 13 on page III* shows the data values and page listings for this unit.



LD22443

**FIGURE 20 - LON E-LINK GATEWAY OPTION**

**TABLE 13 - YVAA NATIVE COMMUNICATIONS DATA MAP**

| YVAA YVFA YAGK |                          |  |               | Modbus RTU, BACnet MS/TP, N2 Data Map |  |  |  |  |  |  |  |  |  | Board: 031-03478 |  |  |  |  |  |  |  |  |  |
|----------------|--------------------------|--|---------------|---------------------------------------|--|--|--|--|--|--|--|--|--|------------------|--|--|--|--|--|--|--|--|--|
| Item           | Version                  |  | York P/N      | Comments                              |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 1              | Y.ACS.20.02              |  | 031-03476-010 | New                                   |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 2              | Y.ACS.20.04, Y.ACS.20.05 |  | 031-03476-010 | Updated                               |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 3              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 4              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 5              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 6              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 7              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 8              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 9              |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |
| 10             |                          |  |               |                                       |  |  |  |  |  |  |  |  |  |                  |  |  |  |  |  |  |  |  |  |

| Item Ref Num | BACnet Name | BACnet Object Instance | Modbus Address | Modbus Data Type Supported | Modbus Scaling (See Note 5) | N2 Metasys | Engineering Units |    | Point List Description |   |   |   |   |   |   |   |   |    |
|--------------|-------------|------------------------|----------------|----------------------------|-----------------------------|------------|-------------------|----|------------------------|---|---|---|---|---|---|---|---|----|
|              |             |                        |                |                            |                             |            | Imperial          | SI | 1                      | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |

Point List Code: S = Standard O = Optional N = Not Available

| ANALOG WRITE POINTS |           |     |      |          |        |       |       |       |                                                                         |  |  |  |  |  |  |  |   |   |
|---------------------|-----------|-----|------|----------|--------|-------|-------|-------|-------------------------------------------------------------------------|--|--|--|--|--|--|--|---|---|
| 1                   | REM_SETPT | AV1 | 1026 | 03,06,16 | Div 10 | ADF 1 | °F    | °C    | Remote Setptnt (Start cmd must be active to take effect)                |  |  |  |  |  |  |  | S | S |
| 2                   | DMD_LIMIT | AV2 | 1027 | 03,06,16 | Div 10 | ADF 2 | % FLA | % FLA | Remote Current Limit Setpoint (Start cmd must be active to take effect) |  |  |  |  |  |  |  | S | S |
| 3                   | SND_LIMIT | AV3 | 1028 | 03,06,16 | Div 10 | ADF 3 | %     | %     | Remote Sound Limit (RSL option must be enabled and ignored)             |  |  |  |  |  |  |  | S | S |
| 4                   | SPARE AV1 | AV4 | 1029 | 03,06,16 | Div 10 | ADF 4 | None  | None  | Spare                                                                   |  |  |  |  |  |  |  | N | N |

| BINARY WRITE POINTS |            |     |      |                |     |      |     |     |                                            |  |  |  |  |  |  |  |   |   |
|---------------------|------------|-----|------|----------------|-----|------|-----|-----|--------------------------------------------|--|--|--|--|--|--|--|---|---|
| 5                   | START_STOP | BV1 | 1538 | 01,03,05,06,15 | N/A | BD 1 | 0/1 | 0/1 | RemoteStart / Stop Command [0=Stop, 1=Run] |  |  |  |  |  |  |  | S | S |
| 6                   | SPARE BV1  | BV2 | 1539 | 01,03,05,06,15 | N/A | BD 2 | 0/1 | 0/1 | Spare                                      |  |  |  |  |  |  |  | N | N |
| 7                   | SPARE BV2  | BV3 | 1540 | 01,03,05,06,15 | N/A | BD 3 | 0/1 | 0/1 | Spare                                      |  |  |  |  |  |  |  | N | N |
| 8                   | SPARE BV3  | BV3 | 1541 | 01,03,05,06,15 | N/A | BD 3 | 0/1 | 0/1 | Spare                                      |  |  |  |  |  |  |  | N | N |

| ANALOG READ ONLY POINTS |                  |      |     |       |     |        |      |      |                                                       |  |  |  |  |  |  |  |   |   |
|-------------------------|------------------|------|-----|-------|-----|--------|------|------|-------------------------------------------------------|--|--|--|--|--|--|--|---|---|
| 9                       | LCHLT            | A11  | 514 | 03,04 | x10 | ADF 5  | °F   | °C   | Leaving Chilled Liquid Temperature                    |  |  |  |  |  |  |  | S | S |
| 10                      | ECHLT            | A12  | 515 | 03,04 | x10 | ADF 6  | °F   | °C   | Entering Chilled Liquid Temperature                   |  |  |  |  |  |  |  | S | S |
| 11                      | EV_ELT           | A13  | 516 | 03,04 | x10 | ADF 7  | °F   | °C   | Evaporator Entering Liquid Temperature (Free Cooling) |  |  |  |  |  |  |  | O | O |
| 12                      | VSD_IA_TEMP      | A14  | 517 | 03,04 | x10 | ADF 8  | °F   | °C   | VSD Internal Ambient Temperature                      |  |  |  |  |  |  |  | S | S |
| 13                      | S1_COND_TEMP     | A15  | 518 | 03,04 | x10 | ADF 9  | °F   | °C   | Sys 1 Condensa Temperature                            |  |  |  |  |  |  |  | S | S |
| 14                      | S2_COND_TEMP     | A16  | 519 | 03,04 | x10 | ADF 10 | °F   | °C   | Sys 2 Condenser Temperature                           |  |  |  |  |  |  |  | S | S |
| 15                      | S1_DSCH_TEMP     | A17  | 520 | 03,04 | x10 | ADF 11 | °F   | °C   | Sys 1 Discharge Temperature                           |  |  |  |  |  |  |  | S | S |
| 16                      | S2_DSCH_TEMP     | A18  | 521 | 03,04 | x10 | ADF 12 | °F   | °C   | Sys 2 Discharge Temperature                           |  |  |  |  |  |  |  | S | S |
| 17                      | OAT              | A19  | 522 | 03,04 | x10 | ADF 13 | °F   | °C   | Ambient Air Temperature                               |  |  |  |  |  |  |  | S | S |
| 18                      | S1_EDT_TEMP      | A110 | 523 | 03,04 | x10 | ADF 14 | °F   | °C   | Sys 1 Eductoff temperature                            |  |  |  |  |  |  |  | S | O |
| 19                      | S2_EDT_TEMP      | A111 | 524 | 03,04 | x10 | ADF 15 | °F   | °C   | Sys 2 Eductoff temperature                            |  |  |  |  |  |  |  | S | O |
| 20                      | S1_OIL_PRESS     | A112 | 525 | 03,04 | x10 | ADF 16 | PSI  | BAR  | Sys 1 Oil Pressure                                    |  |  |  |  |  |  |  | S | S |
| 21                      | S2_OIL_PRESS     | A113 | 526 | 03,04 | x10 | ADF 17 | PSI  | BAR  | Sys 2 Oil Pressure                                    |  |  |  |  |  |  |  | S | S |
| 22                      | S1_SUCTION_PRESS | A114 | 527 | 03,04 | x10 | ADF 18 | PSI  | BAR  | Sys 1 Suction Pressure                                |  |  |  |  |  |  |  | S | S |
| 23                      | S2_SUCTION_PRESS | A115 | 528 | 03,04 | x10 | ADF 19 | PSI  | BAR  | Sys 2 Suction Pressure                                |  |  |  |  |  |  |  | S | S |
| 24                      | S1_DSCH_PRESS    | A116 | 529 | 03,04 | x10 | ADF 20 | PSI  | BAR  | Sys 1 Discharge Pressure                              |  |  |  |  |  |  |  | S | S |
| 25                      | S2_DSCH_PRESS    | A117 | 530 | 03,04 | x10 | ADF 21 | PSI  | BAR  | Sys 2 Discharge Pressure                              |  |  |  |  |  |  |  | S | S |
| 26                      | S1_MC_FLA        | A118 | 531 | 03,04 | x10 | ADF 22 | %    | %    | Sys 1 Motor Current FLA                               |  |  |  |  |  |  |  | S | S |
| 27                      | S2_MC_FLA        | A119 | 532 | 03,04 | x10 | ADF 23 | %    | %    | Sys 2 Motor Current FLA                               |  |  |  |  |  |  |  | S | S |
| 28                      | S1_OP_HRS        | A120 | 533 | 03,04 | x1  | ADF 24 | None | None | Sys 1 Operating Hours                                 |  |  |  |  |  |  |  | S | S |
| 29                      | S2_OP_HRS        | A121 | 534 | 03,04 | x1  | ADF 25 | None | None | Sys 2 Operating Hours                                 |  |  |  |  |  |  |  | S | S |
| 30                      | S1_COMP_ST       | A122 | 535 | 03,04 | x1  | ADF 26 | None | None | Sys 1 Compressor Starts                               |  |  |  |  |  |  |  | S | S |
| 31                      | S2_COMP_ST       | A123 | 536 | 03,04 | x1  | ADF 27 | None | None | Sys 2 Compressor Starts                               |  |  |  |  |  |  |  | S | S |
| 32                      | S1_HI_MTR_T      | A124 | 537 | 03,04 | x10 | ADF 28 | °F   | °C   | Sys 1 Highest Motor Temperature                       |  |  |  |  |  |  |  | S | S |

Property of Johnson Controls, Inc.  
Subject to change without notice.

**TABLE 13 - YVAA NATIVE COMMUNICATIONS DATA MAP (CONT'D)**

| Item<br>Ref<br>Num | BACnet Name   | BACnet<br>Object<br>Instance | Modbus<br>Address | Modbus Data Type<br>Supported | Modbus<br>Scaling (See<br>Note 5) | N2 Metasys | Engineering Units |           | Point List Description                                                                  |   |   |   |   |   |   |   |   |    |
|--------------------|---------------|------------------------------|-------------------|-------------------------------|-----------------------------------|------------|-------------------|-----------|-----------------------------------------------------------------------------------------|---|---|---|---|---|---|---|---|----|
|                    |               |                              |                   |                               |                                   |            | Imperial          | SI        | 1                                                                                       | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| 33                 | S2 HI_MTR_T   | AI25                         | 538               | 03.04                         | x10                               | ADF 29     | °F                | °C        | Sys 2 Highest Motor Temperature                                                         | S | S |   |   |   |   |   |   |    |
| 34                 | VSD_OUT_FR    | AI26                         | 539               | 03.04                         | x10                               | ADF 30     | Hz                | Hz        | VSD Output Frequency                                                                    | S | S |   |   |   |   |   |   |    |
| 35                 | VSD_CMD_FR    | AI27                         | 540               | 03.04                         | x10                               | ADF 31     | Hz                | Hz        | VSD Command Frequency                                                                   | S | S |   |   |   |   |   |   |    |
| 36                 | S1_COND_DR    | AI28                         | 541               | 03.04                         | x10                               | ADF 32     | %                 | %         | Sys 1 Condenser Drain Valve % Open                                                      | S | S |   |   |   |   |   |   |    |
| 37                 | S2_COND_DR    | AI29                         | 542               | 03.04                         | x10                               | ADF 33     | %                 | %         | Sys 2 Condenser Drain Valve % Open                                                      | S | S |   |   |   |   |   |   |    |
| 38                 | S1_OP_CODE    | AI30                         | 543               | 03.04                         | x1                                | ADF 34     | None              | None      | Sys 1 Operational Code                                                                  | S | S |   |   |   |   |   |   |    |
| 39                 | S2_OP_CODE    | AI31                         | 544               | 03.04                         | x1                                | ADF 35     | None              | None      | Sys 2 Operational Code                                                                  | S | S |   |   |   |   |   |   |    |
| 40                 | S1_FTL_CODE   | AI32                         | 545               | 03.04                         | x1                                | ADF 36     | None              | None      | Sys 1 Fault Code                                                                        | S | S |   |   |   |   |   |   |    |
| 41                 | S2_FTL_CODE   | AI33                         | 546               | 03.04                         | x1                                | ADF 37     | None              | None      | Sys 2 Fault Code                                                                        | S | S |   |   |   |   |   |   |    |
| 42                 | S1_FAN_STG    | AI34                         | 547               | 03.04                         | x1                                | ADF 38     | None              | None      | Sys 1 Condenser Fan Stage [0-14]                                                        | S | S |   |   |   |   |   |   |    |
| 43                 | S2_FAN_STG    | AI35                         | 548               | 03.04                         | x1                                | ADF 39     | None              | None      | Sys 2 Condenser Fan Stage [0-14]                                                        | S | S |   |   |   |   |   |   |    |
| 44                 | S1_FAN_SPD    | AI36                         | 549               | 03.04                         | x10                               | ADF 40     | %                 | %         | Sys 1 Condenser Fan Speed (VSD)                                                         | O | O |   |   |   |   |   |   |    |
| 45                 | S2_FAN_SPD    | AI37                         | 550               | 03.04                         | x10                               | ADF 41     | %                 | %         | Sys 2 Condenser Fan Speed (VSD)                                                         | O | O |   |   |   |   |   |   |    |
| 46                 | LEAD          | AI38                         | 551               | 03.04                         | x1                                | ADF 42     | None              | None      | Lead System                                                                             | S | S |   |   |   |   |   |   |    |
| 47                 | LCHLT_SETP    | AI39                         | 552               | 03.04                         | x10                               | ADF 43     | °F                | °C        | Leaving Chilled Liquid Setpoint                                                         | S | S |   |   |   |   |   |   |    |
| 48                 | LCHLT_CUTOVT  | AI40                         | 553               | 03.04                         | x10                               | ADF 44     | °F                | °C        | Leaving Chilled Liquid Cutoff                                                           | S | S |   |   |   |   |   |   |    |
| 49                 | S1_ECON_VLV   | AI41                         | 554               | 03.04                         | x10                               | ADF 45     | %                 | %         | Sys 1 Economizer Valve % Open                                                           | S | S |   |   |   |   |   |   |    |
| 50                 | S2_ECON_VLV   | AI42                         | 555               | 03.04                         | x10                               | ADF 46     | %                 | %         | Sys 2 Economizer Valve % Open                                                           | S | S |   |   |   |   |   |   |    |
| 51                 | SUCT_PRS_CUT  | AI43                         | 556               | 03.04                         | x10                               | ADF 47     | PSI               | BAR       | Suction Pressure Cutoff                                                                 | S | S |   |   |   |   |   |   |    |
| 52                 | VSD_DCB_VT    | AI44                         | 557               | 03.04                         | x1                                | ADF 48     | Volts             | Volts     | VSD DC Bus Voltage (Unit)                                                               | S | S |   |   |   |   |   |   |    |
| 53                 | VSD_DCB_VT2   | AI45                         | 558               | 03.04                         | x1                                | ADF 49     | Volts             | Volts     | VSD DC Bus Voltage Sys 1 (Frame E/F)                                                    | O | O |   |   |   |   |   |   |    |
| 54                 | REM_SETPPOINT | AI46                         | 559               | 03.04                         | x10                               | ADF 50     | °F                | °C        | Remote Leaving Chilled Liquid Setpoint                                                  | S | S |   |   |   |   |   |   |    |
| 55                 | S1_SUBCOOL    | AI47                         | 560               | 03.04                         | x10                               | ADF 51     | °F (diff)         | °C (diff) | Sys 1 Subcooling (Microchannel)                                                         | O | O |   |   |   |   |   |   |    |
| 56                 | S1_EVAP_LL    | AI48                         | 561               | 03.04                         | x10                               | ADF 52     | %                 | %         | Sys 1 Evaporator Liquid Level (Round Tube)                                              | S | S |   |   |   |   |   |   |    |
| 57                 | S2_SUBCOOL    | AI49                         | 562               | 03.04                         | x10                               | ADF 53     | °F (diff)         | °C (diff) | Sys 2 Subcooling (Microchannel)                                                         | O | O |   |   |   |   |   |   |    |
| 58                 | S2_EVAP_LL    | AI50                         | 563               | 03.04                         | x10                               | ADF 54     | %                 | %         | Sys 2 Evaporator Liquid Level (Round Tube)                                              | S | S |   |   |   |   |   |   |    |
| 59                 | COOLING_RNG   | AI51                         | 564               | 03.04                         | x10                               | ADF 55     | °F                | °C        | Cooling Range                                                                           | S | S |   |   |   |   |   |   |    |
| 60                 | S1_DSC_SHEAT  | AI52                         | 565               | 03.04                         | x10                               | ADF 56     | °F (diff)         | °C (diff) | Sys 1 Discharge Superheat                                                               | S | S |   |   |   |   |   |   |    |
| 61                 | S2_DSC_SHEAT  | AI53                         | 566               | 03.04                         | x10                               | ADF 57     | °F (diff)         | °C (diff) | Sys 2 Discharge Superheat                                                               | S | S |   |   |   |   |   |   |    |
| 62                 | S1_SYS_STATE  | AI54                         | 567               | 03.04                         | x1                                | ADF 58     | None              | None      | Sys 1 System State [0=Stopped, 1=Running, 2=Faulted, 4=Locked Out, 5=Pre-Run]           | S | S |   |   |   |   |   |   |    |
| 63                 | S2_SYS_STATE  | AI55                         | 568               | 03.04                         | x1                                | ADF 59     | None              | None      | Sys 2 System State [0=Stopped, 1=Running, 2=Faulted, 4=Locked Out, 5=Pre-Run]           | S | S |   |   |   |   |   |   |    |
| 64                 | S1_MTR_OVER   | AI56                         | 569               | 03.04                         | x1                                | ADF 60     | Amps              | Amps      | Sys 1 Motor Current Overload Setting                                                    | S | S |   |   |   |   |   |   |    |
| 65                 | S2_MTR_OVER   | AI57                         | 570               | 03.04                         | x1                                | ADF 61     | Amps              | Amps      | Sys 2 Motor Current Overload Setting                                                    | S | S |   |   |   |   |   |   |    |
| 66                 | FAN_TYPE      | AI58                         | 571               | 03.04                         | x1                                | ADF 62     | None              | None      | Condenser Fan Control Type [1-4]                                                        | S | S |   |   |   |   |   |   |    |
| 67                 | FC_MODE       | AI59                         | 572               | 03.04                         | x1                                | ADF 63     | None              | None      | Free Cooling Mode [0=Mech, 1=Free Cool, 2=Hybrid]                                       | O | O |   |   |   |   |   |   |    |
| 68                 | FC_CTRL       | AI60                         | 573               | 03.04                         | x1                                | ADF 64     | %                 | %         | Free Cooling Control Programmed [0=Disabled, 1=Open Loop, 2=Closed Loop] (Free Cooling) | N | O |   |   |   |   |   |   |    |
| 69                 | CC_BYP_VALVE  | AI61                         | 574               | 03.04                         | x10                               | ADF 65     | %                 | %         | Cooling Coil Bypass Valve (Free Cooling Closed Loop)                                    | N | O |   |   |   |   |   |   |    |
| 70                 | CC_VALVE      | AI62                         | 575               | 03.04                         | x10                               | ADF 66     | %                 | %         | Cooling Coil Valve (Free Cooling Closed Loop)                                           | N | O |   |   |   |   |   |   |    |
| 71                 | CC_TEMP       | AI63                         | 576               | 03.04                         | x10                               | ADF 67     | °F                | °C        | Cooling Coil Temperature (Free Cooling Closed Loop)                                     | N | O |   |   |   |   |   |   |    |
| 72                 | HX_LEAVE_TEMP | AI64                         | 577               | 03.04                         | x10                               | ADF 68     | °F                | °C        | Heat Exchanger Leaving Temperature (Free Cooling Closed Loop)                           | N | O |   |   |   |   |   |   |    |
| 73                 | HX_ENTER_TEMP | AI65                         | 578               | 03.04                         | x10                               | ADF 69     | °F                | °C        | Heat Exchanger Entering Temperature (Free Cooling Closed Loop)                          | N | O |   |   |   |   |   |   |    |

Property of Johnson Controls, Inc.  
Subject to change without notice.

YVAA YVFA YAGK Native 3 OCT 17

2 of 4

TABLE 13 - YVAA NATIVE COMMUNICATIONS DATA MAP (CONT'D)

| Item<br>Ref<br>Num      | BACnet Name  | BACnet<br>Object<br>Instance | Modbus<br>Address | Modbus Data Type<br>Supported | Modbus<br>Scaling (See<br>Note 5) | N2 Metasys | Engineering Units |           | Point List Description                                   | Point List Code: S = Standard O = Optional N = Not Available |   |   |   |   |   |   |   |   |    |
|-------------------------|--------------|------------------------------|-------------------|-------------------------------|-----------------------------------|------------|-------------------|-----------|----------------------------------------------------------|--------------------------------------------------------------|---|---|---|---|---|---|---|---|----|
|                         |              |                              |                   |                               |                                   |            | Imperial          | SI        |                                                          | 1                                                            | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| 74                      | GLY_PMP_SPD  | AI66                         | 579               | 03.04                         | x10                               | ADF 70     | %                 | %         | Glycol Pump Speed (Free Cooling Closed Loop)             | N                                                            | O |   |   |   |   |   |   |   |    |
| 75                      | 1 SUCT_TEMP  | AI67                         | 580               | 03.04                         | x10                               | ADF 71     | °F                | °C        | Sys 1 Suction Temperature (YAGK)                         | N                                                            | O |   |   |   |   |   |   |   |    |
| 76                      | 1 SAT SUCT   | AI68                         | 581               | 03.04                         | x10                               | ADF 72     | °F                | °C        | Sys 1 Sat Suction Temperature (YAGK)                     | N                                                            | O |   |   |   |   |   |   |   |    |
| 77                      | 1 SUCT SHEAT | AI69                         | 582               | 03.04                         | x10                               | ADF 73     | °F (diff)         | °C (diff) | Sys 1 Suction Superheat (YAGK)                           | N                                                            | O |   |   |   |   |   |   |   |    |
| 78                      | 1 FTDV_CMD   | AI70                         | 583               | 03.04                         | x10                               | ADF 74     | %                 | %         | Sys 1 Flash Tank Drain Valve % (YAGK)                    | N                                                            | O |   |   |   |   |   |   |   |    |
| 79                      | 2 SUCT_TEMP  | AI71                         | 584               | 03.04                         | x10                               | ADF 75     | °F                | °C        | Sys 2 Suction Temperature (YAGK)                         | N                                                            | O |   |   |   |   |   |   |   |    |
| 80                      | 2 SAT SUCT   | AI72                         | 585               | 03.04                         | x10                               | ADF 76     | °F                | °C        | Sys 2 Sat Suction Temperature (YAGK)                     | N                                                            | O |   |   |   |   |   |   |   |    |
| 81                      | 2 SUCT SHEAT | AI73                         | 586               | 03.04                         | x10                               | ADF 77     | °F (diff)         | °C (diff) | Sys 2 Suction Superheat (YAGK)                           | N                                                            | O |   |   |   |   |   |   |   |    |
| 82                      | 2 FTDV_CMD   | AI74                         | 587               | 03.04                         | x10                               | ADF 78     | %                 | %         | Sys 2 Flash Tank Drain Valve % (YAGK)                    | N                                                            | O |   |   |   |   |   |   |   |    |
| 83                      | INPUT_CURR   | AI75                         | 588               | 03.04                         | x10                               | ADF 79     | Amps              | Amps      | Unit Input Current Amps                                  | N                                                            | S |   |   |   |   |   |   |   |    |
| BINARY READ ONLY POINTS |              |                              |                   |                               |                                   |            |                   |           |                                                          |                                                              |   |   |   |   |   |   |   |   |    |
| 84                      | CH_ALARM     | BI1                          | 1282              | 01.02.03                      | N/A                               | BD5        | 0/1               | 0/1       | Chiller Alarm [0=No Alarm, 1=Alarm]                      | S                                                            | S |   |   |   |   |   |   |   |    |
| 85                      | CH_RUN       | BI2                          | 1283              | 01.02.03                      | N/A                               | BD6        | 0/1               | 0/1       | Chiller Run [0=No Run, 1=Run]                            | S                                                            | S |   |   |   |   |   |   |   |    |
| 86                      | EVAP HEATER  | BI3                          | 1284              | 01.02.03                      | N/A                               | BD7        | 0/1               | 0/1       | Evaporator Heater Status                                 | S                                                            | S |   |   |   |   |   |   |   |    |
| 87                      | EVAP PUMP    | BI4                          | 1285              | 01.02.03                      | N/A                               | BD8        | 0/1               | 0/1       | Evaporator Pump Status                                   | S                                                            | S |   |   |   |   |   |   |   |    |
| 88                      | S1 COMP_RUN  | BI5                          | 1286              | 01.02.03                      | N/A                               | BD9        | 0/1               | 0/1       | Sys 1 Compressor Run Status                              | S                                                            | S |   |   |   |   |   |   |   |    |
| 89                      | S2 COMP_RUN  | BI6                          | 1287              | 01.02.03                      | N/A                               | BD10       | 0/1               | 0/1       | Sys 2 Compressor Run Status                              | S                                                            | S |   |   |   |   |   |   |   |    |
| 90                      | S1 VI STEP1  | BI7                          | 1288              | 01.02.03                      | N/A                               | BD11       | 0/1               | 0/1       | Sys 1 VI Step Solenoid Valve 1 Status                    | S                                                            | S |   |   |   |   |   |   |   |    |
| 91                      | S2 VI STEP1  | BI8                          | 1289              | 01.02.03                      | N/A                               | BD12       | 0/1               | 0/1       | Sys 2 VI Step Solenoid Valve 1 Status                    | S                                                            | S |   |   |   |   |   |   |   |    |
| 92                      | S1 VI STEP2  | BI9                          | 1290              | 01.02.03                      | N/A                               | BD13       | 0/1               | 0/1       | Sys 1 VI Step Solenoid Valve 2 Status                    | S                                                            | S |   |   |   |   |   |   |   |    |
| 93                      | S2 VI STEP2  | BI10                         | 1291              | 01.02.03                      | N/A                               | BD14       | 0/1               | 0/1       | Sys 2 VI Step Solenoid Valve 2 Status                    | S                                                            | S |   |   |   |   |   |   |   |    |
| 94                      | WATER_GLYCOL | BI11                         | 1292              | 01.02.03                      | N/A                               | BD15       | 0/1               | 0/1       | Cooling Type [0=Water, 1=Glycol]                         | S                                                            | S |   |   |   |   |   |   |   |    |
| 95                      | LOCAL_REMOTE | BI12                         | 1293              | 01.02.03                      | N/A                               | BD16       | 0/1               | 0/1       | Local Remote Control Mode [0=Local, 1=Remote]            | S                                                            | S |   |   |   |   |   |   |   |    |
| 96                      | DISP_UNITS   | BI13                         | 1294              | 01.02.03                      | N/A                               | BD17       | 0/1               | 0/1       | Display Units [0=Imperial, 1=S]                          | S                                                            | S |   |   |   |   |   |   |   |    |
| 97                      | S1 LOCKOUT   | BI14                         | 1295              | 01.02.03                      | N/A                               | BD18       | 0/1               | 0/1       | Sys 1 Lockout                                            | S                                                            | S |   |   |   |   |   |   |   |    |
| 98                      | S2 LOCKOUT   | BI15                         | 1296              | 01.02.03                      | N/A                               | BD19       | 0/1               | 0/1       | Sys 2 Lockout                                            | S                                                            | S |   |   |   |   |   |   |   |    |
| 99                      | FC_VALVE     | BI16                         | 1297              | 01.02.03                      | N/A                               | BD20       | 0/1               | 0/1       | Free Cooling Valve [0=Off, 1=On] (Free Cooling)          | S                                                            | S |   |   |   |   |   |   |   |    |
| 100                     | SOFT_SHUT    | BI17                         | 1298              | 01.02.03                      | N/A                               | BD21       | 0/1               | 0/1       | Soft Shutdown [0=Disabled, 1=Enabled]                    | S                                                            | S |   |   |   |   |   |   |   |    |
| 101                     | REM_EVAP     | BI18                         | 1299              | 01.02.03                      | N/A                               | BD22       | 0/1               | 0/1       | Remote Evaporator [0=Disabled, 1=Enabled]                | S                                                            | S |   |   |   |   |   |   |   |    |
| 102                     | QUICK_ST     | BI19                         | 1300              | 01.02.03                      | N/A                               | BD23       | 0/1               | 0/1       | Quick Start [0=Disabled, 1=Enabled]                      | S                                                            | S |   |   |   |   |   |   |   |    |
| 103                     | FRAME_EF     | BI20                         | 1301              | 01.02.03                      | N/A                               | BD24       | 0/1               | 0/1       | Frame E/F [0=Disabled, 1=Enabled]                        | S                                                            | S |   |   |   |   |   |   |   |    |
| 104                     | SOUND_OP     | BI21                         | 1302              | 01.02.03                      | N/A                               | BD25       | 0/1               | 0/1       | Sound Limit Option [0=Disabled, 1=Enabled]               | S                                                            | S |   |   |   |   |   |   |   |    |
| 105                     | GLY_PMP_RUN  | BI22                         | 1303              | 01.02.03                      | N/A                               | BD26       | 0/1               | 0/1       | Glycol Pump Run [0=Off, 1=On] (Free Cooling Closed Loop) | O                                                            | O |   |   |   |   |   |   |   |    |
| 106                     | GLY_HEATER   | BI23                         | 1304              | 01.02.03                      | N/A                               | BD27       | 0/1               | 0/1       | Glycol Heater [0=Off, 1=On] (Free Cooling Closed Loop)   | O                                                            | O |   |   |   |   |   |   |   |    |

| NOTES                                                                                                                                                                                                      |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 1 Units have Native BACnet/MS/TP, Modbus RTU, and N2 communications. No external Gateway is required for these interfaces unless the customer is using Connected Services.                                 |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 2 BACnet Object Types: 0 = Analog In, 1 = Analog Out, 2 = Analog Value, 3 = Binary In, 4 = Binary Out, 8 = Device, 15 = Alarm Notification (0-127 are reserved ASHRAE Objects)                             |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 3 WC = Inches of water Column, CFM = Cubic Feet per Minute, FPM = Feet Per Minute, PSI = Pounds per Square Inch, Pa = Pascals, kPa = kiloPascals, PPM = Parts Per Million, kJ/kg = kiloJoules per kilogram |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 4 Values that are not applicable due to unit configuration and options will be sent as zero (0).                                                                                                           |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 5 Modbus values are all of type signed. Scaling values in x10 (Bold) indicate scaling in metric is x100. Scaling and signing may not be modified in the field.                                             |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 6                                                                                                                                                                                                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 7                                                                                                                                                                                                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 8                                                                                                                                                                                                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 9                                                                                                                                                                                                          |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| 10                                                                                                                                                                                                         |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

**TABLE 14 - YVAA OPERATIONAL AND FAULT / INHIBIT CODES**

| Code Value | Operational Code                   | Code Value | Fault/Inhibit Code                                      |
|------------|------------------------------------|------------|---------------------------------------------------------|
| 63         | Manual Override                    | 0          | No Fault Code                                           |
| 64         | Daily Schedule Shutdown            | 1          | Low Ambient Temperature                                 |
| 65         | Unit Switch OFF                    | 2          | High Ambient Temperature                                |
| 66         | Remote Controlled Shutdown         | 3          | Low Chilled Liquid Temperature                          |
| 67         |                                    | 4          | VSD Initialization Failure                              |
| 68         | Flow Switch Shutdown               | 5          | Low RTC Battery Voltage                                 |
| 69         | VSD Cooling Shutdown               | 6          | Invalid Number of Compressors Selected                  |
| 70         | Serial Number Shutdown             | 7          | VSD Communications Failure                              |
| 71         |                                    | 8          | Pre-charge Low DC Bus Voltage (Unit)                    |
| 72         | Discharge Superheat Recovery       | 9          | Pre-charge DC Bus Voltage Imbalance (Unit)              |
| 73         |                                    | 10         | High DC Bus Voltage (Unit)                              |
| 74         | No Run Permissive                  | 11         | Low DC Bus Voltage (Unit)                               |
| 75         | Anti-Recycle Timer Active          | 12         | DC Bus Voltage Imbalance (Unit)                         |
| 76         | System Switch OFF                  | 13         | High VSD Ambient Temperature                            |
| 77         | System Not Running                 | 14         | Single Phase Input (Unit)                               |
| 78         | System Running                     | 15         | VSD Power Supply Fault                                  |
| 79         | Discharge Pressure Limiting        | 16         | VSD Logic Board Fault                                   |
| 80         | Suction Pressure Limiting          | 17         | Motor Current Overload (Hardware)                       |
| 81         | Motor Current Limiting             | 18         | CT Plug Fault                                           |
| 82         | Free Cooling                       | 19         |                                                         |
| 83         | ISN/BAS Motor Current Limiting     | 20         |                                                         |
| 84         | Remote Motor Current Limiting      | 21         |                                                         |
| 85         | System Shutting Down               | 22         |                                                         |
| 86         | VSD Pre-Charging                   | 23         |                                                         |
| 87         | VSD Baseplate Temp Limiting        | 24         |                                                         |
| 88         | VSD Internal Ambient Temp Limiting | 25         |                                                         |
| 89         | Sound Limiting                     | 26         |                                                         |
| 90         | ISN Sound Limiting                 | 27         | High Discharge Pressure (Software)                      |
| 91         | Remote Sound Limiting              | 28         | High Differential Oil Pressure                          |
| 92         | Pulldown Motor Current Limiting    | 29         | Low Differential Oil Pressure                           |
| 93         | Cooling Demand Shutdown            | 30         | Low Suction Pressure                                    |
| 94         | Input Current Limiting             | 31         | High Discharge Temperature                              |
| 95         | ISN Input Current Limiting         | 32         |                                                         |
| 96         | Remote Input Current Limiting      | 33         | Eductor Clog Fault                                      |
| 97         | Pulldown Input Current Limiting    | 34         | Sensor Failure                                          |
| 98         |                                    | 35         | Low Motor Current                                       |
| 99         |                                    | 36         | High Motor Temperature                                  |
|            |                                    | 37         | Pre-charge Low DC Bus Voltage (System, Frame E/F)       |
|            |                                    | 38         | Pre-charge DC Bus Voltage Imbalance (System, Frame E/F) |
|            |                                    | 39         | High DC Bus Voltage (System, Frame E/F)                 |
|            |                                    | 40         | Low DC Bus Voltage (System, Frame E/F)                  |
|            |                                    | 41         | DC Bus Voltage Imbalance (System, Frame E/F)            |
|            |                                    | 42         | High Motor Current                                      |
|            |                                    | 43         | Motor Current Overload (Software)                       |
|            |                                    | 44         | IGBT Gate Driver Fault                                  |
|            |                                    | 45         | High Baseplate Temperature                              |
|            |                                    | 46         | Single Phase Input (System, Frame E/F)                  |
|            |                                    | 47         | VSD Run Signal Fault                                    |
|            |                                    | 48         | High Discharge Pressure (Hardware - HPCO)               |
|            |                                    | 49         | Low Suction Superheat                                   |
|            |                                    | 50         | Control Voltage Fault                                   |
|            |                                    | 51         | Low Discharge Superheat                                 |

TABLE 15 - YVAA E-LINK COMMUNICATIONS DATA MAP

| YVAA / YVFA Sys 1 & 2 |                       |                    | REV K03H         |                   | SECTION 1        |                | ELINK        |                 | YORK TALK 2  |                                                                    |
|-----------------------|-----------------------|--------------------|------------------|-------------------|------------------|----------------|--------------|-----------------|--------------|--------------------------------------------------------------------|
| Item                  | Version               | Software P/N       | Microboard P/N   | Baud              | POINT LIST CODE: |                | S = STANDARD |                 | O = OPTIONAL |                                                                    |
| ENG PAGE Ref          | BACnet Object Typ/Ins | Bacnet Object Name | LON Profile Name | LON SNVT Type     | N2 Metasys       | MODBUS Address | Scale        | ENG UNITS Imper | SI           | POINT LIST DESCRIPTION                                             |
|                       |                       |                    |                  |                   |                  | See notes 3    |              |                 |              |                                                                    |
| P03                   | AV1                   | Y2 S01 P03         | nvoYTS01p003     | SNVT count f (51) | ADF 1            | 0001           | Div 10       | °F              |              | Setpoint (Start command must be active to take effect)             |
| P04                   | AV2                   | Y2 S01 P04         | nvoYTS01p004     | SNVT count f (51) | ADF 2            | 0002           | Div 10       | °F              |              | ISN Current Limit Start command must be active to take effect      |
| P05                   | AV3                   | Y2 S01 P05         | nvoYTS01p005     | SNVT count f (51) | ADF 3            | 0003           | Div 10       | %               |              | ISN Sound Limit (RSL Option must be enabled or this point ignored) |
| P06                   | AV4                   | Y2 S01 P06         | nvoYTS01p006     | SNVT count f (51) | ADF 4            | 0004           | Div 10       | %               |              |                                                                    |
| P07                   | BV1                   | Y2 S01 P07         | nvoYTS01p007     | SNVT switch (95)  | BD 1             | 0061           | N/A          | 0 / 1           |              | Start / Stop Command                                               |
| P08                   | BV2                   | Y2 S01 P08         | nvoYTS01p008     | SNVT switch (95)  | BD 2             | 0062           | N/A          |                 |              |                                                                    |
| P09                   | BV3                   | Y2 S01 P09         | nvoYTS01p009     | SNVT switch (95)  | BD 3             | 0063           | N/A          |                 |              |                                                                    |
| P10                   | BV4                   | Y2 S01 P10         | nvoYTS01p010     | SNVT switch (95)  | BD 4             | 0064           | N/A          | 0 / 1           |              | History Buffer 1 Request                                           |
| P11                   | AV5                   | Y2 S01 P11         | nvoYTS01p011     | SNVT count f (51) | ADF 5            | 0005           | X 10         | °F              |              | Leaving Chilled Liquid Temp                                        |
| P12                   | AV6                   | Y2 S01 P12         | nvoYTS01p012     | SNVT count f (51) | ADF 6            | 0006           | X 10         | °F              |              | Return Chilled Liquid Temp                                         |
| P13                   | AV7                   | Y2 S01 P13         | nvoYTS01p013     | SNVT count f (51) | ADF 7            | 0007           | X 10         | °F              |              | VSD Internal Ambient Temp                                          |
| P14                   | AV8                   | Y2 S01 P14         | nvoYTS01p014     | SNVT count f (51) | ADF 8            | 0008           | X 10         | °F              |              | Sys 1 Condenser Temperature                                        |
| P15                   | AV9                   | Y2 S01 P15         | nvoYTS01p015     | SNVT count f (51) | ADF 9            | 0009           | X 10         | °F              |              | Sys 1 Discharge Temperature                                        |
| P16                   | AV10                  | Y2 S01 P16         | nvoYTS01p016     | SNVT count f (51) | ADF 10           | 0010           | X 10         | °F              |              | Outside Ambient Air Temperature                                    |
| P17                   | AV11                  | Y2 S01 P17         | nvoYTS01p017     | SNVT count f (51) | ADF 11           | 0011           | X 10         | °F              |              | Sys 1 Eductor Temperature                                          |
| P18                   | AV12                  | Y2 S01 P18         | nvoYTS01p018     | SNVT count f (51) | ADF 12           | 0012           | X 10         | PSI             |              | Sys 1 Oil Pressure                                                 |
| P19                   | AV13                  | Y2 S01 P19         | nvoYTS01p019     | SNVT count f (51) | ADF 13           | 0013           | X 10         | PSI             |              | Sys 1 Suction Pressure                                             |
| P20                   | AV14                  | Y2 S01 P20         | nvoYTS01p020     | SNVT count f (51) | ADF 14           | 0014           | X 10         | PSI             |              | Sys 1 Discharge Pressure                                           |
| P21                   | AV15                  | Y2 S01 P21         | nvoYTS01p021     | SNVT count f (51) | ADF 15           | 0015           | X 10         | %               |              | Sys 1 Compressor % Full Load Amps                                  |
| P22                   | AV16                  | Y2 S01 P22         | nvoYTS01p022     | SNVT count f (51) | ADF 16           | 0016           | X 1          | hrs             |              | Sys 1 Total Run Hours                                              |
| P23                   | AV17                  | Y2 S01 P23         | nvoYTS01p023     | SNVT count f (51) | ADF 17           | 0017           | X 1          | count           |              | Sys 1 Total Number of Starts                                       |
| P24                   | AV18                  | Y2 S01 P24         | nvoYTS01p024     | SNVT count f (51) | ADF 18           | 0018           | X 10         | °F              |              | Sys 1 Highest Motor Temp                                           |
| P25                   | AV19                  | Y2 S01 P25         | nvoYTS01p025     | SNVT count f (51) | ADF 19           | 0019           | X 10         | °F              |              | Sys 2 Highest Motor Temp                                           |
| P26                   | AV20                  | Y2 S01 P26         | nvoYTS01p026     | SNVT count f (51) | ADF 20           | 0020           | X 10         | °F              |              | Sys 2 Discharge Temperature                                        |
| P27                   | AV21                  | Y2 S01 P27         | nvoYTS01p027     | SNVT count f (51) | ADF 21           | 0021           | X 10         | PSI             |              | Sys 2 Oil Pressure                                                 |
| P28                   | AV22                  | Y2 S01 P28         | nvoYTS01p028     | SNVT count f (51) | ADF 22           | 0022           | X 10         | PSI             |              | Sys 2 Suction Pressure                                             |
| P29                   | AV23                  | Y2 S01 P29         | nvoYTS01p029     | SNVT count f (51) | ADF 23           | 0023           | X 10         | PSI             |              | Sys 2 Discharge Pressure                                           |
| P30                   | AV24                  | Y2 S01 P30         | nvoYTS01p030     | SNVT count f (51) | ADF 24           | 0024           | X 1          | %               |              | Sys 2 Compressor % Full Load Amps                                  |
| P31                   | AV25                  | Y2 S01 P31         | nvoYTS01p031     | SNVT count f (51) | ADF 25           | 0025           | X 1          | hrs             |              | Sys 2 Total Run Hours                                              |
| P32                   | AV26                  | Y2 S01 P32         | nvoYTS01p032     | SNVT count f (51) | ADF 26           | 0026           | X 1          | count           |              | Sys 2 Total Number of Starts                                       |
| P33                   | AV27                  | Y2 S01 P33         | nvoYTS01p033     | SNVT count f (51) | ADF 27           | 0027           | X 1          | hz              |              | VSD Output Frequency                                               |
| P34                   | AV28                  | Y2 S01 P34         | nvoYTS01p034     | SNVT count f (51) | ADF 28           | 0028           | X 1          | %               |              | Sys 1 Condenser Drain Valve % Open                                 |
| P35                   | AV29                  | Y2 S01 P35         | nvoYTS01p035     | SNVT count f (51) | ADF 29           | 0029           | X 10         | %               |              | Sys 2 Condenser Drain Valve % Open                                 |
| P36                   | BV5                   | Y2 S01 P36         | nvoYTS01p036     | SNVT switch (95)  | BD 5             | 0065           | N/A          | 0 / 1           |              | Chiller Run                                                        |
| P37                   | BV6                   | Y2 S01 P37         | nvoYTS01p037     | SNVT switch (95)  | BD 6             | 0066           | N/A          | 0 / 1           |              | Chiller Alarm (0 = no alarm, 1 = alarm)                            |
| P38                   | BV7                   | Y2 S01 P38         | nvoYTS01p038     | SNVT switch (95)  | BD 7             | 0067           | N/A          | 0 / 1           |              | Evaporator Heater Status                                           |
| P39                   | BV8                   | Y2 S01 P39         | nvoYTS01p039     | SNVT switch (95)  | BD 8             | 0068           | N/A          | 0 / 1           |              | Evaporator Pump Status                                             |
| P40                   | BV9                   | Y2 S01 P40         | nvoYTS01p040     | SNVT switch (95)  | BD 9             | 0069           | N/A          | 0 / 1           |              | Sys 1 Compressor Run Status                                        |
| P41                   | BV10                  | Y2 S01 P41         | nvoYTS01p041     | SNVT switch (95)  | BD 10            | 0070           | N/A          | 0 / 1           |              | Sys 2 Compressor Run Status                                        |
| P42                   | BV11                  | Y2 S01 P42         | nvoYTS01p042     | SNVT switch (95)  | BD 11            | 0071           | N/A          | 0 / 1           |              | Sys 1 VI Step Solenoid Valve 1 Status                              |

2/16/2016

TABLE 15 - YVAA E-LINK COMMUNICATIONS DATA MAP (CONT'D)

| ENG<br>PAGE<br>Ref | BACnet<br>Object<br>Typ/Ins                                                                                                                                                                                                                                                                                                                                                                                                        | Bacnet Object<br>Name | LON Profile<br>Name | LON SNVT Type     | N2<br>MetaSys | MODBUS  |       | ENG UNITS |       | POINT LIST CODE: S = STANDARD O = OPTIONAL       |   |   |   |   |   |   |   |   |    | ENG<br>PAGE<br>REF |  |     |
|--------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|---------------------|-------------------|---------------|---------|-------|-----------|-------|--------------------------------------------------|---|---|---|---|---|---|---|---|----|--------------------|--|-----|
|                    |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               | Address | Scale | Imper     | SI    | POINT LIST DESCRIPTION                           |   |   |   |   |   |   |   |   |    |                    |  |     |
|                    |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       | 1                                                | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |                    |  |     |
| P43                | BV12                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P43           | nvoYTS01p043        | SNVT switch (95)  | BD 12         | 0072    | N/A   | 0/1       | 0/1   | Sys 2 VI Step Solenoid Valve 1 Status            |   |   |   |   |   |   |   |   |    |                    |  | P43 |
| P44                | BV13                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P44           | nvoYTS01p044        | SNVT switch (95)  | BD 13         | 0073    | N/A   | 0/1       | 0/1   | Sys 1 VI Step Solenoid Valve 2 Status            |   | S | S | S | S |   |   |   |    |                    |  | P44 |
| P45                | BV14                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P45           | nvoYTS01p045        | SNVT switch (95)  | BD 14         | 0074    | N/A   | 0/1       | 0/1   | Sys 2 VI Step Solenoid Valve 2 Status            |   | S | S | S | S |   |   |   |    |                    |  | P45 |
| P46                | BV15                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P46           | nvoYTS01p046        | SNVT switch (95)  | BD 15         | 0075    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P46 |
| P47                | BV16                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P47           | nvoYTS01p047        | SNVT switch (95)  | BD 16         | 0076    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P47 |
| P48                | BV17                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P48           | nvoYTS01p048        | SNVT switch (95)  | BD 17         | 0077    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P48 |
| P49                | BV18                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P49           | nvoYTS01p049        | SNVT switch (95)  | BD 18         | 0078    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P49 |
| P50                | BV19                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P50           | nvoYTS01p050        | SNVT switch (95)  | BD 19         | 0079    | N/A   | 0/1       | 0/1   | SI-1 Cooling Type: 0=Water, 1=Glycol             |   | S | S | S | S |   |   |   |    |                    |  | P50 |
| P51                | BV20                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P51           | nvoYTS01p051        | SNVT switch (95)  | BD 20         | 0080    | N/A   | 0/1       | 0/1   | Local/Remote Control Mode: 0 = Local, 1 = Remote |   | S | S | S | S |   |   |   |    |                    |  | P51 |
| P52                | BV21                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P52           | nvoYTS01p052        | SNVT switch (95)  | BD 21         | 0081    | N/A   | 0/1       | 0/1   | Display Units Mode: 0 = Imperial, 1 = SI         |   | S | S | S | S |   |   |   |    |                    |  | P52 |
| P53                | BV22                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P53           | nvoYTS01p053        | SNVT switch (95)  | BD 22         | 0082    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P53 |
| P54                | BV23                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P54           | nvoYTS01p054        | SNVT switch (95)  | BD 23         | 0083    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P54 |
| P55                | BV24                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P55           | nvoYTS01p055        | SNVT switch (95)  | BD 24         | 0084    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P55 |
| P56                | MV1                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P56           | nvoYTS01p056        | SNVT count f (51) | AD11          | 0030    | X1    | enum      | enum  | *Sys 1 Operational Code                          |   | S | S | S | S |   |   |   |    |                    |  | P56 |
| P57                | MV2                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P57           | nvoYTS01p057        | SNVT count f (51) | AD12          | 0031    | X1    | enum      | enum  | *Sys 1 Fault Code                                |   | S | S | S | S |   |   |   |    |                    |  | P57 |
| P58                | MV3                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P58           | nvoYTS01p058        | SNVT count f (51) | AD13          | 0032    | X1    | enum      | enum  | *Sys 2 Operational Code                          |   | S | S | S | S |   |   |   |    |                    |  | P58 |
| P59                | MV4                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P59           | nvoYTS01p059        | SNVT count f (51) | AD14          | 0033    | X1    | enum      | enum  | *Sys 2 Fault Code                                |   | S | S | S | S |   |   |   |    |                    |  | P59 |
| P60                | MV5                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P60           | nvoYTS01p060        | SNVT count f (51) | AD15          | 0034    | X1    | count     | count | Sys 1 Condenser Fan Stage (0-14)                 |   | S | S | S | S |   |   |   |    |                    |  | P60 |
| P61                | MV6                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P61           | nvoYTS01p061        | SNVT count f (51) | AD16          | 0035    | X1    | count     | count | Sys 1 Condenser Fan Speed (vsd)                  |   | S | S | S | S |   |   |   |    |                    |  | P61 |
| P62                | MV7                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P62           | nvoYTS01p062        | SNVT count f (51) | AD17          | 0036    | X1    | count     | count | Sys 2 Condenser Fan Stage (0-14)                 |   | S | S | S | S |   |   |   |    |                    |  | P62 |
| P63                | MV8                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P63           | nvoYTS01p063        | SNVT count f (51) | AD18          | 0037    | X1    | count     | count | Sys 2 Condenser Fan Speed (vsd)                  |   | S | S | S | S |   |   |   |    |                    |  | P63 |
| P64                | MV9                                                                                                                                                                                                                                                                                                                                                                                                                                | Y12_S01_P64           | nvoYTS01p064        | SNVT count f (51) | AD19          | 0038    | X1    | count     | count | Lead System Number                               |   | S | S | S | S |   |   |   |    |                    |  | P64 |
| P65                | MV10                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P65           | nvoYTS01p065        | SNVT count f (51) | AD10          | 0039    | X1    | enum      | enum  | Spare                                            |   |   |   |   |   |   |   |   |    |                    |  | P65 |
| P66                | AV30                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P66           | nvoYTS01p066        | SNVT count f (51) | ADF 30        | 0040    | X1    | °F        | °C    | Local Leaving Chilled Liquid Setpoint            |   | S | S | S | S |   |   |   |    |                    |  | P66 |
| P67                | AV31                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P67           | nvoYTS01p067        | SNVT count f (51) | ADF 31        | 0041    | X1    | °F        | °C    | Low Leaving Chilled Liquid Temp Cutout           |   | S | S | S | S |   |   |   |    |                    |  | P67 |
| P68                | AV32                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P68           | nvoYTS01p068        | SNVT count f (51) | ADF 32        | 0042    | X1    | %         | %     | Sys 1 Economizer Valve % Open                    |   | S | S | S | S |   |   |   |    |                    |  | P68 |
| P69                | AV33                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P69           | nvoYTS01p069        | SNVT count f (51) | ADF 33        | 0043    | X1    | %         | %     | Sys 2 Economizer Valve % Open                    |   | S | S | S | S |   |   |   |    |                    |  | P69 |
| P70                | AV34                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P70           | nvoYTS01p070        | SNVT count f (51) | ADF 34        | 0044    | X10   | PSI       | BAR   | Low Suction Pressure Cutout                      |   | S | S | S | S |   |   |   |    |                    |  | P70 |
| P71                | AV35                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P71           | nvoYTS01p071        | SNVT count f (51) | ADF 35        | 0045    | X1*   | volts     | volts | VSD DC Bus Voltage                               |   | S | S | S | S |   |   |   |    |                    |  | P71 |
| P72                | AV36                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P72           | nvoYTS01p072        | SNVT count f (51) | ADF 36        | 0046    | X1*   | °F        | °C    | Remote Leaving Chilled Liquid Setpoint           |   | S | S | S | S |   |   |   |    |                    |  | P72 |
| P73                | AV37                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P73           | nvoYTS01p073        | SNVT count f (51) | ADF 37        | 0047    | X1*   | °F        | °C    | Sys 1 Subcooling                                 |   | S | S | S | S |   |   |   |    |                    |  | P73 |
| P74                | AV38                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P74           | nvoYTS01p074        | SNVT count f (51) | ADF 38        | 0048    | X1*   | °F        | °C    | Cooling Range                                    |   | S | S | S | S |   |   |   |    |                    |  | P74 |
| P75                | AV39                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P75           | nvoYTS01p075        | SNVT count f (51) | ADF 39        | 0049    | X1*   | °F        | °C    | Sys 1 Discharge Superheat                        |   | S | S | S | S |   |   |   |    |                    |  | P75 |
| P76                | AV40                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P76           | nvoYTS01p076        | SNVT count f (51) | ADF 40        | 0050    | X1    | °F        | °C    | Sys 2 Condenser Temperature                      |   | S | S | S | S |   |   |   |    |                    |  | P76 |
| P77                | AV41                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P77           | nvoYTS01p077        | SNVT count f (51) | ADF 41        | 0051    | X1    | °F        | °C    | Sys 2 Discharge Temperature                      |   | S | S | S | S |   |   |   |    |                    |  | P77 |
| P78                | AV42                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P78           | nvoYTS01p078        | SNVT count f (51) | ADF 42        | 0052    | X1    | °F        | °C    | Sys 2 Subcooling                                 |   | S | S | S | S |   |   |   |    |                    |  | P78 |
| P79                | AV43                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P79           | nvoYTS01p079        | SNVT count f (51) | ADF 43        | 0053    | X1    | °F        | °C    | Sys 2 Discharge Superheat                        |   | S | S | S | S |   |   |   |    |                    |  | P79 |
| P80                | BV25                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P80           | nvoYTS01p080        | SNVT switch (95)  | BD 25         | 0085    | N/A   | 0/1       | 0/1   | Sys 1 Lockout                                    |   | S | S | S | S |   |   |   |    |                    |  | P80 |
| P81                | BV26                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P81           | nvoYTS01p081        | SNVT switch (95)  | BD 26         | 0086    | N/A   | 0/1       | 0/1   | Sys 2 Lockout                                    |   | S | S | S | S |   |   |   |    |                    |  | P81 |
| P82                | BV27                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P82           | nvoYTS01p082        | SNVT switch (95)  | BD 27         | 0087    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P82 |
| P83                | BV28                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P83           | nvoYTS01p083        | SNVT switch (95)  | BD 28         | 0088    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P83 |
| P84                | BV29                                                                                                                                                                                                                                                                                                                                                                                                                               | Y12_S01_P84           | nvoYTS01p084        | SNVT switch (95)  | BD 29         | 0089    | N/A   |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  | P84 |
| NOTES              |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 1                  | LON SNVTs Used: SNVT_count (8), SNVT_lev_percent (81), SNVT_temp_p (105), SNVT_switch (95), SNVT_time_minute (123), SNVT_freq_hz (76), SNVT_amp (01), SNVT_elec_kwh (13), SNVT_power_kilo (83), SNVT_volt (44), SNVT_volt_ac (138), SNVT_press_p (87)                                                                                                                                                                              |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 2                  |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 3                  | MODBUS scaling factors indicated in BOLD with an (*) asterisk are User Configurable, by a field technician if necessary. All Modbus values are of the type SIGNED with the exception of the User Configurable values that are all UNSIGNED. <b>Modbus Function Types Supported</b> (ENG P03-P06 = Types 03, 06, 16), (ENG P07-P10 = 01, 03, 05, 15, 06, 16), (ENG P11-P35, P56-P79) = 03, 04), (ENG P36-P55, P80-P84 = 01, 02, 03) |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 4                  | <b>BACnet Engineering Units</b> shown with an (*) Asterisk will be assigned a BACnet Eng Unit type of (95) ie NO UNITS.                                                                                                                                                                                                                                                                                                            |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 5                  | <b>Status Codes:</b> Special Display characters such as f, h, l, j, k, %, < and > are not compatible with Elink N2 formats. Substitute text strings: "f", "PCT, GTN will be used .                                                                                                                                                                                                                                                 |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 6                  | <b>Status Codes:</b> Status Code Text string lengths are limited to 60 total characters (including spaces)                                                                                                                                                                                                                                                                                                                         |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 7                  | <b>Codes</b> are available only in Firmware versions C.A21.14.03 or later. Contact your JCI FSC for assistance on upgrading your firmware                                                                                                                                                                                                                                                                                          |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 8                  |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 9                  |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |
| 10                 |                                                                                                                                                                                                                                                                                                                                                                                                                                    |                       |                     |                   |               |         |       |           |       |                                                  |   |   |   |   |   |   |   |   |    |                    |  |     |

NOTE: The Appropriate Product Code Listing Summary Should Accompany Document

2/16/2016

[illegible]

**VSD**

J2 VSD#1 and J1 VSD#2 connections headers for RS-485 communications to the Variable Speed Drive(s).

VSD RX and VSD TX LEDs illuminate to indicate the VSD communications activity. U18 is the VSD Port RS-485 Driver Chip. It is socketed to allow field replacement.

**PROGRAM UPDATE**

The Application software and BACnet database are stored in the IPU II Flash memory. Copying a new version of software and/or database from the SD Flash card changes the IPU II Flash. The new application software must be named SOFTWARE.ELF. The new BACnet database must be named DATABASE.BIN. These files must be located in the root directory of the SD Flash card. The software can be updated without updating the database. In this case, the existing database will be used with the new software. The database cannot be updated without updating the software. Be sure to allow enough time for the software to update properly.

To update the program:

1. Copy the new software in to the root directory of the SD card.
2. Rename this new program file SOFTWARE.ELF.
3. Turn the Unit Switch OFF.
4. Insert the SD card in to the SD card Reader/Writer slot.
5. Press the OPTIONS key and then press the Down Arrow key until the following message is displayed. FLASH CARD UPDATE DISABLED.
6. Press the RIGHT ARROW key to change the DISABLED to ENABLED
7. Press the ENTER key to start the update. Once pressed the message:

FLASH CARD UPDATING PLEASE WAIT...

is displayed until the update has been completed. The keypad and display will not respond during the flash update. After the software is finished updating, the controller will automatically reboot.

8. If an error occurs during the update, an error message will be displayed where XX is the Error Code. See Table 16 on Page 118 for error code definitions.

9. After the update is completed and the controller reboots, the keypad and display will return to full-functionality. The SD card may be left in place for datalogging or else replaced with another SD card dedicated for datalogging.
10. To remove the SD card, GENTLY press the card inslghtly then release the pressure. The card will pop out slightly to allow removal.



***Never reset or power down the chiller until the update is finished. Interrupting the flash update procedure can corrupt the program file and render the control board inoperative.***

**TABLE 16 - FLASH CARD UPDATE ERROR XXXXX**

| FLASH CARD UPDATE ERROR CODE | DEFINITION                                                  |
|------------------------------|-------------------------------------------------------------|
| 0                            | Okay                                                        |
| 10                           | Flash card not found.                                       |
| 11                           | SOFTWARE.ELF file not found                                 |
| 14                           | SOFTWARE.ELF file larger than expected.                     |
| 15                           | RAM to IPU Flash transfer of DATABASE. ELF failed.          |
| 16                           | RAM to IPU Flash transfer of SOFTWARE. ELF failed.          |
| 17                           | Could not allocate sufficient memory to read or write file. |
| 99                           | Internal software error.                                    |

**DATA LOGGING**

A 2GB SD card (p/n 031-03466-000) may be inserted into the 03478 IPU II SD card slot to record the chiller operating parameters at 5 second intervals. The data is stored in a folder named RMYYYMM where YYYY is the year and MM is the month the data was recorded. The controller creates a file for each day within this folder with the format YYYYMMDD.csv where DD equals the day of the month in addition to the YY to the year and MM to the month fields. For example: The folder named RM201503 is a folder created in March of 2015. Within this folder would be a file for each day of that month that the datalogging is running. If a review of the History Report shows that an abnormal event occurred on March 3rd at 2:05pm, the user can import the 20150303.csv file into Excel and look at the system parameter details leading up to the 2:05pm event.



***Follow all JCI Safety Directives when inserting or removing the SD card since the card is located inside the control cabinet.***

To start the Data Logging, insert the SD card into the SD card slot on the 03478 IPUII board. The label on the SD card should be facing outwards.

Once the SD card is inserted and the unit is powered up, press the OPTIONS key. Then press the Down Arrow key to advance to the DATA LOG TO FLASHCARD selection. Next press the Right Arrow key to select ON then press the ENTER key to start the Data Log. A 2GB SD card will hold about 8 months worth of data. A smaller card may be used that will hold less data but should be tested for compatibility. The controller operating system does not support SD cards larger than 2GB. When the SD card becomes full, the oldest date file is automatically deleted and a new day log file is written in its place.

To stop the data logging and retrieve the SD card, press the OPTION key and then the Down Arrow key to display the DATA LOG TO FLASHCARD option and then use the Right Arrow key to select OFF then press the ENTER key.

Again, follow the JCI Safety Directives to stop the chiller, power off the unit and open the control cabinet door to retrieve the SD card.

Once inside the control cabinet, lightly press in on the SD card and then release the pressure. The SD card should pop out slightly to allow removal. You may then copy the files to a PC for analysis or email the file to someone. The files are saved as a CSV format which can be read by Excel. Below is a sample of some of the data imported from a YCIV Chiller.

**TABLE 17 - DATA LOGGING**

| HOUR | MIN | SEC | SYS 1<br>SUCT<br>PRESS | SYS 1<br>DSCH<br>PRESS | SYS 1<br>OIL<br>PRESS | SYS 1<br>SUCT<br>TEMP | SYS 1<br>SAT<br>SUCT<br>TEMP | SYS 1<br>SUCT<br>SHEAT | SYS 1<br>MTR<br>CURR<br>FLA | SYS 1<br>DSCH<br>TEMP | SYS 1<br>SAT<br>DSCH<br>TEMP | SYS 1<br>DSCH<br>SHEAT | SYS 1<br>OIL<br>TEMP | SYS 1<br>COMP<br>STATUS | SYS 1<br>ECON | SYS 1<br>FAN<br>STAGE | SYS 1<br>MOTOR<br>TEMP1 |
|------|-----|-----|------------------------|------------------------|-----------------------|-----------------------|------------------------------|------------------------|-----------------------------|-----------------------|------------------------------|------------------------|----------------------|-------------------------|---------------|-----------------------|-------------------------|
|      |     |     | PSIG                   | PSIG                   | PSIG                  | °F                    | °F                           | °F                     | AMPS                        | °F                    | °F                           | °F                     | °F                   |                         |               |                       | °F                      |
| 0    | 0   | 10  | 82.6                   | 84.4                   | 84.4                  | 93                    | 77.5                         | 15.5                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |
| 11   | 0   | 15  | 82.6                   | 84.4                   | 84.4                  | 93                    | 77.5                         | 15.5                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |
| 11   | 22  | 20  | 82.6                   | 84.4                   | 84.4                  | 93                    | 77.5                         | 15.5                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |
| 11   | 22  | 25  | 82.6                   | 84.4                   | 84.4                  | 93                    | 77.5                         | 15.5                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |
| 11   | 22  | 30  | 82.6                   | 84.4                   | 84.4                  | 93                    | 77.5                         | 15.5                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |
| 11   | 22  | 35  | 82.5                   | 84.4                   | 84.4                  | 93                    | 77.4                         | 15.6                   | 0                           | 83                    | 78.6                         | 4.4                    | 82                   | OFF                     | OFF           | 0                     | 107.9                   |

Once the file is read in to Excel, you can hide unrelated columns or plot desired parameters to analyze the data.


### Invalid Number of Compressors Warning

The INVALID NUMBER OF COMPRESSORS SELECTED warning will occur after the VSD has been initialized, if no jumpers are installed or if more than 1 jumper is installed, "Number of Compressors Select" message is displayed. The following warning message will be displayed indefinitely.

#### UNIT WARNING:

**INVALID NUMBER OF COMPRESSORS SELECTED**

To clear this warning, both the control panel and VSD control voltage must be turned OFF and the jumpers properly installed in the VSD wiring harness.



***These jumpers are factory installed in the wire harness plug and should not require changes.***

### Invalid Serial Number Warning

If the INVALID SERIAL NUMBER message appears, immediately contact Johnson Controls Product Technical Support. The appearance of this message may mean the chiller has lost important factory programmed information. The serial number can be entered using the SERVICE key.

#### UNIT WARNING: INVALID SERIAL NUMBER

**ENTER UNIT SERIAL NUMBER**

This status message can be bypassed to view additional messages under the STATUS key by pressing the STATUS key repeatedly to scroll through as many as three STATUS messages that could possibly be displayed at any time.

## UNIT SAFETIES

### Unit Safety Operation

Unit faults are safeties that cause all running compressors to be shut down, if a safety threshold is exceeded for 3 seconds. Unit faults are recorded in the history buffer along with all data on the unit and system operating conditions. Unit faults are auto reset faults where the unit will be allowed to restart automatically after the fault condition is no longer present. The only exception is any of the VSD related unit faults. If any 3 VSD unit faults occur within 90 minutes, the unit will be locked out on the last fault. A VSD lockout condition requires a manual reset using the system switches. Both system switches must be cycled OFF and ON to clear a VSD unit lockout fault. If a unit safety is in effect, the message will be displayed to the operator when the STATUS key is pressed.

In the descriptions of the fault displays that follow, the fault message will show a YYYYYYYY to indicate that a system is in a “FAULT” condition and will restart when the fault clears or LOCKOUT” and will not restart until the operator clears the fault using the keypad.

If a control panel safety occurs after the VSD fault, but before the fault is reset, the control panel fault is an ALL FAULT of the VSD fault, meaning it will be registered as such in the History because it occurred while the VSD was shutting down or while the systems were shut down. All faults do not store operating data at the time of the fault.

If a “VSD” fault occurs during the fault rampdown or while the systems are shut down, the VSD fault will be registered as a new fault. The reason for this is the belief any VSD fault should be registered with a full account of the systems data at the time of the fault.

### High Ambient Temp Fault

If the ambient temperature rises above 55°C (131°F), the chiller will shut down with a controlled ramped shutdown. Restart will automatically occur, if demand allows, when temperature falls 1.1°C (2°F) below the cutout (53.9°C [129°F]). This fault cannot cause a lockout. The fault display message will be present only during the time when the ambient temperature is causing a fault condition. A sample display is shown below:

UNIT YYYYYYYY  
HIGH AMBIENT TEMP

The unit will also be inhibited from starting any time the temperature is above 53.9°C (129°F).

### Low Ambient Temp Fault

If the ambient temperature falls below the programmable Low Ambient Temp Cutout the chiller will shut down with a controlled ramped shutdown. This fault will only occur if the Low Ambient Cutout is “ENABLED” under the OPTIONS key. Restart can occur, if demand allows, when temperature rises 1.1°C (2°F) above the cutout. This fault cannot cause a lockout. The fault display message will be present only during the time when the ambient temperature is causing a fault condition. A sample display is shown below:

UNIT YYYYYYYY  
LOW AMBIENT TEMP

The unit is also inhibited from starting any time the temperature is below the cutout plus 1.1°C (2°F).

### Low Leaving Chilled Liquid Temp Fault

The Low Leaving Chilled Liquid Temp Cutout helps to protect the chiller from an evaporator freeze-up should the chilled liquid temp drop below the freeze point. This situation could occur under low flow conditions or if the Micro Panel setpoint values are improperly programmed. Any time the leaving chilled liquid temperature (water or brine) drops below the programmable cutout point, the chiller will fault and shutdown with a controlled ramped shutdown. Restart can occur, if demand allows, when chilled liquid temperature rises 2.2°C (4°F) above the cutout. This fault cannot cause a lockout. A sample shutdown message is shown below:

UNIT YYYYYYYY  
LOW LEAVING CHILLED LIQUID TEMP

The unit is inhibited from starting any time the chilled liquid temperature is below the cutout plus 2.2°C (4°F).

### VSD Communications Failure Fault

The VSD Communications Failure is to prevent the unit from trying to run, if the Chiller Control Board never initializes communications with the VSD Logic Board. The unit will also shut down with a controlled ramped shutdown if the Chiller Control Board loses communications with the VSD Logic Board while the chiller is operating.

On power-up, the Chiller Microprocessor Board will attempt to initialize communications with the VSD Logic Board. The control panel will request data from the VSD, which includes the number of compressors and the VSD software version. Once these data points have been received by the Chiller Control Board,

and have been successfully initialized, the Chiller Control Board will not request them again. If the comms connection fails to occur and a reply from the VSD Logic Board does take place in 8 seconds, the Chiller Control Board will prevent the chiller from operating and a fault message will be displayed.

During normal operation, if the control panel Chiller Control Board receives no valid response to messages for 8 seconds, the unit will shut down all compressors on a Comms fault. The Chiller Control Board will continue to send messages to the VSD while faulted. The unit will be inhibited from starting until communications is established. The fault will automatically reset when the Chiller Control Board receives a valid response from the VSD for a data request. Shown below is an example of a Comms Failure fault message:

```
UNIT YYYYYYYY
VSD COMMUNICATIONS FAILURE
```

## SYSTEM SAFETIES (FAULTS)

### System Safety (Fault) Operation

System safeties are faults that cause individual systems to be shut down if a safety threshold is exceeded for 3 seconds. System faults are auto reset faults in that the system will be allowed to restart automatically after the 120 second anti-recycle timer times out. The only exception is after any 3 faults on the same system occur within 90 minutes, that system will be “locked out” on the last fault. The lockout condition requires a manual reset using the system switch. The respective system switch must be cycled OFF and ON to clear the lockout fault.

When multiple systems are operating and a system fault occurs, the running systems will ramp down and the faulted system will be shut OFF and the previously operating will restart if required after the fault clears and/or the 120 second anti-recycle timer times out.

In the descriptions of the fault displays that follow, the fault message will show a YYYYYYYY to indicate that a system is in a “FAULT” condition and will restart when the fault clears, or “LOCKOUT” and will not restart until the operator clears the fault using the keypad. If a system safety is in effect, the message will be displayed to the operator when the STATUS key is pressed.

In some cases, a control panel fault will occur after a VSD fault, possibly during system shutdown or at some later time. This is known as an “ALL FAULT”

and these faults will be recorded as such under the HISTORY information stored at the instant of the primary fault. In some cases, this information may be valuable in troubleshooting the primary fault. An example of the “ALL FAULT” history message as shown in the *“All Fault Data” on page 139* under the HISTORY key. When an “ALL FAULT” occurs, associated history information will not be stored. If an additional fault does not occur, the “ALL FAULTS” display will indicate NONE.

In cases where a VSD fault occurs during the ramp-down of a control panel fault (that is, low suction pressure, low water temp, and so on), the VSD fault will be stored as a new fault with the associated fault information stored at the instant the VSD fault occurred (that is, IGBT Gate Drive, Single Phase Input, VSD CT Plug, and so on). The control panel fault that occurred prior to the VSD fault will be stored with the associated complete data related to the fault as a numerically lower numbered history in the history buffers.

### High Discharge Pressure Cutout (Software) Fault

The High Discharge Pressure Cutout is a software fault. A system will fault and shut down with a controlled ramped shutdown on high discharge pressure when the discharge pressure rises above 22.4 barg (325 PSIG) for 0.5 seconds. The system will be allowed to restart when the discharge pressure falls to 20.3 barg (295 PSIG). The system will also be inhibited from starting if the pressure is above 20.3 barg (295 PSIG). The fault message for this safety is shown below:

```
SYS X YYYYYYYY HIGH DISCHARGE PRESSURE
```

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out, or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### High Discharge Pressure Cutout (HPCO) (Hardware) Fault

The mechanical High Pressure Cutout protects the system from experiencing dangerously high discharge pressure. A system will fault and shut down immediately when the mechanical high pressure cutout contacts open. The fault will occur immediately and not wait 3 seconds, which is typical of most system faults.

The HPCO is wired in series with the VSD Run Signal and will only be checked by the Chiller Control Board when the system is running. The mechanical cutout opens at 23.2 barg  $\pm$  0.55 barg (337 PSIG  $\pm$  8 PSIG) and closes at 17.4 barg  $\pm$  0.69 barg (252 PSIG  $\pm$  10 PSIG). The Status display fault message for this system is shown below:

**SYS X YYYYYYYY HPCO FAULT**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### Low Suction Pressure Cutout (Software) Fault

The programmable Low Suction Pressure Cutout is a secondary back-up for the flow switch and protects against operation with low refrigerant charge, which helps protect the chiller from an evaporator freeze-up, should the system attempt to run with a low refrigerant charge. The Status display fault message for this cutout is shown below:

**SYS X YYYYYYYY LOW SUCTION PRESSURE**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad. Typically, the cutout will be set at 1.65 barg (24 PSIG) for chilled water applications.

The cutout is ignored for the first 30 seconds of system run time. During the next 3 minutes of run time the cutout point is linearly ramped from 10% of the cutout value up to the programmed cutout point. If at any time during the first 3 minutes of operation the suction pressure falls below the ramped cutout point, the system will shut down with a controlled ramped shutdown.

The cutout pressure during operating periods of 30 seconds to 210 seconds is ramped and can be calculated by the following:

After the first 3 minutes and 30 seconds of run time, if the suction pressure falls below the cutout as a result of a transient in the system, a transient timer is set at 30 seconds and a linearly ramped cutout is set starting at 10% of the programmed cutout. If over the next

30 seconds, the suction pressure does not stay above the ramped cutout, which ramps between 10% of the cutout and the programmed cutout over the 30 second period, the system will fault on low suction pressure.

### Low Motor Current Cutout Fault

The Motor Current Cutout shuts the system down with a controlled ramped shutdown when the microprocessor detects the absence of motor current (less than 10% FLA), usually indicating that a compressor is not running. This safety is ignored for the first 10 seconds of operation.

The status display fault message for this safety is shown below:

**SYS X YYYYYYYY LOW MOTOR CURRENT**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### High Differential Oil Pressure Cutout Fault

The High Differential Oil Pressure Cutout protects the compressor from low oil flow and insufficient lubrication, possibly from a dirty oil filter. A system will fault and shut down with a controlled ramped shutdown when its Discharge to Oil Differential Pressure rises above the cutout of 4.48 barg (65 PSID). This safety is ignored for the first 90 seconds of run time. This safety measures the pressure differential between discharge and oil pressure, which is the pressure drop across the oil filter. The Status display fault message for this safety is shown below:

**SYS X YYYYYYYY HIGH DIFF OIL PRESSURE**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### Low Differential Oil Pressure Cutout Fault

The Low Differential Oil Pressure Cutout protects the compressor from low oil flow and insufficient lubrication. A system will fault and shut down with a controlled ramped shutdown when its differential between oil and suction pressure falls below the cutout. This safety assures that the compressor is pumping sufficiently to

push oil through the oil cooling circuit and through the internal compressor lubrication system. The Status display fault message for this safety is shown below:

**SYS X YYYYYYYY LOW DIFF OIL PRESSURE**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

The safety is ignored for the first 60 seconds of run time. After the first 60 seconds of operation, the cutout is linearly ramped from 0 to 2.09 barg (0 PSID to 30 PSID) in 5 to 10 minutes based on ambient temperature. See the following table for the ramp times for the given ambient temperatures.

**TABLE 18 - LOW DIFFERENTIAL OIL PRESSURE CUTOUT**

| AMBIENT TEMPERATURE                | RAMP TIME  |
|------------------------------------|------------|
| more than 10°C (50°F)              | 5 Minutes  |
| more than 7.2°C (45°F)             | 6 Minutes  |
| more than 4.4°C (40°F)             | 7 Minutes  |
| more than 1.6°C (35°F)             | 8 Minutes  |
| more than 1.1°C (30°F)             | 9 Minutes  |
| more than or equal to 1.1°C (30°F) | 10 Minutes |

A 30 second safety bypass below 50 Hertz is employed during rampdown. The bypass is primarily needed under conditions where another compressor is being brought on and the running compressor is being ramped down to 5 Hertz to add the additional compressor due to load requirements. Under these conditions, the slow speed of the running compressor(s) causes the oil differential to become very low, especially if the water temperature is high and the suction pressure is high. The bypass assures the compressor(s) will not trip on a nuisance low oil differential fault.

### High Discharge Temperature Cutout Fault

The High Discharge Temperature Cutout protects the motor and compressor from overheating. A system will fault and shut down with a controlled ramped shutdown when its Discharge Temperature rises above 121°C (250°F). A system will also be inhibited from starting if the discharge temperature is above 93°C (200°F). The Status display fault message for this safety is shown below:

**SYS X YYYYYYYY HIGH DISCHARGE TEMP**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### Low Discharge Superheat Cutout Fault

The Low Discharge Superheat safety helps protect the compressor from liquid floodback through the economizer line due to a high flashtank level. It also helps protect the compressor from excessive oil in circulation due to excess oil charge in the system. Excessive oil in circulation brings back liquid refrigerant which is entrained in the oil. The liquid then drops out once it enters the compressor.

The safety is ignored for the first 10 minutes of operation if the system economizer feed valve is closed (0%) and for 5 minutes of operation if the economizer feed valve is open greater than 0%. If the discharge superheat falls below 2.8°C (5.0°F) for 5 minutes under either condition, the system will shut down.

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the 120 second anti-recycle timer times out or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### Discharge Pressure Load Limiting/Unloading

Discharge pressure load limiting protects the condenser from experiencing dangerously high pressures. A system is permitted to load normally as long as the discharge pressure is below the High Discharge Pressure Cutout minus 20 PSIG. Between Cutout minus 20PSIG and Cutout minus 15 PSIG loading is inhibited even though increased loading may be required. Between Cutout minus 15 PSIG and the Discharge Pressure Cutout, forced unloading is performed every 2 seconds according to the following table. The discharge pressure unload point is fixed at 255 PSIG.

**TABLE 19 - DISCHARGE PRESSURE LOAD LIMITING/UNLOADING**

| DISCHARGE PRESSURE                                                        | UN-LOADING |
|---------------------------------------------------------------------------|------------|
| Discharge Pressure Cutout- 20 PSIG and Discharge Pressure Cutout- 15 PSIG | 0 Hz       |
| Discharge Pressure Cutout- 13.5 PSIG                                      | 1 Hz       |
| Discharge Pressure Cutout- 12 PSIG                                        | 2 Hz       |
| Discharge Pressure Cutout- 10.5 PSIG                                      | 3 Hz       |
| Discharge Pressure Cutout- 9 PSIG                                         | 4 Hz       |
| Discharge Pressure Cutout- 7.5 PSIG                                       | 5 Hz       |
| Discharge Pressure Cutout- 6 PSIG                                         | 6 Hz       |
| Discharge Pressure Cutout- 4.5 PSIG                                       | 7 Hz       |
| Discharge Pressure Cutout- 3 PSIG                                         | 8 Hz       |
| Discharge Pressure Cutout- 1.5 PSIG                                       | 9 Hz       |
| Discharge Pressure Cutout- 0 PSIG                                         | 10 Hz      |

**Suction Pressure Load Limiting/Unloading**

Suction pressure load limiting helps to protect the evaporator from freezing. A system is permitted to load normally as long as the Suction Pressure is above the Suction Pressure Cutout plus 2 PSIG. Between Cutout plus 2 PSIG and the Cutout, loading is inhibited, even though increased loading is required. Between the Suction pressure Cutout and Suction Pressure Cutout minus 10 PSIG, forced unloading is performed every 2 seconds according to *Table 20 on Page 124*. This situation would occur if the suction pressure cutout transient override control is in effect (Refer to *Low Suction Pressure Cutout (Software) Fault on Page 122*). The suction pressure cutout is programmed under the PROGRAM key. The default Suction Pressure Cutout is set at 24.0 PSIG.

Suction pressure load limiting is active at startup, to only prevent loading of the compressors. Suction pressure limit unloading will not occur until the system run time reaches 5 minutes of operation to allow the system to stabilize.


**TABLE 20 - SUCTION PRESSURE LOAD LIMITING/UNLOADING**

| SUCTION PRESSURE                                                       | UN-LOADING |
|------------------------------------------------------------------------|------------|
| Suction Pressure is between Cutout +2 PSIG and Suction Pressure Cutout | 0 Hz       |
| Suction Pressure Cutout- 1 PSIG                                        | 1 Hz       |
| Suction Pressure Cutout- 2 PSIG                                        | 2 Hz       |
| Suction Pressure Cutout- 3 PSIG                                        | 3 Hz       |
| Suction Pressure Cutout- 4 PSIG                                        | 4 Hz       |
| Suction Pressure Cutout- 5 PSIG                                        | 5 Hz       |
| Suction Pressure Cutout- 6 PSIG                                        | 6 Hz       |
| Suction Pressure Cutout- 7 PSIG                                        | 7 Hz       |
| Suction Pressure Cutout- 8 PSIG                                        | 8 Hz       |
| Suction Pressure Cutout- 9 PSIG                                        | 9 Hz       |
| Suction Pressure Cutout- 10 PSIG                                       | 10 Hz      |

**Sensor Failure Cutout Fault**

The Sensor Failure Cutout prevents the system from running when a critical sensor (transducer, level sensor, or motor winding temp sensor) is not functioning properly and reading out of range. This safety is checked at startup and will prevent the system from running if one of the sensors has failed.

The sensor failure safety will also fault and shutdown a system while in operation, if a safety threshold is exceeded or a sensor reads out of range (high or low). Following is the Status display fault message.

**SYS X YYYYYYYY SENSOR FAILURE:****ZZZZZZZZZZZZ**

*The X indicates the specific system. YYYYYYYY will either indicate the system is in a "FAULT" condition and will restart when the fault clears, or "LOCKOUT" after 3 faults and will not restart until the operator clears the fault using the keypad.*

ZZZZZZZZZZZZ indicates the failed sensor below:

- SUCT PRESS
- OIL PRESS
- DSCH PRESS
- MOTOR TEMP X \*

The Unit Setup Mode allows a specific motor temperature sensor to be ignored, if it fails.

The start inhibit thresholds for each sensor are shown in the following table.

**TABLE 21 - START INHIBIT SENSOR THRESHOLDS**

| SENSOR               | LOW THRESHOLD | HIGH THRESHOLD |
|----------------------|---------------|----------------|
| Suction Transducer   | 0.3VDC        | 4.7VDC         |
| Oil Transducer       | 0.3VDC        | 4.7VDC         |
| Discharge Transducer | 0.3VDC        | 4.7VDC         |
| Motor Temp. Sensor   | 0°C (0°F)     | 116°C (240°F)  |

### High Motor Temperature Cutout Fault

The High Motor Temperature Cutout prevents a compressor from running when its motor temperature is too high. A system will fault and shut down when any compressor motor temperature sensor rises above 121°C (250°F). The system will be inhibited from starting if its motor temperatures sensors indicate temperatures above 116°C (240°F). If any single temperature sensor is being ignored under the Unit Set-up Mode, that sensor will not be utilized when evaluating motor temperature.

Below is a sample Status display fault message:

**SYS X YYYYYYYY HIGH MOTOR TEMP**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the fault clears or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### System Control Voltage Cutout Fault

The System Control Voltage Cutout alerts the operator the 115VAC Control voltage to one of the systems is missing. This could be due to a system fuse that has been removed or is blown. The affected system will fault and shut down immediately when the 115VAC supply is lost.

The safety will “not” shut down a system if the UNIT switch is OFF, which electrically removes the 115VAC to “all” systems. The safety is only used to indicate a situation where a single system is missing the 115VAC. The safety will not cause a lockout and the system fault will reset when power is returned. A sample message is shown below:

**SYS X YYYYYYYY CONTROL VOLTAGE**

The X indicates the system and YYYYYYYY indicates the system is in a “FAULT” condition and will restart when the fault clears or “LOCKOUT” and will not restart until the operator clears the fault using the keypad.

### Eductor Clog Fault

To sense a loss of oil return to the compressor, an eductor clog detection safety is utilized. The safety monitors the temperature of the line between the eductor and the suction line.

The control algorithm looks at the eductor line temperature once a second. At start, a clog timer is set at 600 seconds. If the eductor line temperature is less than the saturated suction temperature plus 5.5°C (10°F) each time the control circuit looks at the temperature, the clog timer is reset to 600 seconds.


If the eductor line temperatures is greater than the saturated suction temperature plus 5.5°C (10°F), the clog timer is decremented one second. If the temperature remains above the saturated suction temperature plus 5.5°C (10°F) for 600 seconds, the clog timer will count to “0” and the system will shut down and lock out. The status fault will indicate an eductor clog fault.

**EDUCTOR CLOG FAULT**

Whenever this fault occurs, the eductor filter should be changed. The clog timer resets to 600 seconds whenever the control algorithm sees the eductor line temperature is less than the saturated suction pressure plus 5.5°C (10°F). This prevents nuisance eductor clog faults.

THIS PAGE INTENTIONALLY LEFT BLANK

## SECTION 8 - MICROPANEL



LD10605

8

### STATUS KEY OPERATION

The STATUS key displays the current chiller or system operational status. The messages displayed include running status, cooling demand, system faults, unit faults, VSD faults, unit warnings, external device status, load limiting, anti-recycle timer, status of unit/system switches, and a number of other messages. Pressing the STATUS key will enable the operator to view the current status of the chiller. The display will show one message relating to the “highest priority” information as determined by the microprocessor. There are three types of status data, which may appear on the display:

- General Status messages
- Unit Safeties
- System Safeties

When power is first applied to the control panel, the following message displaying York International Corporation, the EPROM version, date, and time will be displayed for 2 seconds, followed by the appropriate general status message:

(C)2004 YORK INTERNATIONAL CORPORATION  
C.XXX.XX.XX 18-SEPT-2010 12:45: AM

Unit status messages occupy 2 lines of the Status message display. If no unit status message applies, individual status messages for each system will be displayed.

Any time the STATUS key is pressed or after the EPROM message disappears at power-up, a status display indicating chiller or system status will appear.

Multiple STATUS messages may appear and can be viewed by pressing the STATUS key repeatedly to allow scrolling through as many as three STATUS messages, which could possibly be displayed at any time on a 2 compressor chiller.

Examples of the typical Status messages are shown in the next topic.

### GENERAL STATUS MESSAGES

#### UNIT STATUS MANUAL OVERRIDE

This message indicates the chiller is operating in MANUAL OVERRIDE mode. This message is a priority message and cannot be overridden by any other STATUS message. When in Manual Override, no other status message will ever be present.

**UNIT STATUS**  
**UNIT SWITCH OFF SHUTDOWN**

This message indicates the UNIT SWITCH is in the OFF position and not allowing the unit to run.

**UNIT STATUS**  
**DAILY SCHEDULE SHUTDOWN**

This message indicates that either the daily or holiday schedule programmed is keeping the chiller from running.

**UNIT STATUS**  
**REMOTE CONTROLLED SHUTDOWN**

This message indicates that either an ISN or RCC has turned the chiller OFF and is not allowing it to run.

**UNIT STATUS**  
**FLOW SWITCH SHUTDOWN**

This message indicates the flow switch is not allowing the chiller to run. There is a 1 second delay on this safety to assure the flow switch did not momentarily open.

**UNIT STATUS**  
**VSD COOLING SHUTDOWN**

This message indicates the chiller is shutdown, but running all the condenser fans, VSD glycol pump, and VSD fan in an effort to bring the internal VSD ambient temperature down to an acceptable level before allowing the chiller to start.

**SYS X REMOTE RUN CONTACT IS OPEN**

This message indicates the remote start / stop contact between 2 and 15 or 2 and 16 of the 1TB terminal block is open. There is a 1 second delay on this safety to assure the remote contacts did not momentarily open.

**SYS X SYSTEM SWITCH IS OFF**

This message indicates the system switch (software via keypad) is turned OFF. The system will not be allowed to run until the system switch is turned ON via the keypad.

**SYS X NOT RUNNING**

This message indicates the system is not running because the chilled liquid is below the setpoint or the micro has not loaded the lead system far enough into the loading sequence to bring the lag system ON. This

message will be displayed on the lag system until the loading sequence is ready for the lag system to start.

**SYS X COOLING DEMAND SHUTDOWN**

This message is only displayed in the Normal Shutdown History display to indicate a capacity control shutdown.

**SYS X COMPRESSOR RUNNING**

This message indicates the system is running as a result of cooling demand.

**SYS X SHUTTING DOWN**

The compressor shutting down message indicates the respective system is ramping down in speed prior to shutting OFF. This message is displayed after the software run signal is disabled until the VSD notifies the Chiller Control Board the compressor is no longer running.

**SYS X ANTI-RECYCLE TIMER = XXX SEC**

This message indicates the amount of time left on the respective system anti-recycle timer and the system is unable to start until the timer times out.

**SYS X DISCHARGE PRESSURE LIMITING**

The Discharge Pressure Limiting message indicates the discharge pressure load limit or discharge pressure unloading is in effect.

**SYS X SUCTION PRESSURE LIMITING**

The Suction Pressure Limiting message indicates the suction pressure load limit or suction pressure unloading is in effect.

**SYS X MOTOR TEMP LIMITING**

The Motor Temp Limiting message indicates the motor temp load limit or motor temp unloading is in effect.

**SYS X MOTOR CURRENT LIMITING**

The motor current limiting message indicates the motor current load limit or motor current unloading is in effect.

#### **SYS X PULLDOWN MOTOR CURRENT LIMITING**

The pulldown motor current limiting message indicates the pulldown motor current load limit or pulldown motor current unloading is in effect based on the programmed setpoint.

#### **SYS X ISN CURRENT LIMITING**

The ISN Current Limiting message indicates the motor current load limit or motor current unloading is in effect through the use of the YORKTalk setpoint.

#### **SYS X REMOTE MOTOR CURRENT LIMITING**

The Remote Motor Current Limiting message indicates the motor current load limit or motor current unloading is in effect through the use of the remote setpoint offset. The setpoint may be offset using a remote voltage or a current signal. The remote current limit must be activated for this function to operate.

#### **SYS X VSD BASEPLATE TEMP LIMITING**

The VSD Baseplate Temp Limiting message indicates the VSD Baseplate temp is high and load limit or unloading is in effect.

#### **SYS X VSD INTERNAL AMBIENT TEMP LIMITING**

The VSD Internal Ambient Temp Limiting message indicates the VSD internal ambient temp is high and load limit or unloading is in effect.

#### **SYS X SOUND LIMITING**

The sound limiting message indicates the sound load limit is in effect based on the locally programmed sound limit from the keypad. The sound limit must be activated for this function to operate.


#### **SYS X ISN SOUND LIMITING**

The ISN sound limiting message indicates the sound load limit is in effect based on the ISN transmitted sound limit setpoint. The sound limit must be activated for this function to operate.

#### **SYS X REMOTE SOUND LIMITING**

The Remote sound limiting message indicates the sound load limit is in effect based on the Remote controlled sound limit setpoint. The setpoint may be offset using a remote voltage or current signal. The sound limit option must be activated for this function to operate.

## UNIT DATA KEY



### General

The UNIT DATA key provides the user with displays of unit temperatures, and unit related data. Displays can be selected by repeatedly pressing the UNIT DATA key or the ▲ or ▼ Arrow Keys.

### Unit Data Key Operation

The first key press displays Evaporator Leaving and Return Chilled Liquid Temperatures.

**UNIT CHILLED LIQUID LEAVING = XXX.X °F**  
**ENTERING = XXX.X °F**

The next key press of the UNIT DATA key or the ▼ (ARROW) key displays the ambient air temperature.

**UNIT**  
**OUTSIDE AMBIENT AIR TEMP = XXX.X °F**

The next key press will display the time remaining on the load and unload timers.

**UNIT**  
**LOAD TIMER = XXX SEC**  
**UNLOAD TIMER = XXX SEC**

The next key press displays the error in temperature between the actual leaving chilled liquid temperature and the setpoint temperature. The display also shows the rate of change of the chilled liquid temperature.

**UNIT**  
**TEMP ERROR = XXX.X °F**  
**RATE = XXX.X °F/M**

The next key press displays the system designated as the lead system and the Flow Switch status (ON or OFF).

**UNIT**  
**LEAD SYSTEM NUMBER = X**  
**FLOW SWITCH = XXX**

The next key press displays the status of the evaporator pump and heater, where XXX is either ON or OFF.

**UNIT**  
**EVAP PUMP RUN = XXX**  
**EVAP HEATER = XXX**

The next key press displays the status of Active Remote Control.

**UNIT**  
**ACTIVE REMOTE CONTROL = XXXXXX**  
**TYPE: RCC ISN CURR TEMP SOUND**

XXXXXX is either ACTIVE or NONE.

If no remote keys are active, the items on the second line are all blanked out. Any remote items that are active will be displayed, while the inactive items will be blanked out.


The types of remote control are listed as follows:

- NONE - No remote control is actively controlling the chiller; however, remote monitoring by a remote device may still be active.
- RCC - A Remote Control Center is providing remote control. The chiller is in remote mode.
- ISN - YorkTalk via ISN. The chiller in remote mode.
- CURR - Remote Current Limiting is enabled.
- TEMP - Remote Temperature Reset is enabled.
- SOUND - Remote Sound Limiting is enabled.

The next key press displays the sound limit values as set under the PROGRAM key by the Local, ISN, and the Remote Sound Limit Inputs. Any sound limits that are inactive will display XXX instead of a numeric value.

|                         |                       |
|-------------------------|-----------------------|
| <b>UNIT SOUND LIMIT</b> | <b>LOCAL = XXX %</b>  |
| <b>ISN = XXX</b>        | <b>REMOTE = XXX %</b> |

## SYSTEM DATA KEYS 1 THROUGH 4



LD10605

**General**

The data keys provide the user with many displays of individual system temperatures, pressures, and other operating data. These keys have multiple displays, which can be seen by repeatedly pressing the SYSTEM DATA or the ▲ or ▼ (Arrow) keys. An explanation of each key and its messages is provided below.

**System 1 Data Key Operation**

The SYSTEM 1 DATA key provides the user with access to System 1 operating parameters. The following is a list of the data in the order in which it appears.

The first key press of the SYSTEM X DATA key displays all of the measured system pressures (oil and discharge).

**SYS 1 PRESSURES**      OIL = XXXX PSIG  
DISCHARGE = XXXX PSIG

The second key press of the SYSTEM DATA key or the ▼ (DOWN ARROW) key displays system suction and condenser liquid pressure.

**SYS 1 PRESSURES**      SUCTION = XXXX PSIG  
CONDENSER LIQUID = XXXX PSIG

The next key press displays system oil and eductor temperatures.

**SYS 1 TEMPERATURES**      OIL = XXX.X °F  
EDUCTOR = XXX.X °F

The next key press displays system condenser liquid temperature, liquid line subcooling and saturated discharge temperature on the liquid line.


**SYS 1 CONDENSER LIQUID TEMP = XXX.X °F**  
SUBCOOLING = XXX.X SAT TEMP = XXX.X °F

The next key press displays discharge temperature, discharge superheat and saturated discharge pressure at the compressor.

**SYS 1 DISCHARGE**      TEMP = XXX.X °F  
SUPERHEAT = XXX.X      SAT TEMP = XXX.X °F

The next key press displays the System 1 motor thermistor temperatures.

**SYS 1 MOTOR TEMPS**      T1 = XXX.X °F  
T2 = XXX.X °F      T3 = XXX.X °F



***If any motor temp sensor is being ignored, (selectable under Unit Set-up Mode), that sensor's value will be displayed as XXXXX.***

The next key press displays the compressor speed in % (0 to 100%) and the compressor heater status (ON or OFF).

**SYS 1 COMPRESSOR                      SPEED = XXX.X %  
                                                 HEATER = XXX**

The next key press indicates the flash tank level low/high and the economizer valve % open.

**SYS 1                      FLASH TANK LEVEL = XXX.X %  
                                         ECONOMIZER VALVE = XXX.X %**

The next key press displays the condenser liquid line subcooling and the drain valve position.

**SYS 1                      CONDENSER SUBCOOLING = XXX.X °F  
                                         CONDENSER DRAIN VALVE = XXX.X %**

The next key press indicates the number of condenser fans steps that are enabled (1 to 4), if the fans are not operating on a VSD.

**SYS 1                      CONDENSER FANS ON = X**

If the fans are controlled by an optional VSD, the display will indicate fan speed signal control voltage to the VSD and the fan speed (0 to 100%).

**SYS 1                      CONDENSER FANS ON = X  
                                         VSD FAN SPEED = XX.X V = XXX %**

The next key press will indicate the state of the optional VI solenoids where XXX indicates ON or OFF.

**SYS 1                      VI STEP SOLENOID 1 = XXX  
                                         VI STEP SOLENOID 2 = XXX**

The next key press displays the system run time in days, hours, minutes and seconds.

**SYS 1 RUN TIME  
XX DAYS XX HOURS XX MINUTES XX SECONDS**

The next key press indicates the status of the RUN Relay where XXX is ON or OFF, the status of the RUN Permissive signal (flow switch/remote start/stop circuit 2 and 15 of 1TB, SYS 1) or 2 and 16 of 1TB, SYS 2) and whether the internal software is telling the system to run (ON or OFF).

**SYS 1 RUN SIGNALS                      RELAY = XXX  
RUN PERM = XXX                      SOFTWARE = XXX**

## System 2 Data Key Operation

System 2 keys function the same as the SYSTEM 1 DATA key except that it displays data for System 2.

On a 2 compressor system, the SYSTEM 3 and SYSTEM 4 data keys will display the following messages:

**SYS 3 DATA NOT AVAILABLE**

**SYS 4 DATA NOT AVAILABLE**

**Sensor Displays**


Table 22 on page 134 lists all the sensors attached to the control board associated with system data keys. The minimum and maximum values displayed on the micro display are provided.

If values exceed the limits in the table, a < (less than) or > (more than) sign will be display along with the minimum or maximum value.

**TABLE 22 - SENSOR MIN/MAX OUTPUTS**

| SYSTEM SENSOR               |                                                   |                     |                        |
|-----------------------------|---------------------------------------------------|---------------------|------------------------|
| SENSOR / INPUT              | TYPE                                              | MINIMUM VALUE       | MAXIMUM VALUE          |
| Suction Pressure            | Transducer                                        | 0.0 PSIG (0 barg)   | 125.0 PSIG (8.62 barg) |
| Condenser Liquid Pressure   | Transducer                                        | 0.0 PSIG (0 barg)   | 400.0 PSIG (27.6 barg) |
| Discharge Pressure          | Transducer                                        | 0.0 PSIG (0 barg)   | 400.0 PSIG (27.6 barg) |
| Oil Pressure                | Transducer                                        | 0.0 PSIG (0 barg)   | 400.0 PSIG (27.6 barg) |
| Flash Tank Level            | Switch                                            | Low                 | High                   |
| Condenser Liquid Temp       | Thermistor                                        | -4.1 °F (-20.06 °C) | 155.6 °F (68.67°C)     |
| Leaving Chilled Liquid Temp | Thermistor                                        | -19.1 °F (-28.49°C) | 110.2 °F (43.44°C)     |
| Return Chilled Liquid Temp  | Thermistor                                        | -19.1 °F (-28.49°C) | 110.2° F (43.44°C)     |
| Eductor Temp                | Thermistor                                        | -4.1° F (-20.06°C)  | 132.8 °F (56.00°C)     |
| Ambient Air Temp            | Thermistor                                        | -4.6 °F (-20.33°C)  | 137.9° F (58.83°C)     |
| Compressor Motor Temp       | Thermistor                                        | -30.2 °F (-34.56°C) | 302.0° F (150.00°C)    |
| Discharge Temp              | Thermistor                                        | 40.3 °F (4.61°C)    | 302.6 °F (150.33°C)    |
| Remote Temp Reset           | 4 to 20ma, 0 to 10VDC,<br>0 to 20ma or 2 to 10VDC | 0%                  | 100%                   |
| Remote Current Limit        | 4 to 20ma, 0 to 10VDC,<br>0 to 20ma or 2 to 10VDC | 0%                  | 100%                   |
| Remote Sound Limit          | 4 to 20ma, 0 to 10VDC,<br>0 to 20ma or 2 to 10VDC | 0%                  | 100%                   |

## VSD DATA KEY



LD10605

8

### General

The VSD DATA key provides the user with displays of VSD temperatures, voltages, currents, and other operating data. This key has multiple displays, which can be seen by repeatedly pressing the VSD DATA or the ▲ or ▼ (Arrow) keys. An explanation of each message is provided below.

### VSD Data Key Operation

The first VSD DATA key press displays the actual VSD Output Frequency and Command Frequency.

**VSD FREQUENCY      ACTUAL = XXX.X HZ  
COMMAND = XXX.X HZ**

The second key press of the VSD DATA key or the ▼ (ARROW) key displays the calculated compressor % FLA and measured motor currents in amps for systems 1 and 2. When measuring motor current keep in mind that measuring inverter PWM current is difficult and meter error can be significant.

**VSD COMP 1 = XXX AMPS      = XXX %FLA  
COMP 2 = XXX AMPS      = XXX %FLA**

The next key press displays the current limit values set locally on the panel under the PROGRAM key, remotely by an ISN, and remotely by the Current Limit input. Any current limits that are inactive will display “XXX” instead of a numeric value.

**VSD CURRENT LIMIT      LOCAL = XXX %FLA  
ISN = XXX      REMOTE = XXX %FLA**

The next key press displays DC Bus voltage.

**VSD      DC BUS VOLTAGE = XXX VDC**

The next key press displays the Control Panel/VSD Internal Ambient Temperature and VSD Cooling Pump/Fan Status. YYY will indicate ON or OFF.

**VSD      INTERNAL AMBIENT TEMP = XXX.X °F  
COOLING SYSTEM STATUS = YYY**

The next key press displays the IGBT highest baseplate temperature.

**VSD IGBT BASEPLATE TEMPS T1 = XXX °F  
T2 = XXX °F**

The next key press displays the state of the Precharge signal, where XXX is either ON or OFF.

**VSD      PRECHARGE SIGNAL = XXX**


The next key press displays the setting of the VSD’s 105% FLA overload potentiometer for Compressor #1 and 2. The settings are determined by the adjustment of the overload potentiometers on the VSD Logic Board. These pots are factory set and should not require changing unless the circuit board is replaced.

**VSD      COMP 1 MOTOR OVERLOAD = XXX AMPS  
COMP 2 MOTOR OVERLOAD = XXX AMPS**

**TABLE 23 - COMPRESSOR MOTOR OVERLOAD SETTINGS**

| MODEL         |             | 380V-60HZ  |            | 400V-50HZ  |            | 460V-60HZ (see note 1) |            |
|---------------|-------------|------------|------------|------------|------------|------------------------|------------|
|               |             | SYS # 1    | SYS # 2    | SYS # 1    | SYS # 2    | SYS # 1                | SYS # 2    |
| 50/60 HZ TONS | 50/60 HZ KW | OL SETTING | OL SETTING | OL SETTING | OL SETTING | OL SETTING             | OL SETTING |
| YVAA0153      | YVAA0543    | 225        | 225        | 225        | 225        | 175                    | 175        |
| YVAA0165      | YVAA0565    | 225        | 225        | 225        | 225        | 175                    | 175        |
| YVAA0178      | YVAA0588    | 225        | 225        | 225        | 225        | 175                    | 175        |
| YVAA0183      | YVAA0643    | 283        | 236        | 283        | 231        | 225                    | 175        |
| YVAA0195      | YVAA0665    | 283        | 236        | 283        | 231        | 225                    | 175        |
| YVAA0198      | YVAA0688    | 283        | 236        | 283        | 231        | 225                    | 175        |
| YVAA0200      | YVAA0700    | 300        | 300        | 283        | 283        | 236                    | 236        |
| YVAA0213      | YVAA0743    | 283        | 283        | 283        | 283        | 225                    | 225        |
| YVAA0215      | YVAA0765    | 283        | 283        | 283        | 283        | 225                    | 225        |
| YVAA0218      | YVAA0788    | 283        | 283        | 283        | 283        | 225                    | 225        |
| YVAA0233      | YVAA0843    | 338        | 300        | 338        | 283        | 283                    | 236        |
| YVAA0245      | YVAA0865    | 338        | 300        | 338        | 283        | 283                    | 236        |
| YVAA0248      | YVAA0888    | 338        | 300        | 338        | 283        | 283                    | 236        |
| YVAA0263      | YVAA0943    | 338        | 338        | 338        | 338        | 283                    | 283        |
| YVAA0273      | YVAA0963    | 338        | 338        | 338        | 338        | 283                    | 283        |
| YVAA0275      | YVAA0965    | 338        | 338        | 338        | 338        | 283                    | 283        |
| YVAA0278      | YVAA0988    | 334        | 334        | 317        | 317        | 276                    | 276        |
| YVAA0295      | YVAA1015    | 412        | 334        | 412        | 317        | 392                    | 276        |
| YVAA0303      | YVAA1093    | 412        | 334        | 412        | 317        | 392                    | 276        |
| YVAA0305      | YVAA1065    | 412        | 334        | 412        | 317        | 392                    | 276        |
| YVAA0308      | YVAA1088    | 412        | 334        | 412        | 317        | 392                    | 276        |
| YVAA0318      | YVAA1188    | 412        | 334        | 412        | 317        | 392                    | 276        |
| YVAA0323      | YVAA1143    | 412        | 412        | 412        | 412        | 392                    | 392        |
| YVAA0333      | YVAA1173    | 412        | 412        | 412        | 412        | 392                    | 392        |
| YVAA0343      | YVAA1193    | 412        | 412        | 412        | 412        | 392                    | 392        |
| YVAA0345      | YVAA1215    | 412        | 412        | 412        | 412        | 392                    | 392        |
| YVAA0368      | YVAA1288    | 720        | 338        | 720        | 338        | 590                    | 283        |
| YVAA0373      | YVAA1343    | 720        | 338        | 720        | 338        | 590                    | 283        |
| YVAA0375      | YVAA1315    | 720        | 338        | 720        | 338        | 590                    | 283        |
| YVAA0398      | YVAA1388    | 720        | 412        | 720        | 412        | 590                    | 392        |
| YVAA0413      | YVAA1443    | 720        | 412        | 720        | 412        | 590                    | 392        |
| YVAA0425      | YVAA1515    | 720        | 412        | 720        | 412        | 590                    | 392        |
| YVAA0428      | YVAA1488    | 720        | 412        | 720        | 412        | 590                    | 392        |
| YVAA0443      | YVAA1543    | 720        | 720        | 720        | 720        | 590                    | 590        |
| YVAA0475      | YVAA1665    | 720        | 720        | 720        | 720        | 590                    | 590        |
| YVAA0483      | YVAA1693    | 720        | 720        | 720        | 720        | 590                    | 590        |
| YVAA0500      | YVAA1700    | 720        | 720        | 720        | 720        | 590                    | 590        |
| YVAA0523      | YVAA1843    | 720        | 720        | 720        | 720        | 590                    | 590        |

## OPERATING HOURS / START COUNTER KEY



LD10605


8

Compressor operating hours and compressor starts are displayed with a single key press. The maximum value for both hours and starts is 99,999, at which point they will roll over to 0.

A single display is available under this key and is displayed below.

HOURS 1=XXXXXX, 2=XXXXXX  
START 1=XXXXXX, 2=XXXXXX

## HISTORY KEY



LD10605

### History Key Operation

The HISTORY key provides the user access to many unit and system operating parameters captured at the instant a unit or system safety (fault) shutdown occurs. The history buffer will also capture system data at the time of normal shutdowns such as cycling shutdowns. When the HISTORY key is pressed the following screen is displayed:

```

HISTORY    CHOOSE HISTORY TYPE
◀ ▶  XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
  
```

The ◀ and ▶ (ARROW) keys allow choosing between NORMAL SHUTDOWNS and FAULT SHUTDOWNS. “Fault” shutdowns provide information on safety shutdowns, while “Normal” shutdowns provide chiller cycling information on temperature (demand), cycling, remote, system switch, and so on, shutdowns that are non-safety related shutdowns. Once the selection is made, the ✓ (ENTER) key must be pressed to enter the selection.

### Normal Shutdowns History

If the NORMAL SHUTDOWNS History is selected, the following screen will be displayed:

```

NORM HIST XX 18-JUN-2004 10:34:58 AM
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
  
```

XX is the normal shutdown number. The display will provide date and time of the shutdown and the reason for the cycling shutdown (YYY....).

The operator can view any of the stored 20 single display normal shutdown history buffers. History buffer number 1 provides the most recent shutdown information and buffer number 20 is the oldest safety shutdown information saved. The ◀ and ▶ (ARROW) keys allow scrolling between each of the history buffers. The ▶ (ARROW) key scrolls to the next normal history shutdown and the ◀ (ARROW) key scrolls to the previous normal history shutdown.

The following display will typically be displayed on a normal shutdown due to shutdown on lack of cooling demand.

```

NORM HIST XX 18-JUN-2004 10:34:58 AM
SYS X COOLING DEMAND SHUTDOWN
  
```

### Fault Shutdowns History

If the FAULT SHUTDOWNS History is selected, the following screen will be displayed:

```

FAULT HIST XX 18-JUN-2004 10:34:58 AM
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
  
```

XX is the FAULT HISTORY shutdown number. The display will provide the date, time, and a description of the specific type of fault that occurred (YYY....).

The operator can view any of the stored 10 fault history buffers. History buffer number 1 provides the most recent safety shutdown information and buffer number 10 is the oldest safety shutdown information saved. The ◀ and ▶ arrow keys allow scrolling between each of the FAULT HIST buffers 1 through 10. The ▲ (UP) and ▼ (DOWN) arrow keys can be used to scroll forwards and backwards through the data in a specific history buffer, once it is displayed.

There is a large amount of data provided under each history. Rather than scroll sequentially through the data in a history, which is possible using the ▼ arrow key, the use of a combination of the ◀, ▶, ▲, and ▼ arrow keys allows fast scrolling to specific data the user desires to view. To use this feature, the user needs to be aware the ◀ and ▶ arrow keys allow scrolling to the top of the data subgroups. Once a specific history is selected, the history data is divided under the subgroups of Unit Data, VSD Data, System Data, Hours / Starts, Setpoints, Options, and Program data. The ◀ and ▶ arrow keys allow moving to the first display under the next or previous subgroup at any time. Once the first display of a subgroup is displayed, the ▲, and ▼ arrow keys allow scrolling through the data in the subgroup. The ▼ arrow key allows scrolling through the data from first to last. When the last piece of data is displayed, the next press of the ▼ arrow key scrolls to the first piece of data in the next subgroup. The ▲ arrow key allows going to the previous display.

Listed below is a description of the fault data displays and their meaning. Data will be displayed in a specific order starting with the Status Display (System Faults only), Fault Display, All Fault Display, Unit Data, VSD Data, System Data, Operating Hours/Starts, Setpoints, Options, and Program Values at the time of the fault.

### Status Fault Type

**SYS X COMPRESSOR RUNNING**  
**SYS X YYYYYYYY HIGH DIFF OIL PRESSURE**

This message indicates the type of system fault. This screen is skipped if a UNIT Fault caused the shutdown.

### Unit Fault Type

**UNIT FAULT**  
**LOW AMBIENT TEMP**

This message indicates the type of unit fault. This screen is skipped if a SYSTEM Fault caused the shutdown.

## All Fault Data

**FAULT HIST XX ALL FAULTS ZZ OF WW**  
**YYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYYY**

The ALL FAULT display indicates whether a fault occurred while the unit is shutting down on another fault.

If a control panel fault occurred while the unit is shutting down on a VSD fault before it is reset, the control panel fault is an ALL FAULT of the VSD fault.

If another VSD fault occurs while the unit is shutting down on a VSD fault, the next VSD fault will be registered as an ALL FAULT of the VSD fault.

If a VSD fault occurs during the ramp down shutdown of a control panel fault, the VSD fault is registered as a new fault, not an ALL FAULT.

XX is the history number, YY is the ALL FAULT description, ZZ is the ALL FAULT number and WW is the total number of All Faults for the current history. Sometimes, multiple faults may occur during the shutdown and multiple displays will be observed when scrolling through the data using the ▼ arrow. In most cases, the ALL FAULT display will indicate NONE. The ALL FAULT display will only indicate the cause of the fault. No additional chiller information will be displayed under the ALL FAULT, since a snapshot of all chiller data was taken at the time of the first fault.

## Unit Data

### Evaporator Leaving and Entering Chilled Liquid Temperatures

**UNIT CHILLED LIQUID LEAVING = XXX.X °F**  
**ENTERING = XXX.X °F**

This message indicates the leaving and entering chilled liquid temperatures at the time of the fault.

## Ambient Air Temperature

**UNIT**  
**OUTSIDE AMBIENT AIR TEMP = XXX.X °F**

This message indicates the ambient air temperature at the time of the fault.

**Load / Unload Timers**

|      |                        |
|------|------------------------|
| UNIT | LOAD TIMER = XXX SEC   |
|      | UNLOAD TIMER = XXX SEC |

This message indicates remaining time on the load and unload timers at the time of the fault.

**Chilled Liquid Temperature Error and Rate of Change**

|      |                       |
|------|-----------------------|
| UNIT | TEMP ERROR = XXX.X °F |
|      | RATE = XXX.X °F/M     |

This message indicates the temperature error between the actual and the programmed setpoint at the time of the fault and the rate of temperature change.

**Programmed Lead System Selection and Flow Switch Status**

|      |                        |
|------|------------------------|
| UNIT | LEAD SYSTEM NUMBER = X |
|      | FLOW SWITCH = XXX      |

This message indicates the designated lead system at the time of the fault and whether the flow switch was ON (Closed) or OFF (Open) at the time of the fault.

**Evaporator Pump and Evaporator Heater Status**

|      |                     |
|------|---------------------|
| UNIT | EVAP PUMP RUN = XXX |
|      | EVAP HEATER = XXX   |

This message indicates the status of the evaporator pump and the evaporator heater at the time of the fault. XXX indicates ON or OFF.

**Active Remote Control Status**

|      |                                |
|------|--------------------------------|
| UNIT | ACTIVE REMOTE CONTROL = XXXXXX |
|------|--------------------------------|

This message indicates whether the system was operating under Active Remote Control (RCC, ISN, LOAD, TEMP, or SOUND) or standard control (NONE) at the time of the fault.

|      |             |                |
|------|-------------|----------------|
| UNIT | SOUND LIMIT | LOCAL = XXX %  |
|      | ISN = XXX   | REMOTE = XXX % |

This message indicates that sound limiting was in effect, the amount, and whether it was local or remotely limited.

**VSD Data****VSD Actual and Command Frequency**

|               |                    |
|---------------|--------------------|
| VSD FREQUENCY | ACTUAL = XXX.X HZ  |
|               | COMMAND = XXX.X HZ |

This message indicates the VSD actual operating frequency and the command frequency at the time of the fault. Actual and command may not match due to load/unload timers, limitation of 1 Hz per load/unload increment, and to allowable acceleration/deceleration of the motor.

**Compressor Amps and %FLA**

The message indicates the compressor %FLA and motor currents for systems 1 and 2 at the time of the fault.

|        |            |            |
|--------|------------|------------|
| COMP 1 | = XXX AMPS | = XXX %FLA |
| COMP 2 | = XXX AMPS | = XXX %FLA |

**VSD Current Limit**

|                   |                   |
|-------------------|-------------------|
| VSD CURRENT LIMIT | LOCAL = XXX %FLA  |
| ISN = XXX         | REMOTE = XXX %FLA |

This message displays the current limit values as set locally, by an ISN, or a remote current limiting input at the time of the fault.

**DC BUS Voltage**

|     |                          |
|-----|--------------------------|
| VSD | DC BUS VOLTAGE = XXX VDC |
|-----|--------------------------|

This message displays the DC Bus voltage at the time of the fault.

**VSD Internal Ambient Temp**

|     |                                  |
|-----|----------------------------------|
| VSD | INTERNAL AMBIENT TEMP = XXX.X °F |
|     | COOLING SYSTEM STATUS = YYY      |

This message displays the VSD/Microprocessor internal ambient cabinet temperature and the cooling system status (ON or OFF) at the time of the fault.

**IGBT Baseplate Temperature**

|     |                      |             |
|-----|----------------------|-------------|
| VSD | IGBT BASEPLATE TEMPS | T1 = XXX °F |
|     |                      | T2 = XXX °F |

This message displays the IGBT highest baseplate temperature for 2 and 3 compressor units at the time of the fault. 4 compressor units display temperatures for 1/3 (T1) and 2/4 (T2).

## Precharge Signal Status and VSD Cooling Status

**VSD PRECHARGE SIGNAL = XXX**

This display provides the state of the precharge signal, where XXX is either ON or OFF at the time of the fault.

## Compressor #1 and #2, 105% FLA Motor Overload Current Setting

**VSD COMP 1 MOTOR OVERLOAD = XXX AMPS  
COMP 2 MOTOR OVERLOAD = XXX AMPS**

This message displays the setting of the VSD's 100% FLA potentiometer for Compressor #1 and #2 at the time of the fault.

## System Data

### System #1 Pressures

**SYS 1 PRESSURES OIL = XXXX PSIG  
DISCHARGE = XXXX PSIG**

This message displays the measured system oil and discharge pressures at the time of the fault.

**SYS 1 PRESSURES SUCTION = XXXX PSIG  
CONDENSER LIQUID = XXXX PSIG**

This message displays the measured system suction and condenser liquid line pressure at the time of the fault.

### System # 1 Temperatures

**SYS 1 TEMPERATURES OIL = XXX.X °F  
EDUCTOR = XXX.X °F**

This message displays the measured system oil and eductor temperatures at the time of the fault.

**SYS 1 CONDENSER LIQUID TEMP = XXX.X °F  
SUBCOOLING = XXX.X SAT TEMP = XXX.X °F**

This message displays the condenser liquid, liquid line subcooling and saturated discharge temperatures at the time of the fault.

**SYS 1 DISCHARGE TEMP = XXX.X °F  
SUPERHEAT = XXX.X SAT TEMP = XXX.X °F**

This message displays the system discharge, discharge superheat and saturated discharge temperatures at the time of the fault.

## Compressor Speed and Heater Status

**SYS 1 COMPRESSOR SPEED = XXX.X %  
HEATER = XXX.X °F**

This message indicates the compressor speed in % and the heater status at the time of the fault.

## System #1 Motor Temperatures

**SYS 1 MOTOR TEMPS T1 = XXX.X °F  
T2 = XXX.X T3 = XXX.X °F**

This message displays the System 1 motor thermistor temperatures at the time of the fault.

## Flash Tank Level and Economizer Position

**SYS 1 FLASH TANK LEVEL Y 512 ADC  
ECONOMIZER VALVE = XXX.X %**

This message displays the flash tank level and the economizer valve position in % at the time of the fault.

## Condenser Subcooling and Condenser Drain Valve Position

**SYS 1 CONDENSER SUBCOOLING = XXX.X °F  
CONDENSER DRAIN VALVE = XXX.X %**

This message displays the condenser subcooling and the Condenser Drain Valve position at the time of the fault.

## Condenser Fans

**SYS 1 CONDENSER FANS ON = X**

**SYS 1 CONDENSER FANS ON = X  
VSD FAN SPEED XX.X V = XXX %**

This message displays the number of condenser fans ON or the optional VSD fan control speed signal to the inverter and the % of full speed.

## VI Step Solenoid

**SYS 1 VI STEP SOLENOID 1 = XXX  
VI STEP SOLENOID 2 = XXX**

This message displays whether the VI solenoids were ON or OFF at the time of the fault.

**Compressor #1 Run Time**

|                                               |
|-----------------------------------------------|
| <b>SYS 1 RUN TIME</b>                         |
| <b>XX DAYS XX HOURS XX MINUTES XX SECONDS</b> |

This message displays the system run time since the last start in days, hours, minutes, and seconds at the time of the fault.

**System #1 Run Signals**

|                          |                       |
|--------------------------|-----------------------|
| <b>SYS 1 RUN SIGNALS</b> | <b>RELAY = XXX</b>    |
| <b>RUN PERM = XXX</b>    | <b>SOFTWARE = XXX</b> |

This message displays the System Run Signal Relay (Relay Output Board) status, Run Permissive Input status, and the Internal Software (microprocessor command) ON/OFF Start status. The status of each will indicate either ON or OFF.

**System 2 Data**

Data for the system 2 at the time of the fault is displayed in the same sequence as the system #1 data.

**Compressor Operating Hours and Starts**

|                               |
|-------------------------------|
| <b>HOURS 1=XXXXX, 2=XXXXX</b> |
| <b>START 1=XXXXX, 2=XXXXX</b> |

This message displays compressor operating hours and compressor starts at the time of the fault.

**Chilled Liquid Setpoint Cooling Setpoints**

|                                          |
|------------------------------------------|
| <b>SETPOINTS</b>                         |
| <b>LOCAL COOLING SETPOINT = XXX.X °F</b> |

This message displays the programmed cooling setpoint at the time of the fault.

|                                         |
|-----------------------------------------|
| <b>SETPOINTS</b>                        |
| <b>LOCAL CONTROL RANGE = +/- X.X °F</b> |

This message displays the programmed Control Range at the time of the fault.

**Remote Setpoint and Range**

|                                             |
|---------------------------------------------|
| <b>SETPOINTS REMOTE SETPOINT = XXX.X °F</b> |
| <b>REMOTE CONTROL RANGE = +/- X.X °F</b>    |

This message displays the remote setpoint and Control Range at the time of the fault.

**Maximum Remote Temperature Setpoint**

|                                             |
|---------------------------------------------|
| <b>SETPOINTS</b>                            |
| <b>MAXIMUM REMOTE TEMP RESET = XXX.X °F</b> |

This message displays the maximum remote reset programmed at the time of the fault.

**Options****Display Language**

|                |                              |
|----------------|------------------------------|
| <b>OPTIONS</b> | <b>DISPLAY LANGUAGE</b>      |
| <b>◀ ▶</b>     | <b>XXXXXXXXXXXXXXXXXXXXX</b> |

This message displays the language selected at the time of the fault.

**Chilled Liquid Cooling Mode**

|                |                                    |
|----------------|------------------------------------|
| <b>OPTIONS</b> | <b>CHILLED LIQUID COOLING MODE</b> |
| <b>◀ ▶</b>     | <b>WATER COOLING</b>               |

This message displays the chilled liquid temperature mode (water or glycol) selected at the time of the fault.

**Local / Remote Control Mode**

|                |                                    |
|----------------|------------------------------------|
| <b>OPTIONS</b> | <b>CHILLED LIQUID COOLING MODE</b> |
| <b>◀ ▶</b>     | <b>GLYCOL COOLING</b>              |

This message indicates whether Local or Remote Control Mode was selected at the time of the fault.

|                |                                    |
|----------------|------------------------------------|
| <b>OPTIONS</b> | <b>LOCAL / REMOTE CONTROL MODE</b> |
| <b>◀ ▶</b>     | <b>XXXXXXXXXXXXXXXXXXXXX</b>       |

When Remote Control Mode is selected, control of the Chilled Liquid Setpoint is from a remote device such as an ISN/BAS controller.

**Display Units Mode**

|                |                              |
|----------------|------------------------------|
| <b>OPTIONS</b> | <b>DISPLAY UNITS</b>         |
| <b>◀ ▶</b>     | <b>XXXXXXXXXXXXXXXXXXXXX</b> |

This message indicates whether SI (°C, barg) or Imperial units (°F, PSIG) was selected at the time of the fault.

## System Lead/Lag Control Mode

| OPTIONS | LEAD / LAG CONTROL MODE |
|---------|-------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX    |

This message indicates the type of lead lag control selected at the time of the fault. Three choices are available:

- Automatic
- Sys 1 Lead
- Sys 2 Lead

The default mode will be AUTOMATIC.

## Remote Temperature Reset

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | XXXXXXXXXX              |

This message indicates whether temperature reset was active or disabled at the chiller keypad at the time of the fault and if active, the type of reset signal selected.

If the option is not factory enabled, the option will not appear.

## Remote Current Reset

| OPTIONS | REMOTE CURRENT LIMIT INPUT |
|---------|----------------------------|
| ◀ ▶     | XXXXXXXXXXXX               |

This message indicates whether remote current reset was active or disabled at the chiller keypad at the time of the fault and if active, the type of reset signal selected.

If the option is not factory enabled, the option will not appear.

## Remote Sound Limit Selection

| OPTIONS | REMOTE SOUND LIMIT INPUT |
|---------|--------------------------|
| ◀ ▶     | XXXXXXXXXXXX             |

This message indicates whether remote sound limit was active or disabled at the chiller keypad at the time of the fault and if active, the type of reset signal selected.

If the option is not factory enabled, the option will not appear.

## Program Values

### Suction Pressure Cutout

| PROGRAM                              |
|--------------------------------------|
| SUCTION PRESSURE CUTOUT = XXX.X PSIG |

This message indicates the suction pressure cutout programmed at the time of the fault.

## Low Ambient Cutout

| PROGRAM                            |
|------------------------------------|
| LOW AMBIENT TEMP CUTOUT = XXX.X °F |

This message displays the low ambient temp cutout programmed at the time of the fault.

## Low Leaving Chilled Liquid Temp Cutout

| PROGRAM                               |
|---------------------------------------|
| LEAVING LIQUID TEMP CUTOUT = XXX.X °F |

This message displays the low leaving chilled liquid temperature cutout programmed at the time of the fault.

## Motor Current Limit

| PROGRAM                        |
|--------------------------------|
| MOTOR CURRENT LIMIT = XXX %FLA |

This message indicates the motor current limit programmed at the time of the fault.

## Pulldown Current Limit

| PROGRAM                           |
|-----------------------------------|
| PULLDOWN CURRENT LIMIT = XXX %FLA |

This message indicates the pulldown current limit programmed at the time of the fault.

## Pulldown Current Limit Time

| PROGRAM                               |
|---------------------------------------|
| PULLDOWN CURRENT LIMIT TIME = XXX MIN |

This message indicates the pulldown current limit time programmed at the time of the fault.

## Condenser Subcooling Setpoint

| PROGRAM                        |
|--------------------------------|
| SUBCOOLING SETPOINT = XXX.X °F |

This message indicates the liquid subcooling setpoint programmed at the time of the fault.

## Unit ID Number

| PROGRAM                   |
|---------------------------|
| REMOTE UNIT ID NUMBER = X |

This indicates the unit ID # programmed at the time of the fault.

**Sound Limit Setpoint**

**PROGRAM**  
**SOUND LIMIT SETPOINT = XXX %**

This indicates the sound limit setpoint programmed at the time of the fault, if the sound limit option is activated at the factory. If the option is not factory activated, the display will not appear.

**Eductor Differential Temperature**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**EDUCTOR DIFFERENTIAL = XXX °F**

This message indicates the programmed eductor differential temperature at the time of the fault.

**Eductor Safety Time**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**EDUCTOR SAFETY TIME = XXX MIN**


This message indicates the eductor safety time programmed at the time of the fault.

**Motor Temperature Unload**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**MOTOR TEMPERATURE UNLOAD = XXX °F**

This message indicates the motor temperature programmed at the time of the fault.

## SETPOINTS KEY



LD10605

### Setpoints Key Operation

Cooling setpoints and ranges may be programmed by pressing the SETPOINTS key. The first setpoint entry screen will be displayed as shown below. The first line of the display will show the chiller default (DEF), minimum acceptable value (LO) and maximum acceptable value (HI). The second line shows the actual programmed value. *Table 24 on page 146* also shows the allowable ranges for the cooling setpoints and Control Ranges. Note that the Imperial units are exact values while the Metric units are only approximate.

**SETPOINTS ◀DEF XXXXX LO XXXXX HI XXXXX  
LOCAL COOLING SETPOINT = XXX.X °F**

Pressing the SETPOINTS key a second time or the ▼ (ARROW) key will display the leaving chilled liquid Control Range, default, and low/high limits.

**SETPOINTS ◀DEF XXXXX LO XXXXX HI XXXXX  
LOCAL CONTROL RANGE = +/- X.X °F**

Pressing the SETPOINTS key or the ▼ (ARROW) key a third time will display the remote setpoint and cooling range. This display automatically updates about every 2 seconds. This remote setpoint message is shown below:

**SETPOINTS REMOTE SETPOINT = XXX.X °F  
REMOTE CONTROL RANGE = +/- X.X °F**

If there is no remote setpoint being utilized, the remote setpoint value will be displayed as XXXXXX and the remote Control Range will display XXX.

Pressing the SETPOINTS key or the Arrow key a fourth time will bring up a screen that allows the Maximum Remote Temperature Reset to be programmed. This message is shown below:

**SETPOINTS ◀DEF XXXXX LO XXXXX HI XXXXX  
MAXIMUM REMOTE TEMP RESET = XXX.X °F**

The values displayed under each of the key presses may be changed by keying in new values and pressing the ✓ (ENTER) key to store the new value into memory. Where more than one value may be keyed in on a display, a portion of the data that does not need updating may be skipped by pressing the ✓ (ENTER) key. The ✓ (ENTER) key must also be pressed after the last value in the display to store the data into memory.


The ▲ (ARROW) key allows scrolling back through the setpoints displays.

The minimum, maximum, and default values allowed under the SETPOINTS key are provided in *Table 24 on page 146*.

**TABLE 24 - SETPOINT LIMITS**

| PROGRAM VALUE                        | MODE           | LOW LIMIT | HIGH LIMIT | DEFAULT |
|--------------------------------------|----------------|-----------|------------|---------|
| Leaving Chilled Liquid Setpoint      | Water Cooling  | 40.0°F    | 60.0°F     | 44.0°F  |
|                                      |                | 4.4°C     | 15.6°C     | 6.7°C   |
|                                      | Glycol Cooling | 15.0°F    | 70.0°F     | 44.0°F  |
|                                      |                | -9.4°C    | 15.6°C     | 6.7°C   |
| Leaving Chilled Liquid Control Range | -              | 1.5°F     | 2.5°F      | 2.0°F   |
|                                      |                | 0.8°C     | 1.4°C      | 1.1°C   |
| Max. Remote Temperature Reset        | -              | 2°F       | 40°F       | 20°F    |
|                                      |                | 1°C       | 22°C       | 11°C    |

## PROGRAM KEY



8

### Program Key Operation

Various operating parameters are programmable by the user. These are modified by pressing the PROGRAM key and then the ✓ (ENTER) key to enter Program Mode. A listing of the limits of the programmable values is found below. Note that the Imperial units are exact values, while Metric units are only approximate.

The ▲ and ▼ (ARROW) keys are used to scroll through the user programmable values. A value may be changed by keying in the new value and pressing the ✓ (ENTER) key to store the new value in memory. The cursor will be displayed on the screen when a number key is pressed. The first line of each message will indicate the chiller default (DEF) value), lowest acceptable programmable value (LO), and highest acceptable programmable value (HI). The user programmable value is programmed ON in the second line of the message.

When the PROGRAM key is first pressed, the following display will appear indicating the user is in the program mode:

```
PROGRAM MODE XXXX
PRESS ENTER KEY TO CONTINUE
```

Pressing the ✓ (ENTER) key again will display the first programmable selection.

### Suction Pressure Cutout

```
PROGRAM ◀DEF XXXXX LO XXXXX HI XXXXX
SUCTION PRESSURE CUTOUT = XXX.X PSIG
```

The suction pressure cutout is protects the chiller from a low refrigerant condition. It also helps protect from a freeze-up due to low or no chilled liquid flow. However, it is only a back-up for a flow switch and cannot protect against an evaporator freeze under many conditions. This cutout is programmable and should generally be programmed for 1.65 barg (24 PSIG) for chilled water cooling for R-134a system, and 1.93 barg (28 PSIG) for R-513A system.

For R-134a refrigerant, the cutout is programmable between 1.65 and 2.48 barg (24.0 and 36.0 PSIG) in the Water Cooling mode and 0.34 and 2.28 barg (5.0 and 36.0 PSIG) in the Glycol Cooling mode. The default value for both modes will be 1.65 barg (24.0 PSIG).

For R-513a refrigerant, the cutout is programmable between 1.93 and 2.80 barg (28.0 and 40.7 PSIG) in the Water Cooling mode and 0.53 and 2.80 barg (7.7 and 40.7 PSIG) in the Glycol Cooling mode. The default value for both modes will be 1.93 barg (28.0 PSIG).

**Low Ambient Cutout**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**LOW AMBIENT TEMP CUTOUT** = XXX.X °F

The low ambient temp cutout allows programming the outdoor temperature at which it is desired to shut down the chiller to utilize other methods of cooling.

The cutout is programmable between -18.9°C (-2.0°F) and 10.0°C (50°F) with a -3.9°C (25°F) default.

**Low Leaving Liquid Temp Cutout**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**LEAVING LIQUID TEMP CUTOUT** = XXX.X °F

The leaving chilled liquid temp cutout is programmed to avoid freezing the evaporator due to excessively low chilled liquid temperatures. The cutout is automatically set at 2.2 °C (36°F) in the Water Cooling mode and is programmable in the Glycol Cooling mode. In the Glycol Cooling Mode, the cutout is programmable from -11.7°C to 2.2°C (11.0°F to 36.0°F) with a default of 2.2°C (36.0°F).

**Motor Current Limit**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**MOTOR CURRENT LIMIT** = XXX % FLA

The motor current limit %FLA is programmable. This allows the microprocessor to limit a system before it faults on high current. Typically, the limit point is set at 100%. The unload point is programmable from 30 to 100% with a default of 100%.

**Pulldown Current Limit**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**PULLDOWN CURRENT LIMIT** = XXX % FLA

The pulldown current limit %FLA is programmable. This allows the microprocessor to limit a system on pulldown limiting for the purpose of peak time energy savings. Typically, the limit point is set at 100%. The pulldown limit point is programmable from 30 to 100% with a default of 100%. Be aware when using pulldown motor current limit, the chiller may not be able to load to satisfy temperature demand.

**Pulldown Current Limit Time**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**PULLDOWN CURRENT LIMIT TIME** = XXX MIN

The pulldown current limit time is programmable. This allows the microprocessor to limit a system on

pulldown limiting for a defined period of time for the purpose of peak time energy savings. The pulldown limit point is programmable from 0 to 255 with a default of 0 Min.

**Subcooling Setpoint**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**SUBCOOLING SETPOINT** = XXX.X °F

The liquid subcooling superheat setpoint is programmable from 0.0 to 11.1°C (0.0 to 20.0°F) with a 2.8°C (5.0°F) default. Typically the subcooling control will be programmed for 2.8°C (5.0 °F).

**Unit ID Number**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**REMOTE UNIT ID NUMBER** = X

For purposes of remote communications, multiple chillers may be connected to an RS-485 communications bus. To allow communications to each chiller, a chiller ID number may be programmed into memory. On a single chiller application, the value will be "0".

**Sound Limit Setpoint**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**SOUND LIMIT SETPOINT** = XXX %

The sound limit setpoint is programmable from 0 to 100 % with a 0% default. 0% allows operating up to the full speed capability of the unit with no sound limiting. Typically the sound limit control setting will be programmed for 0 % unless sound limiting is utilized on the chiller. Sound limiting will only permit the unit to run to a frequency less than the maximum speed capability of the unit. Programming a value of 1% would be the minimum sound limiting that can be programmed and 100% will be the maximum. 100% will only allow the unit speed to operate at the minimum frequency. Usually, the sound limit % will be programmed somewhere between 0 and 100% according the limiting needed to satisfy the sound requirements of the site. Typically, sound limiting will be utilized in areas sensitive to noise during night-time hours. The sound limit display will only be present if the sound limit option is programmed at the factory.

**Eductor Differential**

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**EDUCTOR DIFFERENTIAL** = XXX °F

The eductor temperature differential is programmable from 0°C to 10.0°C (0°F to 50.0°F). The default value is 5.0°F.

The programmed temperature assures the micro will sense a loss of educator oil flow, if the temperature differential rises. A small differential of 2.8°C (5.0°F) is recommended.

### Eductor Safety Time

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**EDUCTOR SAFETY TIME** = XXXX MIN

The educator safety time allows programming the time period the system is permitted to run if the safety threshold is exceeded. The safety time is programmable for 10 minutes to 1000 minutes with 10 minutes as the default. A minimum safety time is recommended to assure the compressor is not starved for oil for long periods of time due to the educator circuit not siphoning oil from the evaporator. A minimum time of 10 minutes is recommended as the program point.

### Motor Temperature Unload

**PROGRAM** ◀DEF XXXXX LO XXXXX HI XXXXX  
**MOTOR TEMPERATURE UNLOAD** = XXX °F

The motor temperature unload is programmable from 65.6°C (150.0°F) to 121.1°C 250.0°F. The default value is 115.5°C (240.0°F). The programmed temperature assures the micro will sense a rise in motor temperature due to a lack of compressor cooling. If the temperature rises above the programmed threshold, the system will unload the compressor by reducing speed. An unload temperature of 115.5°C (240.0°F) is recommended to assure the system does provides maximum capacity.


### Default Values

A listing of the low limits, high limits, and default values for each of the programmable values is noted in each display and can be found in *Table 25 on page 149*. Note that the Imperial units are exact values while the Metric units are only approximate.

**TABLE 25 - PROGRAMMABLE OPERATING PARAMETERS**

| PROGRAM VALUE                       | MODE                       | LOW LIMIT | HIGH LIMIT | DEFAULT   |
|-------------------------------------|----------------------------|-----------|------------|-----------|
| Suction Pressure Cutout             | Water Cooling (R-134a)     | 24.0 PSIG | 36.0 PSIG  | 24.0 PSIG |
|                                     |                            | 1.65 barg | 2.48 barg  | 1.65 barg |
|                                     | Glycol Cooling (R-134a)    | 5.0 PSIG  | 36.0 PSIG  | 24.0 PSIG |
|                                     |                            | 0.34 barg | 2.48 barg  | 1.65 barg |
| Suction Pressure Cutout             | Water Cooling (R-513A)     | 28.0 PSIG | 40.7 PSIG  | 28.0 PSIG |
|                                     |                            | 1.93barg  | 2.80 barg  | 1.93 barg |
|                                     | Glycol Cooling (R-513A)    | 7.7 PSIG  | 40.7 PSIG  | 28.0 PSIG |
|                                     |                            | 0.53 barg | 2.80 barg  | 1.93 barg |
| Leaving Chilled Liquid Temp. Cutout | Water Cooling              | -         | -          | 36.0°F    |
|                                     |                            | -         | -          | 2.2°C     |
|                                     | Glycol Cooling             | 11.0°F    | 36.0°F     | 36.0°F    |
|                                     |                            | -11.7°C   | 2.2°C      | 2.2°C     |
| Motor Current Limit                 | -                          | 30% FLA   | 103% FLA   | 103% FLA  |
| Pulldown Motor Current Limit        | -                          | 30% FLA   | 100% FLA   | 100% FLA  |
| Pulldown Motor Current Limit Time   | -                          | 0 Min     | 255 Min    | 0 Min     |
| Condenser Subcooling Setpoint       | -                          | 0.0°F     | 20.0°F     | 5.0°F     |
|                                     |                            | 0.0°C     | 11.1°C     | 2.8°C     |
| Unit ID Number                      | -                          | 0         | 7          | 0         |
| Sound Limit Setpoint                | Sound Limit Option Enabled | 0%        | 100%       | 0%        |
| Eductor Temp Differential           | -                          | 5.0°F     | 50.0°F     | 15.0°F    |
|                                     |                            | 2.77°C    | 27.8°C     | 8.3°C     |
| Eductor Safety Time                 | -                          | 10 Min    | 1000 Min   | 30 Min*   |
| Motor Temperature Unload            | -                          | 150.0°F   | 250.0°F    | 240.0°F   |
|                                     |                            | 65.6°C    | 121.1°C    | 115.5°C   |

OPTIONS KEY



Options Key Operation

The OPTIONS key provides the user with a display of unit configuration and the capability to modify the configuration. These options can only be viewed under the OPTIONS key. To view the current options settings, press the OPTIONS key. Each press of the OPTIONS key or press of the ▲ or ▼ (ARROW) keys will scroll to the next option setting. The ◀ and ▶ (ARROW) keys allow changing the option choices. The ✓ (ENTER) key must be pressed after a selection is made to save the change in memory.

An explanation of each option message is provided below.

Display Language Selection

The display language can be selected for English, Italian, Polish, Hungarian, German, French, Portuguese, and Spanish.

| OPTIONS | DISPLAY LANGUAGE     |
|---------|----------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX |

The default language will be English.

Chilled Liquid Cooling Mode Selection

The Chilled liquid cooling mode can be selected for Water Cooling or low temperature Glycol Cooling.

| OPTIONS | CHILLED LIQUID COOLING MODE |
|---------|-----------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX        |

When Water Cooling is chosen, the chilled liquid temperature setpoint can only be programmed from 4°C to 21°C (40°F to 70°F).

| OPTIONS | CHILLED LIQUID COOLING MODE |
|---------|-----------------------------|
| ◀ ▶     | WATER COOLING               |

When Glycol Cooling is chosen, the chilled liquid temperature setpoint can be programmed from -12°C to 21°C (10°F to 70°F).

| OPTIONS | CHILLED LIQUID COOLING MODE |
|---------|-----------------------------|
| ◀ ▶     | GLYCOL COOLING              |

The default Chilled Liquid Mode will be WATER COOLING.

Local / Remote Control Mode Selection

Local or Remote Control Mode allows the user to select the chilled liquid temperature control mode.

| OPTIONS | LOCAL / REMOTE CONTROL MODE |
|---------|-----------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX        |

When LOCAL CONTROL mode is selected, chilled liquid control is from the keypad of the chiller. In local mode, a remote device can read system data, but not reset operating parameters.

| OPTIONS | LOCAL / REMOTE CONTROL MODE |
|---------|-----------------------------|
| ◀ ▶     | LOCAL CONTROL               |

When REMOTE CONTROL mode is selected, control of the chilled liquid setpoint is from a remote device such as an ISN/BAS controller.

| OPTIONS | LOCAL / REMOTE CONTROL MODE |
|---------|-----------------------------|
| ◀ ▶     | REMOTE CONTROL              |

The default mode will be LOCAL CONTROL.

### Display Units Selection

Imperial or SI display units may be selected for data display.

| OPTIONS | DISPLAY UNITS        |
|---------|----------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX |

The user may select system operating temperatures and pressures to be displayed in either SI (°C, barg) or Imperial units (°F, PSIG).

| OPTIONS | DISPLAY UNITS |
|---------|---------------|
| ◀ ▶     | IMPERIAL      |

| OPTIONS | DISPLAY UNITS |
|---------|---------------|
| ◀ ▶     | SI            |

The default mode is IMPERIAL.

### System Lead/Lag Control Mode Selection

The operator may select the type of lead/lag control desired.

| OPTIONS | LEAD / LAG CONTROL MODE |
|---------|-------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX    |

In most cases, automatic lead/lag will be selected. When automatic lead/lag is selected, the microprocessor will attempt to balance run time by switching the lead compressor whenever all compressors are shut OFF. If a compressor is not able to run when the microprocessor attempts a start, the microprocessor will select another compressor in an effort to control chilled liquid temperature. Manual lead/lag allows selecting a specific compressor to be the lead.

| OPTIONS | LEAD / LAG CONTROL MODE |
|---------|-------------------------|
| ◀ ▶     | AUTOMATIC               |

The default mode will be AUTOMATIC.

Lag selections of individual systems will appear as:

| OPTIONS | LEAD / LAG CONTROL MODE |
|---------|-------------------------|
| ◀ ▶     | MANUAL SYS 1 LEAD       |

| OPTIONS | LEAD / LAG CONTROL MODE |
|---------|-------------------------|
| ◀ ▶     | MANUAL SYS 2 LEAD       |

### Remote Temperature Reset Selection

Remote temperature reset from an external source may be tied directly into the chiller microprocessor board.

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX    |

Selections may be made for DISABLED (no signal), 0 to 10VDC, 2 to 10VDC, 0 to 20ma, and 4 to 20ma.

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | DISABLED                |

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | 0.0 TO 10.0 VOLTS DC    |

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | 2.0 TO 10.0 VOLTS DC    |

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | 0.0 TO 20.0 MILLIAMPS   |

| OPTIONS | REMOTE TEMP RESET INPUT |
|---------|-------------------------|
| ◀ ▶     | 4.0 TO 20.0 MILLIAMPS   |

The default setting for Remote Temp Reset is DISABLED. This display will only appear if the remote temperature limit option is enabled under the Unit Setup Mode.

### Remote Current Limit Input Selection

Remote current limit from an external source may be tied directly into the chiller microprocessor board.

| OPTIONS | REMOTE CURRENT LIMIT INPUT |
|---------|----------------------------|
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXX       |

Selections may be made for DISABLED (no signal), 0 to 10VDC, 2 to 10VDC, 0 to 20ma, and 4 to 20ma.

| OPTIONS | REMOTE CURRENT LIMIT INPUT |
|---------|----------------------------|
| ◀ ▶     | DISABLED                   |

|         |                            |
|---------|----------------------------|
| OPTIONS | REMOTE CURRENT LIMIT INPUT |
| ◀ ▶     | 0.0 TO 10.0 VOLTS DC       |

|         |                            |
|---------|----------------------------|
| OPTIONS | REMOTE CURRENT LIMIT INPUT |
| ◀ ▶     | 2.0 TO 10 VOLTS DC         |

|         |                            |
|---------|----------------------------|
| OPTIONS | REMOTE CURRENT LIMIT INPUT |
| ◀ ▶     | 0.0 TO 20.0 MILLIAMPS      |

|         |                            |
|---------|----------------------------|
| OPTIONS | REMOTE CURRENT LIMIT INPUT |
| ◀ ▶     | 4.0 TO 20.0 MILLIAMPS      |

The default setting for Remote Current Reset is DISABLED. This display will only appear if the remote current limit option is enabled under the Unit Setup Mode.

### Remote Sound Limit Selection

Remote sound limit from an external source may be tied directly into the chiller microprocessor board.

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | XXXXXXXXXXXXXXXXXXXXX    |

Selections may be made for DISABLED (no signal), 0 to 10VDC, 2 to 10VDC, 0 to 20ma, and 4 to 20ma.

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | DISABLED                 |

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | 0.0 TO 10.0 VOLTS DC     |

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | 2.0 TO 10.0 VOLTS DC     |

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | 0.0 TO 20.0 MILLIAMPS    |

|         |                          |
|---------|--------------------------|
| OPTIONS | REMOTE SOUND LIMIT INPUT |
| ◀ ▶     | 4.0 TO 20.0 MILLIAMPS    |

The default setting for Remote Sound Limit is DISABLED. This display will only appear if the remote sound limit option is enabled under the Unit Setup Mode.

### Low Ambient Cutout Enable/Disable


The low ambient cutout may be enabled or disabled. When enabled, the chiller will cut OFF when the low ambient cutout is reached. When disabled, the chiller will run at any temperature.

|         |                                |
|---------|--------------------------------|
| OPTIONS | LOW AMBIENT TEMPERATURE CUTOUT |
| ◀ ▶     | ENABLED                        |

|         |                                |
|---------|--------------------------------|
| OPTIONS | LOW AMBIENT TEMPERATURE CUTOUT |
| ◀ ▶     | DISABLED                       |

The default setting for the low ambient cutout will be ENABLED.

## DATE/TIME AND SCHEDULE KEYS



LD10605

8

### Date/Time Key Operation

When the DATE/TIME key is pressed, the chiller microprocessor will display the date and the time. This feature is useful and required for using the Daily Schedule. It is also a valuable tool for troubleshooting to allow a technician to determine the time of the fault, which is stored in the history memory buffers. When the DATE/TIME key is pressed, the first display screen shown below will be displayed:

**CLOCK FRI 18-JUN-2011 10:15:33 AM**  
**DAY OF WEEK ◀ ▶ = XXX**

Whenever any changes are made, the ✓ (ENTER) key must be pressed to store the data.

Pressing the ▲ or ▼ (Arrow) keys allows scrolling to the next programmed item. Pressing the ▼ (DOWN ARROW) key scrolls to the next item that can be programmed and the ▲ (UP ARROW) key scrolls to the previous item.


The day of the week is the first display and can be changed by pressing either the ◀ or ▶ (LEFT OR RIGHT ARROW) key to select the day. After the day is selected, the ✓ (ENTER) key must be pressed to store the data.

**CLOCK FRI 18-JUN-2011 10:15:33 AM**  
**DAY OF MONTH = XX**

Pressing the ▼ (DOWN ARROW) key again scrolls to the day of the month:

**CLOCK FRI 18-JUN-2011 10:15:33 AM**  
**DAY OF MONTH = XX**

The day of the month can be selected by keying in the numerical value to select the day. After the day of the month is selected, the ✓ (ENTER) key must be pressed to store the data.



*A "0" must be typed in to select dates for days of the 1st through the 9th.*

Pressing the ▼ (DOWN ARROW) key again scrolls to month:

**CLOCK FRI 18-JUN-2011 10:15:33 AM**  
**MONTH ◀ ▶ = XXX**

The month can be selected by scrolling through the months with the ◀ or ▶ arrow keys. After the month is selected, the ✓ (ENTER) key must be pressed to store the data.

Pressing the ▼ (DOWN ARROW) key again scrolls to the year:


CLOCK FRI 18-JUN-2011 10:15:33 AM  
YEAR = XXXX

The year can be selected by keying in the numerical value to select the year. After the year is selected, the ✓ (ENTER) key must be pressed to store the data.

Pressing the ▼ (DOWN ARROW) key again scrolls to the hour:

CLOCK FRI 18-JUN-2011 10:15:33 AM  
HOUR = XX

The hour can be selected by keying in the numerical value for the hour. After the hour is selected, the ✓ (ENTER) key must be pressed to store the data.




*One or two "0's" must be keyed in for minutes 00 through 09.*

Pressing the ▼ (DOWN ARROW) key again scrolls to the minute:

CLOCK FRI 18-JUN-2011 10:15:33 AM  
MINUTE = XX

The minute can be selected by keying in the numerical value for the hour. After the minute is selected, the ✓ (ENTER) key must be pressed to store the data.



*One or two "0's" must be keyed in for minutes 00 through 09.*

Pressing the ▼ (DOWN ARROW) key again scrolls to AM/PM:

CLOCK FRI 18-JUN-2011 10:15:33 AM  
AM/PM ◀ ▶ = XX

AM/PM can be selected by pressing the ◀ or ▶ (ARROW) keys. After the meridian is selected, the ✓ (ENTER) key must be pressed to store the data.

Pressing the ▼ (DOWN ARROW) key again scrolls to the time format selection:

CLOCK FRI 18-JUN-2011 10:15:33 AM  
TIME FORMAT ◀ ▶ = XXXXXXXX

The time format may be displayed in either a 12 hour or 24 hour format. Selection can be changed by pressing the ◀ or ▶ (ARROW) keys. The ✓ (ENTER) key must be pressed to store the data.

### Schedule Key Operation

The Daily Schedule must be programmed for the unit start and stop times. To set the schedule, press the SCHEDULE key. The display will provide a message allowing access to 2 types of schedule information:

SCHEDULE CHOOSE SCHEDULE TYPE  
◀ ▶ XXXXXXXXXXXXXXXXXXXXXXXX

The schedule types are:

- UNIT OPERATING SCHEDULE
- (Default selection)
- SOUND LIMIT SCHEDULE  
(Only if Sound Limiting is enabled by the factory when the option is installed.)

The schedule type (UNIT OPERATING SCHEDULE or SOUND LIMIT SCHEDULE) may be changed by pressing the ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys followed by the ✓ (ENTER) key. The selection must be entered by pressing the ✓ (ENTER) key before a schedule display will appear.

### Unit Operating Schedule


The Unit Operating Schedule is used to enable/disable the chiller unit on time of day. The chiller can be enabled and disabled once each day or it can be programmed to run continuously. Any time the daily or holiday schedule shuts the chiller down, the running system(s) will go through a controlled ramped shut-down. If the UNIT OPERATING SCHEDULE is selected under the CHOOSE SCHEDULE display, the following message will appear:

SCHEDULE UNIT OPERATING  
MON START = 06:00 AM STOP = 10:00 PM

The line under the 0 above is the cursor. If the start time is wrong, it can be changed by keying in the new time from the numeric keypad. Once the correct values for the START hour and minute are entered, press

the ✓ (ENTER) key. The cursor will then move to the AM/PM selection. The meridian (AM/PM) value may be changed by the ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys and entered by pressing ✓ (ENTER) key. Repeat this process for the STOP time. Once a schedule is entered, the schedule for the next day will appear. The start and stop time of each day may be programmed differently.

To view the schedule without making a change, simply press the SCHEDULE key until the day you wish to view appears. The ▲ (UP ARROW) key will scroll backwards to the previous screen.



***If at any time the schedule is changed for Monday, all the other days will change to the new Monday schedule. This means if the Monday times are not applicable for the whole week, then the exceptional days would need to be reprogrammed to the desired schedule.***

To program the chiller for 24 hour operation, program the start and stop times of each day of the week for 00:00.


After the SUN (Sunday) schedule appears on the display, a subsequent press of the SCHEDULE or ▲ (UP ARROW) key will display the Holiday schedule. This is a two-part display. The first reads:

| SCHEDULE | UNIT OPERATING                   |
|----------|----------------------------------|
| HOL      | START = 00:00 AM STOP = 00:00 PM |

The holiday times may be set using the same procedure as described above for the days of the week. Be sure to press the ✓ (ENTER) key after setting the START and STOP times to save the change in memory. Pressing the SCHEDULE key a second time, the display will show the individual days:

| SCHEDULE      | UNIT OPERATING     |
|---------------|--------------------|
| S M T W T F S | HOLIDAY NOTED BY * |

The line below the empty space is the cursor and will move to the next or previous empty space when the ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys and pressed. To set a day for the Holiday Schedule, the cursor must be moved to the space following the day of the week. The \* key is then pressed and an “\*” will appear in the space signifying that day as a holiday. The Holiday schedule must be programmed weekly. If there is no holiday, the “\*” key is also used to delete the “\*”. The ✓ (ENTER) key is used to accept the holiday schedule for the entire week.



***The HOLIDAY SCHEDULE is a temporary schedule. Once the schedule is executed, the selected holidays will be cleared from memory for the following week.***

## Sound Limit Schedule

The SOUND LIMIT SCHEDULE allows setting the day and time when the user desires using the “SILENT NIGHT” factory programmed option to limit chiller loading and fan operation for reduced audible noise in the surrounding area. If the SOUND LIMIT SCHEDULE is selected under the CHOOSE SCHEDULE display, the following message will appear:

| SCHEDULE | SOUND LIMIT      | = XXX %         |
|----------|------------------|-----------------|
| MON      | START = 06:00 AM | STOP = 10:00 PM |

The Sound Limit option can be enabled and disabled once each day or the chiller can be set to run continuously in this mode for sound limiting whenever the chiller is operating. When sound limiting is enabled, the unit will be limited by the Sound Limit setpoint % as set under the PROGRAM key. XXX in the display above will show the Sound Limit Setpoint % programmed under the PROGRAM key. 0% will cause no speed reduction, while 100% only allows running at minimum speed.


The START Time for a specific day (hour and minute) is entered using the same guidelines used for the start/stop schedules, and press the ✓ (ENTER) key to store it into memory. The cursor will then move to the AM/PM selection.

The AM/PM selection may be chosen using the ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys and pressing ✓ (ENTER) key to store the value.

This process is repeated for the STOP time.

Once the schedule for a specific day is programmed and entered, the schedule for the next day will appear. The schedule for each day may be programmed the same or differently.

To view the schedule without changing it, simply press the SCHEDULE key or the ▼ (DOWN ARROW) key until the desired day is displayed. The ▲ (UP ARROW) key will scroll backwards to the previous screen.

**MANUAL OVERRIDE KEY**

LD10605


**Manual Override Key Operation**

If the MANUAL OVERRIDE key is pressed during a schedule shutdown, the STATUS display will display the message below. This indicates that the Daily Schedule is being ignored and the chiller will start when chilled liquid temperature allows, Remote Contacts, UNIT switch and SYSTEM switches permitting. This is a priority message and cannot be overridden by anti-recycle messages, fault messages, and so on, when in

the STATUS display mode. Therefore, do not expect to see any other STATUS messages when in the MANUAL OVERRIDE mode. MANUAL OVERRIDE is to only be used in emergencies or for servicing. Manual override mode automatically disables itself after 30 minutes.

**MANUAL OVERRIDE**

PRINT KEY



Print Key Operation

The PRINT key is used to initiate a printout of current operating data (real time data), a complete history printout of all history (fault) buffers, a printout of all normal shutdowns (compressor cycling, chiller shut-down, and so on) or history (fault) data printout of a specific fault. History Buffer 1 will always be the most recent fault history printout. Printing may also be canceled by selecting the CANCEL PRINTING option. The following message is displayed when the PRINT key is pressed.



After pressing the PRINT key, the printout type is selected by pressing the ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys until the desired printout is displayed.


The following table shows the available printout types.

TABLE 26 - PRINTOUT TYPES

| PRINTOUT TYPES                        |
|---------------------------------------|
| Operating Data<br>(Default Selection) |
| All History Buffers                   |
| Normal Shutdowns                      |
| History Buffer 1                      |
| History Buffer 2                      |
| History Buffer 3                      |
| History Buffer 4                      |
| History Buffer 5                      |
| History Buffer 6                      |
| History Buffer 7                      |
| History Buffer 8                      |
| History Buffer 9                      |
| History Buffer 10                     |
| Cancel Printing                       |

The specific printout is initiated by pressing the ✓ (ENTER) key.

A sample of the is shown below. The operating data printout is a snapshot of current system operating conditions when the printout was selected. The sample shows combined printouts of 2, 3, and 4 circuit units. The actual printout will only show data for the appropriate chiller type.



***Bold italic text below a line of print is not on the actual printout. Bold italic text indicates information that may not be available on all printouts or is additional information to help explain the difference in a 2/3 or 4 circuit printout.***

### Operating Data Printout

YORK INTERNATIONAL CORPORATION

YVAA SCREW CHILLER

OPERATING DATA

2:04:14 PM 30 DEC 11

SYS 1

NOT RUNNING

SYS 2

COMPRESSOR RUNNING

OPTIONS

CHILLED LIQUID WATER

LOCAL/REMOTE MODE REMOTE

LEAD/LAG CONTROL AUTOMATIC

REMOTE TEMP RESET DISABLED

REMOTE CURRENT LIMIT 0 TO 10 V

REMOTE SOUND LIMIT 4 TO 20 MA

(if Sound Limiting enabled)

LOW AMBIENT CUTOUT ENABLED

PROGRAM VALUES

SUCT PRESS CUTOUT 44 PSIG

LOW AMBIENT CUTOUT 25.0 DEGF

LEAVING LIQUID CUTOUT 36.0 DEGF

MOTOR CURRENT LIMIT 100 %FLA

PULLDOWN CURRENT LIMIT 100 %FLA

PULLDOWN LIMIT TIME 0 MIN

SUBCOOLING SETPOINT 12.0 DEGF

UNIT ID NUMBER 0

SOUND LIMIT SETPOINT 100%

(if Sound Limiting enabled)

UNIT DATA

LEAVING LIQUID TEMP 49.0 DEGF

RETURN LIQUID TEMP 58.2 DEGF

|                          |                 |
|--------------------------|-----------------|
| TEMP RATE                | XXX.X DEGF/MIN  |
| COOLING RANGE            | 42.0+/-2.0 DEGF |
| REMOTE SETPOINT          | 44.0 DEGF       |
| AMBIENT AIR TEMP         | 74.8 DEGF       |
| LEAD SYSTEM              | SYS 2           |
| FLOW SWITCH              | ON              |
| EVAPORATOR PUMP RUN      | ON              |
| EVAPORATOR HEATER        | OFF             |
| ACTIVE REMOTE CONTROL    | NONE            |
| OPERATING HOURS 1=XXXXX, | 2=XXXXX         |
| START COUNTER 1=XXXXX,   | 2=XXXXX         |
| SOFTWARE VERSION         | C.ACS.XX.00     |

VSD DATA

|                       |              |
|-----------------------|--------------|
| ACTUAL FREQUENCY      | XXX.X HZ     |
| COMMAND FREQUENCY     | XXX.X HZ     |
| DC BUS VOLTAGE        | XXX VDC      |
| INTERNAL AMBIENT TEMP | XXX.X DEGF   |
| COOLING SYSTEM STATUS | XXX          |
| BASEPLATE TEMPS       | XXX XXX DEGF |
| PRECHARGE SIGNAL      | XXX          |
| MOTOR OVERLOADS 1/2   | XXX XXX AMPS |
| SOFTWARE VERSION      | C.VSD.XX.00  |
| UNIT SERIAL NUMBER    | YYYY XXXZZZ  |

SYSTEM 1 DATA

|                       |                     |
|-----------------------|---------------------|
| COMPRESSOR STATUS     | OFF                 |
| RUN TIME              | 0- 0- 0- 0 D-H-M-S  |
| MOTOR CURRENT         | 0AMPS 0 %FLA        |
| SUCTION PRESSURE      | 125 PSIG            |
| DISCHARGE PRESSURE    | 131 PSIG            |
| OIL PRESSURE          | 130 PSIG            |
| CONDENSER LIQUID TEMP | 68.4 DEGF           |
| DISCHARGE TEMPERATURE | 68.8 DEGF           |
| OIL TEMPERATURE       | 68.8 DEGF           |
| SAT SUCTION TEMP      | 71.8 DEGF           |
| SUBCOOLING            | 3.4 DEGF            |
| SAT DISCHARGE TEMP    | 74.5 DEGF           |
| DISCHARGE SUPERHEAT   | 6.3 DEGF            |
| MOTOR TMP             | XXX.XXXX.XXXX.XDEGF |
| COMPRESSOR SPEED      | XXX.X %             |
| FLASH TANK LEVEL      | > 512 ADC           |
| COND DRAIN % OPEN     | XXX.X %             |
| ECONOMIZER % OPEN     | XXX.X %             |

```

CONDENSER FANS ON                                0
CONDENSER FAN SPEED          XXX % (vsd)
COMPRESSOR HEATER                                ON
VI STEP SOLENOID 1                                OFF
VI STEP SOLENOID 2                                OFF
RUN PERMISSIVE                                ON
VSD RUN RELAY                                OFF
VSD SOFTWARE RUN SIGNAL                        OFF

                SYSTEM 2 DATA
COMPRESSOR STATUS                                ON
RUN TIME                                0-0-15-26 D-H-M-S
MOTOR CURRENT                                104 AMPS  87 %FLA
SUCTION PRESSURE                                57 PSIG
DISCHARGE PRESSURE                            233 PSIG
OIL PRESSURE                                218 PSIG
CONDENSER LIQUID TEMP                        42.9 DEGF
DISCHARGE TEMPERATURE                      145.5 DEGF
OIL TEMPERATURE                            102.8 DEGF
SAT CONDENSER TEMP                          31.7 DEGF
SUBCOOLING                                11.2 DEGF
SAT DISCHARGE TEMP                        112.1 DEGF
DISCHARGE SUPERHEAT                        33.4 DEGF
MOTOR TMP          XXX.X XXX.X XXX.X DEGF
COMPRESSOR SPEED                                XXX.X%
FLASH TANK LEVEL                                < 512 ADC
COND DRAIN % OPEN                            XXX.X%
ECONOMIZER % OPEN                            XXX.X%
CONDENSER FANS ON                                3
CONDENSER FAN SPEED          XXX% (vsd)
COMPRESSOR HEATER                                OFF
VI STEP SOLENOID 1                                OFF
VI STEP SOLENOID 2                                OFF
RUN PERMISSIVE                                ON
VSD RUN RELAY                                OFF
VSD SOFTWARE RUN SIGNAL                        OFF

                UNIT OPERATING SCHEDULE
S M T W T F S          *=HOLIDAY
MON START=00:00AM          STOP=00:00AM
TUE START=00:00AM          STOP=00:00AM
WED START=00:00AM          STOP=00:00AM
THU START=00:00AM          STOP=00:00AM

```

```

FRI START=00:00AM          STOP=00:00AM
SAT START=00:00AM          STOP=00:00AM
HOL START=00:00AM          STOP=00:00AM

                SOUND LIMIT SCHEDULE
                (if enabled)
MON START=00:00AM          STOP=00:00AM
TUE START=00:00AM          STOP=00:00AM
WED START=00:00AM          STOP=00:00AM
THU START=00:00AM          STOP=00:00AM
FRI START=00:00AM          STOP=00:00AM
SAT START=00:00AM          STOP=00:00AM
HOL START=00:00AM          STOP=00:00AM

```

### History Data Printout

History printouts, when selected, provide stored data relating to all specific system and chiller operating conditions at the time of the fault, regardless of whether a lockout occurred. History information is stored in battery-backed memory on the Chiller Control Board and is not affected by power failures or resetting of faults. Whenever a fault of any type occurs, all system operating data is stored in battery-backed memory at the instant of the fault. The history printout is similar to the operating data printout except for the change in the header information shown below:


```

                YORK INTERNATIONAL CORPORATION
                YVAA SCREW CHILLER
                HISTORY NUMBER 1
                2:04:14 PM  30 APR 11
SYS 1 YYYYYYYY
                HIGH DSCH PRESS SHUTDOWN
                STATUS AT TIME OF SHUTDOWN
SYS 1 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
SYS 2 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
                ALL FAULTS
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX

```

The most recent fault will always be stored as HISTORY BUFFER #1.

## SYSTEM SWITCHES KEY



## System Switches Key Operation

The SYSTEM SWITCHES key allows the operator to turn individual systems ON and OFF. Safety lock-outs are also reset by selecting the respective system switch RESET. When the SYSTEM SWITCHES key is pressed, the following message will appear:

|                        |                               |
|------------------------|-------------------------------|
| <b>SYSTEM SWITCHES</b> | <b>SYS 1 ON / OFF / RESET</b> |
| ◀ ▶                    | =XXXXXXXXXXXXXXXXXX           |

The display indicates the respective system and it's ON/OFF /reset switch status. The ▲▼ (ARROW) keys allow scrolling to the next and previous system switch (System 1 and 2).


|                        |                               |
|------------------------|-------------------------------|
| <b>SYSTEM SWITCHES</b> | <b>SYS 2 ON / OFF / RESET</b> |
| ◀ ▶                    | =XXXXXXXXXXXXXXXXXX           |

The ◀ (LEFT ARROW) or ▶ (RIGHT ARROW) keys allow scrolling through the choices of:

- SYSTEM OFF (default)
- SYSTEM ON
- RESET (LOCKOUT)

The switch selection is accepted into memory by pressing the ✓ (ENTER) key.

When the "RESET" selection is made and accepted, it will not change the position of the switch (either ON or OFF).




***Whenever possible, except in emergencies, always use the associated system switch to turn off a compressor, which allows the compressors to go through a controlled shutdown. Avoid using the "UNIT" switch to turn off the compressors.***

## SECTION 9 - MAINTENANCE

### GENERAL REQUIREMENTS

The units have been designed to operate continuously, provided they are regularly maintained and operated within the limitations given in this manual. Each unit should be included in a routine schedule of daily maintenance checks by the operator/customer, backed up by regular service inspection and maintenance visits by a suitably qualified Service Engineer.

It is entirely the responsibility of the owner to provide for these regular maintenance requirements and/or enter into a maintenance agreement with a Johnson Controls service organization to protect the operation of the unit. If damage or a system failure occurs due to improper maintenance during the warranty period, Johnson Controls shall not be liable for costs incurred to return the unit to satisfactory condition.



*This “Maintenance” section applies to the basic unit only and may, on individual contracts, be supplemented by additional requirements to cover any modifications or ancillary equipment as applicable.*



*The “Safety” section of this manual should be read carefully before attempting any maintenance operations on the unit.*

### Weekly Maintenance

The following maintenance checks should be carried out on a weekly basis by the operator/customer. Please note that the units are not generally user serviceable and no attempt should be made to rectify faults or problems found during daily checks unless competent and equipped to do so. If in any doubt, contact your local Johnson Controls Service Agent.

### Unit Status

Press the ‘STATUS’ key on the keypad and ensure no fault messages are displayed.

### Refrigerant Leaks

Visually check the heat exchangers, compressors and pipework for damage and gas leaks.

### Operating Conditions

Read the operating pressures and temperatures at the control panel using the display keys and check that these are within the operating limitations given in the manual.

### Compressor Oil Level


Compressor oil level will typically run below the bottom of the sight glass. Oil levels will only be visible in the sight glass after running for periods of 15 to 30 minutes at full compressor speed. Do not run with oil levels above the sight glass. Be careful when viewing the sight glass not to confuse a full sight glass with an empty sight glass.

### Refrigerant Charge

Assure there is a level of refrigerant in the evaporator sight glass while running at “Full Load” for 15 to 30 minutes.

### Adding Charge to a System

A sight glass is located in the evaporator. When optimally charged after running full load, the refrigerant level should be approximately in the center of the sight glass. There should be little concern if the level is high or low in the glass, it should not affect operation.



*It is not necessary to weigh charge unless the entire charge has been lost. The ease of charging is possible since the micro-channel coils hold only a small amount of refrigerant charge. A charging valve, located between the fixed orifice and the evaporator, may be used if charge adjustment is required. Charge should be added as liquid while circulating water through the evaporator. If the complete charge needs to be added, see Refrigerant Removal, Evacuation and Charging a YVAA Chiller on Page 162 in this section. Use the valve on the liquid line for adding the full charge and open the valves per the procedure.*

## REFRIGERANT REMOVAL, EVACUATION AND CHARGING A YVAA CHILLER

### Refrigerant Removal

The YVAA utilizes a flooded evaporator. Extreme care must be taken when removing refrigerant to prevent damage to the evaporator and the chiller. Carefully review the following caution below before proceeding with the recommended process.



***Incorrect removal of refrigerant will result in catastrophic freeze damage to the evaporator and possible additional damage to other chiller components. Whenever there is water in the evaporator, the chilled liquid pumps must be ON and circulating liquid through the evaporator above minimum recommended flow rates. When liquid refrigerant is being removed, monitor the pressure and do not allow the pressure to drop below the freeze point of the chilled liquid flowing through the evaporator until all liquid refrigerant has been removed from the evaporator and only gas remains. Once all liquid has been removed, the remaining refrigerant vapor can be removed while allowing the pressure to drop below the freeze point with the pump circulating liquid through the evaporator.***

To remove refrigerant from the evaporator, follow the procedure below:

1. Turn the chilled liquid pump ON and assure the flow is above the minimum recommended flow.
2. Assure all manual valves in the system are open. Open Condenser Drain and Economizer Feed valves to 100% in the service mode.
3. Connect the recovery unit and a manifold gauge to the liquid line feeding the eductor. There may be a valve in the line or a Schrader fitting on the eductor filter for this purpose.
4. Connect the recovery unit to a recovery cylinder sitting on an accurate scale. Turn the recovery unit ON and observe the liquid refrigerant flowing from the line into the cylinder. The flow of liquid should be obvious.

5. Monitor the pressure gauge to assure that the pressure does not drop below the freeze point of the chilled liquid. Throttle the flow as needed with the manifold gauge valves to prevent pressures from dropping below the freeze point.
6. Continue to remove the liquid refrigerant while observing the flow and the pressure. Note the charge in the system based on the nameplate data to determine when the charge removal is nearly complete. Monitor the weight of the recovery cylinder to determine when the cylinder is full. Change the cylinder as needed.
7. Continue removing refrigerant until liquid is no longer observed flowing in the manifold hoses.
8. Once the liquid is removed and no longer visible in the hose, the remaining gas can be pumped out with the recovery unit while the pressure is allowed to drop to 0 barg (0 PSIG).
9. Servicing may now be performed on the system as needed.

### Evacuating a System

To evacuate a system, follow the procedure below:

1. Turn the chilled liquid pump ON and assure the flow is above the minimum recommended flow.
2. Assure all manual valves are open. Open the Condenser Drain (Flash Tank Feed) and Economizer Valves in the Service Mode to 100 %.
3. Connect vacuum hoses to as many points as possible. Be sure that at least one connection is made on both the high and low side of the piping. A connection to the evacuation fitting on the compressor is also recommended. Evacuate the system to a minimum of 500 microns. Close the valves at the evacuation points and assure the pressure in the chiller does not rise more than 50 microns in 10 minutes. Check for leaks if the pressure rises.

## Charging Refrigerant into a System

To charge the system with refrigerant, follow the procedure below:

1. With all system valves open and the Condenser Drain and Economizer Valves open to 100% by manually opening them in the Service Mode, charge refrigerant vapor into the high side of the system at the charging port on the liquid line. Continue charging vapor until the pressure is above the freeze point of the chilled liquid. Once above the freeze point, liquid can be charged according to the recommended nameplate charge.
2. Reconnect the water piping to the water boxes.
3. Close the evaporator drain valves and fill the evaporator with water from the cooling loop.
4. Fill the water loop and check for leaks.
5. Close (0%) the Condenser Drain and Economizer Valve in the Service Mode. Recycle the chiller power.
6. Once the system is operating, the charge will distribute itself throughout the system. Trim the charge as needed to a level of about midway on the evaporator sight glass while running full speed for 15 minutes.

## MICROCHANNEL COIL CLEANING

The coil cleaning procedure for microchannel coils is significantly different than tube and fin type coils. As such, care must be taken to understand the differences to avoid damage to the microchannel coil. These differences require a number of DO NOT's that must be observed:

- DO NOT use coil cleaners or any chemical on a microchannel coil. This can cause severe damage to the coils.
- DO NOT use a pressure washer to clean the coils. While it is possible to clean a coil with a pressure washer, it's also possible to destroy it.
- DO NOT contact the coil with a hard surface such as a hose nozzle or metal vacuum nozzle or any other tool.

Microchannel coils tend to accumulate more dirt on the surface, but less dirt inside the coils, which makes them easier to clean. Follow the three steps below for cleaning the coils:

1. Remove surface debris such as dirt, leaves, insects, fibers, and so on, with a vacuum cleaner having a soft attachment rather than a metal tube. Compressed air blown from the inside out can also be used. When brushing debris off the face of the coil a soft bristle (not wire) brush can be used. Do not scrape the coil with the vacuum nozzle, air nozzle, or any other tool.
2. Rinse the coil with tap water. Do not use coil cleaners. Rinse the coil from the inside out, running water through every passage in the heat exchanger surface until it is clean. Microchannel coils are stronger than conventional tube and fin coils, but handle them with care, since you can cause a leak due to impact. Use a gentle spray from a spray nozzle with a plastic end or put your finger on the end of the spray nozzle to reduce impact and provide a gentle spray.
3. Because of the fin geometry, microchannel coils retain water more than tube and fin style. It is generally recommended to blow or vacuum out the rinse water from the coils to speed drying and prevent water pooling.

## Scheduled Maintenance

The maintenance operations detailed in the following table should be carried out on a regular basis by a suitably qualified Service Engineer. It should be noted that the interval necessary between each 'minor' and 'major' service can vary depending on, for instance, application, site conditions and expected operating schedule. Normally a 'minor' service should be carried out every three to six months and a 'major' service once a year. It is recommended that your local Johnson Controls Service Center is contacted for recommendations for individual sites.

## MAINTENANCE REQUIREMENTS FOR YVAA CHILLERS



| PROCEDURE                                                                                               | WEEKLY | QUARTERLY | SEMI-ANNUALLY | ANNUALLY | EVERY 5 YEARS | EVERY * HOURS |
|---------------------------------------------------------------------------------------------------------|--------|-----------|---------------|----------|---------------|---------------|
| Check Oil Level in Oil Separator Sight Glass.                                                           | X      |           |               |          |               |               |
| Check Liquid Line Sight Glass/ Moisture Indicator.                                                      | X      |           |               |          |               |               |
| Check refrigerant level in the Evaporator Sight Glass while running full load for 10 to 15 minutes.     | X      |           |               |          |               |               |
| Record System Operating Temperatures & Pressures.                                                       | X      |           |               |          |               |               |
| Check Condenser Coils for dirt / debris and clean as necessary.                                         | X      |           |               |          |               |               |
| Check Programmable Operating Setpoints and Safety Cutouts. Assure they are correct for the application. |        | X         |               |          |               |               |
| Check Compressor and Evaporator Heater operation.                                                       |        | X         |               |          |               |               |
| Check for dirt in the Panel. Check Door Gasket sealing integrity.                                       |        | X         |               |          |               |               |
| **Leak check the Chiller.                                                                               |        |           | X             |          |               |               |
| **Sample Compressor Oil, check for Acid, and replace if necessary.                                      |        |           |               | X        |               |               |
| **Disconnect Power Source and Lock Out. Check tightness of Power Wiring connections.                    |        |           |               | X        |               |               |
| Check Glycol concentration on Low Temp. or other applications where freezing may be a problem.          |        |           |               | X        |               |               |
| VSD Glycol Change.                                                                                      |        |           |               |          | X             |               |

\* Reserved for customer use for any special site requirements.

\*\*This procedure must be performed at the specific time by an industry certified technician who has been trained and qualified to work on this type of equipment. A record of this procedure be successfully carried out should be maintained on file by the equipment owner should proof of adequate maintenance be required at a later date for warranty purposes.

**TABLE 27 - TROUBLESHOOTING GUIDE**

| PROBLEM                                               | POSSIBLE CAUSE                                                            | ACTION                                                                                    |
|-------------------------------------------------------|---------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|
| <b>NO DISPLAY ON CONTROL PANEL UNIT WILL NOT RUN.</b> | Supply to the Panel is missing.                                           | High Voltage to the Chiller is missing.                                                   |
|                                                       |                                                                           | Check 1FU, 2FU, 4FU, 5FU 17FU, or 19FU.                                                   |
|                                                       |                                                                           | Check 2T or 10T Transformer.                                                              |
|                                                       | Line Fuse is blown.                                                       | Check Fuses.                                                                              |
|                                                       | Chiller Control Board is defective.                                       | Replace Chiller Control Board.                                                            |
|                                                       | Display Board defective.                                                  | Replace Display Board.                                                                    |
| <b>LINE FUSE BLOWS.</b>                               | SCR Diode Module is defective.                                            | Check SCR/Diode Module.                                                                   |
|                                                       | IGBT Module is defective.                                                 | Check IGBT Module.                                                                        |
|                                                       | VSD Logic Board is defective.                                             | Replace VSD Logic Board.                                                                  |
|                                                       | SCR Trigger Board is defective.                                           | Replace SCR Trigger Board.                                                                |
| <b>CHILLER FAULT:<br/>LOW AMBIENT TEMPERATURE</b>     | Ambient temperature is lower than the programmed operating limit.         | Check the programmed cutout and determine if it is programmed correctly.                  |
|                                                       | Ambient Sensor is defective.                                              | Check the panel against the thermometer reading of ambient temperature.                   |
| <b>CHILLER FAULT:<br/>HIGH AMBIENT TEMPERATURE</b>    | Ambient Temperature is above the maximum operating limit.                 | Check outside air temperature.                                                            |
|                                                       | Ambient Sensor is defective.                                              | Check the Panel Display against Thermometer reading of Ambient Temperature at the sensor. |
| <b>CHILLER FAULT:<br/>LOW LEAVING CHILLED LIQUID</b>  | Leaving chilled liquid temperature drops faster than the unit can unload. | Check for restricted flow.                                                                |
|                                                       |                                                                           | Check for rapid flow changes.                                                             |
|                                                       |                                                                           | Water loop is too small.                                                                  |
|                                                       |                                                                           | Flow is below minimum for chiller.                                                        |
|                                                       | Chilled Water Sensor is defective.                                        | Check Sensor against Temp. Gauge in water line.                                           |
|                                                       |                                                                           | Check Sensor for intermittent operation.                                                  |
|                                                       |                                                                           | Check Wiring for shorts or opens.                                                         |
| <b>SYSTEM FAULT:<br/>CONTROL VOLTAGE</b>              | System Fuse is blown.                                                     | Check respective system Fuse 20FU or 21FU.                                                |
| <b>SYSTEM FAULT:<br/>HIGH OIL TEMPERATURE</b>         | Oil Temperature Sensor is defective.                                      | Check Sensor with infrared to determine if reading is reasonable.                         |
|                                                       | Condenser Fans NOT operating or running backwards.                        | Check Fans.                                                                               |
|                                                       | Coils dirty.                                                              | Check and clean Coils.                                                                    |

**NOTE:** Always remove power to the chiller and assure the DC Bus voltage has bled off.

**TABLE 27 - TROUBLESHOOTING GUIDE (CONT'D)**

| <b>PROBLEM</b>                                           | <b>POSSIBLE CAUSE</b>                                           | <b>ACTION</b>                                                              |
|----------------------------------------------------------|-----------------------------------------------------------------|----------------------------------------------------------------------------|
| <b>SYSTEM FAULT:<br/>HIGH DISCHARGE<br/>PRESSURE</b>     | Coils dirty.                                                    | Check and clean coils.                                                     |
|                                                          | Coils are damaged.                                              | Comb out fins.                                                             |
|                                                          | Fans NOT operating.                                             | Check fan fuses.                                                           |
|                                                          |                                                                 | Check fan rotation.                                                        |
|                                                          |                                                                 | Check fan motor/blade.                                                     |
|                                                          | System is overcharged.                                          | Remove charge and check subcooling.                                        |
| <b>SYSTEM FAULT:<br/>HIGH DISCHARGE<br/>TEMPERATURE</b>  | Discharge Temperature Sensor is defective.                      | Check Sensor.                                                              |
|                                                          | Condenser Fans NOT operating or are running backwards.          | Check Fans.                                                                |
|                                                          | Coils dirty.                                                    | Check and clean Coils.                                                     |
|                                                          | High Superheat.                                                 | Measure Superheat with gauges and thermocouple. Determine cause.           |
| <b>SYSTEM FAULT:<br/>HIGH MOTOR<br/>TEMPERATURE</b>      | High Motor temperature input from one of the sensors.           | Refrigerant charge low. Check subcooling.                                  |
|                                                          |                                                                 | Excess charge in system, High discharge pressure. Check subcooling.        |
|                                                          |                                                                 | High Superheat. Drain/Feed Valves NOT controlling. Isolate cause.          |
|                                                          |                                                                 | Motor Sensor reading incorrectly. Program panel to ignore a single sensor. |
|                                                          |                                                                 | Economizer Solenoid energized at low speeds. Valve is leaking through.     |
| <b>SYSTEM FAULT:<br/>LOW SUCTION<br/>PRESSURE</b>        | Low charge.                                                     | Check subcooling.                                                          |
|                                                          | Transducer reads incorrectly.                                   | Check transducer against a gauge.                                          |
|                                                          | Suction Temp. Sensor reads incorrectly.                         | Check sensor against a thermocouple.                                       |
|                                                          | Low flow.                                                       | Check flow.                                                                |
|                                                          | Condenser Drain (Flash Tank Feed) Valve NOT operating.          | Check Feed and Drain Valve operation. Check superheat.                     |
|                                                          | Condenser or Drain (Flash Tank Feed) Valve defective.           | Check Feed and Drain Valve operation. Check superheat.                     |
| <b>SYSTEM FAULT:<br/>DISCHARGE PRESSURE<br/>LIMITING</b> | Discharge Transducer is defective.                              | Check transducer against a gauge.                                          |
|                                                          | Ambient Temp. very high.                                        | Normal operation.                                                          |
|                                                          | Fans NOT operating.                                             | Check fan operation.                                                       |
|                                                          | Remote or local discharge pressure load limiting is programmed. | Normal operation.                                                          |

**NOTE:** Always remove power to the chiller and assure the DC Bus voltage has bled off.

**TABLE 27 - TROUBLESHOOTING GUIDE (CONT'D)**

| PROBLEM                                              | POSSIBLE CAUSE                                                           | ACTION                                                       |
|------------------------------------------------------|--------------------------------------------------------------------------|--------------------------------------------------------------|
| <b>SYSTEM STATUS:<br/>MOTOR CURRENT<br/>LIMITING</b> | A high motor current anticipatory control has activated current limiting | Ambient temperature is high, normal response from controller |
|                                                      |                                                                          | Remote or panel limiting is in effect, Normal response.      |
|                                                      |                                                                          | Excess charge in system, adjust charge.                      |
|                                                      |                                                                          | Condenser coils dirty, Clean condenser.                      |
|                                                      |                                                                          | Fans NOT operating. Check fans.                              |
| <b>VSD FAULT:<br/>HIGH BASEPLATE<br/>TEMPERATURE</b> | Coolant level low.                                                       | Add coolant.                                                 |
|                                                      | Glycol Pump is defective.                                                | Replace Glycol Pump.                                         |
|                                                      | VSD Board is defective                                                   | Replace VSD Logic Board.                                     |
|                                                      | IGBT Module is defective.                                                | Check defective IGBT Module.                                 |
| <b>VSD FAULT:<br/>LOW DC BUS VOLTAGE</b>             | SCR / Diode Module is defective.                                         | Check SCR / Diode Module.                                    |
|                                                      | SCR Trigger Board is defective.                                          | Check SCR Trigger Board.                                     |

**NOTE:** Always remove power to the chiller and assure the DC Bus voltage has bled off.

**R-513A CONVERSION TABLE**

The table below can be used for conversion of refrigerant R-513A from pressure to saturated temperature.

**TABLE 28 - R-513A REFRIGERANT PRESSURE TO SATURATED TEMPERATURE**

| PRESSURE (PSIG) | TEMP. AVG. (°F) | PRESSURE (PSIG) | TEMP. AVG. (°F) | PRESSURE (PSIG) | TEMP. AVG. (°F) | PRESSURE (PSIG) | TEMP. AVG. (°F) |
|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| 0               | -20.5           | 130             | 99.3            | 260             | 146.7           | 390             | 179.1           |
| 5               | -8.4            | 135             | 101.6           | 265             | 148.1           | 395             | 180.2           |
| 10              | 1.4             | 140             | 103.9           | 270             | 149.6           | 400             | 181.2           |
| 15              | 9.8             | 145             | 106.1           | 275             | 151.0           | 405             | 182.3           |
| 20              | 17.2            | 150             | 108.3           | 280             | 152.4           | 410             | 183.3           |
| 25              | 23.8            | 155             | 110.4           | 285             | 153.7           | 415             | 184.3           |
| 30              | 29.8            | 160             | 112.4           | 290             | 155.1           | 420             | 185.4           |
| 35              | 35.3            | 165             | 114.5           | 295             | 156.4           | 425             | 186.4           |
| 40              | 40.4            | 170             | 116.4           | 300             | 157.7           | 430             | 187.4           |
| 45              | 45.1            | 175             | 118.4           | 305             | 159.0           | 435             | 188.4           |
| 50              | 49.5            | 180             | 120.3           | 310             | 160.3           | 440             | 189.4           |
| 55              | 53.7            | 185             | 122.2           | 315             | 161.6           | 445             | 190.3           |
| 60              | 57.7            | 190             | 124.0           | 320             | 162.9           | 450             | 191.3           |
| 65              | 61.5            | 195             | 125.8           | 325             | 164.1           | 455             | 192.2           |
| 70              | 65.1            | 200             | 127.6           | 330             | 165.3           | 460             | 193.2           |
| 75              | 68.5            | 205             | 129.3           | 335             | 166.6           | 465             | 194.1           |
| 80              | 71.9            | 210             | 131.0           | 340             | 167.8           | 470             | 195.1           |
| 85              | 75.0            | 215             | 132.7           | 345             | 168.9           | 475             | 196.0           |
| 90              | 78.1            | 220             | 134.3           | 350             | 170.1           | 480             | 196.9           |
| 95              | 81.0            | 225             | 136.0           | 355             | 171.3           | 485             | 197.8           |
| 100             | 83.9            | 230             | 137.6           | 360             | 172.4           | 490             | 198.7           |
| 105             | 86.6            | 235             | 139.1           | 365             | 173.6           | 495             | 199.6           |
| 110             | 89.3            | 240             | 140.7           | 370             | 174.7           | 500             | 200.4           |
| 115             | 91.9            | 245             | 142.2           | 375             | 175.8           | 505             | 201.3           |
| 120             | 94.4            | 250             | 143.7           | 380             | 176.9           |                 |                 |
| 125             | 96.9            | 255             | 145.2           | 385             | 178.0           |                 |                 |

**NOTES:**

1. Temperature data is mean of vapor temperature and liquid temperature.
2. Source of the tabulated data above: REFPROP 9.1214, R513a.MIX, HMX.BNC from Chemours, saturation table.  
Data generated by Justin P. Kauffman on and as of 07/29/2016.

## R-513A CONVERSION TABLE

The table below can be used for conversion of refrigerant R-513A from temperature to equivalent pressure.

**TABLE 29 - R-513A REFRIGERANT TEMPERATURE TO PRESSURE**

| TEMP. (°F) | PRESSURE (PSIG) | TEMP. (°F) | PRESSURE (PSIG) | TEMP. (°F) | PRESSURE (PSIG) | TEMP. (°F) | PRESSURE (PSIG) |
|------------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|
| -100       | -13.52          | -24        | -1.25           | 52         | 52.89           | 128        | 201.25          |
| -98        | -13.42          | -22        | -0.55           | 54         | 55.31           | 130        | 207.04          |
| -96        | -13.32          | -20        | 0.18            | 56         | 57.81           | 132        | 212.94          |
| -94        | -13.21          | -18        | 0.94            | 58         | 60.37           | 134        | 218.96          |
| -92        | -13.09          | -16        | 1.73            | 60         | 62.99           | 136        | 225.10          |
| -90        | -12.96          | -14        | 2.55            | 62         | 65.69           | 138        | 231.36          |
| -88        | -12.82          | -12        | 3.40            | 64         | 68.45           | 140        | 237.74          |
| -86        | -12.68          | -10        | 4.28            | 66         | 71.29           | 142        | 244.25          |
| -84        | -12.53          | -8         | 5.20            | 68         | 74.19           | 144        | 250.88          |
| -82        | -12.37          | -6         | 6.15            | 70         | 77.18           | 146        | 257.64          |
| -80        | -12.20          | -4         | 7.14            | 72         | 80.23           | 148        | 264.53          |
| -78        | -12.01          | -2         | 8.16            | 74         | 83.36           | 150        | 271.56          |
| -76        | -11.82          | 0          | 9.22            | 76         | 86.57           | 152        | 278.72          |
| -74        | -11.62          | 2          | 10.32           | 78         | 89.86           | 154        | 286.00          |
| -72        | -11.40          | 4          | 11.46           | 80         | 93.23           | 156        | 293.44          |
| -70        | -11.17          | 6          | 12.63           | 82         | 96.67           | 158        | 301.01          |
| -68        | -10.93          | 8          | 13.85           | 84         | 100.20          | 160        | 308.72          |
| -66        | -10.68          | 10         | 15.11           | 86         | 103.82          | 162        | 316.58          |
| -64        | -10.41          | 12         | 16.41           | 88         | 107.51          | 164        | 324.58          |
| -62        | -10.13          | 14         | 17.76           | 90         | 111.30          | 166        | 332.74          |
| -60        | -9.83           | 16         | 19.14           | 92         | 115.17          | 168        | 341.05          |
| -58        | -9.52           | 18         | 20.58           | 94         | 119.12          | 170        | 349.51          |
| -56        | -9.19           | 20         | 22.06           | 96         | 123.17          | 172        | 358.12          |
| -54        | -8.85           | 22         | 23.59           | 98         | 127.31          | 174        | 366.90          |
| -52        | -8.49           | 24         | 25.16           | 100        | 131.54          | 176        | 375.85          |
| -50        | -8.11           | 26         | 26.79           | 102        | 135.87          | 178        | 384.96          |
| -48        | -7.71           | 28         | 28.47           | 104        | 140.29          | 180        | 394.23          |
| -46        | -7.29           | 30         | 30.19           | 106        | 144.80          | 182        | 403.69          |
| -44        | -6.86           | 32         | 31.97           | 108        | 149.42          | 184        | 413.32          |
| -42        | -6.40           | 34         | 33.81           | 110        | 154.13          | 186        | 423.14          |
| -40        | -5.92           | 36         | 35.70           | 112        | 158.94          | 188        | 433.14          |
| -38        | -5.42           | 38         | 37.64           | 114        | 163.86          | 190        | 443.34          |
| -36        | -4.90           | 40         | 39.64           | 116        | 168.88          | 192        | 453.73          |
| -34        | -4.35           | 42         | 41.70           | 118        | 174.00          | 194        | 464.33          |
| -32        | -3.78           | 44         | 43.81           | 120        | 179.23          | 196        | 475.15          |
| -30        | -3.19           | 46         | 45.99           | 122        | 184.57          | 198        | 486.19          |
| -28        | -2.57           | 48         | 48.23           | 124        | 190.02          | 200        | 497.47          |
| -26        | -1.92           | 50         | 50.53           | 126        | 195.58          |            |                 |

**NOTES:**

1. Temperature data is mean of vapor temperature and liquid temperature.
2. Source of the tabulated data above: REFPROP 9.1214, R513a.MIX, HMX.BNC from Chemours, saturation table.  
Data generated by Justin P. Kauffman on and as of 07/29/2016.

**CHILLED LIQUID AND SUCTION TEMPERATURE SENSOR INPUT VOLTAGE****TABLE 30 - TEMPERATURE INPUT VOLTAGE SENSOR (MEASURED SIGNAL TO SHIELD AT THE SENSOR)**

| TEMP. °F (°C) | VOLTAGE | TEMP. °F (°C) | VOLTAGE | TEMP. °F (°C) | VOLTAGE |
|---------------|---------|---------------|---------|---------------|---------|
| 16.1 (-8.8)   | 1.52    | 35.9 (2.2)    | 2.19    | 55.6 (13.1)   | 2.85    |
| 16.7 (-8.5)   | 1.54    | 36.5 (2.5)    | 2.21    | 56.3 (13.5)   | 2.87    |
| 17.3 (-8.2)   | 1.56    | 37.0 (2.8)    | 2.23    | 56.9 (13.8)   | 2.89    |
| 17.9 (-7.8)   | 1.58    | 37.6 (3.1)    | 2.25    | 57.5 (14.2)   | 2.91    |
| 18.5 (-7.5)   | 1.60    | 38.2 (3.4)    | 2.27    | 58.1 (14.5)   | 2.93    |
| 19.1 (-7.2)   | 1.62    | 38.7 (3.7)    | 2.29    | 58.7 (14.8)   | 2.95    |
| 19.7 (-6.8)   | 1.64    | 39.3 (4.1)    | 2.30    | 59.4 (15.2)   | 2.97    |
| 20.3 (-6.5)   | 1.66    | 39.9 (4.4)    | 2.32    | 60.0 (15.6)   | 2.99    |
| 20.9 (-6.2)   | 1.68    | 40.4 (4.7)    | 2.34    | 60.6 (15.9)   | 3.01    |
| 21.5 (-5.8)   | 1.70    | 41.0 (5.0)    | 2.36    | 61.3 (16.3)   | 3.03    |
| 22.1 (-5.5)   | 1.72    | 41.6 (5.3)    | 2.38    | 61.9 (16.6)   | 3.05    |
| 22.7 (-5.2)   | 1.74    | 42.1 (5.6)    | 2.40    | 62.5 (16.9)   | 3.07    |
| 23.3 (-4.8)   | 1.76    | 42.7 (5.9)    | 2.42    | 63.2 (17.3)   | 3.09    |
| 23.9 (-4.5)   | 1.78    | 43.3 (6.3)    | 2.44    | 63.8 (17.7)   | 3.11    |
| 24.5 (-4.2)   | 1.80    | 43.9 (6.6)    | 2.46    | 64.5 (18.1)   | 3.13    |
| 25.0 (-3.9)   | 1.82    | 44.4 (6.9)    | 2.48    | 65.1 (18.4)   | 3.14    |
| 25.6 (-3.6)   | 1.84    | 45.0 (7.2)    | 2.50    | 65.8 (18.8)   | 3.16    |
| 26.2 (-3.2)   | 1.86    | 45.6 (7.5)    | 2.52    | 66.5 (19.2)   | 3.18    |
| 26.8 (-2.9)   | 1.88    | 46.2 (7.9)    | 2.54    | 67.1 (19.5)   | 3.20    |
| 27.3 (-2.6)   | 1.90    | 46.7 (8.2)    | 2.56    | 67.8 (19.9)   | 3.22    |
| 27.9 (-2.8)   | 1.91    | 47.3 (8.5)    | 2.58    | 68.5 (20.3)   | 3.24    |
| 28.5 (-1.9)   | 1.93    | 47.9 (8.8)    | 2.60    | 69.2 (20.7)   | 3.26    |
| 29.0 (-1.7)   | 1.95    | 48.5 (9.2)    | 2.62    | 69.9 (21.1)   | 3.28    |
| 29.6 (-1.3)   | 1.97    | 49.1 (9.5)    | 2.64    | 70.6 (21.4)   | 3.30    |
| 30.2 (-1)     | 1.99    | 49.7 (9.8)    | 2.66    | 71.3 (21.8)   | 3.32    |
| 30.8 (-0.7)   | 2.01    | 50.3 (10.2)   | 2.68    | 72.0 (22.2)   | 3.34    |
| 31.3 (-0.4)   | 2.03    | 50.8 (10.4)   | 2.70    | 72.7 (22.6)   | 3.36    |
| 31.9 (-0.1)   | 2.05    | 51.4 (10.8)   | 2.71    | 73.4 (23)     | 3.38    |
| 32.5 (0.3)    | 2.07    | 52.0 (11.1)   | 2.73    | 74.2 (23.4)   | 3.40    |
| 33.0 (0.6)    | 2.09    | 52.6 (11.4)   | 2.75    | 74.9 (23.8)   | 3.42    |
| 33.6 (0.9 )   | 2.11    | 53.2 (11.8)   | 2.77    |               |         |
| 34.2 (1.2)    | 2.13    | 53.8 (12.1)   | 2.79    |               |         |
| 34.8 (1.5)    | 2.15    | 54.5 (12.5)   | 2.81    |               |         |
| 35.3 (1.8)    | 2.17    | 55.0 (12.8)   | 2.83    |               |         |

**TABLE 31 - OUTSIDE AIR TEMPERATURE SENSOR INPUT VOLTAGE (MEASURED SIGNAL TO SHIELD AT THE SENSOR)**

| TEMP. °F (°C) | VOLTAGE | TEMP. °F (°C) | VOLTAGE | TEMP. °F (°C) | VOLTAGE |
|---------------|---------|---------------|---------|---------------|---------|
| 0.24 (-17.6)  | 0.68    | 49.8 (9.9)    | 2.00    | 93.3 (34.1)   | 3.31    |
| 1.79 (-16.8)  | 0.71    | 50.7 (10.4)   | 2.03    | 94.4 (34.7)   | 3.34    |
| 3.30 (-15.9)  | 0.74    | 51.6 (10.9)   | 2.06    | 95.6 (35.3)   | 3.37    |
| 4.76 (-15.1)  | 0.77    | 52.5 (11.4)   | 2.09    | 96.8 (36)     | 3.40    |
| 6.19 (-14.3)  | 0.80    | 53.4 (11.9)   | 2.11    | 98.0 (36.7)   | 3.43    |
| 7.58 (-13.6)  | 0.83    | 54.3 (12.4)   | 2.14    | 99.2 (37.3)   | 3.46    |
| 8.94 (-12.8)  | 0.85    | 55.3 (12.9)   | 2.17    | 100.4 (38)    | 3.49    |
| 10.3 (-12.1)  | 0.88    | 56.2 (13.4)   | 2.20    | 101.6 (38.7)  | 3.52    |
| 11.6 (-11.3)  | 0.91    | 57.1 (13.9)   | 2.23    | 102.9 (39.4)  | 3.55    |
| 12.8 (-10.7)  | 0.94    | 58.0 (14.4)   | 2.26    | 104.2 (40.1)  | 3.57    |
| 14.1 (-9.9)   | 0.97    | 58.9 (14.9)   | 2.29    | 105.5 (40.8)  | 3.60    |
| 15.3 (-9.3)   | 1.00    | 59.8 (15.4)   | 2.32    | 106.8 (41.6)  | 3.63    |
| 16.5 (-8.6)   | 1.03    | 60.7 (15.9)   | 2.35    | 108.1 (42.3)  | 3.66    |
| 17.7 (-7.9)   | 1.06    | 61.6 (16.4)   | 2.38    | 109.5 (43.1)  | 3.69    |
| 18.9 (-7.3)   | 1.09    | 62.6 (17)     | 2.41    | 110.9 (43.8)  | 3.72    |
| 20.0 (-6.7)   | 1.12    | 63.5 (17.5)   | 2.44    | 112.3 (44.6)  | 3.75    |
| 21.2 (-6)     | 1.15    | 64.4 (18)     | 2.47    | 113.8 (45.4)  | 3.78    |
| 22.3 (-5.4)   | 1.18    | 65.3 (18.5)   | 2.50    | 115.2 (46.2)  | 3.81    |
| 23.4 (-4.8)   | 1.21    | 66.3 (19.1)   | 2.52    | 116.7 (47.1)  | 3.84    |
| 24.4 (-4.2)   | 1.24    | 67.2 (19.5)   | 2.55    | 118.3 (47.9)  | 3.87    |
| 25.5 (-3.6)   | 1.26    | 68.1 (20.1)   | 2.58    | 119.9 (48.8)  | 3.90    |
| 26.6 (-3)     | 1.26    | 69.1 (20.6)   | 2.61    | 121.5 (49.7)  | 3.93    |
| 27.6 (-2.4)   | 1.32    | 70.0 (21.1)   | 2.64    | 123.2 (50.7)  | 3.96    |
| 28.7 (-1.8)   | 1.35    | 70.9 (21.6)   | 2.67    | 124.9 (51.6)  | 3.98    |
| 29.7 (-1.3)   | 1.38    | 71.9 (22.2)   | 2.70    | 126.6 (52.6)  | 4.01    |
| 30.7 (-0.7)   | 1.41    | 72.8 (22.7)   | 2.73    | 128.4 (53.6)  | 4.04    |
| 31.7 (-0.2)   | 1.44    | 73.8 (23.2)   | 2.76    | 130.3 (54.6)  | 4.07    |
| 32.7 (0.4)    | 1.47    | 74.8 (23.8)   | 2.76    |               |         |
| 33.7 (0.9)    | 1.50    | 75.8 (24.3)   | 2.82    |               |         |
| 34.7 (1.5)    | 1.53    | 76.7 (24.8)   | 2.85    |               |         |
| 35.7 (2.1)    | 1.56    | 77.7 (25.4)   | 2.88    |               |         |
| 36.7 (2.6)    | 1.59    | 78.7 (25.9)   | 2.91    |               |         |
| 37.6 (3.1)    | 1.62    | 79.7 (26.5)   | 2.93    |               |         |
| 38.6 (3.7)    | 1.65    | 80.7 (27.1)   | 2.96    |               |         |
| 39.6 (4.2)    | 1.67    | 81.7 (27.6)   | 2.99    |               |         |
| 40.5 (4.7)    | 1.70    | 82.7 (28.2)   | 3.02    |               |         |
| 41.4 (5.2)    | 1.73    | 83.6 (28.7)   | 3.05    |               |         |
| 42.4 (5.8)    | 1.76    | 84.6 (29.2)   | 3.08    |               |         |
| 43.3 (6.3)    | 1.79    | 85.7 (29.8)   | 3.11    |               |         |
| 44.3 (6.8)    | 1.82    | 86.7 (30.4)   | 3.13    |               |         |
| 45.2 (7.3)    | 1.85    | 87.8 (31)     | 3.16    |               |         |
| 46.1 (7.8)    | 1.88    | 88.9 (31.6)   | 3.19    |               |         |
| 47.0 (8.3)    | 1.91    | 90.1 (32.3)   | 3.22    |               |         |
| 48.0 (8.9)    | 1.94    | 91.1 (32.8)   | 3.25    |               |         |
| 48.9 (9.4)    | 1.97    | 92.2 (33.4)   | 3.28    |               |         |

**TABLE 32 - PRESSURE TRANSDUCER OUTPUT VOLTAGE (MEASURED SIGNAL TO RETURN AT THE TRANSDUCER)**

| SUCTION PRESSURE TRANSDUCER<br>(125 PSIG) |         | DISCHARGE CONDENSER LIQUID PRESSURE AND<br>DISCHARGE PRESSURE TRANSDUCER<br>(400 PSIG) |         |
|-------------------------------------------|---------|----------------------------------------------------------------------------------------|---------|
| PRESSURE                                  | VOLTAGE | PRESSURE                                                                               | VOLTAGE |
| 0                                         | 0.50    | 0                                                                                      | 0.50    |
| 5                                         | 0.66    | 25                                                                                     | 0.75    |
| 10                                        | 0.82    | 50                                                                                     | 1.00    |
| 15                                        | 0.98    | 75                                                                                     | 1.25    |
| 20                                        | 1.14    | 100                                                                                    | 1.50    |
| 25                                        | 1.30    | 125                                                                                    | 1.75    |
| 30                                        | 1.46    | 150                                                                                    | 2.00    |
| 35                                        | 1.62    | 175                                                                                    | 2.25    |
| 40                                        | 1.78    | 200                                                                                    | 2.50    |
| 45                                        | 1.94    | 225                                                                                    | 2.75    |
| 50                                        | 2.10    | 250                                                                                    | 3.00    |
| 55                                        | 2.26    | 275                                                                                    | 3.25    |
| 60                                        | 2.42    | 300                                                                                    | 3.50    |
| 65                                        | 2.58    | 325                                                                                    | 3.75    |
| 70                                        | 2.74    | 350                                                                                    | 4.00    |
| 75                                        | 2.90    | 375                                                                                    | 4.25    |
| 80                                        | 3.06    | 400                                                                                    | 4.50    |
| 85                                        | 3.22    |                                                                                        |         |
| 90                                        | 3.38    |                                                                                        |         |
| 95                                        | 3.54    |                                                                                        |         |
| 100                                       | 3.70    |                                                                                        |         |
| 105                                       | 3.86    |                                                                                        |         |
| 110                                       | 4.02    |                                                                                        |         |
| 115                                       | 4.18    |                                                                                        |         |
| 120                                       | 4.34    |                                                                                        |         |
| 125                                       | 4.50    |                                                                                        |         |

**TABLE 33 - MOTOR TEMPERATURE SENSOR RESISTANCE (CHECK AT THE MOTOR)**

| TEMP.<br>°F (°C) | R NOMINAL<br>(OHMS) | R TOL<br>(± %) | RMIN<br>(OHMS) | RMAX<br>(OHMS) |
|------------------|---------------------|----------------|----------------|----------------|
| -4 (-20)         | 97,062              | 5.00           | 92,209         | 101,915        |
| 5 (-15)          | 77,941              | 4.60           | 69,586         | 76,296         |
| 14 (-10)         | 55,391              | 4.20           | 52,996         | 57,643         |
| 23 (-5)          | 42,324              | 3.85           | 40,695         | 43,954         |
| 32 (0)           | 32,654              | 3.50           | 31,511         | 33,797         |
| 41 (5)           | 25,396              | 3.15           | 24,596         | 26,196         |
| 50 (10)          | 19,903              | 2.80           | 19,346         | 20,461         |
| 59 (15)          | 15,713              | 2.50           | 15,321         | 16,106         |
| 68 (20)          | 12,493              | 2.20           | 12,218         | 12,768         |
| 77 (25)          | 10,000              | 2.00           | 9,800          | 10,200         |
| 86 (30)          | 8,056               | 2.40           | 7,863          | 8,250          |
| 95 (35)          | 6,531               | 2.70           | 6,354          | 6,707          |
| 104 (40)         | 5,326               | 3.00           | 5,166          | 5,485          |
| 113 (45)         | 4,368               | 3.25           | 4,226          | 4,510          |
| 122 (50)         | 3,602               | 3.50           | 3,476          | 3,728          |
| 131 (55)         | 2,986               | 3.75           | 2,874          | 3,098          |
| 140 (60)         | 2,488               | 4.00           | 2,389          | 2,588          |
| 149 (65)         | 2,083               | 4.25           | 1,995          | 2,172          |
| 158 (70)         | 1,753               | 4.50           | 1,674          | 1,832          |
| 167 (75)         | 1,481               | 4.75           | 1,411          | 1,551          |
| 176 (80)         | 1,257               | 5.00           | 1,194          | 1,321          |
| 185 (85)         | 1,071               | 5.20           | 1,016          | 1,127          |
| 194 (90)         | 916.9               | 5.40           | 867.4          | 966.4          |
| 203 (95)         | 787.7               | 5.60           | 743.6          | 831.9          |
| 212 (100)        | 679.3               | 5.80           | 639.9          | 718.7          |
| 221 (105)        | 587.9               | 6.00           | 552.6          | 623.2          |
| 230 (110)        | 510.6               | 6.20           | 479.9          | 542.3          |
| 239 (115)        | 445.0               | 6.40           | 416.5          | 473.5          |
| 248 (120)        | 389.0               | 6.60           | 363.4          | 414.7          |
| 257 (125)        | 341.2               | 6.70           | 318.4          | 364.1          |
| 266 (130)        | 300.2               | 6.90           | 279.5          | 320.9          |
| 275 (135)        | 264.9               | 7.10           | 246.1          | 283.7          |
| 284 (140)        | 234.4               | 7.30           | 217.3          | 251.5          |
| 293 (145)        | 208.0               | 7.40           | 192.6          | 223.3          |
| 302 (150)        | 185.0               | 7.50           | 171.1          | 198.9          |

THIS PAGE INTENTIONALLY LEFT BLANK.

## SECTION 10 - DECOMMISSIONING, DISMANTLING AND DISPOSAL



*Never release refrigerant to the atmosphere when emptying the refrigerating circuits. Suitable retrieval equipment must be used. If reclaimed refrigerant cannot be reused. It must be returned to the manufacturer.*



*Never discard used compressor oil, as it contains refrigerant in solution. Return used oil to the oil manufacturer.*

Never discard used compressor oil, as it contains refrigerant in the solution. Return used oil to the oil manufacturer.

Unless otherwise indicated, the operations described below can be performed by any properly trained maintenance technician.

### GENERAL

Isolate all sources of electrical supply to the unit including any control system supplies switched by the unit. Ensure that all points of isolation are secured in the 'OFF' position. The supply cables may then be disconnected and removed. For connection points See *SECTION 4 - INSTALLATION*.

Remove all refrigerant from each system of the unit into a suitable container using a refrigerant reclaim or recovery unit. This refrigerant may then be re-used, if appropriate, or returned to the manufacturer for disposal. Under NO circumstances should refrigerant be vented to atmosphere. Drain the refrigerant oil from each system into a suitable container and dispose of according to local laws and regulations governing the disposal of oily wastes. Any spilt oil should be mopped up and disposed of as mentioned above.

Isolate the unit heat exchanger from the external water systems and drain the heat exchanger section of the system. If no isolation valves are installed it may be necessary to drain the complete system.



*If glycol or similar solutions have been used in the water system, or chemical additives are contained, the solution MUST be disposed of in a suitable and safe manner. Under NO circumstances should any system containing glycol or similar solutions be drained directly into domestic waste or natural water systems.*

After draining, the water pipework can be disconnected and removed.

Packaged units can generally be removed in one piece after disconnection as above. Any fixing down bolts should be removed and then the unit should be lifted from position using the points provided and equipment of adequate lifting capacity.

See *SECTION 4 - INSTALLATION* for unit installation instructions, *SECTION 9 - MAINTENANCE* for unit weights and *SECTION 3 - RIGGING, HANDLING AND STORAGE* for handling.

Units which cannot be removed in one piece after disconnection as above must be dismantled in position. Special care should be taken regarding the weight and handling of each component. Where possible units should be dismantled in the reverse order of installation.



*Residual refrigerant oil and glycol or similar solutions may remain in some parts of the system. These should be mopped up and disposed of as described above.*

It is important to ensure that whilst components are being removed the remaining parts are supported in a safe manner.



*Only use lifting equipment of adequate capacity.*

After removal from position the unit parts may be disposed of according to local laws and regulations.

The following factors can be used to convert from English to the most common SI Metric values.

**TABLE 34 - SI METRIC CONVERSION**

| MEASUREMENT   | MULTIPLY ENGLISH UNIT         | BY FACTOR | TO OBTAIN METRIC UNIT |
|---------------|-------------------------------|-----------|-----------------------|
| Capacity      | Tons Refrigerant Effect (ton) | 3.516     | Kilowatts (kW)        |
| Power         | Horsepower                    | 0.7457    | Kilowatts (kW)        |
| Flow Rate     | Gallons / Minute (gpm)        | 0.0631    | Liters / Second (l/s) |
| Length        | Feet (ft)                     | 0.3048    | Meters (m)            |
|               | Inches (in)                   | 25.4      | Millimeters (mm)      |
| Weight        | Pounds (lbs)                  | 0.4536    | Kilograms (kg)        |
| Velocity      | Feet / Second (fps)           | 0.3048    | Meters / Second (m/s) |
| Pressure Drop | Feet of Water (ft)            | 2.989     | Kilopascals (kPa)     |
|               | Pounds / Square Inch (psig)   | 6.895     | Kilopascals (kPa)     |

## TEMPERATURE

Example:  $(45.0^{\circ}\text{F} - 32^{\circ}) \times 0.5556 = 7.22^{\circ}\text{C}$ .

To convert a temperature range (that is a range of  $10^{\circ}\text{F}$ ) from Fahrenheit to Celsius, multiply by  $5/9$  or 0.5556.

Example:  $10.0^{\circ}\text{F}$  range  $\times 0.5556 = 5.6^{\circ}\text{C}$  range.

## NOTES



5000 Renaissance Drive, New Freedom, Pennsylvania USA 17349  
Copyright © by Johnson Controls 2018  
Form 201.28-NM1.1 (118)  
Issue Date: January 31, 2018  
Supersedes 201.28-NM1.1 (1117)

800-861-1001  
[www.johnsoncontrols.com](http://www.johnsoncontrols.com)

Subject to change without notice. Printed in USA  
ALL RIGHTS RESERVED